
Technical Assignment One

ASHREA Standard 62.1 and Standard 90.1 Compliance



Richard T. Flood Jr. & Sally Elliot Flood Athletic Center
Salisbury, CT

Prepared for:
Dr. William P. Bahnflath
Department of Architectural Engineering
The Pennsylvania State University

Prepared by:
Woong June Chung
Mechanical Option

Table of Content

Executive Summary-----	3
ASHREA Standard 62.1	
Section 5 Compliance-----	4
Section 6 Procedure-----	5, 6
ASHREA Standard 90.1	
Section 5 Building Envelope-----	7
Section 6 Heating, Ventilating, and Air Conditioning--	8, 9
Section 7 Service Water Heating-----	9
Section 9 Lighting-----	9
Appendix A-----	10-17
Calculation Spreadsheet for Outside Air Requirements	
References-----	18

Executive Summary

Technical assignment one was given as a task to students in AE481. Student with mechanical option were required to use ASHRAE Standard 62.1 and ASHRAE Standard 90.1 to evaluate the building.

ASHRAE Standard 62.1 contains the information about ventilation. Certain ventilation is required for the building to control the air quality. In section 5, Local capture of contaminants was considered due to the consideration of amount of sulfur dioxide, particles, carbon monoxide, oxidants, nitrogen dioxide, and lead. Also, dehumidification was considered because of the mold growth in the building. Section 6 explains about procedure to calculate the required value of design outdoor air intake flow.

ASHRAE Standard 90.1 covers the energy design evaluation. Required R-value for the building can be calculated in section 5. Section 6 carries Heating, Ventilating, and Air Conditioning information, which deals with compliance of efficiency of equipments. In Section 7, efficiency of boiler can be evaluated. Section 9 contains data to calculate Lighting Power Density.

According to the results of data, Richard T. Flood Jr., & Sally Elliot Flood Athletic Center can be improved in outdoor air intake flow. Squash court and wrestling room do not allow enough outside air to enter the area and should be considered due to the air quality of the building.

ASHRAE 62.1 - 2007 Section 5

5.3 Exhaust Duct Location

All exhaust ducts are located away from occupied spaces.

5.5 Airstream Surfaces

Building system uses dehumidifier in the ice rink and material surfaces are determined to be resistant to mold growth.

5.7 Local Capture of Contaminants

All mechanical rooms use exhaust fans to discharge the potential contaminants generated by the equipment.

5.10 Dehumidification System

Building system provides ventilating and dehumidifying unit due to the ice rink in the building. Also, the air is heated and dehumidified in Air Handling Units. Occupied spaces in the building maintain relative humidity less than 65%.

5.14 Access for Inspection, Cleaning, and Maintenance

Ventilation equipment is installed with sufficient working spaces for routine inspection, maintenance, or calibration.

5.15 Building Envelope and Interior Surfaces

Exterior wall provides to prevent liquid water. All pipes and ducts are insulated due to the condensation on interior surfaces.

5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas

Building is part of school facilities and all spaces are non-smoking area.

ASHREA 62.1 - 2007 Section 6 Procedure

The procedure to achieve the required value of design outdoor air intake flow is shown as below.

$$V_{bz} = R_p * P_z + R_a * A_z \quad (6-1)$$

A_z = zone floor area (ft²)
 P_z = zone population (table 6-1)
 R_p = outdoor air flow rate (table 6-1)
 R_a = outdoor airflow rate (table 6-1)
 V_{bz} = breathing zone outdoor air flow

$$V_{oz} = V_{bz} / E_z \quad (6-2)$$

V_{oz} = design zone outdoor airflow
 E_z = 1 zone air distribution effectiveness (table 6-2)

$$Z_p = V_{oz} / V_{pz} \quad (6-5)$$

Z_p = zone primary outdoor air fraction
 V_{pz} = zone primary air flow

$$V_{ou} = D * \sum_{\text{all zones}} (R_p * P_z) + \sum_{\text{all zones}} (R_a * A_z) \quad (6-6)$$

V_{ou} = design uncorrected outdoor air intake
 D = occupant diversity

$$D = P_s / \sum_{\text{all zones}} P_z \quad (6-7)$$

P_s = system population

$$V_{ot} = V_{ou} / E_v \quad (6-8)$$

V_{ot} = design outdoor air intake flow
 E_v = system ventilation efficiency (table 6-3)

	required OA	OA CFM		Comply?
AHU - 1, AHU - 2	4508	17600	basketball court	yes
AHU - 4	618	2950	Storage	yes
AHU - 5	1906	640	squash court	no
AHU - 6	1936	1500	wrestling room, locker room	no
AHU - 7	741	800	weight room, locker room	yes
AHU - 8	416	855	corridor of second floor	yes
AHU - 9	815	1400	athlete waiting room	yes
AHU - 10	69	360	Offices	yes

Air Handling Unit 1 and 2 have excessive amount of outside air intake due to the audiences of basketball game event. Air Handling Units for squash court and wrestling room do not comply with ASHRAE 62.1-2007.

The spread sheet for calculation is provided in Appendix A.

ASHRAE 90.1 - 2007
 Section 5 Building Envelope

Vertical glazing area has to be less than 40% of gross area.

	Wall Gross Area(sf)	Glass Area(sf)	Max Glass Area(sf)	Comply?
West	13865	3028.15	5546	yes
East	13865	1541.37	5546	yes
North	11718	3520.29	4687.2	yes
South	11718	0	4687.2	yes

Climate Zone of Connecticut is 5 from ASHREAE 90.1 -2007 Appendix B Table B-1.
 According to Table 5.5-5, required R-values of roof, wall above grade and slab on grade floor area shown as below.

		Required R-value	Actual R-value	Comply?
Roof	insulated	20	54.4	yes
Wall above grade	mass	11.4	40.941	yes
Slab on grade floors	unheated	NR	13.6	yes

All of actual R-values exceed greatly, because the facility holds ice rink which needs more insulation. If the heat enters the building easily, it will cost more money to maintain the ice rink condition.

ASHRAE 90.1 - 2007

Section 6 Heating, Ventilating, and Air Conditioning

The gross area of the building exceeds 25,000 ft². Mandatory provision method will be used to determine the compliance with ASHREA 90.1 section 6. With variable volume, CFM*0.0015 should be greater than horsepower that was used for the equipment.

Ice Rink Ventilating & Dehumidifying Unit				
	CFM	CFM * 0.0015	HP	Comply?
IRDU-1	10000	15	15	yes

Fan	CFM	CFM * 0.0015	HP	Comply?
EF-1	2000	3	1	yes
EF-2	150	0.225	0.068	yes
EF-3	800	1.2	0.333	yes
EF-4	75	0.1125	0.027	yes
EF-5	740	1.11	0.346	yes
EF-6	900	1.35	0.333	yes
EF-7	75	0.1125	0.027	yes
EF-8	300	0.45	0.114	yes
EF-9	300	0.45	0.114	yes
EF-10	4400	6.6	2	yes
EF-11	6950	10.425	3	yes
EF-12	200	0.3	0.143	yes
EF-13	3500	5.25	0.75	yes
EF-14	340	0.51	0.125	yes
EF-15	12500	18.75	5	yes
EF-16	6270	9.405	3	yes
EF-17	11000	16.5	10	yes
EF-18	5675	8.5125	3	yes
EF-19	3100	4.65	3	yes
EF-20	3200	4.8	0.5	yes
SAF -1	400	0.6	0.167	yes

AHU	CFM	CFM * 0.0015	HP	Comply?
AHU-1	15400	23.1	10	yes
AHU-2	15400	23.1	10	yes
AHU-4	5675	8.5125	3	yes
AHU-5	11000	16.5	10	yes
AHU-6	6950	10.425	5	yes
AHU-7	6270	9.405	5	yes
AHU-8	10000	15	7.5	yes
AHU-9	4550	6.825	3	yes
AHU-10	1200	1.8	1	yes

All the equipment units comply with ASHRAE 90.1-2007.

Section 7 Service Water Heating

Boiler	IBR gross output (MBH)	IBR net output (MBH)	Efficiency	Required Efficiency	Comply?
B-1	3957	3441	86.96%	80%	yes
B-2	3957	3441	86.96%	80%	yes
B-3	1281	1114	86.96%	80%	yes
B-4	1281	1114	86.96%	80%	yes

The required efficiency for the boilers is 80%. All the boilers have an efficiency of 86.96% and complies with ASHRAE 90.1-2007.

Section 9 Lighting

According to the Table 9.5.1, Lighting Power Density for the gymnasium is 1.1 W/ft²
The LPD of the facility is 0.93 W/ ft² does not exceed the allowable value. Therefore it complies with ASHRAE 90.1-2007

Appendix A Calculation Spreadsheet for Outside Air Requirements

AHU – 1, AHU - 2

Building:		Delete Zone		Richard T. Flood Jr. & Sally Elliot Flood Athletic Cent				
System Tag/Name:		Add Zone		AHU - 1, AHU - 2				
Operating Condition Description:		Add Zone		Basketball Court				
Units (select from pull-down list)				IP				
OA req'd per person for system area (Weighted average)		Rps	cfm/p					0.0
Inputs for Potentially Critical zones				Zone title turns purple italic for critical zone(s)		Potentially Critical Zones		
Zone Name						enter name		enter name
Zone Tag						AHU - 1		AHU - 2
Space type				Select from pull-down list		Gym, stadium (play area)		Gym, stadium (play area)
Floor Area of zone		Az	sf			7,513		7513
Design population of zone		Pz	P	(default value listed; may be overridden)		225.39		225.39
Design total supply to zone (primary plus local recirculation)		Vdzd	cfm			15,400		15400
Induction Terminal Unit, Dual Fan Dual Duct or Transfer		Fan?		Select from pull-down list or leave blank if N/A				
Local recirc. air % representative of ave system return air		Er						
Inputs for Operating Condition Analyzed								
Percent of total design airflow rate at conditioned analysis		Ds	%			100%		100%
Air distribution type at conditioned analysis				Select from pull-down list		CS		CS
Zone air distribution effectiveness at conditioned analysis		Ez		Show codes for Ez		1.00		1.00
Primary air fraction of supply air at conditioned analysis		Ep						
Results								
Ventilation System Efficiency		Ev				1.00		
Outdoor air intake required for system		Vot	cfm			4508		
Outdoor air per unit floor area		Vot/As	cfm/sf			0.30		
Outdoor air per person served by system (including direct)		Vot/Ps	cfm/p			10.0		
Outdoor air as a % of design primary supply air		Ypd	cfm			15%		
Detailed Calculations								
Initial Calculations for the System as a whole								
Primary supply air flow to system at conditioned analysis		Vps	cfm	=	VpdDs	=	30800	
Uncorrected OA requirement for system		Vou	cfm	=	Rps Ps + Ras As	=	4508	
Uncorrected OA req'd as a fraction of primary SA		Xs		=	Vou / Vps	=	0.15	
Initial Calculations for individual zones								
OA rate per unit area for zone		Raz	cfm/sf				0.30	0.30
OA rate per person		Rpz	cfm/p				0.00	0.00
Total supply air to zone (at condition being analyzed)		Vdz	cfm				15400	15400
Unused OA req'd to breathing zone		Vbz	cfm	=	Rpz Pz + Raz Az	=	2253.9	2253.9
Unused OA requirement for zone		Voz	cfm	=	Vbz/Ez	=	2254	2254
Fraction of zone supply not directly recirc. from zone		Fa		=	Ep + (1-Ep)Er	=	1.00	1.00
Fraction of zone supply from fully mixed primary air		Fb		=	Ep	=	1.00	1.00
Fraction of zone OA not directly recirc. from zone		Fc		=	1-(1-Ez)(1-Ep)(1-Er)	=	1.00	1.00
Unused OA fraction required in supply air to zone		Zd		=	Voz / Vdz	=	0.15	0.15
Unused OA fraction required in primary air to zone		Zp		=	Voz / Vpz	=	0.15	0.15
System Ventilation Efficiency								
Zone Ventilation Efficiency (App A Method)		Evz		=	(Fa + FbXs - FcZ) / Fa	=	1.00	1.00
System Ventilation Efficiency (App A Method)		Ev		=	min (Evz)	=	1.00	
Ventilation System Efficiency (Table 6.3 Method)		Ev		=	Value from Table 6.3	=	1.00	
Minimum outdoor air intake airflow								
Outdoor Air Intake Flow required to System		Vot	cfm	=	Vou / Ev	=	4508	
OA intake req'd as a fraction of primary SA		Y		=	Vot / Vps	=	0.15	
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot	cfm	=	Vou / Ev	=	4491	16.36
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		=	Vot / Vps	=	0.15	0.00
OA Temp at which Min OA provides all cooling								
OAT below which OA Intake flow is @ minimum		Deg F		=	{(Tp-dTsf)-(1-Y)*(Tr+d	=	-44	

AHU – 4

Building:		Delete Zone		Richard T. Flood Jr. & Sally Elliot Flood Athletic Cent				
System Tag/Name:		AHU - 4						
Operating Condition Description:		Add Zone		Storage				
Units (select from pull-down list)		IP						
Inputs for System				Name	Units		System	
Floor area served by system				As	sf		5150	
Population of area served by system (including diversity)				Ps	P	100% diversity	0	
Design primary supply fan airflow rate				Vpsd	cfm		5,675	
OA req'd per unit area for system (Weighted average)				Ras	cfm/sf		0.12	
OA req'd per person for system area (Weighted average)				Rps	cfm/p		0.0	
Inputs for Potentially Critical zones				<i>Zone title turns purple italic for critical zone(s)</i>			Potentially Critical Zones	
Zone Name		Zone Tag				enter name	enter name	
Space type		Show Values per Zone		Select from pull-down list		Storage rooms	Office space	
Floor Area of zone				Az	sf		5,150	
Design population of zone				Pz	P	(default value listed; may be overridden)	0	0
Design total supply to zone (primary plus local recirculation)				Vdzd	cfm		5,675	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?				Fan?		Select from pull-down list or leave blank if N/A		
Local recirc. air % representative of ave system return air				Er				
Inputs for Operating Condition Analyzed								
Percent of total design airflow rate at conditioned analyzed				Ds	%		100%	100%
Air distribution type at conditioned analyzed						Select from pull-down list:	CS	CS
Zone air distribution effectiveness at conditioned analyzed				Ez		Show codes for Ez	1.00	1.00
Primary air fraction of supply air at conditioned analyzed				Ep				
Results								
Ventilation System Efficiency				Ev			1.00	
Outdoor air intake required for system				Vot	cfm		618	
Outdoor air per unit floor area				Vot/As	cfm/sf		0.12	
Outdoor air per person served by system (including diversity)				Vot/Ps	cfm/p		#DIV/0!	
Outdoor air as a % of design primary supply air				Ypd	cfm		11%	
Detailed Calculations								
Initial Calculations for the System as a whole								
Primary supply air flow to system at conditioned analyzed				Vps	cfm	= VpdDs	=	5675
Uncorrected OA requirement for system				Vou	cfm	= Rps Ps + Ras As	=	618
Uncorrected OA req'd as a fraction of primary SA				Xs		= Vou / Vps	=	0.11
Initial Calculations for individual zones								
OA rate per unit area for zone				Raz	cfm/sf		0.12	0.06
OA rate per person				Rpz	cfm/p		0.00	5.00
Total supply air to zone (at condition being analyzed)				Vdz	cfm		5675	0
Unused OA req'd to breathing zone				Vbz	cfm	= Rpz Pz + Raz Az	=	618.0
Unused OA requirement for zone				Voz	cfm	= Vbz/Ez	=	618
Fraction of zone supply not directly recirc. from zone				Fa		= Ep + (1-Ep)Er	=	1.00
Fraction of zone supply from fully mixed primary air				Fb		= Ep	=	1.00
Fraction of zone OA not directly recirc. from zone				Fc		= 1-(1-Ez)(1-Ep)(1-Er)	=	1.00
Unused OA fraction required in supply air to zone				Zd		= Voz / Vdz	=	0.11
Unused OA fraction required in primary air to zone				Zp		= Voz / Vpz	=	0.11
System Ventilation Efficiency								
Zone Ventilation Efficiency (App A Method)				Evz		= (Fa + FbXs - FcZ) / Fa	=	1.00
System Ventilation Efficiency (App A Method)				Ev		= min (Evz)	=	1.00
Ventilation System Efficiency (Table 6.3 Method)				Ev		= Value from Table 6.2	=	1.04
Minimum outdoor air intake airflow								
Outdoor Air Intake Flow required to System				Vot	cfm	= Vou / Ev	=	618
OA intake req'd as a fraction of primary SA				Y		= Vot / Vps	=	0.11
Outdoor Air Intake Flow required to System (Table 6.3 Method)				Vot	cfm	= Vou / Ev	=	594
OA intake req'd as a fraction of primary SA (Table 6.3 Method)				Y		= Vot / Vps	=	0.10
OA Temp at which Min OA provides all cooling								
OAT below which OA Intake flow is @ minimum				Deg F		= ((Tp-dTsf)-(1-Y))*(Tr+d	=	-84

AHU – 5

Building:		Richard T. Flood Jr. & Sally Elliot Flood Athletic Cent					
System Tag/Name:		AHU - 5					
Operating Condition Description:		Squash Court					
Units (select from pull-down list)		IP					
Population of area served by system (including diversity)	Ps	P	100%	diversity	191		
Design primary supply fan airflow rate	Vpsd	cfm			11,000		
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf			0.30		
OA req'd per person for system area (Weighted average)	Rps	cfm/p			0.0		
Inputs for Potentially Critical zones				Potentially Critical Zones			
Zone Name	Zone title turns purple italic for critical zone(s)				enter name	enter name	
Zone Tag	Show Values per Zone				enter tag	enter tag	
Space type	Select from pull-down list				Gym, stadium (play area)	Office space	
Floor Area of zone	Az	sf			6,352		
Design population of zone	Pz	P	(default value listed; may be overridden)		190.58	0	
Design total supply to zone (primary plus local recirculation)	Vdzd	cfm			11,000		
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Unit	Fan?	Select from pull-down list or leave blank if N/A					
Local recirc. air % representative of ave system return air	Er						
Inputs for Operating Condition Analyzed							
Percent of total design airflow rate at conditioned analysis	Ds	%			100%	100%	
Air distribution type at conditioned analysis	Select from pull-down list				CS	CS	
Zone air distribution effectiveness at conditioned analysis	Ez		Show codes for Ez		1.00	1.00	
Primary air fraction of supply air at conditioned analysis	Ep						
Results							
Ventilation System Efficiency	Ev				1.00		
Outdoor air intake required for system	Vot	cfm			1906		
Outdoor air per unit floor area	Vot/As	cfm/sf			0.30		
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/p			10.0		
Outdoor air as a % of design primary supply air	Ypd	cfm			17%		
Detailed Calculations							
Initial Calculations for the System as a whole							
Primary supply air flow to system at conditioned analysis	Vps	cfm	=	VpdDs	=	11000	
Uncorrected OA requirement for system	Vou	cfm	=	Rps Ps + Ras As	=	1906	
Uncorrected OA req'd as a fraction of primary SA	Xs		=	Vou / Vps	=	0.17	
Initial Calculations for individual zones							
OA rate per unit area for zone	Raz	cfm/sf			0.30	0.08	
OA rate per person	Rpz	cfm/p			0.00	5.00	
Total supply air to zone (at condition being analyzed)	Vdz	cfm			11000	0	
Unused OA req'd to breathing zone	Vbz	cfm	=	Rpz Pz + Raz Az	=	1905.6	
Unused OA requirement for zone	Voz	cfm	=	Vbz/Ez	=	1906	
Fraction of zone supply not directly recirc. from zone	Fa		=	Ep + (1-Ep)Er	=	1.00	
Fraction of zone supply from fully mixed primary air	Fb		=	Ep	=	1.00	
Fraction of zone OA not directly recirc. from zone	Fc		=	1-(1-Ez)(1-Ep)(1-Er)	=	1.00	
Unused OA fraction required in supply air to zone	Zd		=	Voz / Vdz	=	0.17	
Unused OA fraction required in primary air to zone	Zp		=	Voz / Vpz	=	0.17	
System Ventilation Efficiency							
Zone Ventilation Efficiency (App A Method)	Evz		=	(Fa + FbXs - FcZ) / Fa	=	1.00	
System Ventilation Efficiency (App A Method)	Ev		=	min (Evz)	=	1.00	
Ventilation System Efficiency (Table 6.3 Method)	Ev		=	Value from Table 6.3	=	0.98	
Minimum outdoor air intake airflow							
Outdoor Air Intake Flow required to System	Vot	cfm	=	Vou / Ev	=	1906	
OA intake req'd as a fraction of primary SA	Y		=	Vot / Vps	=	0.17	
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	=	Vou / Ev	=	1951	
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		=	Vot / Vps	=	0.18	
OA Temp at which Min OA provides all cooling							
OAT below which OA Intake flow is @ minimum	Deg F		=	((Tp-dTsf)-(1-Y)*(Tr+d	=	-28	

AHU – 6

Building: Richard T. Flood Jr. & Sally Elliot Flood Athletic Center		Delete Zone		AHU - 6	
System Tag/Name:		Add Zone		Wrestling Room, Locker Room	
Operating Condition Description:				IP	
Units (select from pull-down list)					
Inputs for System		Name Units		System	
Floor area served by system		As sf		6454	
Population of area served by system (including diversity)		Ps P		100% diversity 194	
Design primary supply fan airflow rate		Vpsd cfm		6,950	
OA req'd per unit area for system (Weighted average)		Ras cfm/sf		0.30	
OA req'd per person for system area (Weighted average)		Rps cfm/p		0.0	
Inputs for Potentially Critical zones		<i>Zone title turns purple italic for critical zone(s)</i>		Potentially Critical Zones	
Zone Name				enter name	
Zone Tag				enter tag	
Space type		Select from pull-down list		Gym, stadium (play area) Office space	
Floor Area of zone		Az sf		6,454	
Design population of zone		Pz P (default value listed; may be overridden)		193.62 0	
Design total supply to zone (primary plus local recirculation)		Vdzd cfm		6,950	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Fan? Select from pull-down list or leave blank if N/A			
Local recirc. air % representative of ave system return air		Er			
Inputs for Operating Condition Analyzed					
Percent of total design airflow rate at conditioned analysis		Ds %		100%	
Air distribution type at conditioned analysis		Select from pull-down list		100% CS 100% CS	
Zone air distribution effectiveness at conditioned analysis		Ez		Show codes for Ez 1.00 1.00	
Primary air fraction of supply air at conditioned analysis		Ep			
Results					
Ventilation System Efficiency		Ev		1.00	
Outdoor air intake required for system		Vot cfm		1936	
Outdoor air per unit floor area		Vot/As cfm/sf		0.30	
Outdoor air per person served by system (including diversity)		Vot/Ps cfm/p		10.0	
Outdoor air as a % of design primary supply air		Ypd cfm		28%	
Detailed Calculations					
Initial Calculations for the System as a whole					
Primary supply air flow to system at conditioned analysis		Vps cfm = VpdDs =		6950	
Uncorrected OA requirement for system		Vou cfm = Rps Ps + Ras As =		1936	
Uncorrected OA req'd as a fraction of primary SA		Xs = Vou / Vps =		0.28	
Initial Calculations for individual zones					
OA rate per unit area for zone		Raz cfm/sf		0.30 0.06	
OA rate per person		Rpz cfm/p		0.00 5.00	
Total supply air to zone (at condition being analyzed)		Vdz cfm		6950 0	
Unused OA req'd to breathing zone		Vbz cfm = Rpz Pz + Raz Az =		1936.2 0.0	
Unused OA requirement for zone		Voz cfm = Vbz/Ez =		1936 0	
Fraction of zone supply not directly recirc. from zone		Fa = Ep + (1-Ep)Er =		1.00 1.00	
Fraction of zone supply from fully mixed primary air		Fb = Ep =		1.00 1.00	
Fraction of zone OA not directly recirc. from zone		Fc = 1-(1-Ez)(1-Ep)(1-Er) =		1.00 1.00	
Unused OA fraction required in supply air to zone		Zd = Voz / Vdz =		0.28 0.00	
Unused OA fraction required in primary air to zone		Zp = Voz / Vpz =		0.28 0.00	
System Ventilation Efficiency					
Zone Ventilation Efficiency (App A Method)		Evz = (Fa + FbXs - FcZ) / Fa =		1.00 1.28	
System Ventilation Efficiency (App A Method)		Ev = min (Evz) =		1.00	
Ventilation System Efficiency (Table 6.3 Method)		Ev = Value from Table 6.3 =		0.87	
Minimum outdoor air intake airflow					
Outdoor Air Intake Flow required to System		Vot cfm = Vou / Ev =		1936	
OA intake req'd as a fraction of primary SA		Y = Vot / Vps =		0.28	
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot cfm = Vou / Ev =		2222	
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y = Vot / Vps =		0.32	
OA Temp at which Min OA provides all cooling					
OAT below which OA Intake flow is @ minimum		Deg F = ((Tp-dTsf)-(1-Y)*(Tr+d		= 11	

AHU - 7

Building: <input type="button" value="Delete Zone"/>		Richard T. Flood Jr. & Sally Elliot Flood Athletic Center			
System Tag/Name: AHU - 7					
Operating Condition Description: <input type="button" value="Add Zone"/>		Weight Room, Locker Room			
Units (select from pull-down list)		IP			
Inputs for System		Name	Units	System	
Floor area served by system		As	sf	6178	
Population of area served by system (including diversity)		Ps	P	100% diversity	0
Design primary supply fan airflow rate		Vpsd	cfm	6,270	
OA req'd per unit area for system (Weighted average)		Ras	cfm/sf	0.12	
OA req'd per person for system area (Weighted average)		Rps	cfm/p	0.0	
Inputs for Potentially Critical zones		<i>Zone title turns purple italic for critical zone(s)</i>		Potentially Critical Zones	
Zone Name				enter name	enter name
Zone Tag <input type="button" value="Show Values per Zone"/>				enter tag	enter tag
Space type		Select from pull-down list		Storage rooms	Office space
Floor Area of zone		Az	sf	6,178	
Design population of zone		Pz	P	(default value listed; may be overridden)	0
Design total supply to zone (primary plus local recirculation)		Vdzd	cfm	6,270	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Fan?	Select from pull-down list or leave blank if N/A		
Local recirc. air % representative of ave system return air		Er			
Inputs for Operating Condition Analyzed					
Percent of total design airflow rate at conditioned analysis		Ds	%	100%	100% 100%
Air distribution type at conditioned analysis		Select from pull-down list			CS CS
Zone air distribution effectiveness at conditioned analysis		Ez	Show codes for Ez		1.00 1.00
Primary air fraction of supply air at conditioned analysis		Ep			
Results					
Ventilation System Efficiency		Ev	1.00		
Outdoor air intake required for system		Vot	cfm	741	
Outdoor air per unit floor area		Vot/As	cfm/sf	0.12	
Outdoor air per person served by system (including diversity)		Vot/Ps	cfm/p	#DIV/0!	
Outdoor air as a % of design primary supply air		Ypd	cfm	12%	
Detailed Calculations					
Initial Calculations for the System as a whole					
Primary supply air flow to system at conditioned analysis		Vps	cfm	= VpdDs	= 6270
Uncorrected OA requirement for system		Vou	cfm	= Rps Ps + Ras As	= 741
Uncorrected OA req'd as a fraction of primary SA		Xs		= Vou / Vps	= 0.12
Initial Calculations for individual zones					
OA rate per unit area for zone		Raz	cfm/sf		0.12 0.06
OA rate per person		Rpz	cfm/p		0.00 5.00
Total supply air to zone (at condition being analyzed)		Vdz	cfm		6270 0
Unused OA req'd to breathing zone		Vbz	cfm	= Rpz Pz + Raz Az	= 741.4 0.0
Unused OA requirement for zone		Voz	cfm	= Vbz/Ez	= 741 0
Fraction of zone supply not directly recirc. from zone		Fa		= Ep + (1-Ep)Er	= 1.00 1.00
Fraction of zone supply from fully mixed primary air		Fb		= Ep	= 1.00 1.00
Fraction of zone OA not directly recirc. from zone		Fc		= 1-(1-Ez)(1-Ep)(1-Er)	= 1.00 1.00
Unused OA fraction required in supply air to zone		Zd		= Voz / Vdz	= 0.12 0.00
Unused OA fraction required in primary air to zone		Zp		= Voz / Vps	= 0.12 0.00
System Ventilation Efficiency					
Zone Ventilation Efficiency (App A Method)		Ezv		= (Fa + FbXs - FcZ) / Fa	= 1.00 1.12
System Ventilation Efficiency (App A Method)		Ev		= min (Ezv)	= 1.00
Ventilation System Efficiency (Table 6.3 Method)		Ev		= Value from Table 6.3	= 1.03
Minimum outdoor air intake airflow					
Outdoor Air Intake Flow required to System		Vot	cfm	= Vou / Ev	= 741
OA intake req'd as a fraction of primary SA		Y		= Vot / Vps	= 0.12
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot	cfm	= Vou / Ev	= 719 22.82
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		= Vot / Vps	= 0.11 0.03
OA Temp at which Min OA provides all cooling					
OAT below which OA Intake flow is @ minimum		Deg F		= ((Tp-dTsf)-(1-Y)*(Tr+d	= -72

AHU – 8

Building: Richard T. Flood Jr. & Sally Elliot Flood Athletic Cent					
System Tag/Name: AHU - 8					
Operating Condition Description: Corridor					
Units (select from pull-down list) IP					
Inputs for System		Name	Units	System	
Floor area served by system		As	sf	6938	
Population of area served by system (including diversity)		Ps	P	100%	diversity
Design primary supply fan airflow rate		Vpsd	cfm	10,000	
OA req'd per unit area for system (Weighted average)		Ras	cfm/sf	0.06	
OA req'd per person for system area (Weighted average)		Rps	cfm/p	0.0	
Inputs for Potentially Critical zones					Potentially Critical Zones
Zone Name		<i>Zone title turns purple italic for critical zone(s)</i>			enter name
Zone Tag					enter tag
Space type Show Values per Zone		Select from pull-down list			Corridors * Office
Floor Area of zone		Az	sf	6,938	
Design population of zone		Pz	P	(default value listed; may be overridden)	0
Design total supply to zone (primary plus local recirculation)		Vdzd	cfm	10,000	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Fan?	Select from pull-down list or leave blank if N/A		
Local recirc. air % representative of ave system return air		Er			
Inputs for Operating Condition Analyzed					
Percent of total design airflow rate at conditioned analyzed		Ds	%	100%	100%
Air distribution type at conditioned analyzed		Select from pull-down list			CS
Zone air distribution effectiveness at conditioned analyzed		Ez	Show codes for Ez		
Primary air fraction of supply air at conditioned analyzed		Ep	1.00		
Results					
Ventilation System Efficiency		Ev	1.00		
Outdoor air intake required for system		Vot	cfm	416	
Outdoor air per unit floor area		Vot/As	cfm/sf	0.06	
Outdoor air per person served by system (including diversity)		Vot/Ps	cfm/p	#DIV/0!	
Outdoor air as a % of design primary supply air		Ypd	cfm	4%	
Detailed Calculations					
Initial Calculations for the System as a whole					
Primary supply air flow to system at conditioned analyzed		Vps	cfm	= VpdDs	= 10000
Uncorrected OA requirement for system		Vou	cfm	= Rps Ps + Ras As	= 416
Uncorrected OA req'd as a fraction of primary SA		Xs		= Vou / Vps	= 0.04
Initial Calculations for individual zones					
OA rate per unit area for zone		Raz	cfm/sf		0.06
OA rate per person		Rpz	cfm/p		5.00
Total supply air to zone (at condition being analyzed)		Vdz	cfm		10000
Unused OA req'd to breathing zone		Vbz	cfm	= Rpz Pz + Raz Az	= 416.3
Unused OA requirement for zone		Voz	cfm	= Vbz/Ez	= 416
Fraction of zone supply not directly recirc. from zone		Fa		= Ep + (1-Ep)Er	= 1.00
Fraction of zone supply from fully mixed primary air		Fb		= Ep	= 1.00
Fraction of zone OA not directly recirc. from zone		Fc		= 1-(1-Ez)(1-Ep)(1-Er)	= 1.00
Unused OA fraction required in supply air to zone		Zd		= Voz / Vdz	= 0.04
Unused OA fraction required in primary air to zone		Zp		= Voz / Vpz	= 0.04
System Ventilation Efficiency					
Zone Ventilation Efficiency (App A Method)		Evz		= (Fa + FbXs - FcZ) / Fa	= 1.00
System Ventilation Efficiency (App A Method)		Ev		= min (Evz)	= 1.00
Ventilation System Efficiency (Table 6.3 Method)		Ev		= Value from Table 6.3	= 1.11
Minimum outdoor air intake airflow					
Outdoor Air Intake Flow required to System		Vot	cfm	= Vou / Ev	= 416
OA intake req'd as a fraction of primary SA		Y		= Vot / Vps	= 0.04
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot	cfm	= Vou / Ev	= 376
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		= Vot / Vps	= 0.04
OA Temp at which Min OA provides all cooling					
OAT below which OA Intake flow is @ minimum		Deg F		= ((Tp-dTsf)-(1-Y)*(Tr+d	= -336

AHU – 9

Building:		Delete Zone		Richard T. Flood Jr. & Sally Elliot Flood Athletic Cent			
System Tag/Name:				AHU - 9			
Operating Condition Description:		Add Zone		Athlete Waiting Room			
Units (select from pull-down list)				IP			
Inputs for System				Name	Units		System
Floor area served by system				As	sf		3883
Population of area served by system (including diversity)				Ps	P	100%	116
Design primary supply fan airflow rate				Vpsd	cfm		4,550
OA req'd per unit area for system (Weighted average)				Ras	cfm/sf		0.06
OA req'd per person for system area (Weighted average)				Rps	cfm/p		5.0
Inputs for Potentially Critical zones							Potentially Critical Zones
Zone Name		Zone title turns purple italic for critical zone(s)				enter name	enter name
Zone Tag						enter tag	enter tag
Space type		Select from pull-down list				Reception areas	Storage rooms
Floor Area of zone		Az	sf			3,883	
Design population of zone		Pz	P	(default value listed; may be overridden)		116.49	0
Design total supply to zone (primary plus local recirculation)		Vdz	cfm			4,550	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer		Fan?		Select from pull-down list or leave blank if N/A			
Local recirc. air % representative of ave system return air		Er					
Inputs for Operating Condition Analyzed							
Percent of total design airflow rate at conditioned analysis		Ds	%			100%	100%
Air distribution type at conditioned analysis		Select from pull-down list				CS	CS
Zone air distribution effectiveness at conditioned analysis		Ez		Show codes for Ez		1.00	1.00
Primary air fraction of supply air at conditioned analysis		Ep					
Results							
Ventilation System Efficiency		Ev				1.00	
Outdoor air intake required for system		Vot	cfm			815	
Outdoor air per unit floor area		Vot/As	cfm/sf			0.21	
Outdoor air per person served by system (including diversity)		Vot/Ps	cfm/p			7.0	
Outdoor air as a % of design primary supply air		Ypd	cfm			18%	
Detailed Calculations							
Initial Calculations for the System as a whole							
Primary supply air flow to system at conditioned analysis		Vps	cfm	=	VpdDs	=	4550
Uncorrected OA requirement for system		Vou	cfm	=	Rps Ps + Ras As	=	815
Uncorrected OA req'd as a fraction of primary SA		Xs		=	Vou / Vps	=	0.18
Initial Calculations for individual zones							
OA rate per unit area for zone		Raz	cfm/sf			0.06	0.12
OA rate per person		Rpz	cfm/p			5.00	0.00
Total supply air to zone (at condition being analyzed)		Vdz	cfm			4550	0
Unused OA req'd to breathing zone		Vbz	cfm	=	Rpz Pz + Raz Az	=	815.4
Unused OA requirement for zone		Voz	cfm	=	Vbz/Ez	=	815
Fraction of zone supply not directly recirc. from zone		Fa		=	Ep + (1-Ep)Er	=	1.00
Fraction of zone supply from fully mixed primary air		Fb		=	Ep	=	1.00
Fraction of zone OA not directly recirc. from zone		Fc		=	1-(1-Ez)(1-Ep)(1-Er)	=	1.00
Unused OA fraction required in supply air to zone		Zd		=	Voz / Vdz	=	0.18
Unused OA fraction required in primary air to zone		Zp		=	Voz / Vpz	=	0.18
System Ventilation Efficiency							
Zone Ventilation Efficiency (App A Method)		Evz		=	(Fa + FbXs - FcZ) / Fa	=	1.00
System Ventilation Efficiency (App A Method)		Ev		=	min (Evz)	=	1.00
Ventilation System Efficiency (Table 6.3 Method)		Ev		=	Value from Table 6.3	=	0.97
Minimum outdoor air intake airflow							
Outdoor Air Intake Flow required to System		Vot	cfm	=	Vou / Ev	=	815
OA intake req'd as a fraction of primary SA		Y		=	Vot / Vps	=	0.18
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot	cfm	=	Vou / Ev	=	840
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		=	Vot / Vps	=	0.18
OA Temp at which Min OA provides all cooling							
OAT below which OA Intake flow is @ minimum		Deg F		=	((Tp-dTsf)-(1-Y)*(Tr+d	=	-23

AHU – 10

Building: Richard T. Flood Jr. & Sally Elliot Flood Athletic Center					
System Tag/Name: AHU - 10					
Operating Condition Description: Offices					
Units (select from pull-down list): IP					
Inputs for System		Name	Units	System	
Floor area served by system		As	sf	815	
Population of area served by system (including diversity)		Ps	P	100% diversity	4
Design primary supply fan airflow rate		Vpsd	cfm	1,200	
OA req'd per unit area for system (Weighted average)		Ras	cfm/sf	0.06	
OA req'd per person for system area (Weighted average)		Rps	cfm/p	5.0	
Inputs for Potentially Critical Zones					Potentially Critical Zones
Zone Name		<i>Zone title turns purple italic for critical zone(s)</i>			enter name
Zone Tag					enter tag
Space type Show Values per Zone		Select from pull-down list			Office
Floor Area of zone		Az	sf	815	
Design population of zone		Pz	P	(default value listed; may be overridden)	4.075
Design total supply to zone (primary plus local recirculation)		Vdzd	cfm	1,200	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Fan?	Select from pull-down list or leave blank if N/A		
Local recirc. air % representative of ave system return air		Er			
Inputs for Operating Condition Analyzed					
Percent of total design airflow rate at conditioned analysis		Ds	%	100%	100%
Air distribution type at conditioned analysis		Select from pull-down list:			CS
Zone air distribution effectiveness at conditioned analysis		Ez	Show codes for Ez		
Primary air fraction of supply air at conditioned analysis		Ep	1.00		
Results					
Ventilation System Efficiency		Ev	1.00		
Outdoor air intake required for system		Vot	cfm	69	
Outdoor air per unit floor area		Vot/As	cfm/sf	0.09	
Outdoor air per person served by system (including diversity)		Vot/Ps	cfm/p	17.0	
Outdoor air as a % of design primary supply air		Ypd	cfm	6%	
Detailed Calculations					
Initial Calculations for the System as a whole					
Primary supply air flow to system at conditioned analysis		Vps	cfm	= VpdDs	= 1200
Uncorrected OA requirement for system		Vou	cfm	= Rps Ps + Ras As	= 69
Uncorrected OA req'd as a fraction of primary SA		Xs		= Vou / Vps	= 0.06
Initial Calculations for individual zones					
OA rate per unit area for zone		Raz	cfm/sf	0.06	0.06
OA rate per person		Rpz	cfm/p	5.00	5.00
Total supply air to zone (at condition being analyzed)		Vdz	cfm	1200	0
Unused OA req'd to breathing zone		Vbz	cfm	= Rpz Pz + Raz Az	= 69.3
Unused OA requirement for zone		Voz	cfm	= Vbz/Ez	= 69
Fraction of zone supply not directly recirc. from zone		Fa		= Ep + (1-Ep)Er	= 1.00
Fraction of zone supply from fully mixed primary air		Fb		= Ep	= 1.00
Fraction of zone OA not directly recirc. from zone		Fc		= 1-(1-Ez)(1-Ep)(1-Er)	= 1.00
Unused OA fraction required in supply air to zone		Zd		= Voz / Vdz	= 0.06
Unused OA fraction required in primary air to zone		Zp		= Voz / Vpz	= 0.06
System Ventilation Efficiency					
Zone Ventilation Efficiency (App A Method)		Ezv		= (Fa + FbZs - FcZ) / Fa	= 1.00
System Ventilation Efficiency (App A Method)		Ev		= min (Ezv)	= 1.00
Ventilation System Efficiency (Table 6.3 Method)		Ev		= Value from Table 6.3	= 1.09
Minimum outdoor air intake airflow					
Outdoor Air Intake Flow required to System		Vot	cfm	= Vou / Ev	= 69
OA intake req'd as a fraction of primary SA		Y		= Vot / Vps	= 0.06
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Vot	cfm	= Vou / Ev	= 63
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y		= Vot / Vps	= 0.05
OA Temp at which Min OA provides all cooling					
OAT below which OA intake flow is @ minimum		Deg F		= ((Tp-dTsf)-(1-Y)*(Tr+d	= -222

Reference

ASHRAE, 2007, ANSI/ASHARE, Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc. Atlanta, GA

ASHRAE, 2007, ANSI/ASHARE, Standard 90.1-2007, Energy Standard for Buildings Except Low-rise Residential Buildings. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc. Atlanta, GA

Michael Rosenfeld, Inc., Mechanical Specification, West Acton, MA