

The American Swedish Institute

Minneapolis, MN



**Krysta Skinner – Mechanical Option
Advisor – Dr. Stephen Treado
The Pennsylvania State University**

The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

Building Information

- **Building Introduction**

- **Building Information**
- Existing Mechanical System
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Size: 75,000 square feet
- Occupancy Type: Cultural Center
- Construction Cost: \$13.5 million
- Construction Dates: January 2011 – June 2012
- Delivery Method: Design – Bid – Build
- Project Team:
 - Engineers and Architect: HGA
 - Construction Manager: Adolfson & Peterson Construction
 - Owner: The American Swedish Institute



The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

Existing Mechanical System


- **Building Introduction**

- Building Information
- **Existing Mechanical System**

- Proposed Solutions and Goals

- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Geothermal source closed loop heat pump system
- Vertical heat exchanger
- Design Summary
 - Peak design heat loss : 917 MBH
 - Peak design heat gain : 1202 MBH
 - Heat pump COP at 32°F: 3.5
 - Design minimum supply temperature : 32°F
 - Design maximum supply temperature : 88°F
 - 30% propylene glycol in water



Existing Mechanical System

- **Building Introduction**

- Building Information
- **Existing Mechanical System**

- Proposed Solutions and Goals

- Depth 1 – VAV System
- Depth 2 – Chilled Beam System

- Breadth 1 – Structural

- Conclusion


- Questions/Comments

- Makeup Air Unit

- 8,000 cfm
- Serves the heat pumps located in the Addition and Mansion

- Water-to-air heat pumps

- 48 units
- 300-2,000 cfm range



McQuay Enfinity Horizontal Ceiling Water Source Heat Pump



AAON SA Series Makeup Air Unit


- Building Introduction
- **Proposed Solutions and Goals**
 - **Mechanical System Evaluation**
 - Breadth Evaluation
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Areas for improvement:
 - Energy usage
 - Fan energy
 - Cost spent on utilities annually
- Goals:
 - Reduce annual operating costs
 - Decrease fan energy
 - Decrease annual amount of energy usage



- Building Introduction
- **Proposed Solutions and Goals**
 - Mechanical System Evaluation
 - **Breadth Evaluation**
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Breadth 1: Architectural
 - Replace existing roof on walkway
- Breadth 2: Structural
 - Walkway was analyzed for original roof loads
 - Calculate loads for extensive and intensive options
 - Comparison of original to new options




- Building Introduction
 - Proposed Solutions and Goals
 - **Depth 1 – VAV System**
 - **Background Information**
 - Energy Analysis
 - Energy Costs
 - First Cost
 - Life-Cycle Cost
 - Recommendation
 - Depth 2 – Chilled Beam System
 - Breadth 1 – Structural
 - Conclusion
 - Questions/Comments
- Fan powered VAV boxes shall supply conditioned air to zones
 - Water-to-water heat pumps in combination with geothermal system
- Procedure:
 - Schedules and rooms were inputted into Trane TRACE
 - Calculate monthly and annual amounts for energy usage
 - Determine annual costs
 - Size equipment based on results
 - Compare results to original

Energy Analysis

- Building Introduction
- Proposed Solutions and Goals
- **Depth 1 – VAV System**
 - Background Information
 - **Energy Analysis**
 - Energy Costs
 - First Cost
 - Life-Cycle Cost
 - Recommendation
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

Annual Energy Use for HVAC Options by End Use



- 15.1% decrease in end use
- 46.4% decrease in fan energy

	Electricity (kWh)	Natural Gas (kBtu)	Total (kBtu/yr)
Original	917,790	66,748	3,199,165
VAV	773,055	78,169	2,716,604

- 15.8% decrease in electricity
- 14.6% increase in natural gas

- Building Introduction
- Proposed Solutions and Goals
- **Depth 1 – VAV System**
 - Background Information
 - Energy Analysis
 - **Energy Costs**
 - First Cost
 - Life-Cycle Cost
 - Recommendation
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Utility Rates taken from Xcel Energy
- Electricity Costs:
 - \$11.19/kW from June to Sept.
 - \$7.79/kW from Oct. to May
- Natural Gas Costs:
 - \$0.59/therm from April to Oct.
 - \$0.65/therm from Nov. to March

Annual Utility Breakdown		
Source	Energy (10 ⁶ Btu/yr)	Cost (\$/yr)
Electricity	2,638.4	60,639.45
Gas	78.2	905.68
Total	2,717	61,545.13

First Cost

- Building Introduction
- Proposed Solutions and Goals
- **Depth 1 – VAV System**
 - Background Information
 - Energy Analysis
 - Energy Costs
 - **First Cost**
 - Life-Cycle Cost
 - Recommendation
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- VAV System first cost:
 - \$2,459,350.00
 - \$54.65 per square foot
- Included:
 - Geothermal wellfield & piping
 - Water -to-water heat pumps
 - Air handling unit
 - Fan-powered VAV boxes
- Original system first cost: \$2,031,979
- 17.4% increase

System Components	Component Costs
Geothermal wellfield & piping	\$408,000.00
Water-to-water heat pumps	\$224,000.00
Air handling unit	\$240,000.00
VAV Boxes	\$160,000.00
Boiler	\$81,600.00
Pumps	\$7,500.00
Valving	\$50,000.00
Exhaust Fans	\$52,100.00
Unit heaters & misc.	\$37,500.00
Air Distribution	\$686,600.00
Hydronic piping	\$249,450.00
Controls	\$312,600.00

Life-Cycle Cost

- Building Introduction
- Proposed Solutions and Goals
- **Depth 1 – VAV System**
 - Background Information
 - Energy Analysis
 - Energy Costs
 - First Cost
 - **Life-Cycle Cost**
 - Recommendation
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- 30 year life-cycle cost
- System was analyzed based on:
 - Capital Investment
 - Overhaul
 - Maintenance
 - Annual electric and natural gas costs
 - Escalation Factors

Maintenance (\$)	Annual Electricity Costs (\$)	Annual Natural Gas Costs (\$)	OMB Base Discount Rate (%)
44,285.00	60,639.45	905.68	3.0

- Total net present value: \$ 5,184,469.43
- 3.9% increase

	Original	VAV
HVAC System First Cost	\$2,031,979.00	\$2,459,350.00
Annual Maintenance Cost	\$52,100.00	\$44,285.00
Replacements Costs: 5	-	-
10	-	-
15	\$275,500.00	\$89,600.00
20	\$372,479.00	\$544,100.00
25	\$81,600.00	\$81,600.00
30	\$275,500.00	\$489,600.00
Annual Recurring Electric	\$73,720.36	\$60,639.45
Annual Recurring Natural Gas	\$817.27	\$905.68
Total Energy Costs	\$74,537.63	\$61,545.13

- Building Introduction
- Proposed Solutions and Goals
- **Depth 1 – VAV System**
 - Background Information
 - Energy Analysis
 - Energy Costs
 - First Cost
 - Life-Cycle Cost
 - **Recommendation**
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Decrease of energy consumption and usage
 - 15.1% overall
 - 46.4% for fan and pump energy
 - 16.9% for cooling
 - 31.3% for heating
- \$13,080.91 less spent on electricity annually
- Total first cost: \$2,459,350
- Payback period of 33 years
- Is this a good option?


Yes



- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- **Depth 2 – Chilled Beam System**
 - **Background Information**
 - Energy Analysis
 - Energy Costs
 - Chilled Beam Calculation
 - First Cost
 - Life-Cycle Cost
 - Recommendation
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Active chilled beams shall supply conditioned air to the spaces
- Water-to-water heat pumps combined with geothermal system

- Procedure:
 - Schedules and rooms were inputted into Trane TRACE
 - Calculate energy usage
 - Size equipment
 - Calculate equipment size
 - Determine annual costs and first costs
 - Compare results to original




ASHRAE © Price Resources Limited 2012

Energy Analysis

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- **Depth 2 – Chilled Beam System**
 - Background Information
 - **Energy Analysis**
 - Energy Costs
 - Chilled Beam Calculation
 - First Cost
 - Life-Cycle Cost
 - Recommendation
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

Annual Energy Use for HVAC Options by End Use



- 12.4% decrease in end use
- 66.3% decrease in fan energy
- Primary airflow decreases by 65%

	Electricity (kWh)	Natural Gas (kBtu)	Total (kBtu/yr)
Original	917,790	66,748	3,199,165
Chilled Beams	810,230	31,113	2,798,427

- 11.7% decrease in electricity
- 53.4% decrease in natural gas

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- **Depth 2 – Chilled Beam System**
 - Background Information
 - Energy Analysis
 - **Energy Costs**
 - Chilled Beam Calculation
 - First Cost
 - Life-Cycle Cost
 - Recommendation
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Utility Rates taken from Xcel Energy
- Electricity Costs:
 - \$11.19/kW from June to Sept.
 - \$7.79/kW from Oct. to May
- Natural Gas Costs:
 - \$0.59/therm from April to Oct.
 - \$0.65/therm from Nov. to March

Annual Utility Breakdown		
Source	Energy (10 ⁶ Btu/yr)	Cost (\$/yr)
Electricity	2,765.3	64,953.16
Gas	33.1	556.70
Total	2,798	65,509.85

- Building Introduction
 - Proposed Solutions and Goals
 - Depth 1 – VAV System
 - **Depth 2 – Chilled Beam System**
 - Background Information
 - Energy Analysis
 - Energy Costs
 - **Chilled Beam Calculation**
 - First Cost
 - Life-Cycle Cost
 - Recommendation
 - Breadth 1 – Structural
 - Conclusion
 - Questions/Comments
- Taken from Trace:
 - $Q_{T(\text{sensible})} = 6,480 \text{ Btu/hr}$
 - $Q_{T(\text{latent})} = 1,000 \text{ Btu/hr}$
 - Based on ASHRAE 62.1: $V_r = 85 \text{ cfm}$
 - Room conditions:
 - $T_r = 75^\circ\text{F}$
 - $w_r = 0.0100 \text{ lbw/lbda}$
 - Air conditions:
 - $T_v = 55^\circ\text{F}$
 - $w_v = 0.0090 \text{ lbw/lbda}$
 - Cooling capacity of air:
 - $Q_{(\text{latent})} = 411 \text{ Btu/hr}$
 - $Q_{(\text{sensible})} = 1,836 \text{ Btu/hr}$
 - $Q_{T(\text{latent})} > Q_{(\text{latent})}$ therefore, need to recalculate $V(\text{cfm})$
 - $V = 207 \text{ cfm}$
 - $Q_{(\text{sensible})} = 4,463 \text{ Btu/hr}$
 - Selection made from Price manufacturer:
 - 210 cfm per beam
 - Beam length of 6 ft
 - 7,059 Btu/hr per beam
 - # of beams needed = $210/207 = 1$
 - Total of 546 lf of chilled beams needed

First Cost

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- **Depth 2 – Chilled Beam System**
 - Background Information
 - Energy Analysis
 - Energy Costs
 - Chilled Beam Calculation
 - **First Cost**
 - Life-Cycle Cost
 - Recommendation
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Chilled beam first cost:
 - \$2,549,100.00
 - \$56.65 per square foot
- Included:
 - Geothermal wellfield & piping
 - Water -to-water heat pumps
 - DOAS unit
 - Chilled beams
- Original system first cost: \$2,031,979
- 20.3% increase

System Components	Component Costs
Geothermal wellfield & piping	\$408,000.00
Water-to-water heat pumps	\$224,000.00
DOAS	\$58,000.00
Chilled Beams	\$177,450.00
Boiler	\$81,600.00
Pumps	\$7,500.00
Valving	\$50,000.00
Exhaust Fans	\$52,100.00
Unit heaters & misc.	\$37,500.00
Air Distribution	\$784,600.00
Hydronic piping	\$327,600.00
Controls	\$390,750.00

Life-Cycle Cost

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- **Depth 2 – Chilled Beam System**
 - Background Information
 - Energy Analysis
 - Energy Costs
 - Chilled Beam Calculation
 - First Cost
 - **Life-Cycle Cost**
 - Recommendation
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- 30 year life-cycle cost
- System was analyzed based on:
 - Capital Investment
 - Overhaul
 - Maintenance
 - Annual electric and natural gas costs
 - Escalation Factors

Maintenance (\$)	Annual Electricity Costs (\$)	Annual Natural Gas Costs (\$)	OMB Base Discount Rate (%)
36,470.00	63,951.48	524.13	3.0

- Total net present value: \$ 5,678,296.01
- 12.2% increase

	Original	Chilled Beam
HVAC System First Cost	\$2,031,979.00	\$2,549,100.00
Annual Maintenance Cost	\$52,100.00	\$36,470.00
Replacements Costs: 5	-	-
10	-	-
15	\$275,500.00	\$89,600.00
20	\$372,479.00	\$622,250.00
25	\$81,600.00	\$259,050.00
30	\$275,500.00	\$147,600.00
Annual Recurring Electric	\$73,720.36	\$63,951.48
Annual Recurring Natural Gas	\$817.27	\$524.13
Total Energy Costs	\$74,537.63	\$64,475.61

The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

Recommendation

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- **Depth 2 – Chilled Beam System**
 - Background Information
 - Energy Analysis
 - Energy Costs
 - Chilled Beam Calculation
 - First Cost
 - Life-Cycle Cost
 - **Recommendation**
- Breadth 1 – Structural
- Conclusion
- Questions/Comments

- Decrease of energy consumption and usage
 - 12.5% overall
 - 66.3% for fan and pump energy
 - 38.5% for heating
 - 65% for primary airflow
- \$9,768.88 less spent on electricity annually
- Total first cost: \$2,549,100.00
- Payback period of 52 years
- Is this a good option?


Yes



- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- **Breadth 1 – Structural**
 - **Structural Overview**
 - Original Roof Deck Analysis
 - Extensive Green Roof Analysis
 - Recommendation
- Conclusion
- Questions/Comments

Analysis:

- Calculations were completed for the original roof
- Dead loads
- Flat roof snow load
- Roof live load
- Weights from LiveRoof Hybrid Green Roof System manufacturer
- Total loads based on factored load equation
- Comparison of new loads to original



Original Roof Deck Analysis

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- **Breadth 1 – Structural**
 - Structural Overview
 - **Original Roof Deck Analysis**
 - Extensive Green Roof Analysis
 - Recommendation
- Conclusion
- Questions/Comments

- Dead Load: $D = 25$ psf
 - Metal deck, rigid insulation, built up roofing, misc. dead load
- Snow Load: $S = 35$ psf
- Live Load: $L_r = 20$ psf
- Calculated Factored Load: $R_u = 86$ psf

- Decking selection:
 - Use 3N18, 1 span of 8'-4"
- Check:
 - Max. SDI Construction Span = 15'-11" > 8'-4"
 - For 10'-0" Total Load = 91 psf > 86 psf

No. of Spans	Deck Type	Max. SDI Const. Span		
			10-0	
1	N22	11-7	50 / 43	
	N20	13-2	66 / 56	
	N19	14-7	79 / 69	
	N18	15-11	91 / 81	
	N16	18-6	118 / 110	

Extensive Green Roof Analysis

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- **Breadth 1 – Structural**
 - Structural Overview
 - Original Roof Deck Analysis
 - **Extensive Green Roof Analysis**
 - Recommendation
- Conclusion
- Questions/Comments

- Dead Load: $D = 31$ psf
 - Metal deck, rigid insulation, fenestration system, green roof (lite) saturated, misc. dead load
- Snow Load: $S = 35$ psf
- Live Load: $L_r = 20$ psf
- Calculated Factored Load: $R_u = 94$ psf

- Decking selection:
 - Use 3N16, 1 span of 8'-4"
- Check:
 - Max. SDI Construction Span = 18'-6" > 8'-4"
 - For 10'-0" Total Load = 118psf > 94 psf

No. of Spans	Deck Type	Max. SDI Const. Span		
			10-0	
1	N22	11-7	50 / 43	
	N20	13-2	66 / 56	
	N19	14-7	79 / 69	
	N18	15-11	91 / 81	
	N16	18-6	118 / 110	

Recommendation

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- **Breadth 1 – Structural**
 - Structural Overview
 - Original Roof Deck Analysis
 - Extensive Green Roof Analysis
 - **Recommendation**
- Conclusion
- Questions/Comments

Roof Type	Deck	Dead Load	Roof Live Load	Snow Load	Factored Load
Original	3N18	29	20	35	91
Extensive	3N16	34	20	35	97
Intensive (Opt. 1)	2VLI16	119	100	35	303
Intensive (Opt. 2)	3VLI16	119	100	35	303
Intensive (Opt. 3)	1.5VLI18	105	100	35	286

- Increase in loads
 - Extensive: 6.2%
 - Intensive Opt .1 and 2: 70%
 - Intensive Opt. 3: 68%
- Selection: Extensive green roof
 - Smallest increase in loads
 - 8 psf increase in factored loads

Conclusion

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- **Conclusion**
- Questions/Comments

- Conclusions for depth :

	VAV (%)	Chilled Beam (%)
End Use	(15.1)	(12.5)
Heating	(31.3)	(38.5)
Cooling	(16.9)	20.5
Fan/Pump	(46.4)	(66.3)
FC	17.4	20.3
LLC	3.9	12.2
SPB	33 years	52 years

- Mechanical system recommendation: VAV

- Conclusion for Structural breadth: Extensive green roof
 - Roof decking 3N16



The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

Acknowledgements

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- **Conclusion**
- Questions/Comments

AE Faculty

HGA Architects and Engineers

The American Swedish Institute

Friends and Family



The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

- Building Introduction
- Proposed Solutions and Goals
- Depth 1 – VAV System
- Depth 2 – Chilled Beam System
- Breadth 1 – Structural
- Conclusion
- **Questions/Comments**

Questions?



The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

Occupancy Schedule

Cooling Design Weekday Schedule		
Start Time	End Time	Percentage
Midnight	5 a.m.	30
5 a.m.	6 a.m.	60
6 a.m.	7 a.m.	90
7 a.m.	8 p.m.	100
8 p.m.	9 p.m.	90
9 p.m.	10 p.m.	60
10 p.m.	Midnight	30

Heating Design Schedule		
Start Time	End Time	Percentage
Midnight	Midnight	100


Saturday and Sunday Schedule		
Start Time	End Time	Percentage
Midnight	5 a.m.	30
5 a.m.	7 a.m.	60
7 a.m.	9 a.m.	90
9 a.m.	6 p.m.	100
6 p.m.	8 p.m.	90
8 p.m.	9 p.m.	60
9 p.m.	Midnight	30

The American Swedish Institute


Minneapolis, MN \ Krysta Skinner \ Mechanical Option

Energy Costs


VAV Monthly Utility Costs



Chilled Beam Monthly Utility Costs




Annual Energy Costs




Emissions and Energy Usage


Annual Carbon Emissions from Electricity



Annual Energy Use for HVAC Options by End Use




Life-Cycle Cost




The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

VAV Schematic



Ventilation Schematic for VAV




Geothermal Schematic for VAV


The American Swedish Institute

Minneapolis, MN \ Krysta Skinner \ Mechanical Option

Chilled Beam Schematics



Ventilation Schematic for Chilled Beams



Geothermal Schematic for Chilled Beams

Chilled Beam Full Calculation

- Chilled Beam Calculation:

- Taken from Trace:

- $Q_{T(\text{sensible})} = 6,480 \text{ Btu/hr}$
- $Q_{T(\text{latent})} = 1,000 \text{ Btu/hr}$
- $Q_{\text{total}} = 7,480 \text{ Btu/hr}$

- Type of room based on ASHRAE Std. 62.1-2007, Table 6.1:

Library:

- $R_p = 5 \text{ cfm/person}$
- $P_z = 500(\text{ft}^2) * 10 / 1000 (\# \text{ person/ft}^2) = 5 \text{ person}$
- $R_a = 0.12 \text{ cfm/ft}^2$
- $A_z = 500 \text{ ft}^2$
- $E_z = 1$
- $V_r(\text{cfm}) = R_p * P_z + R_a * A_z = 5 * 5 + 0.12 * 500 = 85 \text{ cfm}$

- Room conditions:

- $T_r = 75^\circ\text{F}$
- $w_r = 0.0100 \text{ lbw/lbda}$

- V conditions:

- $T_v = 55^\circ\text{F}$
- $w_v = 0.0090 \text{ lbw/lbda}$

- Calculated values:

- $Q_{(\text{latent})} = 4840 * \text{cfm} * (w_r - w_v)$
- $Q_{(\text{latent})} = 4840 * 85 * (0.01 - 0.009) = 411 \text{ Btu/hr}$
- $Q_{(\text{sensible})} = 1.08 * \text{cfm} * (T_r - T_v)$
- $Q_{(\text{sensible})} = 1.08 * 85 * (75 - 55) = 1,836 \text{ Btu/hr}$
- $Q_{T(\text{latent})} > Q_{(\text{latent})}$ therefore, need to recalculate V(cfm)
- $V = [Q_{T(\text{latent})}] / [4840 * (w_r - w_v)]$
- $V = [1000] / [4840 * (0.01 - 0.009)] = 207 \text{ cfm}$

- $Q_{(\text{sensible})} = 1.08 * 207 * (75 - 55) = 4,463 \text{ Btu/hr}$

- Check:

- $Q_{(\text{sensible})} = 6,480 \text{ Btu/hr} - 4,463 \text{ Btu/hr} = 2,017 \text{ Btu/hr}$

- Selection made from Price manufacturer:

- 210 cfm per beam
- Nozzle diameter of 0.300 inches
- Beam length of 6 ft
- 7,059 Btu/hr per beam
- # of beams needed = $210 / 207 = 1$
- 4.2 inches of head per beam
- 6 lf of beams needed

- All chilled beam results can be seen in Appendix G of report