

The Ed Roberts Campus

Technical Report 2

Anderson Clemenceau
Mechanical Option

Advisor: Donghyun Rim

October 6, 2014

Contents

Executive Summary 3

Building Overview 4

Mechanical Systems Overview 5

Design Load Estimation Procedure 6

 Model Inputs 6

Design Load Results 8

Annual Energy Use 10

References 12

Appendix A 13

Executive Summary

The objective of this report is to model and analyze the loads and energy use of the Ed Roberts Campus. Trane Trace 700 was the software used to model the building and is an industry standard program for energy modeling. About 130 rooms were grouped and entered in the program as 60 different spaces based on load type and usage. These rooms were zoned under their respective air handling units before the program performed calculations on loads and energy use for the entire building.

The model calculated that the Ed Roberts Campus has a total cooling load of 2,777.3 MBh and a total heating load of 1814.5 MBh. This was found to be drastically different than the design cooling and heating loads of 381 MBh and 1051 MBh, respectively. The reasons for these discrepancies are unclear, but can be mostly attributed to difficulty modeling the exact system layout in Trace 700. A model performed by the design engineers was unavailable for comparison.

Trace calculated that the ERC's annual utility costs will amount to \$62,168. The largest consumption of energy by any one system was by the cooling equipment which accounted for more than half the energy costs for most months of the year.

Emissions data was not calculated by Trace 700 due to unknown errors in the modeling process. However, by referencening emissions data published by the electric service company, PG&E, it was estimated that the electric demand of the ERC would account for approximately 541,342.5 Lbs/Yr of CO₂.

Building Overview

The Ed Roberts Campus is a 2-story, 80,000 sq. ft., transit-oriented community center located in downtown Berkeley, California. The campus is connected to a BART Station (Bay Area Rapid Transit) and is designed with a focus on accessibility for people with disabilities. Completed in 2011, the ERC is home to exhibition spaces, meeting spaces, a child development center, a fitness center, vocational training facilities, and offices.

Every square foot of the building is designed far and above the requirements of the Americans with Disabilities Act through a design concept called “Universal Design”. Universal Design aims to create environments that are useful for people of all ages and abilities without additional cost. Extra-wide corridors, automatic doors, two-sided elevators are examples of this design ideal. In addition, the ERC’s fully accessible connection to the BART station works to connect people directly to airports and bus stations around the city.



Leddy Maytum Stacy Architects

Mechanical Systems Overview

The Ed Roberts Campus combines several system types to heat and cool the building. The building is served by five rooftop air handling units (AHUs):

AHU-1: East Wing – South

AHU-2: B.O.R.P.

AHU-3: West Wing – South

AHU-4: West Wing – North

AHU-5: Covered Court

AHUs 1, 3, and 4 are constant volume units with 100% outdoor air. AHU 2 is a VAV unit with 100% outdoor air that operates in tandem with AHU 1. AHU 5 is a Variable Air Volume (VAV), packaged air cooled DX cooling unit. Each AHU is equipped with a supply fan only. There are also water-source heat pumps for additional heating and cooling to meet the needs of each individual zone within the building.

The building has four roof-mounted fans that serve general exhaust needs (EF-3, EF-4, EF-5, and EF-7) with 1,200 cfm, 1,000 cfm, 800 cfm, and 1,600 cfm respectively. In addition, there are four more roof-mounted fans that serve specific areas. EF-1 serves the BORP with 5,500 cfm of exhaust, EF-2 serves the restrooms with 2,600 cfm, EF-6 serves the garage with 72,000 cfm, and EF-9 serves the BART elevator room with 1,200 cfm. The garbage room has a smaller wall mounted fan that exhausts 350 cfm for that space.

In addition to these air systems, the ERC utilizes a radiant floor system which serves three zones: the entrance lobby, art exhibition space, and covered court area. Altogether, the system provides 115 MBH of cooling (9.6 tons) and 68 MBH of heating (5.6 tons).

Design Load Estimation Procedure

Trane Trace 700 was the software program used to model loads and energy use of the Ed Roberts Campus for this report. To create the model, information was collected from drawings and specifications and entered into the program.

Model Inputs

Climate Conditions

The Ed Roberts Campus is located in Berkeley, CA near the San Francisco Bay area. The closest choice in the Trace 700 weather database was San Francisco (CZ03). This refers to the ASHRAE 90.1 climate zones, investigated in Technical Report 1, and matches with the previously determined zone. Default settings within this climate template were used in the model.

Table 1 - Design Dry Bulb Temperatures

Summer Design Cooling DB (°F)	Summer Design Cooling WB (°F)	Winter Design Heating DB (°F)
74.6	62.6	40

Building Construction

The figure below is a screenshot of the construction materials specified in the templates of the Trace 700 model. These materials are generic choices based on some assumptions from the architectural plans. As a partition schedule was not available during the time of modeling, generic assemblies were chosen based on details and sections throughout the building. In addition, information about the specific type of glass used for windows in the building was not available so a generic glass type was chosen from Trace.

Table 2- Model Construction Materials

	Construction	U-Factor [Btu/h*ft ² *°F]
Slab	6" LW Concrete	0.534759
Roof	4" LW Concrete	0.213535
Wall	Frame Wall, 6" Ins.	0.046783
Partition	0.75" Gyp Frame	0.387955
	U-Factor [Btu/h*ft²*°F]	Shading Coeff.
Windows	1	.73

Occupancy Loads

In order to calculate building loads the building's approximately 130 rooms had to be entered into the program. Each space was dimensioned, including information about exterior facing walls and the percent of exterior walls that were windows. Once this was completed rooms with similar load characteristics were grouped together in order to simplify the modeling process.

Each room/zone was then classified under load templates in Trace 700 according to use. Templates were established in Trace for offices, meeting rooms, break rooms, lobbies, and applied to the different rooms once they had been entered into the program. Additional lighting loads were entered based on Table 9.5.1 Lighting Power Densities from ASHRAE 90.1. The office and classroom spaces included an additional load for computers and other office equipment.

Ventilation Loads

Trace 700 includes the option to apply ASHRAE Std. 62.1 2007 for the modeling of ventilation air requirements. This option was used in the model of the ERC so that the ventilation templates for different room types could be automatically implemented. While the program references an older version of ASHRAE 62.1, the population and area-based ventilation rates were mostly identical to the most recent edition of the standard.

Equipment

As stated in the mechanical overview, the ERC is served by five Dedicated Outdoor Air AHUs, primarily for ventilation air and latent loads, and zone level Water Source Heat Pumps that cover most of the sensible load. In Trace 700, this type of system can be modeled by Fan Coil Units with Optional Ventilation Coils with special inputs for Dedicated Outdoor Air. One exception is for AHU-5 which contains one Direct Expansion coil and is modeled as a Packaged RTU VAV Reheat with DX and Hot Water.

The heating and cooling coils are all served by two rooftop cooling towers and two boilers in the mechanical room that provide hot and cold water. These pieces of equipment were all modeled in Trace 700 with as much information as could be gathered from the specifications.

Design Load Results

The Trace 700 model was able to successfully calculate load information and energy use data for the Ed Roberts Campus. The results will be compared to design data from the engineers and evaluated for its accuracy.

The following two charts show the monthly load profiles and energy use for equipment in the building. The first chart shows that, for the most part, the building load is somewhat constant throughout the year. There are jumps in load in the coldest winter months, where heating loads are increased, and in the warmest summer month where cooling load is highest. However, this seems to represent a reasonable profile for a building in a temperate climate.




Figure 1 - Monthly Load Profiles

The table below displays the resulting load calculations from the Trace 700 model of the ERC. The results of the model will be compared to listed values in the AHU schedule from the mechanical drawings since an energy model from the MEP engineers is not available.

Table 3 - Heating and Cooling Load Comparison

Equipment	Design		Model	
	Cooling (MBh)	Heating (MBh)	Cooling (MBh)	Heating (MBh)
AHU-1	84	295	1,185.1	871.9
AHU-2	59	208	172.4	120.2
AHU-3	38	132	580.1	327.2
AHU-4	65	227	787.1	427.6
AHU-5	135	189	52.6	67.6
Total	381	1051	2,777.3	1814.5

Load Calculation Summary

There are significant differences between the values calculated by the model and the values listed in the design documents, with some model outputs as high as ten times the design load. These differences are likely due to inaccuracies and simplifications made in the modeling process. Trace 700 is also limited in the ways it can model Dedicated Outdoor Air systems like the one in the ERC. Due to differences in load characteristics it was necessary to create different rooms for different uses and occupancies instead of grouping spaces by the mechanical zones as laid out in the drawings. This resulted in Trace adding a Water Source Heat Pump for every room modeled, which is not the case in the actual building, and may have contributed to the inflated loads in the model. Differences in scheduling may have also contributed, as the specifications did not have operation schedules for the building, and in the model some spaces were left at worst-case 100% load. The engineering checks calculated by Trace also indicate problems in the model, such as very high cfm/ft² values, that would contribute to high load results, but the exact reasons for this are unclear.

Annual Energy Use


The table below lists the monthly utility cost of the Ed Roberts Campus, according to the Trace 700 model analysis. Utility cost information was gathered from the Pacific Gas and Electric Company website. Information is not available on the actual operational costs of the building but, based on the results in the load section of the report, it can be assumed that these costs may be inflated.

Table 4- Monthly Utility Costs

Month	Utility Cost (\$)
January	4,409
February	4,815
March	4,477
April	5,057
May	5,443
June	5,673
July	5,955
August	5,905
September	5,991
October	5,335
November	4,661
December	4,447
Total	62,168


This is equal to 0.94 \$/ft² based on a building area of 66,166 ft², which is the area of conditioned space within the building (not including mechanical and parking garage spaces). The figure below, displaying monthly electricity costs per equipment type, shows that lighting is a constant high demand for electricity use and costs. Standard recessed fluorescent lighting was used in the model, but it is possible that more efficient lighting types could decrease costs dramatically. It should be noted that this figure only includes cost of electricity consumed, and not demand costs.

Figure 2 - Monthly Electric Costs by Equipment Type




The next chart displays the breakdown of energy use of specific equipment types throughout the building. The energy use of the equipment matches with the load profiles in the previous section with boiler energy spiking in December and January and cooling equipment energy peaking in July. The maximum energy use of the system is just above 70,000 KWh during the month of July.

Figure 3 - Monthly Energy Use by Equipment Type



Due to errors in the Trace 700 model, emissions data was not able to be calculated and was not available in the report. The reasons for this are unclear.

Figure 4- Trace Environmental Analysis



However, based on emissions data published by PG&E, the CO₂ emissions information can be estimated based on the amount of electricity demanded by the ERC. Trace 700 calculated that the building will use 1,313,938 kWh of electricity. At a rate of 412 Lbs-CO₂/MWh, the CO₂ emissions attributed to the ERC's electricity use amount to 541,342.5 Lbs/Yr.

Energy Summary

It is clear that the process of modeling the buiding could be improved dramatically. While it is likely these results do not accurately represent energy use of the building, it remains a useful exercise in attempting to understand the building systems and their comparative energy use profiles.

References

ANSI/ASHRAE/IES. 2013. *Standard 90.1-2013, Energy Standard for Buildings Except Low-Rise Residential Buildings*. Atlanta, GA. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

Pacific Gas & Electric Company
Utility Rates and Emissions Data

Leddy Maytum Stacy Architects

Arup San Francisco

Appendix A

**TABLE 9.5.1 Lighting Power Densities
Using the Building Area Method**

Building Area Type^a	LPD, W/ft²
Automotive facility	0.80
Convention center	1.01
Courthouse	1.01
Dining: Bar lounge/leisure	1.01
Dining: Cafeteria/fast food	0.90
Dining: Family	0.95
Dormitory	0.57
Exercise center	0.84
Fire station	0.671
Gymnasium	0.94
Health-care clinic	0.90
Hospital	1.05
Hotel/Motel	0.87
Library	1.19
Manufacturing facility	1.17
Motion picture theater	0.76
Multifamily	0.51
Museum	1.02
Office	0.82
Parking garage	0.21
Penitentiary	0.81
Performing arts theater	1.39
Police station	0.87
Post office	0.87
Religious building	1.00
Retail	1.26
School/university	0.87
Sports arena	0.91
Town hall	0.89
Transportation	0.70
Warehouse	0.66
Workshop	1.19

a. In cases where both a general building area type and a specific building area type are listed, the specific building area type shall apply.

Figure 5 - ASHRAE 90.1 Lighting Power Densities

Rate Schedule	Customer Charge	Optional Meter Data Access Charge	Season	Time-of-Use Period	Demand Charge (per kW)			Time-of-Use Period	Total Energy Charge (per kWh)		
					Secondary	Primary	Transmission		Secondary	Primary	Transmission
A-10 (Table A)	\$4.59959 per meter per day		Summer		\$13.87	\$13.10	\$9.36		\$0.15784	\$0.14753	\$0.12308
			Winter		\$6.46	\$6.67	\$5.00		\$0.11770	\$0.11204	\$0.09868
A-10 TOU (Table B)	\$4.59959 per meter per day	\$0.98563 per meter per day	Summer	Peak				Peak	\$0.17479	\$0.16169	\$0.13592
				Part-Peak				Part-Peak	\$0.16711	\$0.15621	\$0.13092
				Off-Peak				Off-Peak	\$0.14377	\$0.13526	\$0.11196
			Winter		\$6.46	\$6.67	\$5.00	Part-Peak	\$0.12798	\$0.12044	\$0.10640
								Off-Peak	\$0.10796	\$0.10405	\$0.09135

Figure 6 - PG&E Utility Rates

PG&E Emissions Factor Summary

Emission Type	Emission Factor			Source
	Year	Lbs CO ₂ /MWh	Metric tons CO ₂ /MWh	
Historical Emissions	2003	620	0.281	PG&E's third-party-verified GHG inventory submitted to the California Climate Action Registry (CCAR) ² (2003-2008) or The Climate Registry (TCR) (2009-2011)
	2004	566	0.257	
	2005	489	0.222	
	2006	456	0.207	
	2007	636	0.288	
	2008	641	0.291	
	2009	575	0.261	
	2010	445	0.202	
	2011	393	0.178	
Future Emissions (estimated)	2012 ³	453	0.205	CPUC GHG Calculator, which provides an independent forecast of PG&E's emission factors as part of a model on how the electricity sector
	2013	431	0.196	
	2014	412	0.187	
	2015	391	0.177	
	2016	370	0.168	

Figure 7 - PG&E CO₂ Emission Rates

System Checksums

By ACADEMIC

AHU-1

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK			
Peaked at Time: Outside Air: OADB:MoHr: 61/55/56				MoHr: Sum of OADB:Peaks				MoHr: Heating Design OADB: 40			
Space Sens. + Lat. Bluh	Plenum Sens. + Lat. Bluh	Net Total Bluh	Percent of Total (%)	Space Sensible Bluh	Percent of Total (%)	Space Peak Bluh	Percent of Total (%)	Space Peak Bluh	Total Sens. Bluh	Percent of Total (%)	Temp. Cooling
Envelope Loads											56.2
Skyline Solar	0	0	0	0	0	0	0	0	0	0	77.9
Skyline Cond	0	0	0	0	0	0	0	0	0	0	75.2
Roof Cond	0	0	0	0	0	0	0	0	0	0	75.2
Roof Infil	0	213,722	23	0	0	0	0	-173,318	19.88	0	69.6
Glass Solar	252,039	0	27	462,009	54	0	0	0	0	0	75.2
Glass Door Cond	-35,865	0	-4	-44,160	-5	0	0	-113,120	12.97	0	75.2
Wall Cond	2,163	1,122	4	3,285	0	0	0	-113,120	0.0	0	0.0
PartitionDoor	0	0	0	0	0	0	0	-4,158	0.0	0	0.0
Floor	0	0	0	0	0	0	0	0	0.0	0	0.1
Adjacent Floor	0	0	0	0	0	0	0	0	0.0	0	0.0
Infiltration	0	0	0	0	0	0	0	0	0.0	0	0.0
Sub Total ==>	218,338	214,844	46	421,133	50	-117,278	-292,689	33.57			
Internal Loads											
Lights	63,583	15,896	8	63,583	7	0	0	0	0	0	
People	347,744	0	37	196,564	23	0	0	0	0	0	
Misc	32,417	0	3	32,417	4	0	0	0	0	0	
Sub Total ==>	443,745	15,896	48	292,564	34	0	0	0	0	0	
Ceiling Load	27,932	-27,932	0	13,820	2	-21,210	0	0	0	0	
Adj Air Trans Heat	78,497	0	8	122,304	14	-178,752	0	0	0	0	
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	
Sup. Fan Heat	-30,206	-30,206	-3	0	0	0	0	0	0	0	
Ret. Fan Heat	7,195	0	1	0	0	0	0	0	0	0	
Duct Heat PkUp	0	0	0	0	0	0	0	0	0	0	
Underfrt Sup Ht PkUp	0	0	0	0	0	0	0	0	0	0	
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	
Grand Total ==>	768,512	172,602	100.00	849,820	100.00	-317,240	-871,863	100.00			

COOLING COIL SELECTION			HEATING COIL SELECTION		
Capacity ton	Sens Cap. MBh	Coil Airflow cfm	Capacity MBh	Coil Airflow cfm	Lvg Ent °F
Main Clg	79.0	948.3	840.9	48,364	48,364
Aux Clg	0.0	0.0	0.0	0.0	0.0
Opt Vent	19.7	236.8	175.3	8,451	8,451
Total	98.8	1,185.1			

TEMPERATURES		AIRFLOWS	
MBh	cfm	Diffuser	Return
75.2	0.0	48,364	56,816
69.6	0.0	48,364	8,451
69.6	0.0	48,364	0
0.0	0.0	0	0
0.0	0.0	0	0
0.0	0.0	0	0
0.0	0.0	0	0
0.1	0.0	0	0

TEMPERATURES		AIRFLOWS	
MBh	cfm	Diffuser	Return
75.2	0.0	48,364	56,816
69.6	0.0	48,364	8,451
69.6	0.0	48,364	0
0.0	0.0	0	0
0.0	0.0	0	0
0.0	0.0	0	0
0.0	0.0	0	0
0.1	0.0	0	0

ENGINEERING CKS	
CKS	Value
% OA	17.5
cfm/wt	1.75
cfm/ton	489.72
ft/ton	278.01
Btu/ft²	43.16
No. People	782

Project Name: Ed Roberts Campus
 Dataset Name: ERC_EnergyModel.trc

TRACE® 700 v6.3 calculated at 03:14 PM on 10/05/2014
 Alternative - 1 System Checksums Report Page 1 of 5

System Checksums

By ACADEMIC

AHU-2		COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Outside Air:		MoHr: 6/17 OADB/NBHR: 69 / 61 / 67				MoHr: Sum of OADB: Peaks				MoHr: Heating Design OADB: 40				Cooling Heating			
		Sens. + Lat. Sens. + Lat				Space Sensible				Space Peak				SADB			
		Plenum				Net Total				Percent				Ra Plenum			
		Bu/h				Bu/h				Of Total				Return			
		Bu/h				Bu/h				Of Total				Ret/OA			
		Bu/h				Bu/h				Of Total				Fn MtrTD			
		Bu/h				Bu/h				Of Total				Fn BldTD			
		Bu/h				Bu/h				Of Total				Fn Frict			
Envelope Loads		0				0				0				0.0			
Skyline Solar		0				0				0				0.0			
Skyline Cond		0				0				0				0.0			
Roof Cond		0				0				0				0.0			
Glass Solar		14,871				87,858				59				81.4			
Glass/Ober Cond		-1,672				14,871				10				81.4			
Wall Cond		718				-1,672				-1				0.0			
Partition/Door		84				802				1				0.0			
Floor		0				0				0				0.1			
Adjacent Floor		0				0				0				0.0			
Infiltration		0				0				0				0.0			
Sub Total ==>		13,917				87,942				68				825			
Internal Loads		15,267				3,817				13				825			
Lights		38,820				0				26				825			
People		10,853				0				7				825			
Misc		64,941				3,817				46				825			
Sub Total ==>		20,213				-20,213				0				825			
Ceiling Load		-13,387				0				-9				825			
Ventilation Load		0				0				0				825			
Adj Air Trans Heat		0				0				0				825			
Dehumid. by Sizing		0				0				0				825			
Exhaust Heat		0				-8,634				-6				825			
Ret. Fan Heat		0				890				1				825			
Dust Heat Pkup		0				0				0				825			
Underflr Sup Ht Pkup		0				0				0				825			
Supply Air Leakage		0				0				0				825			
Grand Total ==>		85,483				62,912				149,286				100.00			
		108,135				100.00				-50,765				100.00			

AHU-2		COOLING COIL SELECTION				HEATING COIL SELECTION				TEMPERATURES			
Total Capacity		Sens Cap.				Coil Airflow				Ent Lvg			
ton		MBh				cfm				-F			
12.4		149.3				131.2				6,007			
0.0		0.0				0.0				0.0			
1.9		23.1				17.1				825			
Total		14.4				172.4				825			
Main Clg		12.4				149.3				6,007			
Aux Clg		0.0				0.0				0.0			
Opt Vent		1.9				23.1				825			
Total		14.4				172.4				825			

AHU-2		AREAS				HEATING COIL SELECTION			
Gross Total		Glass				Capacity			
Floor		ft²				Coil Airflow			
Part		ft²				cfm			
Int Door		ft²				-F			
Roof		ft²				-F			
Wall		ft²				-F			
Ext Door		ft²				-F			
Total		703				825			
6,785		0				-78.9			
0		0				6,007			
0		0				0			
6,785		0				0			
2,005		703				-41.3			
0		0				-120.2			
Total		703				825			

AHU-2		ENGINEERING CKS			
% OA		Cooling			
cfm/ft²		Heating			
ft/ton		-F			
Bluffr-ft²		No. People			
84		84			
13.7		13.7			
418.14		418.14			
472.26		472.26			
25.41		25.41			
-17.71		-17.71			

Project Name: Ed Roberts Campus
 Dataset Name: ERC_EnergyModel.trc
 YRACE® 700 v6.3 calculated at 03:14 PM on 10/05/2014
 Alternative - 1 System Checksums Report Page 2 of 5

System Checksums

By ACADEMIC

AHU-3		COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES				Fan Coil			
Peaked at Time: Outside Air:		Mo/Hr: 6 / 18 OADB/WBtHR: 67 / 60 / 68				Mo/Hr: Sum of OADB: Peaks				Mo/Hr: Heating Design OADB: 40				SAOB				Cooling Heating			
Sens. + Lat. Blt/h		Plenum Blt/h		Net Total Blt/h		Space Sensible Blt/h		Percent Of Total (%)		Space Sensible Blt/h		Coil Peak Tot Sens Blt/h		Percent Of Total (%)		Return		79.1		76.8	
Envelope Loads		0		0		0		0		0		0		0		79.1		68.8		68.8	
SkyLite Solar		0		0		0		0		0		0		0		79.1		68.8		68.8	
SkyLite Cond		0		0		0		0		0		0		0		79.1		68.8		68.8	
Roof Cond		0		0		0		0		0		0		0		79.1		68.8		68.8	
Glass Solar		155.643		231.601		243.594		61		243.594		-108.363		33.12		79.1		68.8		68.8	
Glass/Door Cond		-6.091		-8.091		-11.147		-3		-11.147		-60.453		18.49		0.0		0.0		0.0	
Wall Cond		1,859		2,837		2,466		1		2,466		-2,797		0.00		0.0		0.0		0.0	
Partition/Door		0		0		0		0		0		0		0.00		0.0		0.0		0.0	
Floor		0		0		0		0		0		0		0.00		0.0		0.0		0.0	
Adjacent Floor		0		0		0		0		0		0		0.00		0.0		0.0		0.0	
Infiltration		0		0		0		0		0		0		0.00		0.0		0.0		0.0	
Sub Total ==>		151,411		232,579		383,990		74		234,913		-171,653		52.46		2,298		2,298		2,298	
Internal Loads		37,792		9,448		47,241		9		37,792		0		0.00		2,298		2,298		2,298	
Lights		114,679		0		114,679		22		65,197		0		0.00		2,298		2,298		2,298	
People		25,160		0		25,160		5		25,160		0		0.00		2,298		2,298		2,298	
Misc		177,631		9,448		187,079		36		128,149		0		0.00		2,298		2,298		2,298	
Sub Total ==>		36,821		-36,821		0		0		24,931		-16,645		0.00		2,298		2,298		2,298	
Ceiling Load		0		0		0		0		8,310		-48,607		14.86		2,298		2,298		2,298	
Ventilation Load		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Adj Air Trans Heat		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Dehumid. Ov Sizing		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Ov/Undr Sizing		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Exhaust Heat		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Ret. Fan Heat		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Duct Fan Heat		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Underfir Sup Ht PkUp		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Supply Air Leakage		0		0		0		0		0		0		0.00		2,298		2,298		2,298	
Grand Total ==>		325,052		187,101		515,671		100.00		396,304		-327,198		100.00		2,298		2,298		2,298	

COOLING COIL SELECTION				HEATING COIL SELECTION			
Total Capacity ton	43.0	515.7	466.9	Sens Cap. MBh	47.7	2,298	74.2
Aux Ctg	0.0	0.0	0.0	Coil Airflow cfm	23,746	79.1	62.7
Opt Vent	5.4	64.4	47.7	Enter DBWBtHR °F	0.0	0.0	0.0
Total	48.3	580.1	48.3	Leave DBWBtHR °F	56.9	54.3	59.0

AREAS			
Gross Total	16,420	Floor	16,420
Part	0	Part	0
Int Door	0	Int Door	0
ExFlr	0	ExFlr	0
Roof	17,620	Roof	17,620
Wall	3,948	Wall	3,948
Ext Door	0	Ext Door	0

ENGINEERING CKS			
% OA	9.7	Heating	9.7
cfm/h²	1.45	Aux Htg	1.45
cfm/ton	491.23	Preheat	0.0
#/ton	339.68	Humidif	0.0
Btu/hr-ft²	35.33	Opt Vent	-115.1
No. People	289	Total	-327.2

Project Name: Ed Roberts Campus
 Dataset Name: ERC_EnergyModel.trc
 TRACE® 700 v6.3 calculated at 03:14 PM on 10/05/2014
 Alternative - 1 System Checksums Report Page 3 of 5

System Checksums

By ACADEMIC

AHU-4		COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Peaked at Time: Outside Air:		Mo/Hr: 4 / 17 OADB/BH/HR: 63 / 56 / 57		Mo/Hr: Sum of OADB: Peaks		Mo/Hr: Heating Design OADB: 40		Cooling Heating	
Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Space Sens	Percent Of Total	SADB	Return
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	74.8	74.8
108,978	0	108,978	16	165,796	30	0	0	74.8	76.8
0	-9,448	-9,448	-1	0	0	0	0	69.7	69.7
0	112,622	112,622	17	0	0	0	0	74.8	69.7
156,494	0	156,494	23	156,764	29	0	0	0.0	0.0
-14,465	0	-14,465	-2	-13,120	-2	0	0	0.0	0.0
291	122	412	0	904	0	-56,863	13.30	0.1	0.0
0	0	0	0	0	0	-1,002	0.35	0.0	0.0
0	0	0	0	0	0	0	0.00	0.0	0.0
0	0	0	0	0	0	0	0.00	0.0	0.0
0	0	0	0	0	0	0	0.00	0.0	0.0
0	0	0	0	0	0	0	0.00	0.0	0.0
251,207	103,296	354,503	53	309,345	57	-57,865	35.16	0.0	0.0
Sub Total ==>									
Internal Loads									
Lights	28,289	7,072	5	28,289	5	0	0	0	0
People	246,634	0	37	138,208	25	0	0	0	0
Misc	7,120	0	1	7,120	1	0	0	0	0
Sub Total ==>	282,043	7,072	43	173,617	32	0	0	0	0
Ceiling Load	10,019	-10,019	0	9,365	2	-8,392	0	0	0
Ventilation Load	38,571	0	6	51,627	9	-85,440	19.98	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0
Exhaust Heat	0	-12,555	-2	0	0	10,516	-2.46	0	0
Sup. Fan Heat	0	4,186	1	0	0	-202,357	47.32	0	0
Ret. Fan Heat	0	0	0	0	0	0	0.00	0	0
Duct Heat PkUp	0	0	0	0	0	0	0.00	0	0
Underfir Sup Ht PkUp	0	0	0	0	0	0	0.00	0	0
Supply Air Leakage	0	0	0	0	0	0	0.00	0	0
Grand Total ==>	581,930	87,795	100.00	543,954	100.00	-151,696	100.00	-427,609	540

AHU-4		COOLING COIL SELECTION		HEATING COIL SELECTION	
Total Capacity	Sens Cap.	Coil Airflow	Enter	Capacity	Coil Airflow
ton	MBh	cfm	°F	MBh	cfm
56.2	673.9	585.4	74.8	-225.3	28,255
0.0	0.0	0.0	61.1	0.0	0.0
9.4	113.2	83.8	74.2	0.0	0.0
Total	65.6	787.1	74.2	0.0	0.0

AHU-4		ENGINEERING CKS	
% OA	cfm/ft²	cfm/ton	Btu/hr-ft²
14.3	2.49	430.76	172.66
0.00	0.00	69.50	-37.76
No. People	540		

AHU-4		TEMPERATURES	
Mo/Hr: Heating Design	OADB: 40	Mo/Hr: Sum of	OADB: Peaks
11,325	0	11,325	0
0	0	0	0
0	0	0	0
11,325	0	11,325	0
2,811	1,789	2,811	1,789
0	0	0	0
Ext Door	0	0	0

AHU-4		AREAS	
Gross Total	Glass	ft²	(%)
11,325	0	11,325	0
0	0	0	0
0	0	0	0
11,325	875	875	8
2,811	1,789	2,811	64
0	0	0	0
Ext Door	0	0	0

TRACED 700 v6.3 calculated at 03:14 PM on 10/05/2014
 Alternative - 1 System Checksums Report Page 4 of 5

Project Name: Ed Roberts Campus
 Dataset Name: ERC_EnergyModel.txd

System Checksums By ACADEMIC

System 5 - Packaged RTU VAV Reheat, DX & Hot Water															
COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Outside Air: Mo/Hr: 11/8 OADB/WB/HR: 52 / 51 / 55				Mo/Hr: 5 / 13 OADB: 66				Mo/Hr: Heating Design OADB: 40							
Space Sens. + Lat.	Plenum	Sens. + Lat.	Net Total	Space Sensible	Percent Of Total	Space Sens	Coil Peak Tot Sens	Percent Of Total	SADB	Return	Fn Mtr/D	Fn Blt/D	Fn Frict	Cooling	Heating
Btu/h	Btu/h	Btu/h	Btu/h	Btu/h	(%)	Btu/h	Btu/h	(%)							
Envelope Loads	0	0	0	0	0	0	0	0							
Sky/ite Solar	0	0	0	0	0	0	0	0							
Sky/ite Cond	0	0	0	0	0	0	0	0							
Roof Cond	0	0	0	0	0	0	0	0							
Glass Solar	0	0	0	0	0	0	0	0							
Glass/Door Cond	0	0	0	0	0	0	0	0							
Wall Cond	0	0	0	0	0	0	0	0							
Partition/Door	0	0	0	0	0	0	0	0							
Floor	0	0	0	0	0	0	0	0							
Adjacent Floor	0	0	0	0	0	0	0	0							
Infiltration	0	0	0	0	0	0	0	0							
Sub Total ==>	0	0	0	0	0	0	0	0							
Internal Loads															
Lights	9,358	2,339	11,697	32	32	9,358	0	0.00							
People	13,153	0	13,153	36	36	7,307	0	0.00							
Misc	7,133	0	7,133	20	24	7,133	0	0.00							
Sub Total ==>	29,643	2,339	31,983	89	81	23,797	0	0.00							
Ceiling Load	0	0	0	0	0	0	0	0.00							
Ventilation Load	4,268	0	4,268	12	19	5,744	-8,395	14.46							
Adj Air Trans Heat	0	0	0	0	0	0	0	0.00							
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0.00							
Ov/Undr Sizing	0	0	0	0	0	0	0	0.00							
Exhaust Heat	-449	0	-449	-1	0	0	0	0.00							
Sup. Fan Heat	248	0	248	1	0	0	-19,884	34.24							
Ret. Fan Heat	0	0	0	0	0	0	0	0.00							
Duct Heat PkUp	0	0	0	0	0	0	-29,789	51.30							
Underflr Sup Ht PkUp	0	0	0	0	0	0	0	0.00							
Supply Air Leakage	0	0	0	0	0	0	0	0.00							
Grand Total ==>	33,911	1,891	36,049	100.00	100.00	29,542	-8,395	-58,068	100.00	100.00	29	12.58	-16.18	381.56	953.89

COOLING COIL SELECTION		HEATING COIL SELECTION	
Total Capacity	Sens Cap.	Capacity	Coil Airflow
ton	MBh	MBh	cfm
Main Ctg	3.5	41.5	31.7
Aux Ctg	0.0	0.0	0.0
Opt Vent	0.9	11.1	8.2
Total	4.4	52.6	397

AREAS		HEATING COIL SELECTION	
Gross Total	Glass	Capacity	Coil Airflow
ft²	ft² (%)	MBh	cfm
Floor	4,180	-47.7	1,672
Part	0	0.0	0.0
Int Door	0	0.0	0.0
ExFlr	0	-37.2	1,672
Roof	0	0.0	0.0
Wall	0	-19.9	397
Ext Door	0	0.0	40.0
Total	4,180	-67.6	3,972

ENGINEERING CKS		TEMPERATURES	
% OA	cfm/ft²	Cooling	Heating
	ft³/ton	Btu/h	Btu/h
0.40	0.40	56.1	76.5
0.40	0.40	72.0	72.0
381.56	953.89	73.0	72.0
12.58	-16.18	0.0	0.0
29		0.1	0.0

Project Name: Ed Roberts Campus
 Dataset Name: ERC_EnergyModel.1tc
 TRACE® 700 v6.3 calculated at 03:14 PM on 10/05/2014
 Alternative - 1 - System Checksums Report Page 5 of 5