

WTC EMERGENCY

BUILDING RATINGS AND ACTIONS

New York City DDC/DoB Cooperative Building Damage Assessment

SEAoNY - 22 Sep 2001

No	Block	Lot	Name	Address	DOB Rating		Net Windows or Remove Glass	Board Windows	Sidewalk Bridge	Shoring and/or Large Debris Removal	Roof (2)	SEAoNY/DDC/DOB Report (3)
1	16	3	Gateway	395 South End Ave	Yellow	Major Damage	East (E) façade	East (E) façade	East (E) façade		TBD	
2	16	120	1 WFC Tower A	120 West St	Yellow	Moderate Damage	E façade	N and E façade	E façade		Debris and water	Attached
			South Bridge			Moderate Damage	N and S façade	N and S façade			Debris and water	w/ abv
			1-2 WFC Link Bridge			Moderate Damage	E and W façade	E and W façade			Debris and water	w/ abv
3	16	125	2 WFC Tower B	125 West St	Blue	Major Damage	E façade	E façade	E façade	Required	Debris and water	Attached
4	16	140	3 WFC Tower C - Amex	200 Vesey St	Blue	Major Damage	E façade	E and S façade	E façade	Required	Debris and water	Attached
5	16	140	Winter Garden Bldg	200 Vesey St	Red	Partial Collapse			E façade	Required		Attached
6	50	1		115 Broadway	Yellow	Moderate Damage		N façade	N façade		TBD	
7	52	10		120 Cedar St	Blue	Major Damage		N and W façade	N and W façade	Required	Debris and water	Attached
8	52			110 Liberty St	Yellow	Moderate Damage	N façade	N façade	N façade		TBD	
9	52	21		120 Liberty St	Yellow	Moderate Damage	N façade	N façade	N façade		TBD	
10	52	25		114 Liberty	Blue	Major Damage	N façade	N and E façade	N façade	Required	Debris and water	Attached
11	53	23		5 Carlisle	Yellow	Moderate Damage		N and W façade	N and W façade		TBD	
12	53	28		1 Carlisle	Yellow	Moderate Damage		E façade	N façade		TBD	
13	53	33		110 Greenwich	Yellow	Moderate Damage	E façade (NE side)	N and E façade	N façade		TBD	
14	54	1	Bankers Trust	130 Liberty	Blue	Major Damage	E façade	E and W façade	N Façade and Full bridge across Washington St (W)	Required	Debris and water	Attached
15	55	16	Marriott	85 West St	Yellow	Moderate Damage		N and W façade			TBD	
16	56	1		130 Cedar St	Blue	Major Damage	N façade	N and E façade	N Façade and Full bridge across Washington St (E)	Required	Debris and water	Attached
17	56	4		90 West St	Blue	Major Damage	N and W façade	N, W and S façade	N, W and S façade	Required	TBD	Attached
18	58		South East Plaza	WTC 4	Red	Partial Collapse				Required		
19	58		North East Plaza	WTC 5	Red	Partial Collapse				Required		
20	58		Custom House	WTC 6	Red	Partial Collapse				Required		
21	62	1		1 Liberty Plaza	Yellow	Moderate Damage	W façade	N, W and S façade			TBD	Attached
22	63	3		22 Cortland St	Yellow	Moderate Damage	W façade	N, W and S façade			TBD	Attached
23	63	6	Century 21	19-27 Church	Yellow	Moderate Damage	W façade	N, W and S façade			TBD	
24	80	4	Millenium Hotel	20 Dey Street	Yellow	Moderate Damage	N, W and S façade	N, W and S façade	W and S façade		TBD	Attached
25	84	1	Verizon	140 West St	Blue	Major Damage	E, S and W façade	E, S and W façade	E, S and W façade	Required	TBD	Attached
26	86	1	Post Office	90 Church St	Yellow	Moderate Damage	W and S façade	W and S façade	S façade		TBD	Attached
27	126	2		110 Church St	Yellow	Moderate Damage	S façade	S façade	S façade		TBD	
28	126	27		120 Church St	Yellow	Moderate Damage	S façade	S façade	S façade		TBD	
29	127	1		30 West Broadway	Blue	Major Damage	W and S façade	W and S façade	S façade	Required	TBD	Attached
30	127	18		75 Park Place	Yellow	Moderate Damage	W and S façade	W and S façade	W and S façade		TBD	
31	128	2		224 Greenwich St	Yellow	Moderate Damage	S façade	S façade	S façade		TBD	

G Approximately 384 buildings in damage assessment area (Hudson River - Williams St - Chambers St - Rector St)
Y 18
B 9
R 4

NOTES

- 1 Some netting, boarding and sidewalk bridges may be in place or underway
- 2 Roof assessment will be by DoB
- 3 15 reports incl'd