

# The Millennium Science Complex

University Park, PA

Penn State  
Integrated Project Delivery /  
Building Information Modeling  
Senior Capstone Thesis







## Project Team Members



**Jason Brognano**  
Lighting/Electrical Designer



**Michael Gilroy**  
Mechanical Designer



**David Maser**  
Construction Manager



**Stephen Kijak**  
Structural Designer




## Location, Size, and Use



- Science Research complex
- 275,600 sq. ft.
- Three above grade floors, penthouse, mezzanine, and basement

## Project Overview



## Time and Cost

- Design-Bid-Build Delivery
- June 2008 — July 2011 Construction
- \$230,000,000 budgeted overall cost
- \$175,000,000 building cost

## Sustainability Features

- LEED Gold Certification
- Green roofs on both wings
- Low VOC materials on interior
- Daylight integration in perimeter spaces
- CO<sub>2</sub> occupancy density sensors



## Construction

CONSTRUCTION PHASE	DURATION (DAYS)	START	FINISH
Notice to Proceed	1	8-12-08	8-12-08
Foundation	270	2-16-09	2-26-10
Superstructure	274	7-7-09	7-23-10
Enclosure	303	11-9-09	1-5-11
Building Systems & Finishes	345	12-14-09	4-8-11
Construction Duration	758	8-12-08	7-7-11
Substantial Completion	1	7-7-11	7-7-11

## Project Overview



## Lighting and Power

- All **lighting on 480Y/277V** supply
- **Receptacle** and small loads **on 208Y/120V**
- Lutron Ecosystem in public perimeter spaces
- Occupancy and daylight sensor control
- Lighting control panels for exterior spaces
- Campus tied, 12.47kV supply voltage
- Dual 5000A main-tie-main switchgear
- Rigid conduit and aluminum cladding in electrical rooms to mitigate EMF interference





## Mechanical

- **VAV Reheat Air Distribution**

- (5) 50,000 CFM AHUs deliver 100% OA to General Lab Areas
- (3) 40,000 CFM AHUs serve Office & Common Areas
- Animal Care, Quiet Lab, and Clean Room AHUs

- **High pressure steam** from PSU central plant

- Reduced to medium and low pressure for use

- PSU campus **chilled water** used for cooling coils AHUs

- Dedicated exhaust system for fume hoods, biosafety cabinets

- CO<sub>2</sub> Sensors throughout to maintain air quality

- 4<sup>th</sup> floor penthouse and basement mechanical rooms



## Project Overview



## Structural

- **Steel Structure**

- LWT Concrete on 3inch Metal Deck
- Wide Flange Beams and Girders, 21 and 24 inches deep

- **22ft. X 22ft. Bays**

- **154ft. Cantilever** at the North-West corner of the Building

- 4 Main Supporting Trusses
- Web Members Oriented for Axial Compression
- Moment Connected Members for Stiffness
- Controlled by Deflection - 2 inch Allowance

- Lateral System

- Shear Walls, Braced Frames, Moment Frames
- 90% of Lateral Forces Received by Shear Walls
- Seismic Forces Control

- Foundation

- Micropiles Beneath Pile Caps
- Grid of Foundation Beams






## IPD/BIM Goals

- Update option-specific designs within the appropriate **BIM models**
- Perform analyses using the **central model** as a base
- Document **model sharing processes** to achieve design goals
- Work collaboratively to assess repercussions of design changes on **all disciplines**

## KGB Maser Goals of Analysis



## Engineering Goals

- Decrease energy consumption by **10%**
- **Reduce size** and **cost** of structural system
- Modify façade to accommodate **multiple disciplines**: daylight delivery, structural efficiency, mechanical system sizing, and constructability



## Existing vs. Proposed Façade Key Design Issues

How does overhang depth affect **mechanical load**?

How does overhang depth affect **daylight delivery**?

Is it possible to **reduce the weight** of panels?

Can all options come to a conclusion that is **beneficial** and **cost effective**?



Revised brick attachment to concrete panel

Small louver to allow for additional overhang

Glazing change to balance mechanical and lighting implications



Larger louvered overhang at mid-point of window

Thinner façade panel to decrease weight and cost





# Overhang Investigation: Trane TRACE



Overhang projection out 2.5 ft

External Shading

Overhang - 2.5

	Opening - 1	Opening - 1	Opening - 1	Opening - 1	Opening - 1
Opening Description	Opening - 1	Opening - 1	Opening - 1	Opening - 1	Opening - 1
Wall Description	Wall - 1w	Wall - 1w	Wall - 1w	Wall - 1w	Wall - 2-s
Room / Door	sp-W-321-Neurophys_Invitro	sp-W-322-Neurophys_Invitro	sp-W-325-Neurophys_Invitro	sp-W-326-Neurophys_Invitro	sp-W-326-Neurophys_Invitro
Window / Door	Window	Window	Window	Window	Window
Opening Dimension Type	% Wall Area	% Wall Area	% Wall Area	% Wall Area	% Wall Area
% Area	45.8	45.8	45.8	45.8	100
Opening Length (ft)	0	0	0	0	0
Opening Height (ft)	0	0	0	0	0
Quantity	0	0	0	0	0
Opening Type	6mm Dbl Ref D Clear 13mm Argon	6mm Dbl Ref D Clear 13mm Argon	6mm Dbl Ref D Clear 13mm Argon	6mm Dbl Ref D Clear 13mm Argon	6mm Dbl Ref D Clear 13mm Argon
Opening U-factor (Btu/h ft <sup>2</sup> °F)	0.47	0.47	0.47	0.47	0.47
Shading Coef	0.44	0.44	0.44	0.44	0.44
% Solar Load to RA	0	0	0	0	0
Internal Shading	None	None	None	None	None
External Shading	Overhang - 2.5	Overhang - 2.5	Overhang - 2.5	Overhang - 2.5	Overhang - 2.5




# Overhang Investigation: Project Vasari

Parameter	Value
<b>Common</b>	
Building Type	School or University
Ground Plane	Level 1
Location	40.8015937805176, -77.85958862304
<b>Detailed Model</b>	
Project Phase	New Construction
Sliver Space Tolerance	1' 0"
Export Complexity	Complex with Shading Surfa
<b>Energy Model</b>	
Create Energy Model	<input checked="" type="checkbox"/>
Core Offset	22' 0"
Divide Perimeter Zones	<input checked="" type="checkbox"/>
Conceptual Constructions	Edit...
Target Percentage Glazing	48%
Target Sill Height	5' 0"
Glazing is Shaded	<input checked="" type="checkbox"/>
Shade Depth	3' 0"
Target Percentage Skylights	0%
Skylight Width & Depth	3' 0"
<b>Energy Model - Building Services</b>	
Building Operating Schedule	12/6 Facility
HVAC System	Central VAV, HW Heat, Chiller 5.96
Outdoor Air Information	Edit...

Shade Depth

3' 0"



Mass Glazing




Triple Pane Clear - LowE Hot or Cold Climate

Mass Model	Constructions
Mass Exterior Wall	Lightweight Construction - Typical Mild Climate Insulati
Mass Interior Wall	Lightweight Construction - No Insulation
Mass Exterior Wall - Underground	High Mass Construction - Typical Mild Climate Insulatio
Mass Roof	Typical Insulation - Cool Roof
Mass Floor	Lightweight Construction - No Insulation
Mass Slab	High Mass Construction - No Insulation
Mass Glazing	Triple Pane Clear - LowE Hot or Cold Climate
Mass Skylight	Double Pane Clear - No Coating
Mass Shade	Basic Shade
Mass Opening	Air




# Overhang Investigation: Daysim

1'-0" Panel, 3'-0" Tot Overhang Profiles



Dimming System kWh Savings by Design





At 3'-0" the zone savings density is as follows:

Existing System 0.5905 kWh/SF applied to 14115 SF of perimeter area

3'-0" Overhang 0.5494 kWh/SF applied to 14115 SF of perimeter area

Total operating cost savings at \$0.08/kWh is **\$46.48** for Existing System  
 Existing System 8335.34 kWh energy usage  
 the third floor perimeter spaces  
 3'-0" Overhang 7754.36 kWh energy usage

Net Difference 580.98 kWh energy usage  
 Applied building wide, the overhang saves mechanical operating costs by **\$23,088**

# Overhang Investigation: Operating Cost Findings

## Overhang and Glazing Analysis: Summary of Effect on HVAC Operating Cost

	Existing Glazing			Proposed Glazing			
	2.5	3	3.5	0	2.5	3	3.5
Overhang Depth							
TRACE Results	\$1,501,728	\$1,494,852	\$1,490,400	\$1,512,576	\$1,481,418	\$1,478,640	\$1,478,268
Decrease	-	0.45%	0.75%	-0.7%	1.35%	<b>1.53%</b>	1.56%
Vasari Results	\$953,470	\$952,430	\$951,956	\$888,241	\$884,272	\$883,823	\$883,286
Decrease	-	0.11%	0.16%	6.84%	7.26%	<b>7.30%</b>	7.36%

Design Overhang	Energy Savings (kWh)													% Savings
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec	Total	
Actual Grand	135.01	112.46	118.70	107.26	123.12	117.71	117.71	123.17	113.72	127.98	128.93	125.25	1451.08	0.00%
New Grand	100.58	78.23	73.52	61.91	70.60	63.21	63.13	69.44	70.10	83.76	93.91	99.26	927.72	36.07%
3' Grand	97.35	75.36	70.71	60.18	68.73	62.67	62.82	67.96	67.78	81.56	91.47	96.10	902.75	37.79%
3.5' Grand	100.16	77.80	73.03	61.65	70.54	63.10	63.02	69.23	69.73	83.36	93.51	98.95	924.12	36.32%
4' Grand	96.29	74.55	70.08	59.68	68.31	62.60	62.78	67.51	67.09	80.87	90.47	95.06	895.33	38.30%
Actual Zone	49.61	38.20	37.02	33.01	37.73	36.03	36.03	37.78	35.75	42.59	47.24	47.28	478.33	0.00%
New Zone	60.40	43.29	35.08	26.96	30.42	24.77	24.69	29.25	33.41	43.58	55.47	62.57	469.95	1.75%
3' Zone	57.17	40.42	32.27	25.24	28.55	24.23	24.38	27.77	31.09	41.38	53.04	59.41	444.99	<b>6.97%</b>
3.5' Zone	59.97	42.86	34.59	26.70	30.35	24.66	24.58	29.05	33.04	43.17	55.07	62.26	466.36	2.50%
4' Zone	56.11	39.61	31.64	24.74	28.12	24.16	24.34	27.32	30.40	40.68	52.03	58.36	437.57	8.52%

Design Overhang	Orientation Change Summary						
	MS South kWh from Table X	Mat. Science North		Life Science East		Life Science West	
	Total kWh	% of MS South	Total kWh	% of MS South	Total kWh	% of MS South	
Actual Grand Total	1451.08	1446.46	99.68%	1457.40	100.44%	1447.28	99.74%
Actual Zone Total	478.33	473.70	99.03%	484.65	101.32%	474.53	99.21%




# Impact on Lighting Design




StudentExport.rvt

Export parameter change to "ACIS Solids"




StudentExport.dwg

Import to AGI32 where material properties are assigned



StudentExport.AGI



**Family Types**

Name: 2xT8 BW

Parameter	Value	Formula	Lock
<b>Electrical - Loads</b>			
Apparent Lo	32.65 VA	=	
<b>Dimensions</b>			
Width	8.000	=	<input checked="" type="checkbox"/>
Length	48.000	=	<input checked="" type="checkbox"/>
Height	5.000	=	<input checked="" type="checkbox"/>
<b>Photometrics</b>			
Tilt Angle	-90.000°	=	<input checked="" type="checkbox"/>
Photometric	12-SDx-2x	=	
Light Loss Fa	0.88	=	
Initial Intensi	64.00 W @ 9	=	
Initial Color	4100 K	=	

Buttons: New..., Rename..., Delete, Add..., Modify..., Remove, OK, Cancel, Apply, Help

**Fluorescent Dimming Ballasts** EcoSystem® H-Series

**EcoSystem® H-Series Overview**

EcoSystem H-Series digitally addressable ballasts provide a low-cost, flexible solution for any space in any application. Industry leading dimming to less than 1% meets the needs of the most demanding applications. Individual control with the EcoSystem Digital Link eliminates the need to rewire, reduces design time, and provides a scalable solution from a small area to an entire building.

**Features**

- Continuous, flicker-free dimming from 100% to <1% for T8, and 1% for T5 and T5HO lamps
- Compatible with EcoSystem Energy Savr Node®, GRAFIK Eye® QS, and Quantum®, allowing for integration into an existing/planned EcoSystem lighting control solution
- EcoSystem design preheats lamp cathodes by applying full arc voltage to ensure full-rated lamp life during starting and cycling
- Lamps turn on in many dimmed levels without flashing to full brightness
- Low harmonic distortion throughout the entire dimming range maintains power quality
- Frequency of operation ensures that ballast does not interfere with infrared devices operating between 38 and 42 KHz
- Ballasts maintain consistent light output for different lamp lengths, ensuring fixture-to-fixture uniformity
- Ultra-quiet operation
- Protected from miswiring of any input power to control ballast or from lamp-to-ballast to each other and/or ground

**EcoSystem H-Series, case type C**  
1.18 in. W (30 mm) x 1.00 in. H (25 mm) x 18.00 in. L (457 mm)

**LITECONTROL** Fixture Type: S-1  
Project Name: Penn State MSC

**SDX™**  
P-S/D-1800, S-S/D-1800  
Recessed Mounted Semi-Direct  
Surface Mounted Semi-Direct

**Product Description**  
Estimated aluminum semi-direct fixture with tapered end-ground plate. This fixture is CULIE to CULIE Certified™ by UL.


**Ordering Guide**

Ordering	Part	Color	Length	Lamp	Ballast	Options	Other Options	Price
Recessed	1800	White	1800	4' T8	ELB10	Standard		120
Surface Mounted	1800	White	1800	4' T8	ELB10	Standard		120

**Options:** CW, CWV, CWV1, CWV2, CWV3, CWV4, CWV5, CWV6, CWV7, CWV8, CWV9, CWV10, CWV11, CWV12, CWV13, CWV14, CWV15, CWV16, CWV17, CWV18, CWV19, CWV20, CWV21, CWV22, CWV23, CWV24, CWV25, CWV26, CWV27, CWV28, CWV29, CWV30, CWV31, CWV32, CWV33, CWV34, CWV35, CWV36, CWV37, CWV38, CWV39, CWV40, CWV41, CWV42, CWV43, CWV44, CWV45, CWV46, CWV47, CWV48, CWV49, CWV50, CWV51, CWV52, CWV53, CWV54, CWV55, CWV56, CWV57, CWV58, CWV59, CWV60, CWV61, CWV62, CWV63, CWV64, CWV65, CWV66, CWV67, CWV68, CWV69, CWV70, CWV71, CWV72, CWV73, CWV74, CWV75, CWV76, CWV77, CWV78, CWV79, CWV80, CWV81, CWV82, CWV83, CWV84, CWV85, CWV86, CWV87, CWV88, CWV89, CWV90, CWV91, CWV92, CWV93, CWV94, CWV95, CWV96, CWV97, CWV98, CWV99, CWV100

**Notes:**


- See notes on page 18 for fixture dimensions and mounting options.
- See notes on page 19 for ballast options and wiring diagrams.
- See notes on page 20 for ordering and pricing information.





# Impact on Lighting Design

Study Area Illuminance Summary						
Space	Illuminance (fc)			Max./Min.	Coeff. Of Variation	Uniformity Gradient
	Min.	Avg.	Max.			
Study Area Only	9.0	36.5	106.0*	11.73	0.47	2.47
Corridor Only	4.5	9.36	10.8	2.40	0.15	1.31
Student Area Combined	15.0	34.3	55.0	3.67	0.27	1.42
Corridor Combined	7.3	20.0	25.3	3.47	0.23	1.38



2




2

1



1





## Existing Conditions


- **27.6" Deep**
- 6" Thick Concrete at Face
- **2" Facebrick**
- Largest Panel 21ft. Wide by 11ft. Tall

**Gravity Controlled** Design

- Prone Position Causes Greatest Stress
- 2 Bearing Connections at Either End
- 2 Lateral Connections at Either End

Cracking Stress			
(factored)	477.2971	psi	
Self Weight Check Prone			
Weight/in.	8.53125	lb./in.	(factored)
Inertia of Strip	76.765625	in.4	
Moment	16695.94	lb.in.	
Stress	462.17134	psi.	OK

# Panel Depth Assessment



## Existing Conditions


- **27.6" Deep**
- 6" Thick Concrete at Face
- **2" Facebrick**
- Largest Panel 21ft. Wide by 11ft. Tall

**Gravity Controlled** Design

- Prone Position Causes Greatest Stress
- 2 Bearing Connections at Either End
- 2 Lateral Connections at Either End

Cracking Stress			
(factored)	477.2971	psi	
Self Weight Check Prone			
Weight/in.	8.53125	lb./in.	(factored)
Inertia of Strip	76.765625	in.4	
Moment	16695.94	lb.in.	
Stress	462.17134	psi.	OK

## Panel Depth Assessment




## Redesign

- **15.75" Deep**
- 5" Thick Concrete at Face
- **1/2" Facebrick**
- Largest Panel 21ft. Wide by 11ft. Tall

**Wind Controlled** Design

- Prone Position Causes Greatest Stress
- 2 Corbel Connections at Either End
- 2 Lateral Connections at Either End

Required Steel	
Vu.max=	189 k.
As.req=	0.44 in.2
$\mu_e$ =	3.4
As.req=	0.32 in.2
As.min=	0.77 in.2
As=	0.77 in.2
Ah=	0.30 in.2
Ldh=	8.91 in.





# Cost Assessment

Properties

Stacked Wall  
Exterior - Brick Over Precast Return 1

Stacked Walls (1) Edit Type

Constraints	
Location Line	Wall Centerline
Base Constraint	SECOND FLOOR
Base Offset	-8' 8 5/8"
Base is Attached	<input type="checkbox"/>
Base Extension Distance	0' 0"
Top Constraint	Up to level: SECOND FLOOR
Unconnected Height	11' 8 5/8"
Top Offset	3' 0"
Top is Attached	<input type="checkbox"/>
Top Extension Distance	0' 0"
Related to Mass	<input type="checkbox"/>

Existing Pre-Cast							
Total (SF)	Material	Labor	Equipment	Total	Cost	Time	O & P
72319.11	27.3	1.74	1.63	30.67	\$2,218,027	\$2,816,894	\$3,295,766
				<b>TOTAL COST = \$3,295,766.47</b>			
Redesign Pre-Cast							
Total (SF)	Material	Labor	Equipment	Total	Cost	Time	O & P
72319.11	25.03	1.74	1.63	28.4	\$2,053,862	\$2,608,405	\$3,051,834
				<b>TOTAL COST = \$3,051,834.62</b>			

**Cost Savings = \$240,000**

## Dimensions

Length

363' 0"

Area

4253.91 SF

Volume

Phase Demolished	None
Analytical Model	
Enable Analytical Model	<input checked="" type="checkbox"/>
Horizontal Projection	Auto-detect
Top Vertical Projection	Auto-detect
Bottom Vertical Projection	Auto-detect

Properties help Apply




## Existing VAV Distribution System

Energy efficient design that can be **easily controlled** to space airflow needs

**Familiar system** for designers and contractors

**Less pumping energy** required

## Existing vs. Proposed Distribution



## Proposed Active Chilled Beam Distribution System

Takes advantage of the higher **specific heat capacity of water**


**More concern** for handling **latent** loads

Higher **initial cost**

**Fan energy saved**, pumping energy increased




## Existing VAV Water Flow Diagram



## Existing vs. Proposed Distribution

## Proposed Chilled Beam Water Flow Diagram








## Existing Lab VAV Air Flow Diagram

## Existing vs. Proposed Distribution


## Existing Office VAV Air Flow Diagram




# Perimeter Zone Chilled Beam Air Flow Diagram



# Existing vs. Proposed Distribution



# Interior Lab Chilled Beam Air Flow Diagram





# Active Chilled Beam Design Process

1. Obtain room loads from Trane TRACE updated model

2. Compare ventilation needs: ASHRAE 62.1, Latent, Air Changes

3. Select Chilled Beam Manufacturer

Room Checksums  
By ACADEMIC

sp-N-337-Faculty

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Mo/Hr: 7/8				Mo/Hr: 8/9				Mo/Hr: Heating Design				Cooling			
Outside Air: OADB/WBHR: 78/69/92				OADB: 73				OADB: 11				SADB: 55.0			
												Heating: 74.0			
												Ra Plenum: 75.3			
												Return: 75.3			
Envelope Loads	Space	Plenum	Net	Percent	Space	Percent	Space	Percent	Space	Percent	Space	Percent	Space	Percent	
Skylite Solar	Sens	Sens	Total	Of Total	Sens	Of Total	Sens	Of Total	Sens	Of Total	Sens	Of Total	Sens	Of Total	
Skylite Cond	Lat	Lat	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	
Roof Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Glass Solar	6,970	-23	6,970	85	7,415	85	7,415	85	7,415	85	7,415	85	7,415	85	
Glass/Door Cond	202	0	202	2	-155	2	-155	2	-155	2	-155	2	-155	2	
Wall Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Infiltration	131	0	131	1	-8	1	-8	1	-8	1	-8	1	-8	1	
Sub Total ==>	7,303	-23	7,280	58	7,252	58	7,252	58	7,252	58	7,252	58	7,252	58	
Internal Loads															
Lights	472	118	590	5	472	5	472	5	472	5	472	5	472	5	
People	8,835	0	8,835	70	4,508	70	4,508	70	4,508	70	4,508	70	4,508	70	
Misc	258	0	258	2	258	2	258	2	258	2	258	2	258	2	
Sub Total ==>	9,575	118	9,693	77	5,648	77	5,648	77	5,648	77	5,648	77	5,648	77	
Ceiling Load															
Ventilation Load	67	-67	0	0	49	0	49	0	49	0	49	0	49	0	
Adj Air Trans Heat	0	0	-5,288	-42	0	-42	0	-42	0	-42	0	-42	0	-42	
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Sup. Fan Heat	-324	-324	-324	-3	-324	-3	-324	-3	-324	-3	-324	-3	-324	-3	
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Underfir Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Grand Total ==>	16,945	-296	12,610	100.00	12,950	100.00	12,950	100.00	12,950	100.00	12,950	100.00	12,950	100.00	

Export gbXML - Settings

General Details

Rooms Analytical Surfaces



- Building Model
  - BASEMENT
  - BASEMENT MEZZ
  - FIRST FLOOR
  - SECOND FLOOR
  - THIRD FLOOR
  - MECHANICAL PENTHOUSE
  - ROOF

Next... Save Settings Cancel

Office:  $0.06 * SF + 5 * People$   
 Labs:  $0.18 * SF + 10 * People$

$$Q_{Latent\ CFM} = \frac{q_{latent}}{(0.68 \times (W_{room} - W_{Primary}))}$$

6 Air Change Minimum for Lab Spaces




# Active Chilled Beam Design Process



## 4. Reference RCP & Manufacturer Selection Spacing Program

DID 632 Two Way Active Chilled Beam Selection Program							
Input DID	4 pipe coil		2 pipe coil		Project	Room-No.	Comment
	cooling	heating	cooling	heating			
Vwater DID	1.25 GPM	1.25 GPM	1.00 GPM	0.80 GPM			
Unit length	4.0 ft						
Nozzle-type	U						
Vair-primary DID	140.0 CFM						
Connection-diameter / primary air	6 in						
Input Temperatures		cooling		heating		Input Room Dimensions	
Tair-primary	55.0 °F		55.0 °F		Room Height (H)	11.0 ft	
Troom / rel. Humidity	75.0 °F	53.0 %	70.0 °F	50.0 %	A	12.0 ft	
Twater-flow	58.0 °F		95.0 °F		X	10.0 ft	
					Occupied Zone Height	6.0 ft	
<b>TROX® TECHNIK</b> The art of handling air							
Results		4 pipe coil		2 pipe coil			
	cooling	heating	cooling	heating			
Δtwater	-4.9 °F	5.9 °F	-6.7 °F	14.8 °F			
Twater-return	62.9 °F	89.1 °F	64.7 °F	80.2 °F			
ΔT room - water flow	-17.0 °F	25.0 °F	-17.0 °F	25.0 °F			
ΔT Room water average	-14.5 °F	22.0 °F	-13.7 °F	17.6 °F			
Qwater DID	-3085 BTUH	3694 BTUH	-3332 BTUH	3705 BTUH			
Qair DID	-3048 BTUH	-2297 BTUH	-3048 BTUH	-2297 BTUH			
Q DID	-6133 BTUH	1398 BTUH	-6380 BTUH	1408 BTUH			
ΔP water	1.7 ft WG	2.0 ft WG	4.8 ft WG	1.4 ft WG			
ΔP air	0.68 inch WG						
NC (incl. 10 dB room absorption)	30						
<b>NOTE: This calculation program is only applicable to DID632 beams manufactured by TROX USA.</b>							
Terminal Velocities and Temperatures				Support Values		TROX USA, Inc 4305 Settlebottom Circle Cumming, GA 30028 Phone: (770) 569-1433 Fax: (770) 569-1435 www.TROXUSA.com Version 1.8 1/21/2011	
ΔL2 (measured 2" from wall)	91 FPM	64 FPM	91 FPM	64 FPM	N-nozzles total		
ΔL6 (measured 6" from wall)	55 FPM	38 FPM	54 FPM	38 FPM	Aeff	0.046295 ft²	
ΔH1	53 FPM		53 FPM		veff	3024 FPM	
ΔTL	-1.7 °F	0.1 °F	-1.6 °F	0.1 °F	H1	5.0 ft	
ΔTH1	-0.8 °F		-0.7 °F		L	15.0 ft	
ΔTsupply	-15.8 °F	2.8 °F	-15.1 °F	2.8 °F	room air dew point-cooling	56.7 °F	
Connection-diameter / primary air	DID632-HC		DID632-US				

## 5. Use RCP to place beams in space in Revit MEP model





## 6. Adjust Chilled Beam Families in Revit







# Active Chilled Beam Design Process



## Summary of TROX Chilled Beam Adjustments


Parameter	Downloaded Setting	Adjusted Setting
Flow Configuration	Calculated	Preset
Flow Direction	In	In
Family	Air Terminal	Mechanical Equipment
Location of Inlet	Side	Top (Cost Option)
Air Flow	Instance: Keeps CFM constant for the same family	Type: Allows different CFM for same family

## 6. Adjust Chilled Beam Families in Revit




# Active Chilled Beam Design Process

## 7. Create Systems so Revit can calculate Duct, Pipe Sizes



## 8. Place main duct runs in cellular openings





# Structural Integration With Chilled Beams




## Existing Composite Floor System

- 22ft. X 22ft. Bays
- 21in. Deep Wide Flange Beams
- 24in. Deep Wide Flange Girders
- Floor Supports Green Roof
- NWT Concrete




## Redesign

- 30in. Deep Cellular Beams
- LB30X44 Beams
- LB30X57 Girders
- Lighter Bays



# Chilled Beam Electrical Reaction



## Lab Service:

- ACF-1
- ACF-2
- ACF-3
- ACF-4
- ACF-5

## Office Service:

- ACF-6
- ACF-7
- ACF-8

## Water Pumps:

- CWP-1
- CWP-2
- CWP-3 (standby)
- CWP-4 (low flow)
- HWP-5
- HWP-6

## Labs/Offices:


- AHU-EXT-1
- AHU-EXT-2

## Interior Spaces:

- AHU-INT-LS1
- AHU-INT-LS2
- AHU-INT-MS1
- AHU-INT-MS2

## Consolidated to MCC:


- CWP-1
- CWP-2 (standby)
- CWP-3
- CWP-4 (standby)
- CWP-5 (low flow)
- HWP-5
- HWP-6 (standby)






# Fume Hood Face Velocity Testing: Software Process


Section Box  
applied to  
W324A-Hot  
Room



DXF Export  
from Revit  
Architecture




Attempted  
import as  
geometry  
into  
Phoenics  
2009




# Fume Hood Face Velocity Testing: Software Process


Section Box  
applied to  
W324A-Hot  
Room




DXF Export  
from Revit  
Architecture



Final Model  
created with  
Phoenics  
elements









100 FPM

# CFD Contaminant Test: 18" Sash Position

80 FPM





100 FPM

## CFD Contaminant Test: 30" Sash Position

80 FPM






## Fume Hood Results

1. Face Velocity **achieved during 18"** simulations, **not 30"**
2. **14.2% more** contaminant present at face of fume hood in 80 fpm, 18" sash
3. **18.0% more** contaminant present at face of fume hood in 80 fpm, 30"
4. All contaminant readings **less than 0.015% of source**, drop significantly at Human
5. **31.94%** energy savings from conditioning less air


Summary of Fume Hood Makeup Air Costs and Savings		
Metric	100 fpm VAV	80 fpm ACBs
Cooling/Dehumidification	\$233,356	\$122,597
Heating	\$6,479	\$13,447
Fan	\$110,512	\$81,042
Humidification	\$17,610	\$33,343
CAV Operation Costs	\$367,958	\$250,431
VAV Multiplier for Operation	0.32	0.32
Adjusted Operation Costs	\$116,704	\$79,428.
Percent Savings		<b>31.94%</b>

# Energy Model Results

3 <sup>rd</sup> Floor and Estimated Building Operating Costs			
		3 <sup>rd</sup> Floor	Building
Existing VAV	Building Energy kBtu/yr	16,478,534	98,871,204
	Operating Costs	\$250,288	\$1,501,728
	Cost/SF	\$5.84/ft <sup>2</sup>	
Proposed ACB + Triple Pane Glazing	Building Energy kBtu/yr	13,912,786	83,476,716
	Operating Costs	\$214,983	\$1,289,898
	Cost/SF	\$5.02/ft <sup>2</sup>	
	Percent Savings	14.1%	



## Monthly Operating Costs





## Mechanical Equipment Schedule

Family and Type	Count	Total	COST
Radiant-ACB1-4: ACB1 12" Wide, Inlet 4"	1	1327.75	\$1,327.75
Radiant-ACB1-4: ACB1 12" Wide, Inlet 4"	1	1327.75	\$1,327.75


### Duct Schedule

Size	Area	Length	Unitless Length	Cross Area	Volume Per FT	Weight
13"x13"	88 SF	20' - 4 1/4"	20.354167	0.022 SF	0.02	70.34
14"∅	4 SF	1' - 0"	1.000001	5.445938	0.03781901	6.54
16"x16"	110 SF	20' - 6 7/8"	20.572917	0.026 SF	0.03	106.65
18"x18"	123 SF	20' - 6 7/8"	20.572917	0.035 SF	0.03	106.65
20"x20"	67 SF	10' - 1 9/32"	10.10551	0.038 SF	0.04	69.85

### Pipe Schedule

Family and Type	Size	Length	Unitless Length	Material	Labor	Equipmet	Total	COST
Pipe Types: Standard	1/2"∅	0' - 10 29/32"	0.909167	5.25	5.6	1.25	12.1	\$11.00
Pipe Types: Standard	1/2"∅	0' - 7 31/32"	0.662917	5.25	5.6	1.25	12.1	\$8.02
Pipe Types: Standard	1/2"∅	1' - 0 29/32"	1.075833	5.25	5.6	1.25	12.1	\$13.02

## Mechanical Redesign Cost Assessment



CHILLED BEAMS	DUCTWORK	PIPING	PUMPS	AHUs	TOTAL
\$9,608,000	\$2,966,400	\$377,840	\$165,484	\$2,274,046	\$21,035,567

**Cost Increase = \$1,847,567**

## Comparing Life Cycle Costs of Mechanical Systems

### Coal Plant Findings

	Real Rate	2% Inflation	5% Inflation
VAV	\$54,813,916	\$63,883,395	\$63,856,220
ACB	\$55,346,191	\$62,693,273	\$62,647,108
Percent Savings	<b>-0.97%</b>	1.86%	1.89%
NPV Differential	<b>(\$532,275)</b>	\$1,190,122	\$1,209,111

**If inflation occurs and PSU remains a coal fired plant, the Active Chilled Beam system should be considered**

**If PSU changes to a Natural Gas plant, the Active Chilled Beam system should be considered**


### Natural Gas Plant

	Real Rate	2% Inflation	5% Inflation
VAV	\$64,693,985	\$72,152,832	\$72,110,021
ACB	\$59,478,486	\$69,307,263	\$69,259,831
Percent Savings	8.06%	3.94%	3.95%
NPV Differential	\$5,215,499	\$2,845,568	\$2,850,190







154ft. Overhang

- 4 Main Trusses at Gridlines 2, 5, B, & E
- **11 Bays** Lengthwise
- **Moment** Connections
- Members Oriented for **Compression**
- Sizes Ranging from W14X90 to W14X550
- Controlled by **Deflection**



## Existing Cantilever



Autodesk Revit  
 Cantilever Model to Serve as Base  
 Considerations  
 Integration with Lighting and Mechanical  
 Utilities to be Taken into Account  
 Redesign Location





154ft. Overhang

- 4 Main Trusses at Gridlines 2, 5, B, & E


- **9 Bays** Lengthwise

- **Pin** Connections




- Members Oriented for **Tension**

- Sizes Ranging from W14X90 to W14X311

- Controlled by **Strength**



## Redesign




### Actual BIM Process





- Build Complete Cantilever in SAP
- Analyze in SAP
- Redesign in SAP
- **Replicate** in Revit
- Use Existing Conditions Model and Modify IPD Considerations
- Integration with Lighting and Mechanical
- Quantities to be Taken from Redesigned Model







# Redesign



## Isolation Lab Interference


- Column **Penetrates** Through Slab
- Labs Limited to 130 micro inches/second
- Labs Sequestered from Foundation

## Proposed Solution

- Column Pile Caps 3ft. Beneath Bottom of Isolation Slabs
- Isolation Slabs **Poured Around** Columns
- **Compressive Material** to Fill Gap

# Structural Redesign Cost Implications

Existing Entire Structure				
Framing Tons	Column Tons	Framing Cost	Column Cost	
3058.7 Tons	953.84 Tons	\$8,179,891.34	\$2,386,659.20	
	<b>Total =</b>	<b>\$10,566,550.54</b>		
Existing 3rd Floor Structure				
Framing Tons	Column Tons	Framing Cost	Column Cost	
595.72 Tons	231.47 Tons	\$1,848,680.85	\$434,508.19	
	<b>Total =</b>	<b>\$2,283,189.04</b>		





**Cost Savings = \$2,290,815**

Redesign 3 <sup>rd</sup> Floor Structure				
	Framing Tons	Column Tons	Framing Cost	Column Cost
	459.79 Tons	202.92 Tons	\$1,310,896.61	\$539,218.72
		<b>Total =</b>	<b>\$1,850,115.33</b>	
Cost Implications to Entire Structure				
	Savings/SF	Total SF	Total Savings	Total Cost
	\$8.3326/SF	274,922 SF	\$2,290,815.05	\$8,275,735.48



# Steel Sequencing 4D Model








# Existing Courtyard Design

Type	Total	Unit	Cost Total	Cost Unit	Cost
RPC Shrub: Century 1'-10"	244	EA	22	EA	\$5,368.00
RPC Shrub: Switchgrass (2) 4'-0"	327	EA	17.1	EA	\$5,591.70
Basic Wall: Concrete Panel Wall	214.5	FT	11.45	LF	\$2,456.03
Custom Park Bench 6'-0"	5	EA	526.5	EA	\$2,632.50
Bicycle Racks	8	EA	649	EA	\$5,192.00
Stamped Stone Path	4271.75	SF	17.05	SF	\$72,833.34
Mulch	4624.63	SF	2.91	SY	\$498.43
Bermuda Ornamental Grass	1298.57	SF	50	SY	\$2,404.76
Ground Cover Grass	8487.97	SF	220	MSF	\$ 1,867.35
Fern/Boulder Area	<b>Total Including O &amp; P, Waste, Delivery, &amp; Time Modifications = \$271,745.24</b>				
Exposed Aggregate Concrete					
Decorative Pea Gravel					
Decorative Boulders					








# Cage Structure Development








# Cage Structure Development





# Final Courtyard Design







# Final Courtyard Design


Type	Total	Unit	Total	Unit	Cost
RPC Shrub: Acacia 3'-6"	101	EA	63.8	EA	\$ 6,443.80
RPC Shrub: Fountain Grass 1'-6"	733	EA	21.01	EA	\$ 15,400.33
Basic Wall: Courtyard Path Wall	1617.89	LF	12.34	LF	\$ 19,964.76
Park Bench 6'-0"	16	EA	448.5	EA	\$ 7,176.00
Courtyard Railing	486.5	LF	22.92	LF	\$ 11,150.58
Mulch	14492.05	SF	2.91	SY	\$ 1,561.92
Cage Structure	1	EA	1	EA	\$ 500,000.00
Courtyard Sod	9356.29	SF	265.95	MSF	\$ 2,488.31

Total Including O & P,  
Delivery, Waste, & Time  
Modifications = **\$866,984.16**







# Final Courtyard Design Lighting




CantileverModel.rvt




Export from Revit as  
Cantilever.fbx;  
Import to 3ds Max Design  
with File Link Manager



3ds Max Calc Points



CantileverModel.max



Courtyard Illuminance Summary


Calculation Grid	AGI Illuminance (fc)			3ds Illuminance (fc)			AGI Specific Values		
	Min.	Avg.	Max.	Min.	Avg.	Max.	Max./Min	Coeff. Of Variation	Uniformity Gradient
Paths	1.10	7.72	63.20	0.102	23.15	59.00	57.45	1.16	3.10
LS Interior Well	1.90	10.32	72.40	Not Measured			38.11	0.59	13.30
LS Exterior Well	1.80	9.33	39.10				21.72	0.41	7.48
MS Interior Well	1.90	9.91	47.60				25.05	0.49	15.03
MS Exterior Well	2.00	9.68	54.10				27.05	0.51	18.03

# Summary of Cost Implications

SUMMARY OF SYSTEM FIRST COSTS				
	FAÇADE REDESIGN	STRUCTURAL REDESIGN	MECANICAL/ENERGY REDESIGN	COURTYARD REDESIGN
EXISTING COST	\$3,295,766	\$10,566,550	\$19,188,000	\$271,745
PROPOSED COST	\$3,051,834	\$8,275,735	\$21,040,000	\$604,910
SAVINGS/EXPENSE	\$243,932	\$2,290,815	\$1,852,000	\$333,165
<b>TOTAL FIRST COST SAVINGS = \$349,582</b>				



# KGB Maser Conclusions



- Decreased energy consumption by **14.2%**
- **Reduced size** and **cost** of structural system: **\$2,290,815**
- Proposed façade provided **marginal operating cost savings** and **lower initial cost** in lighting and structural systems



## IPD/BIM Lessons Learned

- Must work consistently in **communicative** environment
- Challenging to keep **uniform** group formatting **standards**
- Need to **explain technical reasoning** behind each decision **to all disciplines**

- Adequate time must be allotted for **overcoming** software design issues
- **Not all information** can be shared between modeling platforms; intermediate steps must be taken
- A **higher level of coordination** can be achieved during system designs
- Model sharing is a **one way street** outside of Revit platforms





MILLENNIUM SCIENCE COMPLEX - UNIVERSITY PARK, PA

# Acknowledgements

## The Thornton Tomasetti Foundation

## The Leonhard Center Penn State

## Faculty Advisors

Bob Holland

Andres Lepage

Richard Mistrick

Ted Dannerth

Kevin Parfitt

Jelena Srebric

John Messner

Moses Ling

## Whiting Turner

Chris Dolan

## Penn State OPP

Dick Harris

## Corey Wilkinson

Paul Bowers

Thornton Tomasetti Engineers

Flack &amp; Kurtz MEP Engineers

HOK

John Jackson

Penn State Students

Ryan Solnosky

Building Stimulus IPD/BIM Team

BIMception IPD/BIM Team

SKM Systems Analysis

Johnny Ma

Ruperto Sanchez



BR+A Consulting Engr.

Britt Ellis

Michael Lucas

Patrick Morgan

PENNSSTATE








Questions and Comments


Thank you for your time



## Study Occupancy Pendant Sensor Coverage





## Study Occupancy Task Sensor Coverage




# Lighting/Electrical Appendices

## Space 1: Study Area



Space	Area (ft <sup>2</sup> )	Allowable LPD (W/ft <sup>2</sup> )	Allowable Power (W)	Total Power Used (W)	Actual LPD (W/ft <sup>2</sup> )
Study Area	825.0	1.2	990.0	657.0	0.796
Corridor	657.9	0.5	329.0	224.0	0.681*

## Study Area Floor Plan




## Study Area Luminaires

- Lithonia Lighting ES8
- ES8P-132-277-(BALLAST)-L841HT8
- LiteControl SDx
- P-S/D-1824T8-BW-CWM-(BALLAST)-277
- Philips Alcko Aris
- ARIS-11-40-120-PRL-DWC




# EcoSystem Wiring Diagram




# Lighting/Electrical Appendices

## Space 1: Study Area Shading Diagram






# Task Occupancy Sensor Wiring Diagram






# Office Coverage and Contours




# Lighting/Electrical Appendices

## Space 2: Perimeter Office



# Office Floor Plan



Lighting Type	Area (ft <sup>2</sup> )	Allowable LPD (W/ft <sup>2</sup> )	Allowable Power (W)	Total Power Used (W)	Actual LPD (W/ft <sup>2</sup> )
Office General	262.38	1.1	288.61	262.8	1.00
Decorative	262.38	1.0	262.38	132	0.50

Office Illuminance Summary						
Calculation Grid	Illuminance (fc)			Max./Min.	Coeff. Of Variation	Uniformity Gradient
	Min.	Avg.	Max.			
Horizontal Task	7.60	35.75	53.90	7.09	0.31	4.83
Vertical at Shelves	14.9	19.36	22.10	1.48	0.10	1.17


# Office Luminaires

- LiteControl Mod-66  
LG-D-66N-2-4-T8-FP-  
CWM-IND-ECO/ELB-277
- LiteControl Mod-66 Chalkboard  
W-ADW-66N-1080T8-  
6044-CWM- -ELB- -277
- LiteControl Mod<sup>2</sup>  
LG-WWD-44-1-8-T5HO-  
CWM-IND-LP/ELB-277






# Shading Cut Sheet



# Lighting/Electrical Appendices

## Space 2: Office Wiring Diagram





## Courtyard Luminaires

Deco Lighting D457 Wall Pack  
D457-250-M-MT-CG-BL

Philips Allscape SL-23  
SL-23-70MH-T6-277- MFLD-F-BK

Kim Lighting ALF10 Series  
ALF11/70PMH/277/BL/HDS/FH/BL/SM18BL


Lightolier Calculite HID  
C6P30MHACLW/C6A39P30E2

Louis Poulsen Kipp Post  
KIP/1/100W/MH/ED-17/medium/277V/BLK

Kurt Versen Square Aperature  
H8643-SY-LP  
H8460-SW-LP  
H8452-SY-LP

## Lighting/Electrical Appendices

### Space 3: Cantilever Courtyard




## Courtyard Area Floor Plan







# Courtyard 3ds Outputs



Courtyard Illuminance Summary									
Calculation Grid	AGI Illuminance (fc)			3ds Illuminance (fc)			AGI Specific Values		
	Min.	Avg.	Max.	Min.	Avg.	Max.	Max./Min.	Coeff. Of Variation	Uniformity Gradient
Paths	1.10	7.72	63.20	0.102	23.15	59.00	57.45	1.16	3.10
LS Interior Well	1.90	10.32	72.40	Not Measured			38.11	0.59	13.30
LS Exterior Well	1.80	9.33	39.10				21.72	0.41	7.48
MS Interior Well	1.90	9.91	47.60				25.05	0.49	15.03
MS Exterior Well	2.00	9.68	54.10				27.05	0.51	18.03

# Lighting/Electrical Appendices


## Space 3: Cantilever Courtyard Illuminance



Area Location	Area (ft²)
Walkway	4703.50
Courtyard Grass	7962.42
Courtyard Planting	8877.38
Cantilever Soffit*	14691.73
Light Well Walls	9528.10
Entry Outer Planting	5526.18

\*Area of slope that will be floodlighted

# Courtyard AGI32 Outputs




Lighting Type	Area (ft²)	Allowable LPD (W/ft²) or (W/Lf)	Allowable Power (W)**	Total Power Used (W)	Actual LPD (W/ft²)
Building Grounds*	See Area Summary Table Below	1.0 W/Lf	339.5	7191.00 (total redesign — all luminaires)	0.25 (All surfaces redesign is intended to illuminate)
Plaza Areas and Walkways (>10' Wide)*	See Area Summary Table Below	0.2 W/sq.ft.	N/A		
Canopies and Overhangs*	See Area Summary Table Below	1.25 W/sq.ft.	32599.35 to 38044.35	2176.00 to 3791.00	0.16 to 0.23
Building Façades	See Area Summary Table Below	1.25 W/sq.ft.	11910.13 to 24219.83		

\*Areas are tradable by ASHRAE Standard 90.1, Table 9.4.5  
 \*\*Allowable power varies depending upon the classification of the areas in the table below



## Courtyard Wiring Diagram



# Lighting/Electrical Appendices

## Space 3: Courtyard Lighting Control

Eaton Pow-R-Command lighting control panels with Pow-R-Command 1000 Lighting Optimization Software

One central workstation and one lighting optimization workstation

Line-voltage 277V equipment controlled by computer interface and control cabling

Integrated daylight sensor for day/night automatic overrides

Controls exterior courtyard space and light well floods



Director Status

Name	Description	Status	PR1	PR2	PR3	PR4	PR5	PR6	PR7	PR8	PR9	PR10	PR11	PR12	Name
8201	East Hallway Floor 1	Off	1	1	1	1	1	1	1	1	1	1	1	1	Front Office
8202	East Hallway Floor 2	Off	1	1	1	1	1	1	1	1	1	1	1	1	Lobby/Floor Entrance
8203	East Hallway Floor 3	Off	1	1	1	1	1	1	1	1	1	1	1	1	Corridor
8204	West Hallway Floor 1	Off	1	1	1	1	1	1	1	1	1	1	1	1	Media Center A
8205	West Hallway Floor 2	Off	1	1	1	1	1	1	1	1	1	1	1	1	Media Center B
8206	West Hallway Floor 3	Off	1	1	1	1	1	1	1	1	1	1	1	1	Gen. B.
8207	Classrooms 101-126	Off	1	1	1	1	1	1	1	1	1	1	1	1	Gen. B.
8208	Classrooms 127-148	Off	1	1	1	1	1	1	1	1	1	1	1	1	Open Lecture Room East
8209	Classrooms 149-188	Off	1	1	1	1	1	1	1	1	1	1	1	1	Open Lecture Room West
8210	Classrooms 189-228	Off	1	1	1	1	1	1	1	1	1	1	1	1	Public Area
8211	Classrooms 229-248	Off	1	1	1	1	1	1	1	1	1	1	1	1	Front Parking
8212	Classrooms 249-288	Off	1	1	1	1	1	1	1	1	1	1	1	1	West Parking
8213	Classrooms 289-328	Off	1	1	1	1	1	1	1	1	1	1	1	1	Student Center
8214	Classrooms 329-368	Off	1	1	1	1	1	1	1	1	1	1	1	1	Tennis Courts 1
8215	Classrooms 369-388	Off	1	1	1	1	1	1	1	1	1	1	1	1	Tennis Courts 2
8216	Classrooms 389-408	Off	1	1	1	1	1	1	1	1	1	1	1	1	Recreation East
8217	Classrooms 409-428	Off	1	1	1	1	1	1	1	1	1	1	1	1	Recreation West
8218	Classrooms 429-448	Off	1	1	1	1	1	1	1	1	1	1	1	1	Student View Stand
8219	Classrooms 449-468	Off	1	1	1	1	1	1	1	1	1	1	1	1	Student Photo Booth
8220	Classrooms 469-488	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8221	Classrooms 489-508	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8222	Classrooms 509-528	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8223	Classrooms 529-548	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8224	Classrooms 549-568	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8225	Classrooms 569-588	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8226	Classrooms 589-608	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8227	Classrooms 609-628	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8228	Classrooms 629-648	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8229	Classrooms 649-668	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8230	Classrooms 669-688	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8231	Classrooms 689-708	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8232	Classrooms 709-728	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8233	Classrooms 729-748	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8234	Classrooms 749-768	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8235	Classrooms 769-788	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8236	Classrooms 789-808	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8237	Classrooms 809-828	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8238	Classrooms 829-848	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8239	Classrooms 849-868	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8240	Classrooms 869-888	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled
8241	Classrooms 889-908	Off	1	1	1	1	1	1	1	1	1	1	1	1	unlabeled

The Intelligent Lighting Control and Energy Management System  
Be in control from anywhere in the building or anywhere in the world!



# Existing

BRANCH CIRCUIT PANELBOARD SCHEDULE													
Panel Name: HL-3D 277/480, 3 Phase, 4 Wire 14,000MIN A.I.C. SYM Neutral: 100%		Mounting:	Surface:	X	Main Lugs Only:			.	Amp Main CB	200			
			Flush:	.	Shunt Trip Main:			.	Amp Bus	225			
			In MCC:	.	Feed Through:			.	Ground Bus	X			
		Number of Poles:			42	TVSS:			.	Isolated Ground Bus	.		
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles	Poles	KVA/Phase			TRIP (Amp)	Load	CKT No.
			A	B	C			A	B	C			
1	STUDENT LIGHTING	20	0.83			1	2	1.70			20	STAFF & FACULTY LTG	2
3	ELECTROACTIVE POLY LTG	20		1.60		3	4		1.90		20	STUDENT LIGHTING	4
5	ORGANIC ELEC & PHO LTG	20			1.60	5	6			1.90	20	STUDENT LIGHTING	6
7	DRY LAB A&B, STAFF LTG	20	1.41			7	8	2.20			20	STAFF LIGHTING	8
9	STAFF ADMIN, KITCHEN LTG	20		1.23		9	10		1.32		20	CONFERENCE ROOM LTG	10
11	DRY LAB, MISC. COMP. LTG	20			1.28	11	12			1.52	20	CONFERENCE ROOM LTG	12
13	CORRIDOR LIGHTING	20	1.60			13	14				20	SPARE	14
15	CORRIDOR LIGHTING	20		1.54		15	16				20	SPARE	16
17	CORRIDOR LIGHTING	20			1.68	17	18				20	SPARE	18
19	SPARE	20				19	20				20	SPARE	20
21	SPARE	20				21	22				20	SPARE	22
23	SPARE	20				23	24				20	SPARE	24
25	SPARE	20				25	26				20	SPARE	26
27	SPARE	20				27	28				20	SPARE	28
29	SPARE	20				29	30				20	SPARE	30
31	SPARE	20				31	32				20	SPARE	32
33	SPARE	20				33	34				20	SPARE	34
35	SPARE	20				35	36				20	SPARE	36
37	SPARE	20				37	38				20	SPARE	38
39	SPARE	20				39	40				20	SPARE	40
41	SPARE	20				41	42				20	SPARE	42
Subtotals (kVA):		3.84	4.37	4.56				3.90	3.22	3.42		Subtotals (kVA)	
Total Loads:		Phase A: 7.74 kVA			90.00 %			Demand Factor					
		Phase B: 7.59 kVA			20.98 kVA			Demand Load					
		Phase C: 7.98 kVA			26.22 kVA			Load x 1.25					
Total Connected Load:		23.31 kVA			31.58 A			AMP					

# Lighting/Electrical Appendices

## Electrical Panelboard Designs: HL-3D

Panelboard HL-3D Circuit Calculations					
Circuit 2					
Mark	Quantity	W/Luminaire	Total W	PF	Total VA
DC-1A	8	46.0	368.00	0.98	375.51
NF-1	23	65.0	1495.00	0.99	1510.10
O-1	4	65.7	262.80	0.99	265.45
OS-1	1	70.0	70.00	0.98	71.43
WW-1	1	62.0	62.00	0.98	63.27
Totals:			<b>2257.80</b>	<b>0.99</b>	<b>2285.76</b>
Circuit 4					
Mark	Quantity	W/Luminaire	Total W	PF	Total VA
S-1	12	65.7	788.40	0.99	796.36
NF-1	9	65.0	585.00	0.99	590.91
Totals:			<b>1373.40</b>	<b>0.99</b>	<b>1387.27</b>
Circuit 13					
Mark	Quantity	W/Luminaire	Total W	PF	Total VA
C-1	14	32.0	448.00	0.98	457.14
DF-8	5	65.0	325.00	0.99	328.28
Totals:			<b>773.00</b>	<b>0.98</b>	<b>785.43</b>

Panelboard					
Tag	HL-3D	HLE-3D	LR-3D1	LCP-1	
Voltage System	480Y/277 V	480Y/277 V	208Y/120 V	480Y/277 V	
Calculated Design Load (kW)	147.64	169.01	46.94	83.55	
Calculated Power Factor	0.807	0.801	0.833	0.81	
Calculated Design Load (kVA)	182.94	210.88	56.32	102.58	
Calculated Design Load (A)	220.14	253.76	156.44*	123.44	
Feeder					
Feeder Protection Size	125 A	150 A	110 A	70 A	
Number of Sets	1	1	1	1	
Wire Size					
	Phase	(3) 4/0	(3) 250 kcmil	(3) 3/0	(3) #1
	Neutral	(1) 4/0	(1) 250 kcmil	(2) 3/0	(1) #1
	Ground	#6	#6	#6	#8
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.3718	0.4598	0.3117	0.1901
	Total - All Phases	1.1154	1.3788	0.9351	0.5703
	Neutral	0.3718	0.4598	0.6234	0.1901
	Ground	0.0726	0.0726	0.0726	0.0437
	Total - All Wires	1.5598	1.911	1.6311	0.8041
Minimum Conduit Area (Sq. in.) (Above x 2.5)					
		4.0513	4.9293	4.1395	4.1395
Conduit Size (NEC Chapter 9, Table 4)					
		2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT
Conduit Size (NEC Table C.1)					
		2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT
Feeder Length					
		207 ft.	25 ft.	140 ft.	140 ft.
Final Voltage Drop (V)					
		4.80	0.60	1.70	1.70
Final Voltage Drop (%)					
		1.00%	0.12%	1.4%	1.4%
Feeder Re-sizing					
		Not Needed	Not Needed	Not Needed	Not Needed

# Redesign

BRANCH CIRCUIT PANELBOARD SCHEDULE													
Panel Name: HL-3D 277/480, 3 Phase, 4 Wire 14,000MIN A.I.C. SYM Neutral: 100%		Mounting:	Surface:	X	Main Lugs Only:			.	Amp Main CB	125			
			Flush:	.	Shunt Trip Main:			.	Amp Bus	225			
			In MCC:	.	Feed Through:			.	Ground Bus	X			
		Number of Poles:			42	TVSS:			.	Isolated Ground Bus	.		
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles	Poles	KVA/Phase			TRIP (Amp)	Load	CKT No.
			A	B	C			A	B	C			
1	STUDENT LIGHTING	20	0.83			1	2	2.29			20	STAFF & FACULTY LTG	2
3	ELECTROACTIVE POLY LTG	20		1.60		3	4		1.39		20	STUDENT LIGHTING	4
5	ORGANIC ELEC & PHO LTG	20			1.60	5	6			1.90	20	STUDENT LIGHTING	6
7	DRY LAB A&B, STAFF LTG	20	1.41			7	8	2.20			20	STAFF LIGHTING	8
9	STAFF ADMIN, KITCHEN LTG	20		1.23		9	10		1.32		20	CONFERENCE ROOM LTG	10
11	DRY LAB, MISC. COMP. LTG	20			1.28	11	12			1.52	20	CONFERENCE ROOM LTG	12
13	CORRIDOR LIGHTING	20	0.79			13	14	3.50			20	SPARE	14
15	CORRIDOR LIGHTING	20		1.54		15	16		3.50		20	SPARE	16
17	CORRIDOR LIGHTING	20			1.68	17	18			3.50	20	SPARE	18
19	SPARE	20	3.50			19	20	3.50			20	SPARE	20
21	SPARE	20		3.50		21	22		3.50		20	SPARE	22
23	SPARE	20			3.50	23	24			3.50	20	SPARE	24
25	SPARE	20	3.50			25	26	3.50			20	SPARE	26
27	SPARE	20		3.50		27	28		3.50		20	SPARE	28
29	SPARE	20			3.50	29	30			3.50	20	SPARE	30
31	SPARE	20	3.50			31	32	3.50			20	SPARE	32
33	SPARE	20		3.50		33	34		3.50		20	SPARE	34
35	SPARE	20			3.50	35	36			3.50	20	SPARE	36
37	SPARE	20	3.50			37	38	3.50			20	SPARE	38
39	SPARE	20		3.50		39	40		3.50		20	SPARE	40
41	SPARE	20			3.50	41	42			3.50	20	SPARE	42
Subtotals (kVA):		17.03	18.37	18.56				21.99	20.21	20.92		Subtotals (kVA)	
Total Loads:		Phase A: 39.02 kVA			65.78 %			Demand Factor (worksheet)					
		Phase B: 38.58 kVA			77.02 kVA			Demand Load					
		Phase C: 39.48 kVA			96.27 kVA			Load x 1.25					
Total Connected Load:		117.08 kVA			115.93 A			AMP					



# Existing

BRANCH CIRCUIT PANELBOARD SCHEDULE													
Panel Name: HLE-3D		Mounting:	Surface:	X	Main Lugs Only:				.	Amp Main CB	100		
277/480, 3 Phase, 4 Wire			Flush:	.	Shunt Trip Main:				.	Amp Bus	225		
14,000MIN A.I.C. SYM			In MCC:	.	Feed Through:				.	Ground Bus	X		
Neutral: 100%		Number of Poles:		42	TVSS:				.	Isolated Ground Bus	.		
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles		KVA/Phase			TRIP (Amp)	Load	CKT No.
1	EXIT SIGN	20	0.10			1	2	1.02				STAIR N-1 LIGHTING	2
3	TOILET & CORRIDOR LTG	20		2.16		3	4		1.45			STAIR N-1 LIGHTING	4
5	OFFICE LIGHTING	20			2.30	5	6					SPARE	6
7	SPARE	20				7	8					SPARE	8
9	SPARE	20				9	10					SPARE	10
11	SPARE	20				11	12					SPARE	12
13	SPARE	20				13	14					SPARE	14
15	SPARE	20				15	16					SPARE	16
17	SPARE	20				17	18					SPARE	18
19	SPARE	20				19	20					SPARE	20
21	SPARE	20				21	22					SPARE	22
23	SPARE	20				23	24					SPARE	24
25	SPARE	20				25	26					SPARE	26
27	SPARE	20				27	28					SPARE	28
29	SPARE	20				29	30					SPARE	30
31	SPARE	20				31	32					SPARE	32
33	SPARE	20				33	34					SPARE	34
35	SPARE	20				35	36					SPARE	36
37	PENEL LE-3D VIA	50	4.94			37	38					SPARE	38
39	XFMR 'TRE-LE-3D'			3.80		39	40					SPARE	40
41	(50G)	3P			3.80	41	42					SPARE	42
Subtotals (kVA):			5.04	5.96	6.10			1.02	1.45	0.00		Subtotals (kVA)	
Total Loads:			Phase A: 6.06 kVA			60.00 %			Demand Factor				
			Phase B: 7.41 kVA			11.74 kVA			Demand Load				
			Phase C: 6.10 kVA			14.68 kVA			Load x 1.25				
Total Connected Load:			19.6 kVA			17.68 A			AMP				

# Lighting/Electrical Appendices

## Electrical Panelboard Designs: HLE-3D

Panelboard HLE-3D Circuit Calculations					
Circuit 3					
Mark	Quantity	W/Luminaire	Total W	PF	Total VA
C-1	20	32.0	640.00	0.99	646.46
NF-4	2	65.0	130.00	0.98	132.65
SC-2	4	20.0	80.00	0.98	81.63
NF-5	3	65.0	195.00	0.99	196.97
Totals:			1045.00	0.99	1057.72

Panelboard					
Tag	HL-3D	HLE-3D	LR-3D1	LCP-1	
Voltage System	480Y/277 V	480Y/277 V	208Y/120 V	480Y/277 V	
Calculated Design Load (kW)	147.64	169.01	46.94	83.55	
Calculated Power Factor	0.807	0.801	0.833	0.81	
Calculated Design Load (kVA)	182.94	210.88	56.32	102.58	
Calculated Design Load (A)	220.14	253.76	156.44*	123.44	
Feeder					
Feeder Protection Size	125 A	150 A	110 A	70 A	
Number of Sets	1	1	1	1	
Wire Size					
	Phase	(3) 4/0	(3) 250 kcmil	(3) 3/0	(3) #1
	Neutral	(1) 4/0	(1) 250 kcmil	(2) 3/0	(1) #1
	Ground	#6	#6	#6	#8
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.3718	0.4598	0.3117	0.1901
	Total - All Phases	1.1154	1.3788	0.9351	0.5703
	Neutral	0.3718	0.4598	0.6234	0.1901
	Ground	0.0726	0.0726	0.0726	0.0437
	Total - All Wires	1.5598	1.911	1.6311	0.8041
Minimum Conduit Area (Sq. in.) (Above x 2.5)					
Conduit Size (NEC Chapter 9, Table 4)	2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT	
Conduit Size (NEC Table C.1)	2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT	
Feeder Length	207 ft.	25 ft.	140 ft.	140 ft.	
Final Voltage Drop (V)	4.80	0.60	1.70	1.70	
Final Voltage Drop (%)	1.00%	0.12%	1.4%	1.4%	
Feeder Re-sizing	Not Needed	Not Needed	Not Needed	Not Needed	

# Redesign

BRANCH CIRCUIT PANELBOARD SCHEDULE													
Panel Name: HLE-3D		Mounting:	Surface:	X	Main Lugs Only:				.	Amp Main CB	150		
277/480, 3 Phase, 4 Wire			Flush:	.	Shunt Trip Main:				.	Amp Bus	225		
14,000MIN A.I.C. SYM			In MCC:	.	Feed Through:				.	Ground Bus	X		
Neutral: 100%		Number of Poles:		42	TVSS:				.	Isolated Ground Bus	.		
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles		KVA/Phase			TRIP (Amp)	Load	CKT No.
1	EXIT SIGN	20	0.10			1	2	1.02				STAIR N-1 LIGHTING	2
3	TOILET & CORRIDOR LTG	20		1.06		3	4		1.45			STAIR N-1 LIGHTING	4
5	OFFICE LIGHTING	20			2.30	5	6			3.50		SPARE	6
7	SPARE	20	3.50			7	8	3.50				SPARE	8
9	SPARE	20		3.50		9	10		3.50			SPARE	10
11	SPARE	20			3.50	11	12			3.50		SPARE	12
13	SPARE	20	3.50			13	14	3.50				SPARE	14
15	SPARE	20		3.50		15	16		3.50			SPARE	16
17	SPARE	20			3.50	17	18			3.50		SPARE	18
19	SPARE	20	3.50			19	20	3.50				SPARE	20
21	SPARE	20		3.50		21	22		3.50			SPARE	22
23	SPARE	20			3.50	23	24			3.50		SPARE	24
25	SPARE	20	3.50			25	26	3.50				SPARE	26
27	SPARE	20		3.50		27	28		3.50			SPARE	28
29	SPARE	20			3.50	29	30			3.50		SPARE	30
31	SPARE	20	3.50			31	32	3.50				SPARE	32
33	SPARE	20		3.50		33	34		3.50			SPARE	34
35	SPARE	20			3.50	35	36			3.50		SPARE	36
37	PENEL LE-3D VIA	50	4.94			37	38	3.50				SPARE	38
39	XFMR 'TRE-LE-3D'			3.80		39	40		3.50			SPARE	40
41	(50G)	3P			3.80	41	42			3.50		SPARE	42
Subtotals (kVA):			22.54	22.36	23.60			22.02	22.45	24.50		Subtotals (kVA)	
Total Loads:			Phase A: 44.56 kVA			61.27 %			Demand Factor (worksheet)				
			Phase B: 44.81 kVA			84.23 kVA			Demand Load				
			Phase C: 48.10 kVA			105.28 kVA			Load x 1.25				
Total Connected Load:			137.5 kVA			126.79 A			AMP				



# Existing

BRANCH CIRCUIT PANELBOARD SCHEDULE												
<b>Panel Name: LR-3D1</b>		Mounting:	Surface:	X	Main Lugs Only:			.	Amp Main CB	225		
120/208, 3 Phase, 4 Wire		Flush:	.	.	Shunt Trip Main:			.	Amp Bus	225		
10,000MIN A.I.C. SYM		In MCC:	.	.	Feed Through:			X	Ground Bus	X		
Neutral: 200%		Number of Poles:	42		TVSS:			.	Isolated Ground Bus	X		
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles	KVA/Phase			TRIP (Amp)	Load	CKT No.
1	P.C. RECEPTACLE	20	0.80			1	2	0.80		20	P.C. RECEPTACLE	2
3	RECEPTACLE	20		1.08		3	4		0.80	20	P.C. RECEPTACLE	4
5	P.C. RECEPTACLE	20			0.80	5	6			20	P.C. RECEPTACLE	6
7	RECEPTACLE	20	1.08			7	8	0.80		20	P.C. RECEPTACLE	8
9	P.C. RECEPTACLE	20		0.80		9	10		0.80	20	P.C. RECEPTACLE	10
11	RECEPTACLE	20			0.54	11	12		0.80	20	P.C. RECEPTACLE	12
13	P.C. RECEPTACLE	20	0.80			13	14	0.80		20	P.C. RECEPTACLE	14
15	SPARE	20				15	16		0.80	20	P.C. RECEPTACLE	16
17	P.C. RECEPTACLE	20			1.16	17	18		0.80	20	P.C. RECEPTACLE	18
19	RECEPTACLE	20	1.08			19	20	0.80		20	P.C. RECEPTACLE	20
21	P.C. RECEPTACLE	20		0.72		21	22		0.80	20	CLEANING RECEPTACLE	22
23	P.C. RECEPTACLE	20			0.90	23	24		0.80	20	CLEANING RECEPTACLE	24
25	P.C. RECEPTACLE	20	0.72			25	26	0.80		20	CLEANING RECEPTACLE	26
27	RECEPTACLE	20		0.72		27	28		0.80	20	CLEANING RECEPTACLE	28
29	P.C. RECEPTACLE	20			0.40	29	30			20	SPARE	30
31	RECEPTACLE	20	0.36			31	32			20	SPARE	32
33	RECEPTACLE	20		0.72		33	34			20	SPARE	34
35	SPARE	20				35	36			20	SPARE	36
37	SPARE	20				37	38			20	SPARE	38
39	SPARE	20				39	40			20	SPARE	40
41	SPARE	20				41	42			20	SPARE	42
Subtotals (kVA):		4.84	4.04	3.80		4.00	4.00	3.20		Subtotals (kVA)		
Total Loads:		Phase A: 8.84 kVA			60.00 %			Demand Factor				
		Phase B: 8.04 kVA			14.33 kVA			Demand Load				
		Phase C: 7.00 kVA			17.91 kVA			Load x 1.25				
Total Connected Load:		23.88 kVA			49.77 A			AMP				

# Lighting/Electrical Appendices

## Electrical Panelboard Designs: LR-3D1

Panelboard LR-3D1 Circuit Calculations					
Circuit 30					
Mark	Quantity	W/Luminaire	Total W	PF	Total VA
T-1	96	6.0	576.00	0.99	581.82
<b>Totals:</b>			<b>576.00</b>	<b>0.99</b>	<b>581.82</b>

Panelboard					
Tag	HL-3D	HLE-3D	LR-3D1	LCP-1	
Voltage System	480Y/277 V	480Y/277 V	208Y/120 V	480Y/277 V	
Calculated Design Load (kW)	147.64	169.01	46.94	83.55	
Calculated Power Factor	0.807	0.801	0.833	0.81	
Calculated Design Load (kVA)	182.94	210.88	56.32	102.58	
Calculated Design Load (A)	220.14	253.76	156.44*	123.44	
Feeder					
Feeder Protection Size	125 A	150 A	110 A	70 A	
Number of Sets	1	1	1	1	
Wire Size					
	Phase	(3) 4/0	(3) 250 kcmil	(3) 3/0	(3) #1
	Neutral	(1) 4/0	(1) 250 kcmil	(2) 3/0	(1) #1
	Ground	#6	#6	#6	#8
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.3718	0.4598	0.3117	0.1901
	Total - All Phases	1.1154	1.3788	0.9351	0.5703
	Neutral	0.3718	0.4598	0.6234	0.1901
	Ground	0.0726	0.0726	0.0726	0.0437
	Total - All Wires	1.5598	1.911	1.6311	0.8041
Minimum Conduit Area (Sq. in.) (Above x 2.5)					
Conduit Size (NEC Chapter 9, Table 4)	2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT	
Conduit Size (NEC Table C.1)	2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT	
Feeder Length	207 ft.	25 ft.	140 ft.	140 ft.	
Final Voltage Drop (V)	4.80	0.60	1.70	1.70	
Final Voltage Drop (%)	1.00%	0.12%	1.4%	1.4%	
Feeder Re-sizing	Not Needed	Not Needed	Not Needed	Not Needed	

# Redesign

BRANCH CIRCUIT PANELBOARD SCHEDULE												
<b>Panel Name: LR-3D1</b>		Mounting:	Surface:	X	Main Lugs Only:			.	Amp Main CB	110		
120/208, 3 Phase, 4 Wire		Flush:	.	.	Shunt Trip Main:			.	Amp Bus	225		
10,000MIN A.I.C. SYM		In MCC:	.	.	Feed Through:			X	Ground Bus	X		
Neutral: 200%		Number of Poles:	42		TVSS:			.	Isolated Ground Bus	X		
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles	KVA/Phase			TRIP (Amp)	Load	CKT No.
1	P.C. RECEPTACLE	20	0.80			1	2	0.80		20	P.C. RECEPTACLE	2
3	RECEPTACLE	20		1.08		3	4		0.80	20	P.C. RECEPTACLE	4
5	P.C. RECEPTACLE	20			0.80	5	6			20	P.C. RECEPTACLE	6
7	RECEPTACLE	20	1.08			7	8	0.80		20	P.C. RECEPTACLE	8
9	P.C. RECEPTACLE	20		0.80		9	10		0.80	20	P.C. RECEPTACLE	10
11	RECEPTACLE	20			0.54	11	12		0.80	20	P.C. RECEPTACLE	12
13	P.C. RECEPTACLE	20	0.80			13	14	0.80		20	P.C. RECEPTACLE	14
15	SPARE	20			1.50	15	16		0.80	20	P.C. RECEPTACLE	16
17	P.C. RECEPTACLE	20			1.16	17	18		0.80	20	P.C. RECEPTACLE	18
19	RECEPTACLE	20	1.08			19	20	0.80		20	P.C. RECEPTACLE	20
21	P.C. RECEPTACLE	20		0.72		21	22		0.80	20	CLEANING RECEPTACLE	22
23	P.C. RECEPTACLE	20			0.90	23	24		0.80	20	CLEANING RECEPTACLE	24
25	P.C. RECEPTACLE	20	0.72			25	26	0.80		20	CLEANING RECEPTACLE	26
27	RECEPTACLE	20		0.72		27	28		0.80	20	CLEANING RECEPTACLE	28
29	P.C. RECEPTACLE	20			0.40	29	30		0.72	20	STUDY AREA TASK LIGHTING	30
31	RECEPTACLE	20	0.36			31	32	1.50		20	SPARE	32
33	RECEPTACLE	20		0.72		33	34		1.50	20	SPARE	34
35	SPARE	20			1.50	35	36		1.50	20	SPARE	36
37	SPARE	20	1.50			37	38	1.50		20	SPARE	38
39	SPARE	20		1.50		39	40		1.50	20	SPARE	40
41	SPARE	20			1.50	41	42		1.50	20	SPARE	42
Subtotals (kVA):		6.34	7.04	6.80		7.00	7.00	6.92		Subtotals (kVA)		
Total Loads:		Phase A: 13.34 kVA			72.74 %			Demand Factor (worksheet)				
		Phase B: 14.04 kVA			29.90 kVA			Demand Load				
		Phase C: 13.72 kVA			37.37 kVA			Load x 1.25				
Total Connected Load:		41.10 kVA			103.85 A			AMP				



# Existing

BRANCH CIRCUIT PANELBOARD SCHEDULE																	
<b>Panel Name: LCP-1</b>		Mounting:		Surface:		X		Main Lugs Only:		.		Amp Main CB		.			
277/480, 3 Phase, 4 Wire		Flush:		.		.		Shunt Trip Main:		.		Amp Bus		225			
14,000MIN A.I.C. SYM		In MCC		.		.		Feed Through:		.		Ground Bus		.			
Neutral: 100%		Number of Poles:		42		.		TVSS:		.		Isolated Ground Bus		.			
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles	Poles	KVA/Phase			TRIP (Amp)	Load	CKT No.				
			A	B	C			A	B	C							
1	*ZONE 1 LS LOBBY LTG	20	0.42					0.72			20	ZONE 18 SITE LIGHTING*	2				
3	SPARE	20						0.24			20	ZONE 19 SITE LIGHTING*	4				
5	*ZONE 3 EXTERIOR LTG	20			1.40			0.24			20	ZONE 20 SITE LIGHTING*	6				
7	*ZONE 4 LS LOBBY LTG	20	0.31					0.36			20	ZONE 21 SITE LIGHTING*	8				
9	*ZONE 5 LS LOBBY LTG	20		0.56				0.70			20	ZONE 22 SITE LIGHTING	10				
11	*ZONE 6 EXTERIOR LTG	20			1.25			0.38			20	SPARE	12				
13	*ZONE 7 ML LOBBY LTG	20	0.84					0.38			20	ZONE 24 SITE LIGHTING*	14				
15	*ZONE 8 ML LOBBY LTG	20		0.56							20	SPARE	16				
17	*ZONE 9 EXTERIOR LTG	20			1.40			0.40			20	ZONE 26 SITE LIGHTING*	18				
19	SPARE	20						0.05			20	ZONE 27 SITE LIGHTING*	20				
21	*ZONE 11 EXTERIOR LTG	20			1.25			0.40			20	ZONE 28 SITE LIGHTING*	22				
23	*ZONE 12 ML LOBBY LTG	20			0.31			0.27			20	ZONE 29 EXTERIOR LTG*	24				
25	*ZONE 13 EXTERIOR LTG	20	0.63					0.27			20	ZONE 30 EXTERIOR LTG*	26				
27	*ZONE 14 EXTERIOR LTG	20		0.84				0.23			20	ZONE 31 EXTERIOR LTG*	28				
29	*ZONE 15 SITE LIGHTING	20			1.70			0.20			20	ZONE 32 EXTERIOR LTG*	30				
31	*ZONE 16 SITE LIGHTING	20	1.40					0.23			20	ZONE 33 EXTERIOR LTG*	32				
33	*ZONE 17 SITE LILGHTING	20		1.60				0.27			20	ZONE 34 EXTERIOR LTG*	34				
35	*ZONE 35 ML LOBBY LTG	20			0.46			0.42			20	ZONE 36 LS LOBBY LTG	36				
37	SPARE	20									20	SPARE	38				
39	SPARE	20									20	SPARE	40				
41	SPARE	20									20	SPARE	42				
Subtotals (kVA):			3.60	4.81	6.52			2.01	1.84	1.53		Subtotals (kVA)					
Total Loads:			Phase A: 5.61 kVA			80.00 %			Demand Factor								
			Phase B: 6.65 kVA			16.25 kVA			Demand Load								
			Phase C: 8.05 kVA			20.31 kVA			Load x 1.25								
Total Connected Load:			20.31 kVA			24.46 A			AMP								
REMARKS: * - DENOTES REMOTE CONTROL BREAKER																	

# Lighting/Electrical Appendices Electrical Panelboard Designs: LCP-1

Panelboard LR-3D1 Circuit Calculations						
Circuit 5 - Zone 3 Exterior						
Mark	Quantity	V/Luminair	Total W	PF	Total VA	
UL-1	19	85.0	1615.00	0.90	1794.44	
UL-2	2	85	170.00	0.9	188.89	
Totals:			1615.00	0.90	1794.44	
Circuit 11 - Zone 6 Exterior						
Mark	Quantity	V/Luminair	Total W	PF	Total VA	
XWM-1	20	48.0	960.00	0.90	1066.67	
Totals:			960.00	0.90	1066.67	
Circuit 17 - Zone 9 Exterior						
Mark	Quantity	V/Luminair	Total W	PF	Total VA	
FL-1	8	272.0	2176.00	0.90	2417.78	
Totals:			2176.00	0.90	2417.78	
Circuit 18 - Zone 26 Site						
Mark	Quantity	V/Luminair	Total W	PF	Total VA	
XPO-1	4	118.0	472.00	0.90	524.44	
Totals:			472.00	0.90	524.44	
Circuit 21 - Zone 11 Exterior						
Mark	Quantity	V/Luminair	Total W	PF	Total VA	
XWM-1	20	48.0	960.00	0.90	1066.67	
Totals:			960.00	0.90	1066.67	
Circuit 25 - Zone 13 Exterior						
Mark	Quantity	V/Luminair	Total W	PF	Total VA	
XAM-1	12	48.0	576.00	0.90	640.00	
Totals:			576.00	0.90	640.00	
Circuit 27 - Zone 14 Exterior						
Mark	Quantity	V/Luminair	Total W	PF	Total VA	
XAM-1	9	48.0	432.00	0.90	480.00	
Totals:			432.00	0.90	480.00	

Panelboard					
Tag	HL-3D	HLE-3D	LR-3D1	LCP-1	
Voltage System	480Y/277 V	480Y/277 V	208Y/120 V	480Y/277 V	
Calculated Design Load (kW)	147.64	169.01	46.94	83.55	
Calculated Power Factor	0.807	0.801	0.833	0.81	
Calculated Design Load (kVA)	182.94	210.88	56.32	102.58	
Calculated Design Load (A)	220.14	253.76	156.44*	123.44	
Feeder					
Feeder Protection Size	125 A	150 A	110 A	70 A	
Number of Sets	1	1	1	1	
Wire Size					
	Phase	(3) 4/0	(3) 250 kcmil	(3) 3/0	(3) #1
	Neutral	(1) 4/0	(1) 250 kcmil	(2) 3/0	(1) #1
	Ground	#6	#6	#6	#8
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.3718	0.4598	0.3117	0.1901
	Total - All Phases	1.1154	1.3788	0.9351	0.5703
	Neutral	0.3718	0.4598	0.6234	0.1901
	Ground	0.0726	0.0726	0.0726	0.0437
	Total - All Wires	1.5598	1.911	1.6311	0.8041
Minimum Conduit Area (Sq. in.) (Above x 2.5)	4.0513	4.9293	4.1395	4.1395	
Conduit Size (NEC Chapter 9, Table 4)	2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT	
Conduit Size (NEC Table C.1)	2.50" EMT	2.50" EMT	2.50" EMT	2.50" EMT	
Feeder Length	207 ft.	25 ft.	140 ft.	140 ft.	
Final Voltage Drop (V)	4.80	0.60	1.70	1.70	
Final Voltage Drop (%)	1.00%	0.12%	1.4%	1.4%	
Feeder Re-sizing	Not Needed	Not Needed	Not Needed	Not Needed	

# Redesign

BRANCH CIRCUIT PANELBOARD SCHEDULE																	
<b>Panel Name: LCP-1</b>		Mounting:		Surface:		X		Main Lugs Only:		.		Amp Main CB		.			
277/480, 3 Phase, 4 Wire		Flush:		.		.		Shunt Trip Main:		.		Amp Bus		225			
14,000MIN A.I.C. SYM		In MCC		.		.		Feed Through:		.		Ground Bus		.			
Neutral: 100%		Number of Poles:		42		.		TVSS:		.		Isolated Ground Bus		.			
CKT No.	Load	TRIP (Amp)	KVA/Phase			Poles	Poles	KVA/Phase			TRIP (Amp)	Load	CKT No.				
			A	B	C			A	B	C							
1	*ZONE 1 LS LOBBY LTG	20	0.42			1	2	0.72			20	ZONE 18 SITE LIGHTING*	2				
3	SPARE	20				3	4		3.50		20	SPARE	4				
5	*ZONE 3 COURTYARD UPLT	20			1.79	5	6			0.24	20	ZONE 20 SITE LIGHTING*	6				
7	*ZONE 4 LS LOBBY LTG	20	0.31			7	8	3.50			20	SPARE	8				
9	*ZONE 5 LS LOBBY LTG	20		0.56		9	10		0.70		20	ZONE 22 SITE LIGHTING	10				
11	*ZONE 6 EXTERIOR LTG	20			1.07	11	12			3.50	20	SPARE	12				
13	*ZONE 7 ML LOBBY LTG	20	0.84			13	14	3.50			20	SPARE	14				
15	*ZONE 8 ML LOBBY LTG	20		0.56		15	16		3.50		20	SPARE	16				
17	*ZONE 9 LIGHT WELL FLOOD	20			2.42	17	18			0.52	20	ZONE 26 COURTYARD SITE*	18				
19	SPARE	20	3.50			19	20	0.05			20	ZONE 27 SITE LIGHTING*	20				
21	*ZONE 11 EXTERIOR LTG	20			1.07	21	22		0.40		20	ZONE 28 SITE LIGHTING*	22				
23	*ZONE 12 ML LOBBY LTG	20			0.31	23	24			0.27	20	ZONE 29 EXTERIOR LTG*	24				
25	*ZONE 13 EXTERIOR LTG	20	0.64			25	26	0.27			20	ZONE 30 EXTERIOR LTG*	26				
27	*ZONE 14 EXTERIOR LTG	20			0.48	27	28		0.23		20	ZONE 31 EXTERIOR LTG*	28				
29	*ZONE 15 SITE LIGHTING	20			1.70	29	30			0.20	20	ZONE 32 EXTERIOR LTG*	30				
31	*ZONE 16 SITE LIGHTING	20	1.40			31	32	0.23			20	ZONE 33 EXTERIOR LTG*	32				
33	*ZONE 17 SITE LILGHTING	20		1.60		33	34		0.27		20	ZONE 34 EXTERIOR LTG*	34				
35	*ZONE 35 ML LOBBY LTG	20			0.46	35	36			0.42	20	ZONE 36 LS LOBBY LTG	36				
37	SPARE	20	3.50			37	38	3.50			20	SPARE	38				
39	SPARE	20				39	40		3.50		20	SPARE	40				
41	SPARE	20				41	42			3.50	20	SPARE	42				
Subtotals (kVA):			10.61	11.27	11.25			11.77	12.10	8.65		Subtotals (kVA)					
Total Loads:			Phase A: 22.38 kVA			66.24 %			Demand Factor								
			Phase B: 23.37 kVA			43.49 kVA			Demand Load								
			Phase C: 19.90 kVA			54.36 kVA			Load x 1.25								
Total Connected Load:			65.65 kVA			65.46 A			AMP								





# Existing

# Lighting/Electrical Appendices Electrical Panelboard Designs: EDPS-M41

# Redesign

DISTRIBUTION PANEL SCHEDULE									
Panel Name: EDPS-M41		Mounting:		Surface: X		Main Lugs Only: .		Amp Main CB 800	
277/480, 3 Phase, 4 Wire		Flush: .		In MCC		Shunt Trip Main: .		Amp Bus 800	
65,000MIN A.I.C. SYM		In MCC		.		Feed Through: .		100% NEUTRAL	
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	ACF-1	253.90	211.00	100	600A	450A	3	460G	
2	ACF-3	253.90	211.00	100	600A	450A	3	460G	
3	ACF-5	253.90	211.00	100	600A	450A	3	460G (STAND-BY)	
4	HMS-OB - HMS-3B	23.80	20.00		225A	225A	3	300G	
5	RO-2	11.00	9.00	7.5	100A	40A	3	40G	
6	PRE-TREATMENT	7.60	6.32	5	100A	30A	3	30G	
7	CONTROL PANEL	20.00	16.00		100A	30A	3	30NG	
8	SPACE								
9	EFN-24	65.00		50	100A	70A	3	115G (STAND-BY)	
10	EFN-26	72.20	60.00	75	225A	150A	3	150G (STAND-BY)	
11	SPARE				100A	100A	3		
12	SPARE				225A	225A	3		
13									
14									
15									
16									
17									
18									

PROVIDE INTEGRAL TVSS UNIT

Switchboard					
Tag	EDPS-M41	EDPS-M42	MDP-M41	MDP-M42	
Voltage System	480Y/277V	480Y/277V	480Y/277V	480Y/277V	
Calculated Design Load (kW)	700.87	796.10	614.29	904.46	
Calculated Power Factor	0.80	0.80	0.80	0.80	
Calculated Design Load (kVA)	876.08	955.12	767.86	1130.58	
Calculated Design Load (A)	1054.25	1197.50	924.03	1360.50	
Feeder					
Feeder Protection Size	1200A	1600A*	1000A	1600A	
Number of Sets	3	4	3**	4***	
Wire Size					
	Phase	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Neutral	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Ground	3/0	4/0	2/0	4/0
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.7901	0.5958	0.5958	0.7901
	Total – All Phases	2.3703	1.7874	1.7874	2.3703
	Neutral	0.7901	0.5958	0.5958	0.7901
	Ground	0.3117	0.3718	0.2624	0.3718
	Total – All Wires	3.4721	2.7550	2.6456	3.5322
Minimum Conduit Area (Sq. in.) (Above x 2.5)		8.6803	6.8875	6.6140	8.8305
Conduit Size (NEC Chapter 9, Table 4)		3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT
Conduit Size (NEC Table C.1)		3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT
Feeder Length		300 ft.	150 ft.	750 ft.	750 ft.
Final Voltage Drop (V)		2.7	1.7	8.5	6.6
Final Voltage Drop (%)		0.97%	0.61%	3.07%	2.38%
Feeder Re-sizing		Not Needed	Not Needed	500 kcmil**	See Below

\*Main circuit protection is too close to the next breaker size to be considered free from accidental trip  
 \*\*Feeder size change to 4 sets of (3) 500 kcmil + (1) 500 kcmil neutral to yield 4.5V (1.62%) drop  
 \*\*\*Voltage drop calculation yields adding an extra set with the same 500 kcmil cables

DISTRIBUTION PANEL SCHEDULE									
Panel Name: EDPS-M41		Mounting:		Surface: X		Main Lugs Only: .		Amp Main CB 1200	
277/480, 3 Phase, 4 Wire		Flush: .		In MCC		Shunt Trip Main: .		Amp Bus 1200	
65,000MIN A.I.C. SYM		In MCC		.		Feed Through: .		100% NEUTRAL	
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	AHU-INT-LS1	192.00	159.55	75	400A	250A	3	(3) 4/0 phase conductors, (1) #4 ground in 2" C	
2	AHU-INT-LS2	192.00	159.55	75	400A	250A	3	(3) 4/0 phase conductors, (1) #4 ground in 2" C	
3	SPACE								
4	HMS-OB - HMS-3B	23.80	20.00		225A	225A	3	300G	
5	RO-2	11.00	9.00	7.5	100A	40A	3	40G	
6	PRE-TREATMENT	7.60	6.32	5	100A	30A	3	30G	
7	CONTROL PANEL	20.00	16.00		100A	30A	3	30NG	
8	SPACE								
9	EFN-24	65.00	54.02	50	100A	70A	3	115G (STAND-BY)	
10	EFN-26	72.20	60.00	75	225A	150A	3	150G (STAND-BY)	
11	SPARE	80.00	66.48		100A	100A	3		
12	SPARE	180.00	149.58		225A	225A	3		
13									
14									
15									
16									
17									
18									

PROVIDE INTEGRAL TVSS UNIT



# Existing

# Lighting/Electrical Appendices Electrical Panelboard Designs: EDPS-M42

# Redesign

DISTRIBUTION PANEL SCHEDULE									
Panel Name: EDPS-M42 277/480, 3 Phase, 4 Wire 65,000MIN A.I.C. SYM		Mounting:		Surface: X	Main Lugs Only: .		Amp Main CB	800	
				Flush: .	Shunt Trip Main: .		Amp Bus	800	
				In MCC: .	Feed Through: .		100% NEUTRAL		
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	ACF-2	253.90	211.00	100	400A	380A	3	400G	
2	ACF-4	253.90	211.00	100	400A	380A	3	400G	
3	ACF-9	52.00	30.00	40	100A	100A	3	115G (STAND-BY)	
4	ACF-10	52.00	30.00	40	100A	100A	3	115G	
5	ACF-11	34.00	28.00	25	100A	70A	3	85G	
6	HMS-0D - HMS-3D	16.00	13.30		225A	225A	3	300NG	
7	ACF-12	156.00	94.00	125	225A	225A	3	230G	
8	VACUUM PUMP (VCP-1)	104.00		3(40)	200A	200A	3	200G - (2 ACTIVE, 1 STAND-BY)	
9	SPARE				100A	30A	3		
10	SPARE				100A	30A	3		
11									
12									
13									
14									
15									
16									
17									
18									

PROVIDE INTEGRAL TVSS UNIT

Switchboard					
Tag	EDPS-M41	EDPS-M42	MDP-M41	MDP-M42	
Voltage System	480Y/277V	480Y/277V	480Y/277V	480Y/277V	
Calculated Design Load (kW)	700.87	796.10	614.29	904.46	
Calculated Power Factor	0.80	0.80	0.80	0.80	
Calculated Design Load (kVA)	876.08	955.12	767.86	1130.58	
Calculated Design Load (A)	1054.25	1197.50	924.03	1360.50	
Feeder					
Feeder Protection Size	1200A	1600A*	1000A	1600A	
Number of Sets	3	4	3**	4***	
Wire Size					
	Phase	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Neutral	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Ground	3/0	4/0	2/0	4/0
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.7901	0.5958	0.5958	0.7901
	Total – All Phases	2.3703	1.7874	1.7874	2.3703
	Neutral	0.7901	0.5958	0.5958	0.7901
	Ground	0.3117	0.3718	0.2624	0.3718
	Total – All Wires	3.4721	2.7550	2.6456	3.5322
Minimum Conduit Area (Sq. in.) (Above x 2.5)					
		8.6803	6.8875	6.6140	8.8305
Conduit Size (NEC Chapter 9, Table 4)					
		3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT
Conduit Size (NEC Table C.1)					
		3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT
Feeder Length					
		300 ft.	150 ft.	750 ft.	750 ft.
Final Voltage Drop (V)					
		2.7	1.7	8.5	6.6
Final Voltage Drop (%)					
		0.97%	0.61%	3.07%	2.38%
Feeder Re-sizing					
		Not Needed	Not Needed	500 kcmil**	See Below

\*Main circuit protection is too close to the next breaker size to be considered free from accidental trip

\*\*Feeder size change to 4 sets of (3) 500 kcmil + (1) 500 kcmil neutral to yield 4.5V (1.62%) drop

\*\*\*Voltage drop calculation yields adding an extra set with the same 500 kcmil cables

DISTRIBUTION PANEL SCHEDULE									
Panel Name: EDPS-M42 277/480, 3 Phase, 4 Wire 65,000MIN A.I.C. SYM		Mounting:		Surface: X	Main Lugs Only: .		Amp Main CB	1600	
				Flush: .	Shunt Trip Main: .		Amp Bus	2500	
				In MCC: .	Feed Through: .		100% NEUTRAL		
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	AHU-INT-MS1	192.00	159.55	75	400A	250A	3	(3) 4/0 phase conductors, (1) #4 ground in 2" C	
2	AHU-INT-MS2	192.00	159.55	75	400A	250A	3	(3) 4/0 phase conductors, (1) #4 ground in 2" C	
3	ACF-9	52.00	30.00	40	100A	100A	3	115G (STAND-BY)	
4	ACF-10	52.00	30.00	40	100A	100A	3	115G	
5	ACF-11	34.00	28.00	25	100A	70A	3	85G	
6	HMS-0D - HMS-3D	16.00	13.30		225A	225A	3	300NG	
7	ACF-12	156.00	94.00	125	225A	225A	3	230G	
8	VACUUM PUMP (VCP-1)	104.00	86.42	3(40)	200A	200A	3	200G - (2 ACTIVE, 1 STAND-BY)	
9	SPARE	80.00	66.48		100A	30A	3		
10	SPARE	80.00	66.48		100A	30A	3		
11									
12									
13									
14									
15									
16									
17									
18									

PROVIDE INTEGRAL TVSS UNIT





# Existing

DISTRIBUTION PANEL SCHEDULE									
Panel Name: <b>MDP-M41</b> 277/480, 3 Phase, 4 Wire 65,000MIN A.I.C. SYM		Mounting:	Surface: X	Main Lugs Only: .	Amp Main CB	1000			
			Flush: .	Shunt Trip Main: .	Amp Bus	1000			
			In MCC: .	Feed Through: .	100% NEUTRAL				
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	ACF-7	77.00	63.00	60	225A	110A	3	115G	
2	RTF-1	40.00	33.00	30	100A	80A	3	85G	
3	GWP-12	34.00	28.00	25	100A	70A	3	85G (STAND-BY)	
4	RTF-3	27.00	21.49	20	100A	60A	3	60G	
5	HM-3B - HM-OB	57.44	47.70		225A	225A	3	255G	
6	HL-3B - HL-OB	166.74	138.00		400A	400A	3	400NG	
7	HM-4A	26.19	21.75		400A	400A	3	380G	
8	HL-M4	9.15	7.60		100A	100A	3	115NG	
9	LR-4C VIA 30 KVA XFMR 'TRE-LR-4C'	18.70	15.50		100A	50A	3	50G	
10	SPARE				225A	225A	3		
11	SPARE				225A	225A	3		
12									
13									
14									
15									
16									
17									
18									

PROVIDE INTEGRAL TVSS UNIT

# Lighting/Electrical Appendices

## Electrical Panelboard Designs: MDP-M41

Switchboard					
Tag	EDPS-M41	EDPS-M42	MDP-M41	MDP-M42	
Voltage System	480Y/277V	480Y/277V	480Y/277V	480Y/277V	
Calculated Design Load (kW)	700.87	796.10	614.29	904.46	
Calculated Power Factor	0.80	0.80	0.80	0.80	
Calculated Design Load (kVA)	876.08	955.12	767.86	1130.58	
Calculated Design Load (A)	1054.25	1197.50	924.03	1360.50	
Feeder					
Feeder Protection Size	1200A	1600A*	1000A	1600A	
Number of Sets	3	4	3**	4***	
Wire Size					
	Phase	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Neutral	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Ground	3/0	4/0	2/0	4/0
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.7901	0.5958	0.5958	0.7901
	Total – All Phases	2.3703	1.7874	1.7874	2.3703
	Neutral	0.7901	0.5958	0.5958	0.7901
	Ground	0.3117	0.3718	0.2624	0.3718
	Total – All Wires	3.4721	2.7550	2.6456	3.5322
Minimum Conduit Area (Sq. in.) (Above x 2.5)	8.6803	6.8875	6.6140	8.8305	
Conduit Size (NEC Chapter 9, Table 4)	3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT	
Conduit Size (NEC Table C.1)	3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT	
Feeder Length	300 ft.	150 ft.	750 ft.	750 ft.	
Final Voltage Drop (V)	2.7	1.7	8.5	6.6	
Final Voltage Drop (%)	0.97%	0.61%	3.07%	2.38%	
Feeder Re-sizing	Not Needed	Not Needed	500 kcmil**	See Below	

\*Main circuit protection is too close to the next breaker size to be considered free from accidental trip  
 \*\*Feeder size change to 4 sets of (3) 500 kcmil + (1) 500 kcmil neutral to yield 4.5V (1.62%) drop  
 \*\*\*Voltage drop calculation yields adding an extra set with the same 500 kcmil cables

# Redesign

DISTRIBUTION PANEL SCHEDULE									
Panel Name: <b>MDP-M41</b> 277/480, 3 Phase, 4 Wire 65,000MIN A.I.C. SYM		Mounting:	Surface: X	Main Lugs Only: .	Amp Main CB	1000			
			Flush: .	Shunt Trip Main: .	Amp Bus	1200			
			In MCC: .	Feed Through: .	100% NEUTRAL				
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	SPACE								
2	RTF-1	40.00	33.00	30	100A	80A	3	85G	
3	GWP-12	34.00	28.00	25	100A	70A	3	85G (STAND-BY)	
4	RTF-3	27.00	21.49	20	100A	60A	3	60G	
5	HM-3B - HM-OB	57.44	47.70		225A	225A	3	255G	
6	HL-3B - HL-OB	166.74	138.00		400A	400A	3	400NG	
7	HM-4A	26.19	21.75		400A	400A	3	380G	
8	HL-M4	9.15	7.60		100A	100A	3	115NG	
9	LR-4C VIA 30 KVA XFMR 'TRE-LR-4C'	18.70	15.50		100A	50A	3	50G	
10	SPARE	180.00	149.58		225A	225A	3		
11	SPARE	180.00	149.58		225A	225A	3		
12									
13									
14									
15									
16									
17									
18									

PROVIDE INTEGRAL TVSS UNIT



# Existing

DISTRIBUTION PANEL SCHEDULE									
Panel Name: <b>MDP-M42</b> 277/480, 3 Phase, 4 Wire 65,000MIN A.I.C. SYM		Mounting:	Surface: X	Main Lugs Only: .	Amp Main CB	1000			
			Flush: .	Shunt Trip Main: .	Amp Bus	1000			
			In MCC	Feed Through: .	100% NEUTRAL				
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	ACF-6	77.00	64.00	60	225A	110A	3	115G	
2	ACF-8	77.00	64.00	60	225A	110A	3	115G	
3	ACF-12	96.00	80.00	75	225A	125A	3	130G	
4	HM-3D - HM-OD	159.84	132.73	7.5	400A	400A	3	400G	
5	HL-3D - HL-OD	113.63	94.36	7.5	225.00	225A	3	255NG	
6	HM-4B	37.93	31.50	7.5	400A	400A	3	380G	
7									
8	SPARE				225A	225A	3		
9	SPARE				225A	225A	3		
10	GWP-11	34.00	28.00	25	100A	70A	3	85G	
11	RTF-2	27.00	21.49	20	100A	60A	3	60G	
12									
13									
14									
15									
16									
17									
18									

PROVIDE INTEGRAL TVSS UNIT

# Lighting/Electrical Appendices Electrical Panelboard Designs: MDP-M42

Switchboard					
Tag	EDPS-M41	EDPS-M42	MDP-M41	MDP-M42	
Voltage System	480Y/277V	480Y/277V	480Y/277V	480Y/277V	
Calculated Design Load (kW)	700.87	796.10	614.29	904.46	
Calculated Power Factor	0.80	0.80	0.80	0.80	
Calculated Design Load (kVA)	876.08	955.12	767.86	1130.58	
Calculated Design Load (A)	1054.25	1197.50	924.03	1360.50	
Feeder					
Feeder Protection Size	1200A	1600A*	1000A	1600A	
Number of Sets	3	4	3**	4***	
Wire Size					
	Phase	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Neutral	500 kcmil	350 kcmil	350 kcmil	500 kcmil
	Ground	3/0	4/0	2/0	4/0
Wire Area (Sq. in.) (Table above)					
	Each Phase	0.7901	0.5958	0.5958	0.7901
	Total – All Phases	2.3703	1.7874	1.7874	2.3703
	Neutral	0.7901	0.5958	0.5958	0.7901
	Ground	0.3117	0.3718	0.2624	0.3718
	Total – All Wires	3.4721	2.7550	2.6456	3.5322
Minimum Conduit Area (Sq. in.) (Above x 2.5)	8.6803	6.8875	6.6140	8.8305	
Conduit Size (NEC Chapter 9, Table 4)	3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT	
Conduit Size (NEC Table C.1)	3.0" EMT	3.0" EMT	3.0" EMT	3.0" EMT	
Feeder Length	300 ft.	150 ft.	750 ft.	750 ft.	
Final Voltage Drop (V)	2.7	1.7	8.5	6.6	
Final Voltage Drop (%)	0.97%	0.61%	3.07%	2.38%	
Feeder Re-sizing	Not Needed	Not Needed	500 kcmil**	See Below	

\*Main circuit protection is too close to the next breaker size to be considered free from accidental trip  
 \*\*Feeder size change to 4 sets of (3) 500 kcmil + (1) 500 kcmil neutral to yield 4.5V (1.62%) drop  
 \*\*\*Voltage drop calculation yields adding an extra set with the same 500 kcmil cables

# Redesign

DISTRIBUTION PANEL SCHEDULE									
Panel Name: <b>MDP-M42</b> 277/480, 3 Phase, 4 Wire 65,000MIN A.I.C. SYM		Mounting:	Surface: X	Main Lugs Only: .	Amp Main CB	1600			
			Flush: .	Shunt Trip Main: .	Amp Bus	2500			
			In MCC	Feed Through: .	100% NEUTRAL				
CKT NO.	EQUIPMENT	LOAD (CONN)			BREAKER			WIRE SIZE / REMARKS	
		AMPS	KVA	HP	FRAME (AMPS)	TRIP (AMPS)	Poles		
1	AHU-EXT-1	130.00	108.03	50	225A	175A	3	(3) 1/0 phase conductors, (1) #6 ground in 1.5"C	
2	AHU-EXT-2	130.00	108.03	50	225A	175A	3	(3) 1/0 phase conductors, (1) #6 ground in 1.5"C	
3	ACF-12	96.00	80.00	75	225A	125A	3	130G	
4	HM-3D - HM-OD	159.84	132.73	7.5	400A	400A	3	400G	
5	HL-3D - HL-OD	113.63	94.36	7.5	225.00	225A	3	255NG	
6	HM-4B	37.93	31.50	7.5	400A	400A	3	380G	
7									
8	SPARE	180.00	149.58		225A	225A	3		
9	SPARE	180.00	149.58		225A	225A	3		
10	GWP-11	34.00	28.00	25	100A	70A	3	85G	
11	RTF-2	27.00	21.49	20	100A	60A	3	60G	
12									
13									
14									
15									
16									
17									
18									


PROVIDE INTEGRAL TVSS UNIT






# Equipment

SKM Model Equipment Schedule						
Lvl	Name	Location	Floorplan	Voltage	RATING	Series Rating
Switchgear	MDS-01A	W-P003	E2.0B-P	480/277V	5,000A	100 kAIC
	MDS-01B	W-P003	E2.0B-P	480/277V	5,000A	100 kAIC
	MDS-02A	N-P051	E2.0MD-LP	480/277V	2,000A	100 kAIC
	MDS-02B	N-P051	E2.0MD-LP	480/277V	2,000A	100 kAIC
	EMDS-1	N-P052	E2.0MD-LP	480/277V	2,000A	65 kAIC
	EDPS-1E1	N-P052	E2.0MD-LP	480/277V	800A	65 kAIC
	EDPS-1E2	N-P052	E2.0MD-LP	480/277V	800A	65 kAIC
	SDP-2B	W-P249	E2.2B-P	480/277V	1,000A	65 kAIC
	SDP-2D	N-P258	E2.2D-P	480/277V	1,000A	65 kAIC
	SDP-2D1	N-P238	E2.2E-P	480/277V	1,000A	65 kAIC
Switchboards	EDPS-3B	W-P338	E2.3B-P	208/120V	800A	65 kAIC
	EDPS-3D	N-P347	E2.3D-P	208/120V	800A	65 kAIC
	EDPS-M41	N-M401	E2.4C-P	480/277V	800A	65 kAIC
	EDPS-M42	N-M401	E2.4C-P	480/277V	800A	65 kAIC
	MDP-M41	N-M401	E2.4C-P	480/277V	1,000A	65 kAIC
	MDP-M42	N-M401	E2.4C-P	480/277V	1,000A	65 kAIC
	HL-3B	W-P338	E2.3B-P	480/277V	200A	14 kAIC Min.
	HMS-3B	W-P338	E2.3B-P	480/277V	100A	14 kAIC Min.
	LB-3B1/2	W-Q304	E4.3B	208/120V	225A	10 kAIC Min.
	LB-3B3/4	W-321	E4.3B	208/120V	225A	10 kAIC Min.
Level 3B	LB-3B5/6	W-337	E4.3B	208/120V	225A	10 kAIC Min.
	LB-3B7	W-Q304	E4.3B	208/120V	225A/MLO	10 kAIC Min.
	LBS-3B1/2	W-Q304	E4.3B	208/120V	225A	10 kAIC Min.
	LBS-3B3/4	W-321	E4.3B	208/120V	225A	10 kAIC Min.
	LR-3B	W-P338	E2.3B-P	208/120V	150A	10 kAIC Min.
	LR-3B5/6	W-337	E4.3B	208/120V	225A	10 kAIC Min.
	LS-3B	W-P338	E2.3B-P	208/120V	100A	10 kAIC Min.
	LB-3C1/2	W-Q302	E2.3C-P	208/120V	150A	10 kAIC Min.
	LR-3C1/2	N-Q307	E2.3C-P	208/120V	225A	10 kAIC Min.
	HL-3D	N-P347	E2.3D-P	480/277V	200A	14 kAIC Min.
Panelboards: Level 3	HM-3D	N-P347	E2.3D-P	480/277V	100A	14 kAIC Min.
	HMS-3D	N-P347	E2.3D-P	480/277V	100A	14 kAIC Min.
	LB-3D1/2	N-361	E4.3D	208/120V	175A	10 kAIC Min.
	LB-3D5/6	N-361	E4.3D	208/120V	175A	10 kAIC Min.
	LB-3D7/8	N-361	E4.3D	208/120V	175A	10 kAIC Min.
	LB-3D1/2	N-Q304	E4.3D	208/120V	225A	10 kAIC Min.
	LBS-3D5/6	N-361	E4.3D	208/120V	225A	10 kAIC Min.
	LR-3D1/2	N-P346	E2.3D-P	208/120V	225A	10 kAIC Min.
	LR-3D3/4	N-P346	E2.3D-P	208/120V	225A	10 kAIC Min.
	LS-3D	N-P347	E2.3D-P	208/120V	100A	10 kAIC Min.
Distribution Equipment	ATS-HS1	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	ATS-HS2	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	ATS-HS3	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	ATS-HS4	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	TRN-SDP-2B	W-P249	E2.2B-P	300 kVA	480A-208V/120V	N/A
	TRN-SDP-2D	N-P258	E2.2D-P	300 kVA	480A-208V/120V	N/A
	TRN-SDP-2D1	N-P238	E2.2E-P	300 kVA	480A-208V/120V	N/A
	TRE-EDPS-3B	W-P338	E2.3B-P	225 kVA	480A-208V/120V	N/A
Mech. Equipment	ACF-1	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
	ACF-2	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
	ACF-3	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
	ACF-4	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
ACF-5	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----	
ACF-6	N-M401	60 hp	110 A MCP, 100 A FS	-----	-----	
ACF-7	N-M401	60 hp	110 A MCP, 100 A FS	-----	-----	
ACF-8	N-M401	60 hp	110 A MCP, 100 A FS	-----	-----	





# Lighting/Electrical Appendices

## Depth Topic 1: SKM Analysis Summary



Fault Analysis Summary					
Bus Name	Voltage	Available Fault Current			
		3-Phase	X/R	LINE/GRND	X/R
EDPS-1E1	480	39353.3	3	8391.63	0.2
EDPS-1E2	480	38449.6	2.9	8364.93	0.2
EDPS-3B	208	8147.9	1.6	9238.12	1.6
EDPS-3D	208	9963.3	1.6	10713.51	1.6
EDPS-M41	480	26611.3	2.1	7238.23	0.3
EDPS-M42	480	32169.3	2.4	7817.41	0.3
EMDS-1	480	10039.0	4.9	1621.01	0.1
HL-3B	480	13108.6	1.6	5383.71	0.5
HL-3D	480	11810.3	1.2	4971.80	0.5
HM-3D	480	13304.3	1.6	5406.24	0.5
HMS-3B	480	15707.0	1.4	5858.97	0.4
HMS-3D	480	17537.7	1.4	6259.26	0.4
LB-3B1/2	208	7593.2	1.1	6792.20	1.2
LB-3B3/4	208	7756.9	1.1	6964.21	1.2
LB-3B5/6	208	7756.9	1.1	6964.21	1.2
LB-3B7	208	8104.7	1.2	7334.45	1.2
LB-3C1/2	208	4502.6	0.9	4019.60	1
LB-3D1/2	208	138.7	7.9	134.64	8.1
LB-3D5/6	208	138.7	7.9	134.64	8.1
LB-3D7/8	208	4508.2	0.9	4021.00	1
LBS-3B1/2	208	6467.5	1.2	6633.94	1.2
LBS-3B3/4	208	6467.5	1.2	6633.94	1.2
LBS-3D1/2	208	7560.1	1.2	7361.22	1.2
LBS-3D5/6	208	7560.1	1.2	7361.22	1.2
LR-3B5/6	208	7756.9	1.1	6964.21	1.2
LR-3C1/2	208	3773.0	0.8	3288.52	0.9
LR-3D1/2	208	6503.1	1.1	6244.65	1.2
LR-3D3/4	208	6503.1	1.1	6244.65	1.2
LS-3B	208	6746.9	1.1	7098.78	1
LS-3D	208	7936.7	1.1	7928.46	1
MDP-M41	480	18646.1	1.9	6337.24	0.4
MDP-M42	480	19033.2	1.9	6367.69	0.4
MDS-01A	480	57411.7	5.7	9248.60	0.1
MDS-01B	480	57406.8	5.7	9248.52	0.1
MDS-02A	480	44453.2	3.5	8669.88	0.2
MDS-02B	480	44450.1	3.5	8669.80	0.2
SDP-2B	208	10951.5	1.6	10647.34	1.7
SPD-2D	208	8645.7	1.4	9083.76	1.5
SDP-2D1	208	8574.7	1.3	9026.44	1.6

# Results



## Dimming System

Lutron Ecosystem Overview. Lutron Electronics Company. Web. 9 Feb. 2011. <<http://www.lutron.com/Products/WholeBuildingSystems/EcoSystem/Pages/Overview.aspx>>.

## Eaton Distribution Equipment

"Electrical Selector." Eaton Electrical Homepage. Web. 12 Mar. 2011. <<http://www.eaton.com/Electrical/index.htm>>.

## Electrical Code

National Electrical Code: 2008. Quincy, MA: National Fire Protection Association, 2007. Print.

## Electrical System Modeling

Afshin, and Johnny. FAQ: Modeling an Uninterruptable Power System (UPS). Manhattan Beach, CA: SKM Systems Analysis, Inc. PDF. <[http://www.skm.com/Modeling\\_a\\_UPS\\_in\\_PTW.pdf](http://www.skm.com/Modeling_a_UPS_in_PTW.pdf)>

## IES Handbook

Block, Judith, ed. IESNA Lighting Handbook. 9th ed. New York City: Illuminating Engineering Society of North America, 2000. Print.

# Lighting/Electrical References

## Luminaire Products

1. Alkco Lighting - <<http://www.alkco.com/>>
2. LiteControl - <<http://litecontrol.com/>>
3. Lithonia Lighting - <<http://www.lithonia.com/>>
4. Kurt Versen Lighting - <<http://www.kurtversen.com/>>
5. Deco Lighting - <<http://www.getdeco.com/>>
6. AllScape Lighting - <<http://www.allscape.net/new/index.html>>
7. Kim Lighting - <<http://www.kimlighting.com/>>
8. Lightolier - <<http://www.lightolier.com/home/home-swf.jsp>>
9. Louis Poulsen Lighting - <<http://www.louispoulsen.com/en-us.aspx>>

Lutron Control Products - <<http://www.lutron.com/Pages/Default.aspx>>

## Osram Sylvania

Osram Sylvania - Product Catalogs Home. Osram Sylvania. Web. <<http://www.sylvania.com/ProductCatalogs>>.

## Philips Advance Transformer

Product Catalog Datasheets. Philips Advance Transformer. Web. <<http://www.advance.philips.com/ecatalog/>>.

## Reflectance Research

1. Benjamin Moore Paint - Color Selection Tools and Resources for Design Professionals. Benjamin Moore Paints. Web. 2 Feb. 2011. <[http://www.benjaminmoore.com/bmpsweb/portals/bmps.portal?\\_nfpb=true&\\_pageLabel=fa\\_home](http://www.benjaminmoore.com/bmpsweb/portals/bmps.portal?_nfpb=true&_pageLabel=fa_home)>.
2. Resene Paints, Coatings, Wood Stains, Decorating Ideas, Custom Paint, Interior & Exterior Paint. Resene Paints. Web. 2 Feb. 2011. <<http://www.resene.co.nz>>.
3. J+J/Invision Broadloom and Modular Commercial Carpet. J+J/Invision. Web. 2 Feb. 2011. <[http://www.jj-invision.com/products/View\\_All.aspx](http://www.jj-invision.com/products/View_All.aspx)>.

## Shading System

Motorized Shades - ElectroShades - Bottom Up Shades. MechoShade Systems. Web. 9 Feb. 2011. <[http://www.mechoshade.com/motorizedshades/electro\\_bottomup.cfm](http://www.mechoshade.com/motorizedshades/electro_bottomup.cfm)>.

## SquareD Distribution Equipment

"Schneider Electric Home." Schneider Electric Is the Global Specialist in Energy Management - Schneider Electric United States. Web. 28 Feb. 2011. <<http://www.schneider-electric.us/sites/us/en/home.page>>.

## Wattstopper Wall Box Occupancy


"Product Type - Passive Infrared." Wattstopper. Web. 25 Mar. 2011. <[http://wattstopper.com/products/productline\\_list.html?category=37&type=Commercial](http://wattstopper.com/products/productline_list.html?category=37&type=Commercial)>.






# Equipment

SKM Model Equipment Schedule						
Lvl	Name	Location	Floorplan	Voltage	RATING	Series Rating
Switchgear	MDS-01A	W-P003	E2.0B-P	480/277V	5,000A	100 kAIC
	MDS-01B	W-P003	E2.0B-P	480/277V	5,000A	100 kAIC
	MDS-02A	N-P051	E2.0MD-LP	480/277V	2,000A	100 kAIC
	MDS-02B	N-P051	E2.0MD-LP	480/277V	2,000A	100 kAIC
	EMDS-1	N-P052	E2.0MD-LP	480/277V	2,000A	65 kAIC
	EDPS-1E1	N-P052	E2.0MD-LP	480/277V	800A	65 kAIC
	EDPS-1E2	N-P052	E2.0MD-LP	480/277V	800A	65 kAIC
	SDP-2B	W-P249	E2.2B-P	480/277V	1,000A	65 kAIC
	SDP-2D	N-P258	E2.2D-P	480/277V	1,000A	65 kAIC
	SDP-2D1	N-P238	E2.2E-P	480/277V	1,000A	65 kAIC
Switchboards	EDPS-3B	W-P338	E2.3B-P	208/120V	800A	65 kAIC
	EDPS-3D	N-P347	E2.3D-P	208/120V	800A	65 kAIC
	EDPS-M41	N-M401	E2.4C-P	480/277V	800A	65 kAIC
	EDPS-M42	N-M401	E2.4C-P	480/277V	800A	65 kAIC
	MDP-M41	N-M401	E2.4C-P	480/277V	1,000A	65 kAIC
	MDP-M42	N-M401	E2.4C-P	480/277V	1,000A	65 kAIC
	HL-3B	W-P338	E2.3B-P	480/277V	200A	14 kAIC Min.
	HMS-3B	W-P338	E2.3B-P	480/277V	100A	14 kAIC Min.
	LB-3B1/2	W-Q304	E4.3B	208/120V	225A	10 kAIC Min.
	LB-3B3/4	W-321	E4.3B	208/120V	225A	10 kAIC Min.
Level 3B	LB-3B5/6	W-337	E4.3B	208/120V	225A	10 kAIC Min.
	LB-3B7	W-Q304	E4.3B	208/120V	225A/MLO	10 kAIC Min.
	LBS-3B1/2	W-Q304	E4.3B	208/120V	225A	10 kAIC Min.
	LBS-3B3/4	W-321	E4.3B	208/120V	225A	10 kAIC Min.
	LR-3B	W-P338	E2.3B-P	208/120V	150A	10 kAIC Min.
	LR-3B5/6	W-337	E4.3B	208/120V	225A	10 kAIC Min.
	LS-3B	W-P338	E2.3B-P	208/120V	100A	10 kAIC Min.
	LB-3C1/2	W-Q302	E2.3C-P	208/120V	150A	10 kAIC Min.
	LB-3C1/2	N-Q307	E2.3C-P	208/120V	225A	10 kAIC Min.
	HL-3D	N-P347	E2.3D-P	480/277V	200A	14 kAIC Min.
Panelboards: Level 3	HM-3D	N-P347	E2.3D-P	480/277V	100A	14 kAIC Min.
	HMS-3D	N-P347	E2.3D-P	480/277V	100A	14 kAIC Min.
	LB-3D1/2	N-361	E4.3D	208/120V	175A	10 kAIC Min.
	LB-3D5/6	N-361	E4.3D	208/120V	175A	10 kAIC Min.
	LB-3D7/8	N-361	E4.3D	208/120V	175A	10 kAIC Min.
	LB-3D1/2	N-Q304	E4.3D	208/120V	225A	10 kAIC Min.
	LBS-3D5/6	N-361	E4.3D	208/120V	225A	10 kAIC Min.
	LR-3D1/2	N-P346	E2.3D-P	208/120V	225A	10 kAIC Min.
	LR-3D3/4	N-P346	E2.3D-P	208/120V	225A	10 kAIC Min.
	LS-3D	N-P347	E2.3D-P	208/120V	100A	10 kAIC Min.
Distribution Equipment	ATS-HS1	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	ATS-HS2	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	ATS-HS3	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	ATS-HS4	N-P052	E2.0MD-LP	800 A	4P-480V	65 kAIC
	TRN-SDP-2B	W-P249	E2.2B-P	300 kVA	480A-208V/120V	N/A
Level 2	TRN-SDP-2D	N-P258	E2.2D-P	300 kVA	480A-208V/120V	N/A
	TRN-SDP-2D1	N-P238	E2.2E-P	300 kVA	480A-208V/120V	N/A
	TRE-EDPS-3B	W-P338	E2.3B-P	225 kVA	480A-208V/120V	N/A
	TRE-EDPS-3D	N-P347	E2.3D-P	225 kVA	480A-208V/120V	N/A
	UPS-3D-1/2	N-361	E4.3D	50 kVA	N/A	Unknown
Mech. Equipment	UPS-3D-5/6	N-361	E4.3D	50 kVA	N/A	Unknown
	ACF-1	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
	ACF-2	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
	ACF-3	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
	ACF-4	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----
ACF-5	N-M401	100 hp	200 A MCP, 175 A FS	-----	-----	
ACF-6	N-M401	60 hp	110 A MCP, 100 A FS	-----	-----	
ACF-7	N-M401	60 hp	110 A MCP, 100 A FS	-----	-----	
ACF-8	N-M401	60 hp	110 A MCP, 100 A FS	-----	-----	





# Lighting/Electrical Appendices

## Depth Topic 1: SKM Analysis Summary




Fault Analysis Summary					
Bus Name	Voltage	Available Fault Current			
		3-Phase	X/R	LINE/GRND	X/R
EDPS-1E1	480	39353.3	3	8391.63	0.2
EDPS-1E2	480	38449.6	2.9	8364.93	0.2
EDPS-3B	208	8147.9	1.6	9238.12	1.6
EDPS-3D	208	9963.3	1.6	10713.51	1.6
EDPS-M41	480	26611.3	2.1	7238.23	0.3
EDPS-M42	480	32169.3	2.4	7817.41	0.3
EMDS-1	480	10039.0	4.9	1621.01	0.1
HL-3B	480	13108.6	1.6	5383.71	0.5
HL-3D	480	11810.3	1.2	4971.80	0.5
HM-3D	480	13304.3	1.6	5406.24	0.5
HMS-3B	480	15707.0	1.4	5858.97	0.4
HMS-3D	480	17537.7	1.4	6259.26	0.4
LB-3B1/2	208	7593.2	1.1	6792.20	1.2
LB-3B3/4	208	7756.9	1.1	6964.21	1.2
LB-3B5/6	208	7756.9	1.1	6964.21	1.2
LB-3B7	208	8104.7	1.2	7334.45	1.2
LB-3C1/2	208	4502.6	0.9	4019.60	1
LB-3D1/2	208	138.7	7.9	134.64	8.1
LB-3D5/6	208	138.7	7.9	134.64	8.1
LB-3D7/8	208	4508.2	0.9	4021.00	1
LBS-3B1/2	208	6467.5	1.2	6633.94	1.2
LBS-3B3/4	208	6467.5	1.2	6633.94	1.2
LBS-3D1/2	208	7560.1	1.2	7361.22	1.2
LBS-3D5/6	208	7560.1	1.2	7361.22	1.2
LR-3B5/6	208	7756.9	1.1	6964.21	1.2
LR-3C1/2	208	3773.0	0.8	3288.52	0.9
LR-3D1/2	208	6503.1	1.1	6244.65	1.2
LR-3D3/4	208	6503.1	1.1	6244.65	1.2
LS-3B	208	6746.9	1.1	7098.78	1
LS-3D	208	7936.7	1.1	7928.46	1
MDP-M41	480	18646.1	1.9	6337.24	0.4
MDP-M42	480	19033.2	1.9	6367.69	0.4
MDS-01A	480	57411.7	5.7	9248.60	0.1
MDS-01B	480	57406.8	5.7	9248.52	0.1
MDS-02A	480	44453.2	3.5	8669.88	0.2
MDS-02B	480	44450.1	3.5	8669.80	0.2
SDP-2B	208	10951.5	1.6	10647.34	1.7
SPD-2D	208	8645.7	1.4	9083.76	1.5
SDP-2D1	208	8574.7	1.3	9026.44	1.6

# Results





# Structural Appendices



3<sup>rd</sup> Floor

4<sup>th</sup> Floor

**3.25" LWT Concrete Topping on 3" Metal Deck**  
**4.5" NWT Concrete Topping on 3" Metal Deck**




SPAN	Lx ft	Ly ft	t in	w ksf	Wslab kip	Wbeams kip	NODE	Wi kip	Δ in	Wi.Δ <sup>2</sup>	P.Δ P=100 k	Tcalc sec	T(SAP) sec	Vel μ in/sec
SPAN-A	22.0	22.0	3.3	0.049	23.619	4.103	1	0.533	0.0012	0.0000	178.6212	0.0639		3916
- due to load at A13														
							2	0.902	-0.0195	0.0003				
							3	0.902	-0.0330	0.0010				
							4	0.902	-0.0195	0.0003				
							5	0.533	0.0012	0.0000				
							A1	0.902	0.0551	0.0027				
							A2	1.640	0.0596	0.0058				
							A3	1.640	0.0774	0.0098				
							A4	1.640	0.0596	0.0058				
							A5	0.902	0.0552	0.0027				
							A6	0.902	0.0913	0.0075				
							A7	1.640	0.2216	0.0805				
							A8	1.640	0.2886	0.1366				
							A9	1.640	0.2217	0.0806				
							A10	0.902	0.0914	0.0075				
							A11	0.902	0.0614	0.0034				
							A12	1.640	0.6814	0.7615				
							A13	1.640	1.7862	5.2335				
							A14	1.640	0.6818	0.7624				
							A15	0.902	0.0614	0.0034				
							A16	0.533	0.0052	0.0000				
							A17	0.902	0.0818	0.0060				
							A18	0.902	0.1219	0.0134				
							A19	0.902	0.0826	0.0062				
							A20	0.533	0.0051	0.0000				

SPAN	Lx ft	Ly ft	w ksf	Wslab kip	Wbeams kip	NODE	Wi kip	Δ in	Wi.Δ <sup>2</sup>	P.Δ P=100 k	Tcalc sec	T(SAP) sec	Vel μ in/sec
SPAN-A	22.0	22.0	0.049	23.619	4.510	1	0.549	0.0013	0.0000	160.6674	0.0609		3099
- due to load at A13													
						2	0.919	-0.0175	0.0003				
						3	0.919	-0.0295	0.0008				
						4	0.919	-0.0175	0.0003				
						5	0.549	0.0013	0.0000				
						A1	0.919	0.0470	0.0020				
						A2	1.657	0.0640	0.0068				
						A3	1.657	0.0981	0.0160				
						A4	1.657	0.0640	0.0068				
						A5	0.919	0.0470	0.0020				
						A6	0.919	0.0773	0.0055				
						A7	1.657	0.1908	0.0603				
						A8	1.657	0.2487	0.1025				
						A9	1.657	0.1908	0.0603				
						A10	0.919	0.0774	0.0055				
						A11	0.919	0.0525	0.0025				
						A12	1.657	0.6123	0.6212				
						A13	1.657	1.6067	4.2763				
						A14	1.657	0.6122	0.6209				
						A15	0.919	0.0526	0.0025				
						A16	0.549	0.0050	0.0000				
						A17	0.919	0.0907	0.0076				
						A18	0.919	0.1352	0.0168				
						A19	0.919	0.0905	0.0075				
						A20	0.549	0.0050	0.0000				



# Structural Appendices



CELLULAR BEAM INFORMATION			LOADING INFORMATION				EXPAND'D. SXN. PROP'S			
Job Name	TEST		Uniform Distributed Loads				Avg. wt.	57.00 plf		
Beam Mark #	LB1		Live Load	0 plf	Pre-comp %	0%	Anet	12.03 in <sup>2</sup>		
Span	22.000 ft		Dead Load	57 plf	Pre-comp %	85%	Agross	20.43 in <sup>2</sup>		
Spac. Left	11.000 ft		Concentrated Point Loads				lx net	2459 in <sup>4</sup>		
Spac. Right	11.000 ft		Load #	Magnitude	Dist from	Percent DL	Percent	lx gross	2760 in <sup>4</sup>	
Mat. Strength-Fy	50 ksi		(#)	(kips)	Lft. End (ft)	(%)	Pre-Comp.	lx critical	2546 in <sup>4</sup>	
Cellular Beam	LB30X57		P1	68.53	11.00	0%	0%	Min Sx net	161 in <sup>3</sup>	
Root Beams (T/B)	W21X57	W21X57	P2	0.00	0.00	0%	0%	Min Sx gross	181 in <sup>3</sup>	
d	21.06	21.06	P3	0.00	0.00	0%	0%	Min Sx critical	167 in <sup>3</sup>	
bf	6.555	6.555	P4	0.00	0.00	0%	0%	rx min	11.62 in	
tf	0.65	0.65	COMPOSITE INFORMATION				ly net	31 in <sup>4</sup>		
tw	0.405	0.405	Concrete & Deck:		Shear Studs:		Sy net	9.33 in <sup>3</sup>		
CELLULAR PARAMETERS:			conc. strength - fc' (psi)	4000	stud dia. (in)	3/4"	COMPOSITE SXN. PROP'S			
Min. Hole Diameter	15.99	in	conc. wt. - wc (pcf)	115	stud ht. (in)	5	n	11.758		
Max. Hole Diameter	27.97	in	conc. above deck - tc (in)	3 1/4	studs per rib	1	beffec.	66.000 in		
STD Hole Diameter Do	20.75	in	rib height - hr (in)	3	composite %	100%	Actr	18.243 in <sup>2</sup>		
STD Hole Spacing S	29.250	in	rib width - wr (in)	6	STUD SPACING:		N.A. ht.	26.901 In Steel		
Web Post Width "e"	8.500	in			29   29		ltr	5554 in <sup>4</sup>		
S / Do	1.41		RESULTS			WARNINGS				
Gross Depth "dg"	30.52	in	Failure Mode	Interaction	Status		leffec.	5554 in <sup>3</sup>		
dg / Do	1.471		Bending	0.993	OK		Sxconc	562.546 in <sup>3</sup>		
Cutting Loss	0.910		Web Post	0.659	OK		Sxsteel	206.478 in <sup>3</sup>		
dt top	4.887	in	Shear	0.446	OK		CONSTRUCTION BRIDGING			
dt bot	4.887	in	Concrete	0.387	OK		End Connection type	Double clip		
			Pre-Comp.	0.446	OK		Min. No. Of Bridging Rows	0		
			Overall	0.993	OK		Max. Bridging Spacing (ft)	41		
			DEFLECTION			Stnd "Do" & "S"		Find Lightest Cellular Beam		
			Pre-Composite Deflection	0.009	=L/29971		To Help Sheet			
			Live Load Deflection	0.195	=L/1357					




CELLULAR BEAM INFORMATION			LOADING INFORMATION				EXPAND'D. SXN. PROP'S			
Job Name	TEST		Uniform Distributed Loads				Avg. wt.	44.00 plf		
Beam Mark #	LB1		Live Load	1650 plf	Pre-comp %	0%	Anet	8.89 in <sup>2</sup>		
Span	22.000 ft		Dead Load	953 plf	Pre-comp %	85%	Agross	16.16 in <sup>2</sup>		
Spac. Left	11.000 ft		Concentrated Point Loads				lx net	1772 in <sup>4</sup>		
Spac. Right	11.000 ft		Load #	Magnitude	Dist from	Percent DL	Percent	lx gross	2032 in <sup>4</sup>	
Mat. Strength-Fy	50 ksi		(#)	(kips)	Lft. End (ft)	(%)	Pre-Comp.	lx critical	1847 in <sup>4</sup>	
Cellular Beam	LB30X44		P1	0.00	11.00	0%	0%	Min Sx net	118 in <sup>3</sup>	
Root Beams (T/B)	W21X44	W21X44	P2	0.00	0.00	0%	0%	Min Sx gross	135 in <sup>3</sup>	
d	20.66	20.66	P3	0.00	0.00	0%	0%	Min Sx critical	123 in <sup>3</sup>	
bf	6.5	6.5	P4	0.00	0.00	0%	0%	rx min	11.22 in	
tf	0.45	0.45	COMPOSITE INFORMATION				ly net	21 in <sup>4</sup>		
tw	0.35	0.35	Concrete & Deck:		Shear Studs:		Sy net	6.35 in <sup>3</sup>		
CELLULAR PARAMETERS:			conc. strength - fc' (psi)	4000	stud dia. (in)	3/4"	COMPOSITE SXN. PROP'S			
Min. Hole Diameter	15.69	in	conc. wt. - wc (pcf)	115	stud ht. (in)	5	n	11.758		
Max. Hole Diameter	27.44	in	conc. above deck - tc (in)	3 1/4	studs per rib	1	beffec.	66.000 in		
STD Hole Diameter Do	20.75	in	rib height - hr (in)	3	composite %	100%	Actr	18.243 in <sup>2</sup>		
STD Hole Spacing S	29.250	in	rib width - wr (in)	6	STUD SPACING:		N.A. ht.	27.929 In Steel		
Web Post Width "e"	8.500	in			22   22		ltr	4312 in <sup>4</sup>		
S / Do	1.41		RESULTS			WARNINGS				
Gross Depth "dg"	30.12	in	Failure Mode	Interaction	Status		leffec.	4312 in <sup>3</sup>		
dg / Do	1.452		Bending	0.402	OK		Sxconc	510.623 in <sup>3</sup>		
Cutting Loss	0.910		Web Post	0.507	OK		Sxsteel	154.404 in <sup>3</sup>		
dt top	4.687	in	Shear	0.380	OK		CONSTRUCTION BRIDGING			
dt bot	4.687	in	Concrete	0.178	OK		End Connection type	Double clip		
			Pre-Comp.	0.380	OK		Min. No. Of Bridging Rows	0		
			Overall	0.507	OK		Max. Bridging Spacing (ft)	38		
			DEFLECTION			Stnd "Do" & "S"		Find Lightest Cellular Beam		
			Pre-Composite Deflection	0.099	=L/2675		To Help Sheet			
			Live Load Deflection	0.091	=L/2914					





# Structural Appendices



Precast Panel Dimensions		
Panel Height	141.125	in.
Panel Depth	5	in.
Brick Depth at Face	0.75	in.
Flange Height	10	in.
Brick Height at Flange	0.5	in.
Flange Depth	15.75	in.
Panel Width	263.25	in.
Return Thickness	14	in.
Return Depth	10	in.
Return Height	121.125	in.
Volume Concrete	157.593	ft.3
Weight Concrete	23638.96	lb.
Volume Brick	18.52405	ft.3
Weight Brick	2222.886	lb.
(factored) Total	36206.58	lb.
(factored) Total with Planters	43930.29	lb.

Wind Force	
(factored)	50.992 psf.

Self Weight Check Upright		
Weight/in.	137.5369	lb./in.
Inertia of Panel	2032473	in.4
Moment	1191423	lb.in.
Stress	41.36329	psi.

Planter Gravity Check Upright		
Weight/in.	166.8767	lb./in.
Inertia of Panel	2032473	in.4
Moment	1445581	lb.in.
Stress	50.18705	psi.

Wind Check On Face		
Weight/in.	4.249333	lb./in.
Inertia of Strip	125	in.4
Moment	10578.86	lb.in.
Stress	211.58	psi.

Wind Check On Flange		
Weight/in.	24.98697	lb./in.
Inertia of Flange	2812.5	in.4
Moment	172855.3	lb.in.
Stress	460.9476	psi.

Self Weight Check Prostrate		
Weight/in.	8.166667	lb./in.
Inertia of Strip	125	in.4
Moment	14730.64	lb.in.
Stress	294.6128	psi.

Planter Gravity Check Prostate		
Weight/in.	10.79167	lb./in.
Inertia of Strip	125	in.4
Moment	19465.49	lb.in.
Stress	389.3098	psi.

Cantilever Check on Flange Self Weight		
Weight/in.	15.16667	lb./in.
Inertia of Flange	1000	in.4
Moment	758.3333	lb.in.
Stress	3.791667	psi.

Cracking Stress	
	477.2971 psi (factored)



# Structural Appendices

Corbel Dimensions		Required Steel		Results		
L1=	6 in.	Vu.max=	189 k.	As.prov=	0.88 in.2	OK
L2=	6 in.	As.req=	0.44 in.2	Bar Size=	6	
b=	14 in.	$\mu_e$ =	3.4	(#) Bars=	2	
h=	18 in.	As.req=	0.32 in.2	Ah.prov=	0.4 in.2	OK
d=	16.5 in.	As.min=	0.77 in.2	Bar Size=	4	
a=	5.5 in.	As=	0.77 in.2	(#) Bars=	2	
$\lambda$ =	1	Ah=	0.30 in.2			
$\mu$ =	1.4	Ldh=	0.00 in.			
$\beta$ =	1					
$\phi$ =	0.75					
f'c=	5000 psi.					
fy=	60000 psi.					
Vu=	36.2 k.					
Nu=	7.2 k.					

Connection Dimensions			Required Steel			Results			
b=	14 in.		As.1=	0.33 in.2		As.prov=	0.4 in.2		OK
h=	36 in.		$\mu_e$ =	3.4		Bar Size=	4		
d=	35 in.		As.2=	0.32 in.2		(#) Bars=	2		
a=	7 in.		As.req=	0.33 in.2		Ash.prov=	0.88 in.2		OK
$\lambda$ =	1		Ash.req=	0.805 in.2		Bar Size=	6		
$\mu$ =	1.4		An=	0.161 in.2		(#) Bars=	2		
$\phi$ =	0.75		Ah.req=	0.083 in.2		Av.prov=	0.11 in.2		OK
f'c=	5000 psi.		Vc=	69.3 k.		Bar Size=	3		
fy=	60000 psi.		Av.min=	0.001 in.2		(#) Bars=	1		
Vu=	36.2 k.		$\phi V_n$ =	61.87 k.	OK	Ah.prov=	0.11 in.2		OK
Nu=	7.2 k.		Ld.As=	16.97 in.		Bar Size=	3		
						(#) Bars=	1		









# Structural Appendices

TABLE: Element Forces - Frames

Frame	Station	OutputCase	P	V2	V3	M2	M3	Section	Length	Length	Interaction
Text	in	Text	Kip	Kip	Kip	Kip-in	Kip-in		in	ft	
CL(T2)1	0	All Factored Loads	-2566.34	2.013	-0.485	-1.1E-14	-2.3E-13	W14X283	240	20	0.87
CL(T2)1	120	All Factored Loads	-2562.6	2.013	-0.485	58.154	-241.525	W14X283	240	20	0.88
CL(T2)1	240	All Factored Loads	-2558.87	2.013	-0.485	116.307	-483.049	W14X283	240	20	0.90
CL(T2)2	0	All Factored Loads	-763.225	-0.891	0.158	-1.4E-14	-1.1E-13	W14X132	240	20	0.59
CL(T2)2	120	All Factored Loads	-761.641	-0.891	0.158	-18.934	106.876	W14X132	240	20	0.60
CL(T2)2	240	All Factored Loads	-760.057	-0.891	0.158	-37.868	213.751	W14X132	240	20	0.61
CL(T2)3	0	All Factored Loads	-2577.54	-1.544	-0.485	116.307	-35.398	W14X283	240	20	0.89
CL(T2)3	120	All Factored Loads	-2573.8	-1.544	-0.485	174.461	149.839	W14X283	240	20	0.89
CL(T2)3	240	All Factored Loads	-2570.07	-1.544	-0.485	232.615	335.076	W14X283	240	20	0.90
CL(T2)4	0	All Factored Loads	-677.764	-2.592	1.081	155.089	-482.068	W14X132	240	20	0.59
CL(T2)4	120	All Factored Loads	-676.18	-2.592	1.081	25.314	-170.969	W14X132	240	20	0.54
CL(T2)4	240	All Factored Loads	-674.596	-2.592	1.081	-104.46	140.13	W14X132	240	20	0.55
CL(T2)5	0	All Factored Loads	-2460.79	-14.624	29.091	2470.084	-1847.08	w14x311	216	18	0.95
CL(T2)5	108	All Factored Loads	-2457.43	-14.624	29.091	-671.753	-267.677	w14x311	216	18	0.78
CL(T2)5	216	All Factored Loads	-2454.07	-14.624	29.091	-3813.59	311.725	w14x311	216	18	0.98
CL(T2)6	0	All Factored Loads	-565.966	-8.097	7.933	824.811	-605.656	W14X132	216	18	0.61
CL(T2)6	108	All Factored Loads	-564.54	-8.097	7.933	-31.908	268.841	W14X132	216	18	0.44
CL(T2)6	216	All Factored Loads	-563.114	-8.097	7.933	-888.628	1143.338	W14X132	216	18	0.67
CL(T2)7	0	All Factored Loads	-1915.77	36.244	99.693	5802.812	1608.581	w14x311	216	18	1.00
CL(T2)7	60	All Factored Loads	-1913.91	36.244	99.693	821.252	1433.913	w14x311	216	18	0.67
CL(T2)7	120	All Factored Loads	-1912.04	36.244	99.693	-5160.31	-740.755	w14x311	216	18	0.92



# Mechanical Appendices

Utility Information from OPP	
Utility	Cost (\$)/Unit
Purchased Steam	\$9.85/1000 lbm (\$0.82/therm)
Purchased Chilled Water	\$0.22/ton-hr (\$1.83/therm)
Electric Consumption	\$0.07517/kWh
Electric On Peak	\$1.09/kW
Water (N/A in current model)	\$3.32/1000 gallons

ASHRAE Weather Data Used			
ASHRAE Altoona, PA	Summer Design Condition: Cooling 0.4%	Winter Design Condition: Heating 99.6%	Chilled Beam: Dehumidification 0.4%
Outside Air Dry Bulb (°F)	4.7	88.5	-
Mean Coincident Wet Bulb (°F)	-	72.0	77.7
Humidity Ratio (Grains/lb)	-	85.7	118.0
Dew Point (°F)	-	-	70.4

OPP Design Conditions			
Area	Season	Indoor	Outdoor
Comfort Areas	Summer	75°F DB, 50% RH	90°F DB, 74°F WB
	Winter	75°F DB, 50% RH	0°F DB
Labs	Summer	Lab specific	92°F DB, 74°F WB
	Winter		0°F DB
Animal Holding	Summer	64-79°F DB <sup>1</sup> , 30-70% RH <sup>1</sup>	95°F DB, 75°F WB
	Winter		-10°F DB



## Mechanical Appendices




$$3,000 \text{ GPM}_{\text{BeamLoop}} * (62^{\circ}\text{F} - 58^{\circ}\text{F}) * 500 = (1,500 \text{ GPM}_{\text{AHU}} * (58^{\circ}\text{F} - 56^{\circ}\text{F}) * 500) + (187.5 \text{ GPM}_{\text{Campus}} * (58^{\circ}\text{F} - 42^{\circ}\text{F}) * 500)$$

# Mechanical Appendices

Occupant Ventilation Examples: Student/Office Areas				
People	Occupant Latent Load Ventilation Btu/hr	CFM Needed to Offset Latent 50% RH	CFM Needed to Offset Latent 52% RH	CFM Needed to Offset Latent 53% RH
4.8	952	200	140	127
1.1	220	46	32	29
1.8	361	76	53	48




# Mechanical Appendices




# Mechanical Appendices


## Annual Electricity Costs



## Annual Steam Costs




## Annual Chilled Water Costs






# Mechanical Appendices

## Existing Design Energy Use Breakdown



## Proposed Design Energy Use Breakdown



# Mechanical Appendices

Bin Data for Williamsport, PA		
Temperature (°F)	Enthalpy (BTU/lbm)	Hours of Occurrence
-13.0	-3.1	1
-8.0	-1.9	4
-3.0	0.0	10
2.0	1.4	23
7.0	2.6	59
12.0	4.2	107
17.0	5.5	191
22.0	7.2	322
27.0	9.0	528
32.0	10.6	846
37.0	12.6	844
42.0	14.3	689
47.0	16.6	652
52.0	18.7	647
57.0	21.4	707
62.0	24.5	747
67.0	27.1	762
72.0	29.3	630
77.0	30.7	456
82.0	32.3	316
87.0	33.9	151
92.0	35.6	52
97.0	36.5	12

Entering Coil Conditions			
Enthalpy Wheel Only: VAV, 100 fpm		Dual Wheel: Neutral Air+ Chilled Beams, 80 fpm	
Temperature (°F)	Enthalpy (BTU/lbm)	Temperature (°F)	Enthalpy (BTU/lbm)
36.6	14.4	27.7	12.6
38.7	14.9	29.8	13.1
40.9	15.7	32.0	13.9
43.0	16.3	34.1	14.5
45.2	16.8	36.3	15.0
47.3	17.5	38.4	15.7
49.5	18.1	40.6	16.3
51.6	18.8	42.7	17.0
53.8	19.6	44.9	17.8
55.9	20.3	47.0	18.5
58.1	21.1	49.2	19.3
60.2	21.9	51.3	20.1
62.4	22.9	53.5	21.1
64.5	23.7	55.6	21.9
66.7	24.9	57.8	23.1
68.8	26.2	60.8	25.3
71.0	27.4	62.9	26.5
76.0	30.4	65.1	27.4
78.1	31.1	67.2	28.0
80.3	31.7	69.4	28.7
82.4	32.4	71.5	29.4
84.6	33.2	73.7	30.1
86.7	33.5	75.8	30.5

$$\left(\frac{Btu}{hr}\right) = 1.1 * (Bin\ Temperature - 52^{\circ}F) * CFM * Hours\ of\ Occurrence$$

$$\frac{Btu}{hr} = 4.5 * (Bin\ Enthalpy - 21.5) * CFM * Hours\ of\ Occurrence$$

$$\frac{Btu}{hr} = 4.5 * (21.5 - Bin\ Enthalpy) * CFM * Hours\ of\ Occurrence$$

$$Therms = \frac{\frac{Btu}{hr}}{10,000}$$



# Mechanical Appendices

Fume Hood Position- Variable Air Volume Factor				
Percent Open	Percent Bin	Hour Occurrence	Percent Occurrence	Bin*% Occurrence
<b>0-10 (Minimum)</b>	0.05	5100	0.58	0.03
<b>11-20</b>	0.15	0.00	0.00	0.00
<b>21-30</b>	0.25	0.00	0.00	0.00
<b>31-40</b>	0.35	0.00	0.00	0.00
<b>41-50</b>	0.45	0.00	0.00	0.00
<b>51-60</b>	0.55	2384	0.27	0.15
<b>61-70</b>	0.65	0.00	0.00	0.00
<b>71-80</b>	0.75	0.00	0.00	0.00
<b>81-90</b>	0.85	0.00	0.00	0.00
<b>91-100</b>	0.95	1276	0.15	0.14
<b>Totals</b>		8760	1.00	0.32

Fume Hood Exhaust Comparison				
Design	Fan Type	CFM	Static Pressure	HP
<b>Existing 100 fpm</b>	(3) Greenheck Vektor MD-33	21,400	5"	50
	(3) Greenheck Vektor MD-33	11,600	5"	25
<b>Proposed 80 fpm</b>	(3) Greenheck Vektor MD-33	17,200	5"	40
	(3) Greenheck Vektor MD-33	9,280	5"	15



Summary of Fume Hood Makeup Air Costs and Savings		
Metric	100 fpm VAV	80 fpm ACBs
<b>Cooling/Dehumidification</b>	\$233,356.06	\$122,597.17
<b>Heating</b>	\$6,479.29	\$13,447.52
<b>Fan</b>	\$110,512.71	\$81,042.65
<b>Humidification</b>	\$17,610.24	\$33,343.69
<b>CAV Operation Costs</b>	\$367,958.30	\$250,431.03
<b>VAV Multiplier for Operation</b>	0.32	0.32
<b>Adjusted Operation Costs</b>	\$116,704.95	\$79,428.95
<b>Percent Savings</b>		31.94%

# Mechanical Appendices



Price Comparison of Fume Hoods						
Fume Hood Size (feet)	Existing Fume Hoods: Labconco Premier Fume Hoods			Proposed Low Flow Fume Hoods: Labconco XStream Fume Hoods		
	Unit Price	Quantity	Total Price	Unit Price	Quantity	Total Price
4	\$7,360.00	2	\$14,720.00	\$7,480.00	2	\$14,960.00
5	\$8,380.00	14	\$117,320.00	\$8,650.00	14	\$121,100.00
6	\$8,920.00	52	\$463,840.00	\$9,270.00	52	\$482,040.00
8	\$12,350.00	1	\$12,350.00	\$13,220.00	1	\$13,220.00
<b>Total</b>			\$608,230.00	<b>Total</b>		\$631,320.00
Model information on low flow fume hoods can be found in Appendix 4.H						



# Mechanical Appendices





# Mechanical Appendices







# Mechanical Appendices



# Mechanical Appendices

Model Parameters	
Turbulence Model	KECHEN
Differencing Scheme	Hybrid
Energy Equation	Temperature
Iterations	4,000
Ambient Temperature	25°C
Grid Size	55 x 45 x 42





### CFD File Results: Residuals

Scenario	Mass Residual	Temperature Residual	KE Residual	EP Residual	Simulation Length (hr:min)
100 fpm, 18" Sash	1.01%	0.01%	11.6%	0.6%	1:59
80 fpm, 18" Sash	0.63%	0.009%	12.5%	0.1%	2:05
100 fpm, 30" Sash	1.60%	0.01%	12.5%	0.9%	2:04
80 fpm, 30" Sash	1.11%	0.01%	9.8%	0.45%	2:06

## Mechanical Appendices

### CFD Results: Face Velocities and Concentrations

Scenario	Specified Outlet CFM	Supplied Inlet CFM	Face Velocity	Concentration: Face	Percent Increase
100 fpm, 18" Sash	675	600	0.5037 m/s	0.11287	-
80 fpm, 18" Sash	540	600	0.4107 m/s	0.12898	14.2%
100 fpm, 30" Sash	1125	1000	0.4215 m/s	0.11856	-
80 fpm, 30" Sash	900	800	0.3586 m/s	0.13994	18.0%



# Mechanical Appendices

Detailed Geometries						
Element	Length	Width	Height	Location		
	$\Delta x$ (m)	$\Delta y$ (m)	$\Delta z$ (m)	x (m)	y (m)	z (m)
Room	3.3528	3.218	3.3528	-	-	-
Human	0.5	0.5	1.89	2.48	1.21	0.0
Table	1.0668	0.853	1.0668	0.579997	0.0	0.0
Fume Hood Base	1.4	0.853	1.0668	1.9528	0.0	0.0
Fume Hood Wall1	0.0	0.853	2.0	1.9528	0.0	0.0
Fume Hood Wall2	0.0	0.853	2	3.3528	0.0	0.0
Fume Hood Sash	1.4	0.0	0.48	1.9528	0.853	1.52
Fume Hood Top	1.4	0.853	0.1	1.9528	0.0	2.00
Table (2)	3.3528	0.609759	1.0668	0.0	2.608241	0
Cabinet	0.914630	0.304800	0.914630	2.0	2.9132	1.6
Wallboard	1.544630	0.075	1.15	0.0	3.143	1.429996
General Exhaust	0.609	0.609	0.0	2.0	2.0	3.3528
Ceiling Diffuser	0.15225	0.15225	0.15225	Varies		
Contaminant Inlet	0.335280	0.3048	0.0	2.557516	0.49	1.06685
Fume Hood Outlet	1.4	0.853	0.0	1.952800	0.0	2