


# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Thesis Final Presentation



# Presentation Outline

- **Introduction**



- **Facility Information**
- Mechanical Information
- Goals
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Facility Information

Size:	186,000 SF
Location:	Fort George G. Meade, MD
Owner:	Army Corps of Engineers
Architect:	HOK
Engineers:	AECOM   HSMM
Occupancy:	24/7 Operation, Television Studios, Data Center
Completion Date:	September 2011



# Presentation Outline

## •Introduction

- Facility Information
- Mechanical Information
- Goals
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

## DMA Building


Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option

# Mechanical Information

Air Delivery System:	Variable Air Volume
Chilled Water System:	(3) 500 Ton Water Cooled Chillers
Distribution System:	Primary/Secondary Flow
Hot Water System:	(3) 3000 MBH Condensing Boilers
Control System:	Direct Digital Control using BACnet
Waterside Economizers:	Used for Data Center
Airside Economizers:	Used in AHU's



# Presentation Outline

- **Introduction**

- Facility Information
- Mechanical Information

- **Goals**


- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

**Goal:**

Minimize Costs Spent on Energy  
Consumption, Making the Building Less  
Expensive and More Efficient to Operate



# Presentation Outline


- Introduction
- CHP Analysis**
  - Concept**
    - Energy Cost Savings
    - Payback Period
    - Sensitivity Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Combined Heat & Power

Electrical vs. Thermal Loads




### Electric

- 1.8 MW Base Load
- 2.2 MW Peak Load

### Thermal (Heating & Cooling)

- 4,900 MBH Base Load
- 9,200 MBH Peak Load



# Presentation Outline



- Introduction
- CHP Analysis**
  - Concept**
    - Energy Cost Savings
    - Payback Period
    - Sensitivity Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

## DMA Building

Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option



# Presentation Outline

- Introduction
- CHP Analysis**
  - Concept**
    - Energy Cost Savings
    - Payback Period
    - Sensitivity Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

## DMA Building


Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option

### CHP Options

System	Engine Type	Options	Electric Production	Load	Cooling	Heat Source
A	<b>Internal Combustion</b>	-	2390 kW	100%	800 Ton <b>Absorption</b> Chiller	Waste Heat + Boiler
B		-	2390 kW	100%	(2) 500 Ton <b>Electric</b> Chillers	Waste Heat Only
C		-	2390 kW	100%	700 Ton <b>Absorption</b> Chiller and a 300 ton <b>Electric</b> Chiller	Waste Heat Only
D		-	2390 kW	Load-Following	800 Ton <b>Absorption</b> Chiller	Waste Heat + Boiler
E		-	2390 kW	Load-Following	700 Ton <b>Absorption</b> Chiller and a 300 ton <b>Electric</b> Chiller	Waste Heat Only
F		-	1801 kW	100%	800 Ton <b>Absorption</b> Chiller	Waste Heat +Boiler
G	<b>Turbine</b>	-	1200 kW	100%	800 Ton <b>Absorption</b> Chiller	Waste Heat Only
H		Back-Pressure Steam Turbine	1904 kW	100%	800 Ton <b>Absorption</b> Chiller	Waste Heat +Boiler
I		Back-Pressure Steam Turbine	1904kW	100%	400 Ton <b>Absorption</b> Chiller and a 500 ton <b>Electric</b> Chiller	Waste Heat +Boiler



# Presentation Outline



- Introduction
- CHP Analysis**
  - Concept**
    - Energy Cost Savings
    - Payback Period
    - Sensitivity Analysis
  - Electrical Analysis
  - Acoustical Analysis
  - Thermal Storage Analysis
  - System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

## DMA Building

Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option





# Presentation Outline



- Introduction
- CHP Analysis**
  - Concept**
    - Energy Cost Savings
    - Payback Period
    - Sensitivity Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

## DMA Building

Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option



# Presentation Outline



- Introduction
- CHP Analysis**
  - Concept
    - Energy Cost Savings
    - Payback Period
    - Sensitivity Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

## DMA Building

Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option





# Presentation Outline


- Introduction
- CHP Analysis**
  - Concept
  - Energy Cost Savings**
  - Payback Period
  - Sensitivity Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option



## Yearly Energy Cost Savings by System




# Presentation Outline


- Introduction
- CHP Analysis**
  - Concept
  - Energy Cost Savings
  - Payback Period**
  - Sensitivity Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option



## Payback Period



# Presentation Outline


- Introduction
- CHP Analysis**
  - Concept
  - Energy Cost Savings
  - Payback Period
  - Sensitivity Analysis**
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD



**Pavel Likhonin**  
Mechanical Option

## Sensitivity Analysis

System E Payback with Increasing Electricity Costs Only



System E Payback with Increasing Electricity and Natural Gas Costs



# Presentation Outline




- Introduction
- CHP Analysis
- Electrical Analysis**
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Electrical Interface for CHP

- The generator switchboard and the breakers were sized based on current electrical design
- Redundant Automatic Transfer Switches were added to critical equipment
  - Data Center
  - Fire Pump





# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis**
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Acoustical Analysis




# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis**
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Acoustical Analysis



•**Double 8" Concrete filled CMU wall**

•**8" CMU wall, and 8" Concrete wall**

•**8" CMU wall and a Metal Stud wall with insulation**

•**8" CMU wall and a Metal Stud, with no insulation**



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis**
  - Concept**
  - Energy Cost Savings
  - Payback Period
  - Sensitivity Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions



**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Thermal Storage

- Peak Shaving Strategy for:
  - Ice Storage Chilled
  - Water Storage

Ice storage produced negative savings from this analysis due to inefficiency of making ice and low electric rates.



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis**
  - Concept
  - Energy Cost Savings**
  - Payback Period
  - Sensitivity Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD


**Pavel Likhonin**  
Mechanical Option

## Thermal Storage

- Peak demand was determined on a monthly basis.
- On-Peak to Off-Peak shift was determined on a daily basis.

### Chilled Water Storage Savings

Demand Savings:	\$3,617.22
On-Peak Savings:	\$7,025.21
<b>Total Yearly Savings:</b>	<b>\$10,643.43</b>



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis**
  - Concept
  - Energy Cost Savings
  - Payback Period**
  - Sensitivity Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions


**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Simple Payback Period

- Initial Investment was determined based on a 3,500 Ton-hr, 400,000 Gallon Tank and required accessories such as pumps, piping, etc.
- Due to N+1 Redundancy requirements, one chiller/cooling tower could be removed and the remaining chillers/cooling towers have to be upsized to 600 tons.
- Savings from one less chiller can be used to pay for the chilled water storage tank

Initial Investment:	\$173,666
Simple Payback Period:	16.32 Years




# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- **Thermal Storage Analysis**
  - Concept
  - Energy Cost Savings
  - Payback Period
  - **Sensitivity Analysis**
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions


**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option



## Thermal Storage

- Exponential Decline in the payback period
  - As Electricity Rates increase, the payback period decreases
- 16.3 years to  
12.4 years at a  
10% increase



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis

## •System Optimization Analysis

- Thermal Storage & CHP
  - Intro/Energy Cost Savings
  - Initial Investment/Payback Period
- Data Center Chiller
- DOAS
- Conclusion
- Acknowledgements
- Questions

## DMA Building

Fort George G. Meade, MD

## Pavel Likhonin


Mechanical Option

## CHP Integrated with Thermal Storage

- CHP System A was used for this System Optimization Analysis
  - ☐ This system had the largest amount of wasted heat, which makes it a good candidate for integration with thermal storage.
- Integrating thermal storage into a CHP system produced slightly better results than thermal storage on its own.

Yearly Energy Cost Savings:

**\$11,644**



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis

## •System Optimization Analysis

### •Thermal Storage & CHP

- Intro/Energy Cost Savings

### •Initial Investment/Payback Period

- Data Center Chiller
- DOAS
- Conclusion
- Acknowledgements
- Questions

## DMA Building

Fort George G. Meade, MD


## Pavel Likhonin

Mechanical Option

- Due to a smaller tank, and slightly larger yearly savings, the simple payback period for thermal storage was around

10.6 Years

Initial Investment for Thermal Storage with CHP	
350,000 Gallon Tank	\$ 354,200.00
300 Feet of 5" Pipe	\$ 10,500.00
300 Feet of 2" Insulation for 5" Pipe	\$ 5,874.00
(2) 15 HP Pumps	\$ 10,220.00
One Less (500 Ton) Chiller	\$ (293,062.50)
One Less (500 Ton) Cooling Tower	\$ (50,472.80)
Increasing Size of Original Chiller (500 to 650 tons)	\$ 71,200.00
Increasing Size of Original Towers (500 to 650 tons)	\$ 14,950.00
Total	\$ 123,408.70



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis

## •System Optimization Analysis


- Thermal Storage & CHP
- Data Center Chiller
  - Concept
  - Energy Cost Savings/Payback Period
- DOAS
- Conclusion
- Acknowledgements
- Questions

## DMA Building


Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option



### Dedicating a Chiller to the Data Center



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis

## •System Optimization Analysis

- Thermal Storage & CHP
- Data Center Chiller
  - Concept
  - Energy Cost Savings/Payback Period
- DOAS
- Conclusion
- Acknowledgements
- Questions

## DMA Building Fort George G. Meade, MD


## Pavel Likhonin Mechanical Option

Even with higher pumping costs, the total energy savings from running a chiller at higher temps was substantial

### Cooling Cost of the Data Center

Temperature	MMBTU/year	Savings \$/yr
44° F	15137.0	-
55° F	14065.4	<b>\$28,155.00</b>
60° F	13046.8	\$54,946.00

- Initial Investment for dedicating a chiller only involved adding in a few valves, (2) pumps, and some piping.
- The simple payback period calculated for running a chiller at 55° F was **less than a year.**





# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis

## •System Optimization Analysis


- Thermal Storage & CHP
- Data Center Chiller
- DOAS
- Conclusion
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option


## DOAS

- DOAS paralleled with Chilled Beams was modeled in TRACE 700 for annual energy and cost savings
- Only lower energy density areas were modeled as DOAS with Chilled Beams



- Annual Energy Savings:
- Annual Cost Savings:

1,913 x 10<sup>6</sup> [BTU/yr]  
**\$46,949**



# Presentation Outline


- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion**
- Acknowledgements
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Conclusion

CHP System E Yearly Savings:	<b>\$578,552</b>
Dedicated Chiller to Data Center @ 55° F:	<b>\$28,155</b>
Chilled Water Storage W/CHP System A Savings:	<b>\$11,644</b>
Chilled Water Storage Yearly Savings:	<b>\$10,643</b>
DOAS (Office) Yearly Savings:	<b>\$46,949</b>



# Presentation Outline


- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements**
- Questions

**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

## Acknowledgements:

Special Thanks To:  
**All the AE Faculty**  
&  
**Family and Friends**



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions**


## DMA Building

Fort George G. Meade, MD

## Pavel Likhonin

Mechanical Option

### Questions



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions

## DMA Building Fort George G. Meade, MD

## Pavel Likhonin Mechanical Option


Initial Investment by CHP System	
System	Cost
A	\$ 2,754,407.05
B	\$ 2,483,717.55
C	\$ 2,478,387.55
D	\$ 2,800,156.55
E	\$ 2,439,842.55
F	\$ 2,381,676.53

Wall Type	Total Cost
Total: Additional 8" Concrete	\$14,981.44
Total: Additional metal stud wall with insulation	\$28,731.25
Total: Additional metal stud wall, no insulation	\$14,498.80
Total: Additional block wall	\$28,085.95

Initial Investment for Thermal Storage	
400,000 Gallon Tank	\$ 382,800.00
300 Feet of 5" pipe	\$ 10,500.00
300 Feet of 2" Insulation for 5" Pipe	\$ 5,874.00
(2) 15 HP pumps	\$ 10,220.00
One Less Chiller	\$ (293,062.50)
One Less Cooling Tower	\$ (50,472.80)
Increasing size of original Chillers	\$ 94,648.00
Increasing size of original Towers	\$ 13,160.00
<b>Total</b>	<b>\$ 173,666.70</b>

Initial Investment for Thermal Storage with CHP	
400,000 Gallon Tank	\$ 354,200.00
300 Feet of 5" Pipe	\$ 10,500.00
300 Feet of 2" Insulation for 5" Pipe	\$ 5,874.00
(2) 15 HP Pumps	\$ 10,220.00
One Less Chiller	\$ (293,062.50)
One Less Cooling Tower	\$ (50,472.80)
Increasing Size of Original Chiller	\$ 71,200.00
Increasing Size of Original Towers	\$ 14,950.00
<b>Total</b>	<b>\$ 123,408.70</b>

System E Payback with Increasing Natural Gas Costs Only



# Presentation Outline

- Introduction
- CHP Analysis
- Electrical Analysis
- Acoustical Analysis
- Thermal Storage Analysis
- System Optimization Analysis
- Conclusion
- Acknowledgements
- Questions


**DMA Building**  
Fort George G. Meade, MD

**Pavel Likhonin**  
Mechanical Option

CO <sub>2</sub> e Savings when compared to Grid							
		A	B	C	D	E	F
IC Engine	kWh	20,936,400.00	20,982,933.93	20,936,400.00	16,673,858.17	17,305,591.92	15,776,760.00
	BTU	74,893,389,355.47	71,635,736,437.02	71,476,869,600.00	70,082,301,286.29	59,081,290,819.32	53,861,858,640.00
	CO <sub>2</sub> e (lb)	10,260,394.34	9,814,095.89	9,792,331.14	9,601,275.28	8,094,136.84	9,011,793.30
Grid	kWh	18,602,443	18,602,443	18,602,443	18,602,443	18,602,443	18,602,443
	CO <sub>2</sub> e (lb)	33,856,445.42	33,856,445.42	33,856,445.42	33,856,445.42	33,856,445.42	33,856,445.42
	Savings (lb)	23,596,051.08	24,042,349.53	24,064,114.29	24,255,170.15	25,762,308.58	24,844,652.12

- Equivalent of removing 1,916 cars!
- Spark Gap: \$18.99
- O&M costs from EPA.gov: \$0.005/kWh
- Assumed 40% Elect. Efficiency at 75% load. From manufacturer, full load electrical efficiency is 42.6%
- System E never drops below 75% of the load, making load following very efficient
- Thermal to Electric Ratio of 0.85 to 1.25 during the peak summer months

Figure 1. Part Load Efficiency Performance



Source: Caterpillar, EEA/BCF