

Army Reserve Center Newport, Rhode Island



Technical Report Two: Building and Plant Energy Analysis Report

Alexander Hosko
Advisor: Dr. Treado
October 4, 2010

Table of Contents

Executive Summary	3
Mechanical Systems Overview	3
Design Load Estimation	5
Outdoor/Indoor Design Conditions	5
Airflow	5
Building Construction	5
Block Load Method	6
Lighting	7
Occupancy	7
Modeled Versus Designed	7
Annual Energy Consumption and Operating Costs	9
Energy Usage	9
Schedules	11
Fuel Costs	11
Equipment Performance Characteristics	12
Compare to Actual Energy Analysis	12
Emissions	14
References	16
Appendix A	17
Appendix B	21

List of Figures and Tables

Table 1 – Construction of Building	6
Table 2 – Wall Height, Floor to Floor Height, Plenum Height	6
Table 3 – Modeled Versus Designed Energy Use	8
Table 4 – Energy Consumption	9
Table 5 – Schedule	11
Table 6 – Total Cost of Energy Consumption	11
Table 7 – Equipment Performance Characteristics	12
Table 8 – Designed Energy Use	13
Table 9 – Percent Electricity Generation by Energy Type	15
Table 10 – Total Pollution from Electrical Use	15
Table 11 – Total Pollution from Natural Gas Use	15
Figure 1 – Natural Gas Use by Month	10
Figure 2 – Electricity Use by Month	10
Figure 3 – NERC Interconnections	14

Executive Summary

The purpose of this report is to estimate the design loads, to determine the annual energy consumption, and to determine the operating costs of the Army Reserve Center. To model the Army Reserve Center, a block load estimate was performed using Trace 700. The information for the model was taken from the design documents. Assumptions were made when information was not provided or the information was unable to be applied because a block load estimate was used as opposed to the space-by-space method.

According to the model created in Trace 700, the Army Reserve Center consumes 1915 MMBtu/year of energy compared to the 1137 MMBtu/year that was determined by the designed engineer. Another alternative by the design engineer found there to be 1760 MMBtu/year, however, this was not used in the design. The total cost to operate the Army Reserve Center was found to be \$48,700 per year which translates to \$0.83/square foot.

There were several discrepancies between the design documents and the modeled energy usage of the building. The main difference was the energy for lighting in the model compared to the design. The design called for 281 MMBtu/year which is less than three times what the model predicted at 863 MMBtu/year. Both of the schedules are the same so it is not due to a schedule difference. However, it could be because natural lighting is considered in the design, but an average of 0.71 W/ft² was used in the model regardless of the number or size of windows in the space.

Another reason for the differences was that block load was used as opposed to the space-by-space method. Many of the smaller rooms in the building were treated as part of the block. For example, several smaller rooms were either not ventilated or placed on ductless split systems. These rooms did not receive air from any of the main three air handling units. However, they were part of the block and were thus placed on one of the air handling units in the analysis.

Mechanical Systems Overview

The Army Reserve Center contains three air handling units. All three air handling units are located in mechanical rooms on the second floor. AHU-1 serves the first floor offices, is of the variable air volume type, and provides 3700 CFM of supply air which is 24% outside air. AHU-2 serves the second floor, is also of the variable air volume type, and provides 13,200 CFM of supply air which is 18% outside air. AHU-3 serves the auditorium, is of the constant volume type, and provides 2100 CFM of supply air which is 64% outside air. The rest of the ventilation for several other spaces on the first floor is done using small unit ventilators. Each air handling

unit is manufactured by Trane and contains a supply fan, return fan, cooling coil, heating coil, filter, and enthalpy economizer.

The heating accounts for 198 MMBtu/year which is 10.3% of the total energy used in the Army Reserve Center. This comes mainly from the two boilers present in the building. Both boilers have 959 MBH of heating capacity, are manufactured by AERCO, have enter water temperatures of 100 degrees Fahrenheit and leaving water temperatures of 130 degrees Fahrenheit.

The cooling accounts for 250 MMBtu/year which is 13% of the total energy used in the Army Reserve Center. There are two air-cooled rotary screw packaged water chillers piped in parallel in the building. The chillers have capacities of 40 and 52 tons respectively, are both manufactured by Trane, and both have scroll compressors that use R-410A as the refrigerant.

Design Load Estimation

To estimate the design load for the Army Reserve Center, a block load estimate was performed using Trane Trace 700. Most of the information was obtained from the design documents. However, several assumptions needed to be made.

Outdoor / Indoor Design Conditions

The design conditions of Providence, Rhode Island were used for the Army Reserve Center because they were the closest available to Newport, Rhode Island. These are:

Heating: 10.8°F (99.0% Occurrence)
Cooling: 89.7°F DB / 73.2°F WB (0.4% Occurrence)

However, because it was requested by the US Army Corps of Engineers, 0°F was used for heating. Also, because it was requested, indoor cooling design conditions shall be 74°F with 50% relative humidity and indoor heating shall be 72°F for occupied spaces and 55°F for unoccupied spaces.

Airflow

Airflow was determined by the design engineer using ASHRAE 62.1. The infiltration for the building was assumed to be pressurized tight construction thus allowing 0.3 air changes per hour. In order to provide more detail, several of the spaces used in the Trace model are shown in Appendix A.

Building Construction

The U values for the walls, roof, and floor of the building were determined from the architectural and structural drawings and other design documents. They are shown in table 1 below. The wall heights, floor to floor heights, and plenum heights are shown in table 2 below.

Construction of Building	
Roof	Overall Roof U factor = 0.0330, Fully adhered EPDM membrane roofing system, 1/2" Coverboard insulation, 4" Polyisocyanurate board insulation (R-28 min), 1/2" fiber reinforced gypsum decking, 1-1/2" metal roof deck. The assembly hall roof is flat, and the rest of the building is sloped.
Wall Construction	Floor 1: Overall Wall U factor = 0.0673. 4" Vaneer face brick, 2" air space, 2" polystyrene insulation, dampproofing barrier, 6" concrete masonry. Floor 2: Overall Wall U factor = 0.0400. 4" Vaneer face brick, 2" air space, 2" Polystyrene insulation, fluid-applied air and vapor barrier, 1/2" glass-mat gypsum sheathing, 6" metal framing with 6" R-19 insulation, 5/6" gypsum wall board (painted), 4" nominal cast stone band.
High Bay Doors	Overall Door U factor = 1.45 (ASHRAE min)
Swing Doors	Overall Door U factor = 0.7 (ASHRAE min)
Windows	U = 0.57 SHGC = 0.49
Floor	Slab on Grade heated/unheated: 5" concrete with R-10 surrounding 5 feet from the the perimeter

Table 1

	Wall Height	Floor to Floor Height	Plenum Height
1st Floor	14 feet	14 feet	4 feet
2nd Floor	10 feet	10 feet	3 feet

Table 2

Block Load Method

The Army Reserve Center was broken up into several blocks for the design load estimation. Each air handling unit had its own block. AHU-1 serves the first floor offices, AHU-2 serves the second floor, and AHU-3 serves the auditorium. The other blocks are the areas served by the unit ventilators. UV-1, UV-2, and UV-3 are treated as one block since they serve several classrooms that are in a row. UV-4, UV-5, and UV-6 each are treated as a separate block because they each serve a group of several spaces. UV-4 and UV-5 are on the exterior while UV-6 is on the interior. A schematic of AHU-1 is located in Appendix B.

Lighting

The average lighting of the Army Reserve Center is 0.71 Watts / square foot. Since the design load is estimated based on the block load method, this is used for each of the blocks.

Occupancy

The number of people each space is to be designed for is given in the design documents. Those values are used to determine the occupancy. For the offices, each occupant is assumed to have a personal computer that gives off 150 watts. For the library and the copy center, an appropriate amount of watts for each computer, copier, and printer are assumed.

Modeled Versus Designed

Shown in table 3 below are the actual cooling square foot/ton, the heating BTUH/square foot, the total supply air CFM/square foot, and the supply air CFM/square foot. Although the design documents include several Trane Trace 700 files, they do not include the system checksums so the actual numbers cannot be obtained from the Trace file. However, the numbers can be determined from the mechanical schedules.

MODELED VERSUS DESIGNED					
		COOLING FT2 / TON	HEATING BTUH/FT2	TOTAL SA CFM/FT2	VENT SUPPLY CFM/FT2
AHU-1	MODELED	653	11.45	0.42	0.125
	DESIGNED	544	7.32	0.45	0.11
	% DIFF	20.04	56.42	6.67	13.64
AHU-2	MODELED	620	11.52	0.5	0.098
	DESIGNED	561	5.81	0.53	0.096
	% DIFF	10.52	98.28	5.66	2.08
AHU-3	MODELED	287	27.82	0.86	0.37
	DESIGNED	235	43	0.72	0.464
	% DIFF	22.13	35.30	19.44	20.26
UV-1, UV-2, UV-3	MODELED	383	24.95	0.76	0.334
	DESIGNED	408	30.6	0.52	0.157
	% DIFF	6.13	18.46	46.15	112.74
UV-4	MODELED	330	23.51	1.54	0.1
	DESIGNED	506	26.5	0.81	0.127
	% DIFF	34.78	11.28	90.12	21.26
UV-5	MODELED	301	24.2	1.54	0.1
	DESIGNED	359	28.3	0.87	0.127
	% DIFF	16.16	14.49	77.01	21.26
UV-6	MODELED	1320	8.35	0.19	0.083
	DESIGNED	801.00	14.60	0.56	0.12
	% DIFF	64.79	42.81	66.07	29.06

Table 3

As shown table 3, most of the systems appear to be accurately modeled since the percent differences are rarely above 30%. However, there are several discrepancies. This occurs partially because the rooms were designed using the space by space method while the model created used the block method. The block method placed several smaller spaces on the air handling units when they really were not conditioned. The other reason for the differences could be that, especially for the unit ventilators, there are only so many standard sizes. The unit ventilators thus had to be oversized in order to meet the required capacities. The schedules, which had these oversized unit ventilators, were used in determining the heating, cooling, and ventilation CFM/ square foot since the Trace 700 files documenting the required capacities of the spaces which contained the unit ventilators were not given. This error was not noticeable on the larger air handling units because they are big enough that even if they are oversized, it is by a much smaller percentage.

Annual Energy Consumption and Operating Costs

Energy Usage

	Electric Consumption (kWh)	Gas Consumption (kBtu)	% of Total Building Energy	Total Building Energy (mmBtu/yr)
Heating				
Primary Heating		153,112	8.00%	153
Other Htg. Accessories	13,065		2.30%	44.6
Cooling				
Cooling Compressor	62,509		11.10%	213.3
Tower/Cond Fans	9,625		1.70%	32.9
Other Clg Accessories	876		0.20%	3
Auxiliary				
Pumps	59,755		10.70%	203.9
Lighting	252,839		45.10%	862.9
Receptacles	117,384		20.90%	400.6
Total	516053	153112	100%	1,914.40

Table 4 (above)

As shown in table 4 above, the majority of the energy consumption of the Army Reserve Center is due to lighting and receptacles which make up 45.1% and 20.9% of the energy respectively. The cooling and heating loads are both relatively small percentages of the total energy used. This is due to the tight construction of the building, each of the components of the building having small U values, and the building minimizing glass (less than 10%).

Figures 1 and 2 below show the monthly usage of natural gas and electricity, respectively. As one may predict, natural gas usage is negligible (if at all) in the summer because there is hardly any heating from the boilers. However, it increases in the winter month and is a maximum at 422 therms in January.

Electricity usage is at a maximum in July at 51,618 kilowatt hours because many of the air conditioning applications need a lot of electricity to meet their capacities. It is higher also in June and August, but really is about the same for the rest of the year. One thing to consider for the re-design of the building would be to attempt to maximize day lighting. This would help because the most of the energy is due to lighting which makes up 45% of the total energy usage of the building.




Figure 1 (above)




Figure 2 (above)

Schedules

The Army Reserve Center is composed of mostly office spaces. An office-based schedule, shown below in table 5, is thus used.

Start	End	Percentage
Midnight	6 a.m.	0
6 a.m.	7 a.m.	10
7 a.m.	8 a.m.	30
8 a.m.	11 a.m.	100
11 a.m.	1 p.m.	80
1 p.m.	5 p.m.	100
5 p.m.	6 p.m.	10
6 p.m.	Midnight	0

Table 5

Fuel Costs

According to the specifications, the cost for electricity is \$93.15/MWH or \$0.09315/Kwh. The cost of natural gas is approximately \$4.00/MMBtu. As shown in table 6 below, the total cost to operate the building per year is \$48,682.78. Since the area of the building is approximately 59,000 square feet, the cost per square foot to operate the Army Reserve Center is \$0.83 / square foot.

Total Cost of Energy				
	Electric Cost	Gas Cost	% of Total Building Cost	Total Building Cost
Heating				
Primary Heating		\$612.45	8.00%	\$612.45
Other Htg. Accessories	\$1,217.00		2.30%	\$1,217.00
Cooling				
Cooling Compressor	\$5,822.71		11.10%	\$5,822.71
Tower/Cond Fans	\$896.57		1.70%	\$896.57
Other Clg Accessories	\$81.60		0.20%	\$81.60
Auxiliary				
Pumps	\$5,566.18		10.70%	\$5,566.18
Lighting	\$23,551.95		45.10%	\$23,551.95
Receptacles	\$10,934.32		20.90%	\$10,934.32
Total	\$48,070.34	\$612.45	100%	\$48,682.78

Table 6

Equipment Performance Characteristics

Shown below in table 7 are the horsepower for each fan and the supply CFM that the fan creates. These are used to determine the total energy consumption of each fan.

Tag	Supply CFM	HP
AHU-1 Supply Fan	3700	7.50
AHU-2 Supply Fan	13200	20.00
AHU-3 Supply Fan	2100	3.00
AHU-1 Return Fan	3700	3.00
AHU-2 Return Fan	13200	10.00
UV-1	625	0.50
UV-2	440	0.50
UV-3	440	0.50
UV-4	606	0.50
UV-5	650	0.50
UV-6	975	0.50

Table 7

Compare to Actual Energy Analysis

Shown below in table 8 below are two alternatives for the building energy consumption created by the design engineer. The Army Reserve Center was designed based on Alt-1 Training Center Proposed. Although both the design engineer and the model created used Trane Trace 700 for the energy model, alternative 1 was very different than the total energy calculated. The calculated model, closer to alternative 2, used $1,914 * 10^6$ BTU/yr, which is a 68% difference from alternative 1, but only an 8% difference from alternative 2. The lighting load of the model is 863 mmBTU/yr; about three times greater than alternative 1 and twice as large as alternative 2.

Part of this is because the design only takes into account conditioned spaces, while the model created is based on the block load method and thus takes the lighting load of several unconditioned spaces. Another reason for the discrepancies in lighting loads could have arisen if the design engineer took into account natural lighting and thus assumed that the lights would be off or dimmed during much of the day. The model does not take that into account because it assumes 0.71 Watts / square foot for each of the blocks.

The actual utility bills are not yet available as the Army Reserve Center is currently under construction thus no comparison of predicted and actual utility costs can be performed.

Note: The percentage displayed for the "Proposed/ Base %" column of the base case is actually the percentage of the total energy consumption.

* Denotes the base alternative for the ECB study.

		* Alt-2			Alt-1 Training Center Proposed		
		Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtu/h	Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtu/h
Lighting - Conditioned	Electricity	405.2	23	166	280.7	69	109
Space Heating	Electricity	1.4	0	2	37.0	2,738	10
	Gas	454.4	26	712	203.1	45	510
Space Cooling	Electricity	155.0	9	310	97.9	63	220
Pumps	Electricity	0.0	0	0	1.9	0	4
Heat Rejection	Electricity	64.4	4	33	14.6	23	27
Fans - Conditioned	Electricity	99.9	6	84	67.6	68	108
Receptacles - Conditioned	Electricity	219.5	12	98	219.5	100	98
Stand-alone Base Utilities	Electricity	299.0	17	63	163.6	55	34
	Gas	60.4	3	7	50.8	84	6
Total Building Consumption		1,759.2			1,136.6		

Table 8

Emissions




Figure 3 (above)

As shown in figure 3 above, Rhode Island and thus the Army Reserve Center are part of the Eastern Interconnection.

As shown in table 9 below, the Eastern Interconnection uses primarily coal (53.9%), nuclear (23.0%), and natural gas (12.7%) for electricity generation. Also shown in tables 10 and 11 below are the total pounds of toxic substances that are emitted because of the Army Reserve Center's use of electricity and natural gas. The building creates 846,327 and 1,300 pounds of carbon dioxide due to electricity and natural gas respectively.

Percent Electricity Generation by Energy Type for 2004

Energy Type	National %	Eastern %	Western %	ERCOT %	Alaska %	Hawaii %
Bituminous Coal	27.8	34.3	13.1	0.0	0.0	1.0
Subbituminous Coal	19.8	19.6	19.8	21.4	9.9	13.1
Lignite Coal	2.3	1.4	0.0	14.8	0.0	0.0
Natural Gas	18.3	12.7	27.4	49.4	55.5	1.5
Petroleum Fuels	2.8	3.6	0.5	0.5	11.5	77.4
Other Fossil Fuel	0.2	0.2	0.3	0.2	0.0	0.2
Nuclear	19.9	23.0	9.9	12.4	0.0	0.0
Hydro	6.8	3.4	24.6	0.3	23.0	0.8
Renewable Fuels	1.5	1.7	1.3	0.2	0.1	4.2
Geothermal	0.4	0.0	2.1	0.0	0.0	1.9
Wind	0.4	0.1	1.0	0.9	0.0	0.1
Solar (PV)	0.0	0.0	0.1	0.0	0.0	0.0
Fossil Fuel Total	71.2	71.8	60.9	86.2	76.9	93.1
Renewable (non hydro)	2.2	1.8	4.6	1.1	0.1	6.1

Table 9 (above)

	TOTAL ELECTRICAL USAGE (kWh)	TOAL EMISSION FRACTION (LB / kWh)	TOTAL POLLUTION (LB)
CO ₂	516,053	1.64	846,327
NO _x		3.00×10^{-3}	1,548
SO _x		8.57×10^{-3}	4,423
PM		9.26×10^{-5}	4,779

Table 10

	TOTAL GAS USAGE (*1000 FT ³)	TOAL EMISSION FRACTION (LB / 1000 FT ³)	TOTAL POLLUTION (LB)
CO ₂	112	11.6	1,300
NO _x		0.0164	2
SO _x		1.22	137
PM		0.002237	0

Table 11

References

Michel Baker Corporation. Construction Documents & Specifications. 101 Airside Drive, Pittsburgh, PA, 15108.

Previous Senior Thesis Reports 2009-2010.

Trane Trace 700.

Deru & Torcellini. (2007). Source Energy and Emission Factors for Energy Use in Buildings. National Renewable Energy Laboratory.

Appendix A

Alternative 1
 Room description: 104 - Assembly AHU-3

Templates...
 Room: Assembly
 Internal: Assembly
 Airflow: Assembly
 Tstat: Default
 Constr: Construction 1st floor

Partition...
 Tag:
 Length: 0
 Height: 0
 Constr:
 U-factor: 0
 Adj room:
 Adjacent space temperature...
 Method:
 Cooling:
 Heating:
 Buttons: New Partition, Copy Part, Delete Part

Floor...
 Floor - 1
 Tag: Floor - 1
 External temperature...
 Method: Hourly OADB
 Cooling: °F
 Heating: °F
 Constr: 12" LW Conc
 Area: 0 ft²
 Perim: 152.14 ft
 U-factor: 0 Btu/h·ft²·°F
 Loss coeff: 0.1 Btu/hrft·°F
 Adj room: <<No adjacent room>>
 Buttons: New Floor, Copy Floor, Delete Floor

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | **Partn/Floors**

Alternative 1
 Room description: AHU - 2 - Office Area

Templates...
 Room: Office
 Internal: Office
 Airflow: Office
 Tstat: Default
 Constr: Construction 2nd floor

Length: 9679 ft
 Width: 1 ft
 Roof...
 0 ft
 Equals floor

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
North	127	10	0	0 1	175.3	1	☑ ▲
South	127	10	180	0 1	213	1	☑ ▼
East	189	10	90	0 1	417	1	☑ ▼

Internal loads...
 People: 69
 Lighting: 0.71 W/sq ft
 Misc loads: 150 Watts/workst

Airflows...
 Peop-based: 5 cfm/person
 Area-based: 0.06 cfm/sq ft
 VAV minimum: % Clg Airflow

Single Sheet | Rooms | Roofs | **Walls** | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: AHU - 2 Unit Common

Templates...

Room: Break Room Floor...: 9897 ft Length: 1 ft Width: 1 ft
 Internal: Break Room Roof...: 0 ft 0 ft
 Airflow: Break Room Equals floor
 Tstat: Default
 Constr: Construction 2nd floor

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	10	0	0	0	0	<input checked="" type="checkbox"/>
	0	10	0	0	0	0	<input checked="" type="checkbox"/>
	0	10	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 128 sq ft/person
 Lighting: 0.71 w/sq ft
 Misc loads: 0 w/sq ft

Airflows...

Peop-based: 5 cfm/person
 Area-based: 0.06 cfm/sq ft
 VAV minimum: % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: AHU 2 - Pub Storage

Templates...

Room: Storage Floor...: 1193 ft Length: 1 ft Width: 1 ft
 Internal: Storage Roof...: 0 ft 0 ft
 Airflow: Storage Equals floor
 Tstat: Default
 Constr: Construction 2nd floor

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	10	0	0	0	0	<input checked="" type="checkbox"/>
	0	10	0	0	0	0	<input type="checkbox"/>
	0	10	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 0 sq ft/person
 Lighting: 0.71 w/sq ft
 Misc loads: 0 w/sq ft

Airflows...

Peop-based: 0 cfm/person
 Area-based: 0.12 cfm/sq ft
 VAV minimum: % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1
 Room description: **AHU-1 Corridor**

Templates...
 Room: Corridor
 Internal: Corridor
 Airflow: Corridor
 Tstat: Default
 Constr: Construction 1st floor

Length: 2405 ft
 Width: 1 ft
 Floor...: 0 ft
 Roof...: 0 ft
 Equals floor

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	14	0	0	0	0	<input checked="" type="checkbox"/>
	0	14	0	0	0	0	<input type="checkbox"/>
	0	14	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...
 People: 0
 Lighting: 0.71
 Misc loads: 0

Airflows...
 Peop-based: 5
 Area-based: 0.06
 VAV minimum: % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1
 Room description: **AHU-1 Library**

Templates...
 Room: Library
 Internal: Library
 Airflow: Library
 Tstat: Default
 Constr: Construction 1st floor

Length: 1377 ft
 Width: 1 ft
 Floor...: 0 ft
 Roof...: 0 ft
 Equals floor

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	14	0	0	0	0	<input checked="" type="checkbox"/>
	0	14	0	0	0	0	<input type="checkbox"/>
	0	14	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...
 People: 48
 Lighting: 0.71
 Misc loads: 600

Airflows...
 Peop-based: 5
 Area-based: 0.06
 VAV minimum: % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: UV 1-3 Classrooms

Templates...

Room: Classroom | Floor...: 1824 ft | Length: 1824 ft | Width: 1 ft

Internal: Classroom | Roof...: 0 ft | Roof...: 0 ft

Airflow: Classroom | Equals floor:

Tstat: Default

Constr: Construction 1st floor

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
West	25	14	270	0 1	55	1	<input checked="" type="checkbox"/>
North	25	14	0	0 0	0	0	<input type="checkbox"/>
	0	14	0	0 0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 39 | People

Lighting: 0.71 | W/sq ft

Mic loads: 150 | Watts/work

Airflows...

Peop-based: 10 | cfm/person

Area-based: 0.12 | cfm/sq ft

VAV minimum: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Buttons: Apply, Close, New Room, Copy, Delete

Appendix B

