

Final Report

Susquehanna Center Renovations & Expansion

Brad Gaugh

April 7, 2011



Table of Contents

Executive Summary	3
Building Statistics.....	4
Large Work Space – Auxiliary Gymnasium	8
Special Purpose Space – Fitness and Weight Room	22
Circulation Space – Main Lobby.....	33
Exterior Space – Main Entry Façade.....	46
Electrical Depth – Branch Circuit Redesign	59
Short Circuit and Protective Device Study.....	83
Electrical Depth 1 – Motor Control Center.....	86
Electrical Depth 2– SKM Analysis	92
Breadth I – Skylight Structural Analysis	100
Breadth II – Skylight Mechanical Analysis	105
Summary and Conclusions	109
Acknowledgements	110
Appendix A – Luminaire and Control Schedule.....	111
Appendix B – Specification Sheets	115

Electrical Depth – Branch Circuit Redesign

Space Descriptions:

The electrical redesigns of four spaces are the same four spaces, in which a lighting redesign was done. Those four spaces are the Auxiliary Gymnasium, Fitness and Weight Room, Main Lobby, and Main Entry Façade. The lobby is the primary circulation space that has hallways that branch off of it that will lead you to the adjacent Fitness and Weight room. The weight room is a typical fitness facility with all types of workout equipment available to students and athletes on the Harford Community College's campus. One of those branching hallways also leads to the Auxiliary Gymnasium, which is your standard full size basketball court with two smaller perpendicular courts.

The lighting redesign consisted mostly of replacing fluorescent troffers with fluorescent down-lights, wall washers, and other accent lighting hardware. All lighting in the Susquehanna Center is operated using 277 volts.

Panel Boards Affected

Panel Tag	Voltage	System	Exterior Façade	Main Lobby	Fitness and Weight Room	Auxiliary Gym
LPA	480Y/277V, 3P, 4W	N			X	X
LPB	480Y/277V, 3P, 4W	N		X		
SITE	480Y/277V, 3P, 4W	N	X			

Table 20. Panelboards Affected by Lighting Redesign

NOTE: The individual circuits that have been affected are highlighted in the following Panels with their respected colors.

Control Information and Space Layout

Auxiliary Gymnasium

The controls in the space will be primarily used to accommodate the daylight harvesting system that utilizes multiple Lutron products. The primary piece of equipment will be the photocell located in the center of the space that will relay information to the automated day-lighting control via a Lutron Grafik Eye. This Grafik Eye specializes in the utilization of daylight harvesting and will control the light output of the high bay fluorescent luminaires that provide general illumination. All luminaires in this space will be supplied with 277V and controlled by another Grafik Eye, which will be located in the main electric room. Emergency luminaires will have an emergency ballast controlled by both the Grafik Eye and Emergency Relay to switch the luminaire from normal power to emergency power. A new dimming Panel DP was introduced for this space, so that the luminaires could be dimmed. The panel is feed by Panel LPA and located in the Electric. See drawings for exact location.

Fitness and Weight Room

In this space the control system is simplistic in nature. The control system is comprised of a combination of vacancy sensors with wall switches. Wall switches will be the primary controller of the lights, but the vacancy sensor will provide the automatic shut-off requirements for ASHRAE 90.1. Emergency luminaires will have an emergency ballast controlled by both the wall switch and an emergency relay that will switch the luminaire from normal power to emergency power.

Main Lobby

Since this space is a circulation space the lighting will be controlled by an astronomical time clock. Emergency luminaires will have an emergency ballast controlled by both the astronomical time clock and an emergency relay that will switch the luminaire from normal power to emergency power.


Main Entry Façade

This space will be controlled via an astronomical time clock because it is located outside.

NOTE: See the following drawings in order above for Electrical Plans.


Control Wiring Diagrams

Wiring for Lutron MW-PS-WH Photocell




Drawing 19. Wiring Diagram of Photocell

2 or More Sensors to System



Drawing 20. Wiring Diagram of Vacancy Sensors

Single Phase Diagram



Drawing 21. Wiring Diagram of Lighting Relay

Existing Panelboards and Modified Circuits

PANEL		LPA		MAIN: 225A MCB				VOLTAGE: 480Y/ 277 3 PH 4 W					
AIC:		35,000		MOUNTING: SURFACE				NOTE:					
LOCATION:		MAIN ELECT. RM. 157		100% RATED NEUTRAL BUS									
CKT	EQUIPMENT SERVED	LOAD (KVA)			BREAKER		BREAKER		LOAD (KVA)			EQUIPMENT SERVED	CKT
		A	B	C	P	AMPS	P	AMPS	A	B	C		
1	L 137, 38, 57-59 N TOILETS	2.3			1	20	1	20	1.7			L: FITNESS	2
3	L CORRI 150		2.1		1	20	1	20		2.8		L: FITNESS & OFFICES	4
5	L CORRI 152			1.7	1	20	1	20			1.3	L: FITNESS DL	6
7	L CORRI 152 & 56	2.7			1	20	1	20				L: FITNESS COVE	8
9	L 148		1.5		1	20	1	20		2.8		L: MULTI #1 & 2	10
11	L AUX GYM			3.6	1	20	1	20				L: 142A, 43-45, 49 & 51	12
13	L AUX GYM	3.6			1	20	1	20	0.4			L: EXT. BY SAIL	14
15	L 114		0.8		1	20	1	20		3.2		L: NE OFFICES	16
17	SPARE				1	20	1	20			2.8	L: 109, 112 & 113	18
19	SPARE				1	20	1	20				SPARE	20
21	SPACE				-	-	-	-				SPACE	22
23	SPACE				-	-	-	-				SPACE	24
25	SPACE				-	-	-	-				SPACE	26
27	SPACE				-	-	-	-				SPACE	28
29	SPACE				-	-	-	-				SPACE	30
31	SPACE				-	-	-	-				SPACE	32
33	SPACE				-	-	-	-				SPACE	34
35	SPACE				-	-	-	-				SPACE	36
37	PANEL 'RPA' TRANSFORMER	25.9			3	125	3	100	15.9			PANEL 'LPC'	38
39	-----		25.6		-	-	-	-		16.2		-----	40
41	-----			24.2	-	-	-	-			13.7	-----	42
		34.55	30.03	29.5	SUB-TOTALS				18	24.96	17.76		
CONNECTED LOAD:													
A:		52.5 KVA		=	190 A								
B:		55.0 KVA		=	199 A								
C:		47.3 KVA		=	171 A								

Drawing 22. Panel LPA Existing Loads

PANEL		LPB		MAIN: 225A MCB		VOLTAGE: 480Y/ 277 3 PH 4 W								
AIC:		25,000		MOUNTING: SURFACE		NOTE:								
LOCATION:		ELECTRICAL RM. 010				100% RATED NEUTRAL BUS								
CKT	EQUIPMENT SERVED	LOAD (KVA)			BREAKER		BREAKER			LOAD (KVA)			EQUIPMENT SERVED	CKT
		A	B	C	P	AMPS	P	AMPS	A	B	C			
1	L: ARENA COURT	2.7			1	20	1	20	2.4			L: ARENA / THEATER	2	
3	L: ARENA COURT		2.7		1	20	1	20		1.2		L: ARENA SEAT	4	
5	L: ARENA COURT			2.7	1	20	1	20			1.5	L: ARENA SEAT	6	
7	L: ARENA COURT	2.7			1	20	1	20	1			L: ARENA SEAT	8	
9	L: ARENA COURT		2.7		1	20	1	20		0.8		L: ARENA SEAT	10	
11	L: ARENA COURT			2.7	1	20	1	20			1	L: ARENA SEAT	12	
13	L: ARENA COURT	2.7			1	20	1	20	0.8			L: ARENA SEAT	14	
15	L: ARENA COURT		2.7		1	20	1	20		1		L: ARENA SEAT	16	
17	L: ARENA COURT			2.7	1	20	1	20			0.8	L: ARENA SEAT	18	
19	L: ARENA COURT	2.7			1	20	1	20	1			L: ARENA SEAT	20	
21	L: ARENA DOWNLIGHT		0.4		1	20	1	20		0.8		L: ARENA SEAT	22	
23	L: LOWER ENTRANCES			1.2	1	20	1	20			0.7	L: ARENA SEAT	24	
25	L: TOILETS UPPER LEVEL	1.8			1	20	1	20	0.7			L: ARENA SEAT	26	
27	L: TOILET LOWER LEVEL		1.8		1	20	1	20		1.7		L: ARENA SEAT	28	
29	L: 010 & 011			1.2	1	20	1	20			1.7	L: ARENA SEAT	30	
31	L: TOILET LOWER LEVEL	2			1	20	1	20	1.1			L: ARENA SEAT	32	
33	L: CORRIDOR 116		2		1	20	1	20		1		L: ARENA SEAT	34	
35	SPARE				1	20	1	20			1.3	L: CONCESSION	36	
37	SPARE				1	20	1	20	0.6			L: UPPER ENTRANCES	38	
39	SPARE				1	20	1	20		2.6		L: WALL LIGHTING	40	
41	SPARE				1	20	1	20			0.6	L: STAIRS NW & SW	42	
43	SPACE				-	-	-	-				SPACE	44	
45	SPACE				-	-	-	-				SPACE	46	
47	SPACE				-	-	-	-				SPACE	48	
49	SPACE				-	-	-	-				SPACE	50	
51	SPACE				-	-	-	-				SPACE	52	
53	SPACE				-	-	-	-				SPACE	54	
55	PANEL 'RPB' TRANSFORMER	18.4			3	150	-	-				SPACE	56	
57	----		17.3		-	-	-	-				SPACE	58	
59	----			17.1	-	-	-	-				SPACE	60	
		33	29.6	27.6	SUB-TOTALS				7.6	9.1	7.6			
CONNECTED LOAD:														
A:	40.6 KVA	=	147 A											
B:	38.7 KVA	=	140 A											
C:	35.2 KVA	=	127 A											

Drawing 23. Panel LPB Existing Loads

PANEL		SITE		MAIN: 225A MCB				VOLTAGE: 480Y/ 277 3 PH 4 W						
AIC:		25,000		MOUNTING: SURFACE				NOTE:						
LOCATION:		ROOM 011						100% RATED NEUTRAL BUS						
CKT	EQUIPMENT SERVED	LOAD (KVA)			BREAKER		BREAKER		LOAD (KVA)			EQUIPMENT SERVED	CKT	
		A	B	C	P	AMPS	P	AMPS	A	B	C			
1	TENNIS COURT	1.8			2	20	1	20	1.8			SITE LIGHTING	2	
3	-----		1.8		-	-	1	20		1.8		SITE LIGHTING	4	
5	TENNIS COURT			1.8	2	20	1	20			1.8	SITE LIGHTING	6	
7	-----	1.8			-	-	1	20	2			SITE LIGHTING	8	
9	TENNIS COURT		1.8		2	20	1	20		2		SITE LIGHTING	10	
11	-----			1.8	-	-	1	20			2.7	SITE LIGHTING	12	
13	TENNIS COURT	1.8			2	20	1	20	2.4			SITE LIGHTING	14	
15	-----		1.8		-	-	1	20		0.5		SITE LIGHTING	16	
17	TENNIS COURT			1.8	2	20	1	20				SPARE	18	
19	-----	1.8			-	-	3	20	1.3			DOCK LEVELER	20	
21	TENNIS COURT		1.8		2	20	-	-		1.3		-----	22	
23	-----			1.8	-	-	-	-			1.3	-----	24	
25	TENNIS COURT	1.8			2	20	3	20	1.2			RAIN WATER	26	
27	-----		1.8		-	-	-	-		1.2		-----	28	
29	TENNIS COURT			1.8	2	20	-	-			1.2	-----	30	
31	-----	1.8			-	-	3	25	4.2			PUMP RWHB #1 & 2	32	
33	TENNIS COURT		1.8		2	20	-	-		4.2		-----	34	
35	-----			1.8	-	-	-	-			4.2	-----	36	
37	TENNIS COURT	1.8			2	20	1	20	1.2			"SAIL" LIGHTING	38	
39	-----		1.8		-	-	1	20		1.2		"SAIL" LIGHTING	40	
41	TENNIS COURT			1.8	2	20	1	20			0.4	CANOPY LIGHTING	42	
43	-----	1.8			-	-	1	20	1.8			SOFFIT LIGHTING	44	
45	TENNIS COURT		1.8		2	20	1	20		1.5		SOFFIT LIGHTING	46	
47	-----			1.8	-	-	1	20			0.4	ENTRANCE (2)	48	
49	TENNIS COURT	1.8			2	20	-	-				SPACE	50	
51	-----		1.8		-	-	-	-				SPACE	52	
53	TENNIS COURT			1.8	2	20	-	-				SPACE	54	
55	-----	1.8			-	-	-	-				SPACE	56	
57	TENNIS COURT		1.8		2	20	-	-				SPACE	58	
59	-----			1.8	-	-	-	-				SPACE	60	
61	TENNIS COURT	1.8			2	20	-	-				SPACE	62	
63	-----		1.8		-	-	-	-				SPACE	64	
65	SPARE				1	20	-	-				SPACE	66	
67	SPARE				1	20	-	-				SPACE	68	
69	SPACE				-	-	-	-				SPACE	70	
71	SPACE				-	-	-	-				SPACE	72	
73	SPACE				-	-	-	-				SPACE	74	
75	SPACE				-	-	-	-				SPACE	76	
77	SPACE				-	-	-	-				SPACE	78	
79	SPACE				-	-	-	-				SPACE	80	
81	SPACE				-	-	-	-				SPACE	82	
83	SPACE				-	-	-	-				SPACE	84	
		19.8	19.8	18	SUB-TOTALS					15.9	13.7	12		
CONNECTED LOAD:														
A:		35.7 KVA		=	129 A									
B:		33.5 KVA		=	121 A									
C:		30 KVA		=	108 A									

Drawing 24. Panel Site Existing Loads

Revised Panelboards and Modified Circuits

PANELBOARD SIZING WORKSHEET										
Panel Tag----->					LPA	Panel Location:			Electric Room	
Nominal Phase to Neutral Voltage----->					277	Phase:			3	
Nominal Phase to Phase Voltage----->					480	Wires:			4	
Pos	Ph.	Load Type	Cat.	Location	Load	Units	I. PF	Watts	VA	Remarks
1	A	Lighting	3	Toilets	2300	w	0.90	2300	2556	
2	A	Lighting	3	Fitness	1566	w	0.90	1566	1740	
3	B	Lighting	3	Corridor	2100	w	0.90	2100	2333	
4	B	Lighting	3	Fitness	1711	w	0.90	1711	1901	
5	C	Lighting	3	Corridor	1700	w	0.90	1700	1889	
6	C	Lighting	3	Fitness	675	w	0.90	675	750	
7	A	Lighting	3	Corridor	2700	w	0.90	2700	3000	
8	A	Space			0	w		0	0	
9	B	Lighting	3	Dance	1500	w	0.90	1500	1667	
10	B	Lighting	3	Multi	2800	w	0.90	2800	3111	
11	C	Space	3		0	w		0	0	
12	C	Lighting	3	Storage	1800	w	0.90	1800	2000	
13	A	Space	3		0	w		0	0	
14	A	Lighting	3	Sail	400	w	0.90	400	444	
15	B	Lighting	3	Lounge	800	w	0.90	800	889	
16	B	Lighting	3	Offices	3200	w	0.90	3200	3556	
17	C	Spare	9		0	w		0	0	
18	C	Lighting	3	Classroom	2800	w	0.90	2800	3111	
19	A	Spare	9		0	w		0	0	
20	A	Space			0	w		0	0	
21	B	Space			0	w		0	0	
22	B	Space			0	w		0	0	
23	C	Space			0	w		0	0	
24	C	Space			0	w		0	0	
25	A	Space			0	w		0	0	
26	A	Space			0	w		0	0	
27	B	Space			0	w		0	0	
28	B	Space			0	w		0	0	
29	C	Space			0	w		0	0	
30	C	Space			0	w		0	0	
31	A	Space			0	w		0	0	
32	A	Space			0	w		0	0	
33	B	Panel DP	9		1080	w		1080	1350	
34	B	Space			0	w		0	0	
35	C	***	9	***	1080	w		1080	1350	
36	C	Space			0	w		0	0	
37	A	Transformer RPA	9	Electric	25900	w		25900	32375	
38	A	Panel LPC	9	Electric	15900	w		15900	19875	
39	B	***	9	***	25600	w		25600	32000	
40	B	***	9	***	16200	w		16200	20250	
41	C	***	9	***	24200	w		24200	30250	
42	C	***	9	***	13700	w		13700	17125	
PANEL TOTAL								149.7	183.5	Amps= 220.8

PHASE LOADING							kW	kVA	%	Amps
PHASE TOTAL		A					48.8	60.0	34%	216.6
PHASE TOTAL		B					55.0	67.1	39%	242.1
PHASE TOTAL		C					46.0	47.0	27%	169.7
LOAD CATAGORIES			Connected			Demand				Ver. 104
			kW	kVA	DF	kW	kVA	PF		
1	receptacles		0.0	0.0		0.0	0.0			
2	computers		0.0	0.0		0.0	0.0			
3	fluorescent lighting		26.1	28.9		26.1	28.9	0.90		
4	HID lighting		0.0	0.0		0.0	0.0			
5	incandescent lighting		0.0	0.0		0.0	0.0			
6	HVAC fans		0.0	0.0		0.0	0.0			
7	heating		0.0	0.0		0.0	0.0			
8	kitchen equipment		0.0	0.0		0.0	0.0			
9	unassigned		123.7	154.6		123.7	154.6	0.80		
Total Demand Loads						149.7	183.5			
Spare Capacity			20%			29.9	36.7			
Total Design Loads						179.7	220.2	0.82	Amps=	265.0
Default Power Factor =		0.80								
Default Demand Factor =		100 %								

Table 20. Panel LPA New Loads

Panelboard		
Tag		LPA
Voltage System		480Y/ 277V
Calculated Design Load (kW)		180
Calculated Power Factor		0.82
Calculated Design Load (kVA)		220.226
Calculated Design Load (A)		265.0132371
Feeder		
Feeder Protection Size		400
Number of Sets		2
Wire Size		
Phase		2/0
Neutral		2/0
Ground		3
Wire Area (table 5)		
Each Phase		0.2223
Total – All phases		0.6669
Neutral		0.2223
Ground		0.0973
Total – All Wires		0.9865
Minimum Conduit Area (above * 2.5)		2.46625
Conduit Size (Table 4)		2"
Conduit Size (Table C.1)		2-1/2"
Feeder Length		25 ft
Final Voltage Drop (V)		12.3 V
Final Voltage Drop (%)		2.60%
Was feeder re-sized?		NO

Table 21. Panel LPA Feeder Sizing

PANELBOARD SCHEDULE												
VOLTAGE: 480Y/277V, 3PH, 4W			PANEL TAG: LPA			MIN. C/B AIC: 35k						
SIZE/TYPE BUS: 400A			PANEL LOCATION: Electric Room			OPTIONS:						
SIZE/TYPE MAIN: 400A/3P MCB			PANEL MOUNTING: SURFACE									
DESCRIPTION	LOCATION	LOAD (WATTS)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (WATTS)	LOCATION	DESCRIPTION
Lighting	Toilets	2300	20A/1P	1	*			2	20A/1P	1566	Fitness	Lighting
Lighting	Corridor	2100	20A/1P	3		*		4	20A/1P	1711	Fitness	Lighting
Lighting	Corridor	1700	20A/1P	5			*	6	20A/1P	675	Fitness	Lighting
Lighting	Corridor	2700	20A/1P	7	*			8	20A/1P	0		Space
Lighting	Dance	1500	20A/1P	9		*		10	20A/1P	2800	Multi	Lighting
Space		0	20A/1P	11			*	12	20A/1P	1800	Storage	Lighting
Space		0	20A/1P	13	*			14	20A/1P	400	Sail	Lighting
Lighting	Lounge	800	20A/1P	15		*		16	20A/1P	3200	Offices	Lighting
Spare		0	20A/1P	17			*	18	20A/1P	2800	Classroom	Lighting
Spare		0	20A/1P	19	*			20	20A/1P	0		Space
Space		0	20A/1P	21		*		22	20A/1P	0		Space
Space		0	20A/1P	23			*	24	20A/1P	0		Space
Space		0	20A/1P	25	*			26	20A/1P	0		Space
Space		0	20A/1P	27		*		28	20A/1P	0		Space
Space		0	20A/1P	29			*	30	20A/1P	0		Space
Space		0	20A/1P	31	*			32	20A/1P	0		Space
Panel DP		1080	50A/2P	33		*		34	20A/1P	0		Space
***	***	1080		35			*	36	20A/1P	0		Space
Transformer RPA	Electric	25900	125A/3P	37	*			38	100A/3P	15900	Electric	Panel LPC
***	***	25600		39		*		40		16200	***	***
***	***	24200		41			*	42		13700	***	***
CONNECTED LOAD (KW) - A Ph.		48.77							TOTAL DESIGN LOAD (KW)		179.65	
CONNECTED LOAD (KW) - B Ph.		54.99							POWER FACTOR		0.82	
CONNECTED LOAD (KW) - C Ph.		45.96							TOTAL DESIGN LOAD (AMPS)		265	

Table 22. Panel LPA Schedule

PANELBOARD SIZING WORKSHEET										
Panel Tag----->					LPB	Panel Location:			Electric Room	
Nominal Phase to Neutral Voltage----->					277	Phase:			3	
Nominal Phase to Phase Voltage----->					480	Wires:			4	
Pos	Ph.	Load Type	Cat.	Location	Load	Units	I. PF	Watts	VA	Remarks
1	A	Lighting	3	Arena	2700	w		2700	3375	
2	A	Lighting	3	Arena	2400	w		2400	3000	
3	B	Lighting	3	Arena	2700	w		2700	3375	
4	B	Lighting	3	Arena	1200	w		1200	1500	
5	C	Lighting	3	Arena	2700	w		2700	3375	
6	C	Lighting	3	Arena	1500	w		1500	1875	
7	A	Lighting	3	Arena	2700	w		2700	3375	
8	A	Lighting	3	Arena	1000	w		1000	1250	
9	B	Lighting	3	Arena	2700	w		2700	3375	
10	B	Lighting	3	Arena	800	w		800	1000	
11	C	Lighting	3	Arena	2700	w		2700	3375	
12	C	Lighting	3	Arena	1000	w		1000	1250	
13	A	Lighting	3	Arena	2700	w		2700	3375	
14	A	Lighting	3	Arena	800	w		800	1000	
15	B	Lighting	3	Arena	2700	w		2700	3375	
16	B	Lighting	3	Arena	100	w		100	125	
17	C	Lighting	3	Arena	2700	w		2700	3375	
18	C	Lighting	3	Arena	800	w		800	1000	
19	A	Lighting	3	Arena	2700	w		2700	3375	
20	A	Lighting	3	Arena	1000	w		1000	1250	
21	B	Lighting	3	Arena	400	w		400	500	
22	B	Lighting	3	Arena	800	w		800	1000	
23	C	Lighting	3	Toilets	1200	w		1200	1500	
24	C	Lighting	3	Arena	700	w		700	875	
25	A	Lighting	3	Toilets	1800	w		1800	2250	
26	A	Lighting	3	Arena	700	w		700	875	
27	B	Lighting	3	Toilets	1800	w		1800	2250	
28	B	Lighting	3	Arena	1700	w		1700	2125	
29	C	Lighting	3	Electric	1200	w		1200	1500	
30	C	Lighting	3	Arena	1700	w		1700	2125	
31	A	Lighting	3	Toilets	2000	w		2000	2500	
32	A	Lighting	3	Arena	1100	w		1100	1375	
33	B	Lighting	3	Corridor	2000	w		2000	2500	
34	B	Lighting	3	Arena	1000	w		1000	1250	
35	C	Space	9		0	w		0	0	
36	C	Lighting	3	Lobby	564	w		564	705	
37	A	RPB XMFR	9	Electric	18400	w		18400	23000	
38	A	Space	9		0	w		0	0	
39	B	***	9	***	17300	w		17300	21625	
40	B	Lighting	3	Wall	2600	w		2600	3250	
41	C	***	9	***	17100	w		17100	21375	
42	C	Lighting	3	Stairs	600	w		600	750	
PANEL TOTAL								112.3	140.3	Amps= 168.9

PHASE LOADING						kW	kVA	%	Amps
PHASE TOTAL		A				40.0	50.0	37%	180.5
PHASE TOTAL		B				37.8	47.3	35%	170.6
PHASE TOTAL		C				34.5	38.7	28%	139.5
LOAD CATEGORIES			Connected			Demand			Ver. 104
			kW	kVA	DF	kW	kVA	PF	
1	receptacles		0.0	0.0		0.0	0.0		
2	computers		0.0	0.0		0.0	0.0		
3	fluorescent lighting		59.5	74.3		59.5	74.3	0.80	
4	HID lighting		0.0	0.0		0.0	0.0		
5	incandescent lighting		0.0	0.0		0.0	0.0		
6	HVAC fans		0.0	0.0		0.0	0.0		
7	heating		0.0	0.0		0.0	0.0		
8	kitchen equipment		0.0	0.0		0.0	0.0		
9	unassigned		52.8	66.0		52.8	66.0	0.80	
Total Demand Loads						112.3	140.3		
Spare Capacity			20%			22.5	28.1		
Total Design Loads						134.7	168.4	0.80	Amps= 202.6
Default Power Factor =		0.80							
Default Demand Factor =		100 %							

Table 23. Panel LPB New Loads

Panelboard		
Tag		LPB
Voltage System		480Y/ 277V
Calculated Design Load (kW)		134.7
Calculated Power Factor		0.8
Calculated Design Load (kVA)		168.4
Calculated Design Load (A)		202.6
Feeder		
Feeder Protection Size		225
Number of Sets		1
Wire Size		
Phase		4/0
Neutral		4/0
Ground		4
Wire Area (table 5)		
Each Phase		0.3237
Total – All phases		0.9711
Neutral		0.3237
Ground		0.0824
Total – All Wires		1.3772
Minimum Conduit Area (above * 2.5)		3.443
Conduit Size (Table 4)		2- 1/2"
Conduit Size (Table C.1)		2-1/2"
Feeder Length		100ft
Final Voltage Drop (V)		10.5 V
Final Voltage Drop (%)		2.20%
Was feeder re-sized?		NO

Table 24. Panel LPB Feeder Sizing

PANELBOARD SCHEDULE												
VOLTAGE: 208Y/120V,3PH,4W			PANEL TAG: LPB						MIN. C/B AIC: 10K			
SIZE/TYPE BUS: 225A			PANEL LOCATION: Electric Room						OPTIONS: PROVIDE FEED THROUGH LUGS			
SIZE/TYPE MAIN: 225A/3P C/B			PANEL MOUNTING: SURFACE						FOR PANELBOARD 1L1B			
DESCRIPTION	LOCATION	LOAD (WATTS)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (WATTS)	LOCATION	DESCRIPTION
Lighting	Arena	2700	20A/1P	1	*			2	20A/1P	2400	Arena	Lighting
Lighting	Arena	2700	20A/1P	3		*		4	20A/1P	1200	Arena	Lighting
Lighting	Arena	2700	20A/1P	5			*	6	20A/1P	1500	Arena	Lighting
Lighting	Arena	2700	20A/1P	7	*			8	20A/1P	1000	Arena	Lighting
Lighting	Arena	2700	20A/1P	9		*		10	20A/1P	800	Arena	Lighting
Lighting	Arena	2700	20A/1P	11			*	12	20A/1P	1000	Arena	Lighting
Lighting	Arena	2700	20A/1P	13	*			14	20A/1P	800	Arena	Lighting
Lighting	Arena	2700	20A/1P	15		*		16	20A/1P	100	Arena	Lighting
Lighting	Arena	2700	20A/1P	17			*	18	20A/1P	800	Arena	Lighting
Lighting	Arena	2700	20A/1P	19	*			20	20A/1P	1000	Arena	Lighting
Lighting	Arena	400	20A/1P	21		*		22	20A/1P	800	Arena	Lighting
Lighting	Toilets	1200	20A/1P	23			*	24	20A/1P	700	Arena	Lighting
Lighting	Toilets	1800	20A/1P	25	*			26	20A/1P	700	Arena	Lighting
Lighting	Toilets	1800	20A/1P	27		*		28	20A/1P	1700	Arena	Lighting
Lighting	Electric	1200	20A/1P	29			*	30	20A/1P	1700	Arena	Lighting
Lighting	Toilets	2000	20A/1P	31	*			32	20A/1P	1100	Arena	Lighting
Lighting	Corridor	2000	20A/1P	33		*		34	20A/1P	1000	Arena	Lighting
Space	0	0	20A/1P	35			*	36	20A/1P	564	Lobby	Lighting
RPB XMFR	Electric	18400	150A/3P	37	*			38	20A/1P	0		Space
***	***	17300		39		*		40	20A/1P	2600	Wall	Lighting
***	***	17100		41			*	42	20A/1P	600	Stairs	Lighting
CONNECTED LOAD (KW) - A Ph.		40.00							TOTAL DESIGN LOAD (KW)		134.72	
CONNECTED LOAD (KW) - B Ph.		37.80							POWER FACTOR		0.80	
CONNECTED LOAD (KW) - C Ph.		34.46							TOTAL DESIGN LOAD (AMPS)		203	

Table 25. Panel LPB Schedule

PANELBOARD SIZING WORKSHEET										
Panel Tag----->					Site	Panel Location:			Electric Room	
Nominal Phase to Neutral Voltage----->					277	Phase:			3	
Nominal Phase to Phase Voltage----->					480	Wires:			4	
Pos	Ph.	Load Type	Cat.	Location	Load	Units	I. PF	Watts	VA	Remarks
1	A	Lighting	3	Tennis	1800	w		1800	2250	
2	A	Lighting	3	Site	1800	w		1800	2250	
3	B	***	3	***	1800	w		1800	2250	
4	B	Lighting	3	Site	1800	w		1800	2250	
5	C	Lighting	3	Tennis	1800	w		1800	2250	
6	C	Lighting	3	Site	1800	w		1800	2250	
7	A	***	3	***	1800	w		1800	2250	
8	A	Lighting	3	Site	2000	w		2000	2500	
9	B	Lighting	3	Tennis	1800	w		1800	2250	
10	B	Lighting	3	Site	200	w		200	250	
11	C	***	3	***	1800	w		1800	2250	
12	C	Lighting	3	Site	2700	w		2700	3375	
13	A	Lighting	3	Tennis	1800	w		1800	2250	
14	A	Lighting	3	Site	2400	w		2400	3000	
15	B	***	3	***	1800	w		1800	2250	
16	B	Lighting	3	Site	500	w		500	625	
17	C	Lighting	3	Tennis	1800	w		1800	2250	
18	C	Spare	9			w		0	0	
19	A	***	3	***	1800	w		1800	2250	
20	A	Dock Leveler	9	Site	1300	w		1300	1625	
21	B	Lighting	3	Tennis	1800	w		1800	2250	
22	B	***	9	***	1300	w		1300	1625	
23	C	***	3	***	1800	w		1800	2250	
24	C	***	9	***	1300	w		1300	1625	
25	A	Lighting	3	Tennis	1800	w		1800	2250	
26	A	Rain Water	9	Site	1200	w		1200	1500	
27	B	***	3	***	1800	w		1800	2250	
28	B	***	9	***	1200	w		1200	1500	
29	C	Lighting	3	Tennis	1800	w		1800	2250	
30	C	***	9	***	1200	w		1200	1500	
31	A	***	3	***	1800	w		1800	2250	
32	A	Pumps	9	Site	4200	w		4200	5250	
33	B	Lighting	3	Tennis	1800	w		1800	2250	
34	B	***	9	***	4200	w		4200	5250	
35	C	***	9	***	1800	w		1800	2250	
36	C	***	9	***	4200	w		4200	5250	
37	A	Lighting	3	Tennis	1800	w		1800	2250	
38	A	Lighting	3	Site	1200	w		1200	1500	
39	B	***	3	***	1800	w		1800	2250	
40	B	Lighting	3	Site	1375	w		1375	1719	
41	C	Lighting	3	Tennis	1800	w		1800	2250	
42	C	Lighting	3	Site	1638	w		1638	2048	
PANEL TOTAL								75.3	94.1	Amps= 113.3

PHASE LOADING							kW	kVA	%	Amps
PHASE TOTAL		A					26.7	33.4	36%	120.5
PHASE TOTAL		B					23.2	29.0	31%	104.6
PHASE TOTAL		C					25.4	30.9	33%	111.7
LOAD CATAGORIES			Connected				Demand			Ver. 104
			kW	kVA	DF		kW	kVA	PF	
1	receptacles		0.0	0.0			0.0	0.0		
2	computers		0.0	0.0			0.0	0.0		
3	fluorescent lighting		53.4	66.8			53.4	66.8	0.80	
4	HID lighting		0.0	0.0			0.0	0.0		
5	incandescent lighting		0.0	0.0			0.0	0.0		
6	HVAC fans		0.0	0.0			0.0	0.0		
7	heating		0.0	0.0			0.0	0.0		
8	kitchen equipment		0.0	0.0			0.0	0.0		
9	unassigned		21.9	27.4			21.9	27.4	0.80	
Total Demand Loads							75.3	94.1		
Spare Capacity			20%				15.1	18.8		
Total Design Loads							90.4	113.0	0.80	Amps= 135.9
Default Power Factor =		0.80								
Default Demand Factor =		100 %								

Table 26. Panel Site New Loads on first 42 Circuits

PANELBOARD SIZING WORKSHEET										
Panel Tag----->					Site	Panel Location:			Electric Room	
Nominal Phase to Neutral Voltage----->					277	Phase:			3	
Nominal Phase to Phase Voltage----->					480	Wires:			4	
Pos	Ph.	Load Type	Cat.	Location	Load	Units	I. PF	Watts	VA	Remarks
43	A	***	3	***	1800	w		1800	2250	
44	A	Lighting	3	Site	1800	w		1800	2250	
45	B	Lighting	3	Tennis	1800	w		1800	2250	
46	B	Lighting	3	Site	1500	w		1500	1875	
47	C	***	3	***	1800	w		1800	2250	
48	C	Spare	9			w		0	0	
49	A	Lighting	3	Tennis	1800	w		1800	2250	
50	A	Space				w		0	0	
51	B	***	3	***	1800	w		1800	2250	
52	B	Space				w		0	0	
53	C	Lighting	3	Tennis	1800	w		1800	2250	
54	C	Space				w		0	0	
55	A	***	3	***	1800	w		1800	2250	
56	A	Space				w		0	0	
57	B	***	3	***	1800	w		1800	2250	
58	B	Space				w		0	0	
59	C	***	3	***	1800	w		1800	2250	
60	C	Space				w		0	0	
61	A	Lighting	3	Tennis	1800	w		1800	2250	
62	A	Space				w		0	0	
63	B	***	3	***	1800	w		1800	2250	
64	B	Space				w		0	0	
65	C	Spare	9			w		0	0	
66	C	Space				w		0	0	
67	A	Spare	9			w		0	0	
68	A	Space				w		0	0	
69	B	Space				w		0	0	
70	B	Space				w		0	0	
71	C	Space				w		0	0	
72	C	Space				w		0	0	
73	A	Space				w		0	0	
74	A	Space				w		0	0	
75	B	Space				w		0	0	
76	B	Space				w		0	0	
77	C	Space				w		0	0	
78	C	Space				w		0	0	
79	A	Space				w		0	0	
80	A	Space				w		0	0	
81	B	Space				w		0	0	
82	B	Space				w		0	0	
83	C	Space				w		0	0	
84	C	Space				w		0	0	
PANEL TOTAL								23.1	28.9	Amps= 34.7

PHASE LOADING						kW	kVA	%	Amps
PHASE TOTAL		A				9.0	11.3	39%	40.6
PHASE TOTAL		B				8.7	10.9	38%	39.3
PHASE TOTAL		C				5.4	6.8	23%	24.4
LOAD CATAGORIES			Connected			Demand			Ver. 104
			kW	kVA	DF	kW	kVA	PF	
1	receptacles		0.0	0.0		0.0	0.0		
2	computers		0.0	0.0		0.0	0.0		
3	fluorescent lighting		23.1	28.9		23.1	28.9	0.80	
4	HID lighting		0.0	0.0		0.0	0.0		
5	incandescent lighting		0.0	0.0		0.0	0.0		
6	HVAC fans		0.0	0.0		0.0	0.0		
7	heating		0.0	0.0		0.0	0.0		
8	kitchen equipment		0.0	0.0		0.0	0.0		
9	unassigned		0.0	0.0		0.0	0.0		
Total Demand Loads						23.1	28.9		
Spare Capacity			20%			4.6	5.8		
Total Design Loads						27.7	34.7	0.80	Amps= 41.7
Default Power Factor =		0.80							
Default Demand Factor =		100 %							

Table 27. Panel Site New Loads on second 42 Circuits

Panelboard		
Tag		Site
Voltage System		480Y/ 277V
Calculated Design Load (kW)		118.1
Calculated Power Factor		0.8
Calculated Design Load (kVA)		147.7
Calculated Design Load (A)		177.7
Feeder		
Feeder Protection Size		225
Number of Sets		1
Wire Size		
Phase		4/0
Neutral		4/0
Ground		4
Wire Area (table 5)		
Each Phase		0.3237
Total – All phases		0.9711
Neutral		0.3237
Ground		0.0824
Total – All Wires		1.3772
Minimum Conduit Area (above * 2.5)		3.443
Conduit Size (Table 4)		2- 1/2"
Conduit Size (Table C.1)		2-1/2"
Feeder Length		100ft
Final Voltage Drop (V)		10.5V
Final Voltage Drop (%)		2.20%
Was feeder re-sized?		NO

Table 28. Panel Site Feeder Sizing

PANELBOARD SCHEDULE												
VOLTAGE: 208Y/120V,3PH,4W			PANEL TAG: Site							MIN. C/B AIC: 10K		
SIZE/TYPE BUS: 225A			PANEL LOCATION: Electric Room							OPTIONS: PROVIDE FEED THROUGH LUGS		
SIZE/TYPE MAIN: 225A/3P C/B			PANEL MOUNTING: SURFACE							FOR PANELBOARD 1L1B		
DESCRIPTION	LOCATION	LOAD (WATTS)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (WATTS)	LOCATION	DESCRIPTION
Lighting	Tennis	1800	20A/2P	1	*			2	20A/1P	1800	Site	Lighting
***	***	1800		3		*		4	20A/1P	1800	Site	Lighting
Lighting	Tennis	1800	20A/2P	5			*	6	20A/1P	1800	Site	Lighting
***	***	1800		7	*			8	20A/1P	2000	Site	Lighting
Lighting	Tennis	1800	20A/2P	9		*		10	20A/1P	200	Site	Lighting
***	***	1800		11			*	12	20A/1P	2700	Site	Lighting
Lighting	Tennis	1800	20A/2P	13	*			14	20A/1P	2400	Site	Lighting
***	***	1800		15		*		16	20A/1P	500	Site	Lighting
Lighting	Tennis	1800	20A/2P	17			*	18	20A/1P	0	0	Spare
***	***	1800		19	*			20	20A/3P	1300	Site	Dock Leveler
Lighting	Tennis	1800	20A/2P	21		*		22		1300	***	***
***	***	1800		23			*	24		1300	***	***
Lighting	Tennis	1800	20A/2P	25	*			26	20A/3P	1200	Site	Rain Water
***	***	1800		27		*		28		1200	***	***
Lighting	Tennis	1800	20A/2P	29			*	30		1200	***	***
***	***	1800		31	*			32	20A/3P	4200	Site	Pumps
Lighting	Tennis	1800	20A/2P	33		*		34		4200	***	***
***	***	1800		35			*	36		4200	***	***
Lighting	Tennis	1800	20A/2P	37	*			38	20A/1P	1200	Site	Lighting
***	***	1800		39		*		40	20A/1P	1375	Site	Lighting
Lighting	Tennis	1800	20A/2P	41			*	42	20A/1P	1638	Site	Lighting
CONNECTED LOAD (KW) - A Ph.		26.70								TOTAL DESIGN LOAD (KW)		90.38
CONNECTED LOAD (KW) - B Ph.		23.18								POWER FACTOR		0.80
CONNECTED LOAD (KW) - C Ph.		25.44								TOTAL DESIGN LOAD (AMPS)		136
PANELBOARD SCHEDULE												
VOLTAGE: 208Y/120V,3PH,4W			PANEL TAG: Site							MIN. C/B AIC: 10K		
SIZE/TYPE BUS: 225A			PANEL LOCATION: Electric Room							OPTIONS: PROVIDE FEED THROUGH LUGS		
SIZE/TYPE MAIN: 225A/3P C/B			PANEL MOUNTING: SURFACE							FOR PANELBOARD 1L1B		
DESCRIPTION	LOCATION	LOAD (WATTS)	C/B SIZE	POS. NO.	A	B	C	POS. NO.	C/B SIZE	LOAD (WATTS)	LOCATION	DESCRIPTION
***	***	1800		43	*			44	20A/1P	1800	Site	Lighting
Lighting	Tennis	1800	20A/2P	45		*		46	20A/1P	1500	Site	Lighting
***	***	1800		47			*	48		0	0	Spare
Lighting	Tennis	1800	20A/2P	49	*			50		0	0	Space
***	***	1800		51		*		52		0	0	Space
Lighting	Tennis	1800	20A/2P	53			*	54		0	0	Space
***	***	1800		55	*			56		0	0	Space
***	***	1800	20A/2P	57		*		58		0	0	Space
***	***	1800		59			*	60		0	0	Space
Lighting	Tennis	1800	20A/2P	61	*			62		0	0	Space
***	***	1800		63		*		64		0	0	Space
Spare	0	0		65			*	66		0	0	Space
Spare	0	0		67	*			68		0	0	Space
Space	0	0		69		*		70		0	0	Space
Space	0	0		71			*	72		0	0	Space
Space	0	0		73	*			74		0	0	Space
Space	0	0		75		*		76		0	0	Space
Space	0	0		77			*	78		0	0	Space
Space	0	0		79	*			80		0	0	Space
Space	0	0		81		*		82		0	0	Space
Space	0	0		83			*	84		0	0	Space
CONNECTED LOAD (KW) - A Ph.		9.00								TOTAL DESIGN LOAD (KW)		27.72
CONNECTED LOAD (KW) - B Ph.		8.70								POWER FACTOR		0.80
CONNECTED LOAD (KW) - C Ph.		5.40								TOTAL DESIGN LOAD (AMPS)		42

Table 29. Panel Site Schedule

PANELBOARD SIZING WORKSHEET										
Panel Tag----->					DP	Panel Location:			Electric	
Nominal Phase to Neutral Voltage----->					277	Phase:			1	
Nominal Phase to Phase Voltage----->					554	Wires:			3	
Pos	Ph.	Load Type	Cat.	Location	Load	Units	I. PF	Watts	VA	Remarks
1	L1	Lighting	3	Gym	1080	w		1080	1350	
2	L1	Lighting	3	Gym	1080	w		1080	1350	
3	L2	Space			0	w		0	0	
4	L2	Space			0	w		0	0	
5	L1	Space			0	w		0	0	
6	L1	Space			0	w		0	0	
7	L2	Space			0	w		0	0	
8	L2	Space			0	w		0	0	
PANEL TOTAL								2.2	2.7	Amps= 4.9
PHASE LOADING										
LEG TOTAL			L1					kW	kVA	%
								2.2	2.7	100%
LEG TOTAL			L2					0.0	0.0	0.0
LOAD CATAGORIES				Connected			Demand			Ver. 104
				kW	kVA	DF	kW	kVA	PF	
1		receptacles		0.0	0.0		0.0	0.0		
2		computers		0.0	0.0		0.0	0.0		
3		fluorescent lighting		2.2	2.7		2.2	2.7	0.80	
4		HID lighting		0.0	0.0		0.0	0.0		
5		incandescent lighting		0.0	0.0		0.0	0.0		
6		HVAC fans		0.0	0.0		0.0	0.0		
7		heating		0.0	0.0		0.0	0.0		
8		kitchen equipment		0.0	0.0		0.0	0.0		
9		unassigned		0.0	0.0		0.0	0.0		
Total Demand Loads							2.2	2.7		
Spare Capacity					20%		0.4	0.5		
Total Design Loads							2.6	3.2	0.80	Amps= 5.8
Default Power Factor =				0.80						
Default Demand Factor =				100 %						

Table 30. Panel DP New Loads

Panelboard		
Tag		DP
Voltage System		277V
Calculated Design Load (kW)		2.6kW
Calculated Power Factor		0.8
Calculated Design Load (kVA)		3.2kVA
Calculated Design Load (A)		6A
Feeder		
Feeder Protection Size		50
Number of Sets		1
Wire Size		
Phase		6
Neutral		6
Ground		10
Wire Area (table 5)		
Each Phase		0.0507
Total – All phases		0.1521
Neutral		0.0507
Ground		0.0211
Total – All Wires		0.1732
Minimum Conduit Area (above * 2.5)		0.433
Conduit Size (Table 4)		3/4"
Conduit Size (Table C.1)		1"
Feeder Length		100ft
Final Voltage Drop (V)		3.2V
Final Voltage Drop (%)		1.10%
Was feeder re-sized?		NO

Table 31. Panel DP Feeder Sizing

PANELBOARD SCHEDULE											
VOLTAGE: 208Y/120V,3PH,4W			PANEL TAG: DP			MIN. C/B AIC: 10K					
SIZE/TYPE BUS: 225A			PANEL LOCATION: Electric			OPTIONS: PROVIDE FEED THROUGH LUGS					
SIZE/TYPE MAIN: 225A/3P C/B			PANEL MOUNTING: SURFACE			FOR PANELBOARD 1L1B					
DESCRIPTION	LOCATION	LOAD (WATTS)	C/B SIZE	POS. NO.	L1	L2	POS. NO.	C/B SIZE	LOAD (WATTS)	LOCATION	DESCRIPTION
Lighting	Gym	1080	20A/1P	1	*		2	20A/1P	1080	Gym	Lighting
Space		0	20A/1P	3		*	4	20A/1P	0		Space
Space		0	20A/1P	5	*		6	20A/1P	0		Space
Space		0	20A/1P	7		*	8	20A/1P	0		Space
CONNECTED LOAD (KW) - A Ph.		2.16						TOTAL DESIGN LOAD (KW)		2.59	
CONNECTED LOAD (KW) - B Ph.								POWER FACTOR		0.80	
CONNECTED LOAD (KW) - C Ph.		0.00						TOTAL DESIGN LOAD (AMPS)		6	

Table 32. Panel DP Schedule

Short Circuit and Protective Device Study

Description

A short circuit and protective device study were conducted in order to determine the electrical systems reliability to protect itself from faulty wiring, over-current circumstances, and any other problems that could occur. The short circuit study looked into three components of the electrical system. Those components are the service entrance, the next downstream Panel, and a circuit within that Panel. The protective device study will break down the characteristics of the protection that each of these components have. This report assumes all equipment is to be EATON Corporation and Cutler-Hammer products because the project has not been built or bided.

Short Circuit Calculations

Below are charts that break down the three components from the main switch board 'MDS' to the branch Panel 'MLP' and the circuit for roof top unit 4. The main switch board is 480Y/277V, 3PH. 4W, with a 3200 amp frame, the branch Panel 'MLP' is 480Y/277V, 3PH., 4W with a 600 amp frame, and the roof top unit 4 circuit is a 3P 70A breaker.

Available Fault Current Calculation					
Utility Fault Current		0 amperes	kVA = 2000	by John Sotolik Ver. 6.3 jms1jds@earthlink.net	
$I = \frac{kVA \times 1000}{E \times 1.732} = \text{trans. FLA}$			E = 480	trans. FLA = 2406	
$I_{SCA} = \frac{\text{trans. FLA} \times 100}{\text{transformer Z}} =$				2406	
$I_{SCA} = \text{ampere short-circuit current RMS symmetrical.}$				5.75 %	
				$I_{SCA} =$	41,838 amperes
Point to Point Method					
Length (distance) FEET		25	Three Phase 480/277		
('f' factor = $\frac{1.732 \times L \times I}{N \times C \times E_{L-N}}$)		(ASC)	$L =$	25	Aluminum in Nonmetallic Raceway
# conductors per phase			$I_{SCA} =$	41,838	
Phase conductor constant			N =	6	
Volt Line to Line			C =	23,492	Phase Conductor 750 kcmil
			E L - L =	480	Volt
			f =	0.027	
Neutral conductor constant			C =	23,492	Neutral Conductor 750 kcmil
Volt Line to Neutral			E L - N =	277	Volt
			f =	0.046	
Multiplier					
$M = \frac{1}{1 + f}$					
Line to Line			M =	0.974	
Line to Neutral			M =	0.956	
Fault Current at Service Equipment					
$I_{SCA} \times M = \text{fault current at terminals of main disconnect L - L} =$			40,747 amperes		
$I_{SCA} \times M = \text{fault current at terminals of main disconnect L - N} =$			39,983 amperes		

Table 33. Short Circuit Calculation Switchboard MDS

Fault Current from		Switchboard To Panel MLP		Copper in Metal Raceway	
Three Phase Feeder		Length (distance) (ASC)	L = 45	Three Phase	
'f' factor = $\frac{1.732 \times L \times I}{N \times C \times E_{L-N}}$	# conductors per phase	N = 2	Isca = 40,747	Phase	39,983 Neutral
	Phase conductor constant	C = 19,704	E L-L = 480	Phase Conductor	350 kcmil
	Volt Line to Line	f = 0.168	C = 19,704	Neutral Conductor	350 kcmil
	Neutral conductor constant	E L-N = 277	f = 0.285		
Multiplier	M = $\frac{1}{1+f}$	Line to Line	M = 0.856		
		Line to Neutral	M = 0.778		
Isca x M = fault current at terminal of the panel L-L =				34,889 amperes	
Isca x M = fault current at terminal of the panel L-N =				31,103 amperes	
Calculation does not include motor contribution					

Table 34. Short Circuit Calculations Panel MLP

Branch Circuit Fault from		Panel MLP To RTU-4 Branch Circuit		Copper in Metal Raceway	
Three Phase Branch		Length (distance) (ASC)	L = 300	Three Phase	
'f' factor = $\frac{1.732 \times L \times I}{N \times C \times E_{L-N}}$	# conductors per phase	N = 1	Isca = 34,889	Phase	31,103 Neutral
	Phase conductor constant	C = 3,806	E L-L = 480	Phase Conductor	4
	Volt Line to Line	f = 9.923	C = 3,806	Neutral Conductor	4
	Neutral conductor constant	E L-N = 277	f = 15.329		
Multiplier	M = $\frac{1}{1+f}$	Line to Line	M = 0.092		
		Line to Neutral	M = 0.061		
Isca x M = fault current at terminal of the panel L-L =				3,194 amperes	
Isca x M = fault current at terminal of the panel L-N =				1,905 amperes	
Calculation does not include motor contribution					

Table 35. Short Circuit Calculation RTU-4

Protective Devices

This portion of the report analyzes the coordination between protective devices used in the short circuit calculation by hand above. The devices that will be analyzed are the main circuit breaker for Switchboard MDS, Distribution Panel MLP, branch circuit RTU-4, and the motor for RTU-4. For proper coordination of protective devices the trip curve should ascend in an upstream fashion for the current rating. Thus, meaning the breaker for the RTU-4 should trip first, then the breaker for Panel MLP, and lastly the breaker for Switchboard MDS. The Time Current Curve (TCC) shown will indicate that indeed the breakers will trip in this fashion, with one alteration. As seen on the curve, if a spike of 3000A were to enter the system from one second or longer there is no differentiation between the MDS breaker and MLP breaker. This may cause little problems in the coordination process between breakers. The breaker type and color is specified for synchronization of TCC.

Switch Board 'MDS' – Magnum DS, RMS MDS-632 3200A 65kAIC

Panel 'MLP' – Thermal Magnetic M-Frame Circuit Breaker Type HLD, 600V, 3P600A, 65kAIC

Circuit 'RTU-4' – Thermal Magnetic F-Frame Circuit Breaker Type FDC, 480V, 3P70A, 35kAIC




Image 24. TCC Curve for MDS, MLP, RTU-4 Coordination

Electrical Depth 1 – Motor Control Center

Description

This depth looked in to localizing a Motor Control Center within the main mechanical room. The Panel MLP was the primary load center for the space with disconnects located at individual pieces of HVAC equipment. The Motor Control Center took motors with the highest horsepower rating in the 480V Panel MLP and re-localized them with their motor starters and disconnects in the Motor Control Center. The Eaton 2006 Consulting Application Guide for Cutler-Hammer products was used in order to size to produce the layout of the Motor Control Center. Within the calculation the tables used within the guide are specified. See the following charts and drawings to see details of Motor Control Center and Appendix C for specification sheets.

Table 30.1-27 Table 30.1-27 & 30.1-2 Eaton Eaton															Table 30.1-88 Eaton															Table: 430.250 NEC														
Tag	Equipment	HP	Volt	Phase	PF	kVA	NEC	MCA	FLA	Overcurrent Protection (MCCB)	HVAC Controller	Starter Type	Starter (NEMA Type)	# Spaces																														
CWP-1	CHD WTR PUMP #1 - CHESA	40	480	3	0.95	32.84	52	54.74	68.42	100	ATC	FVR	3	4																														
CWP-2	CHD WTR PUMP #2 - CHESA	40	480	3	0.95	32.84	52	54.74	68.42	100	ATC	FVR	3	4																														
HWP-3	HEATING PUMP - SUSQ	30	480	3	0.95	25.26	40	42.11	52.63	70	ATC	FVR	3	4																														
HWP-4	HEATING PUMP - SUSQ	30	480	3	0.95	25.26	40	42.11	52.63	70	ATC	FVR	3	4																														
RTU-3	RTU #3 SUPPLY	25	480	3	0.95	21.47	34	35.79	44.74	70	VFD	AFD	2	6																														
RTU-2	RTU #2 SUPPLY	20	480	3	0.95	17.05	27	28.42	35.53	50	VFD	AFD	2	6																														
RTU-1	RTU #1 SUPPLY	15	480	3	0.95	13.26	21	22.11	27.63	45	VFD	AFD	2	4																														
RTU-3	RTU #3 RETURN	15	480	3	0.95	13.26	21	22.11	27.63	45	VFD	AFD	2	4																														
RTU-2	RTU #2 RETURN	15	480	3	0.95	13.26	21	22.11	27.63	45	VFD	AFD	2	4																														
HWP-1	HEATING PUMP #1 - CHESA	7.5	480	3	0.95	6.95	11	11.58	14.47	25	ATC	FVR	1	3																														
HWP-2	HEATING PUMP #2 - CHESA	7.5	480	3	0.95	6.95	11	11.58	14.47	25	ATC	FVR	1	3																														
PWP	POOL PUMP	7.5	480	3	0.95	6.95	11	11.58	14.47	25	ATC	FVR	1	3																														
DWP-1	PUMP DWP #1	7.5	480	3	0.95	6.95	11	11.58	14.47	25	ATC	FVR	1	3																														
DWP-2	PUMP DWP #2	7.5	480	3	0.95	6.95	11	11.58	14.47	25	ATC	FVR	1	3																														
RTU-1	RTU #1 RETURN	5	480	3	0.95	4.80	7.6	8.00	10.00	15	VFD	AFD	0	4																														
BP-1	BOILER #1	3	480	3	0.85	3.39	4.8	5.65	7.06	15	ATC	FVR	0	3																														
BP-2	BOILER #2	3	480	3	0.85	3.39	4.8	5.65	7.06	15	ATC	FVR	0	3																														
BP-3	BOILER #3	3	480	3	0.85	3.39	4.8	5.65	7.06	15	ATC	FVR	0	3																														
Totals						244.23		294	367					68																														
															Sections:															6														


Notes:

- 1) Manufacturer : Eaton Freedom 2100 Series, bucket size = 6"
- 2) MCC will be feed from the Main Switchboard (MDS)
- 3) The MDS will contain a 400A drawout type circuit breaker
- 4) The feed to the MCC will be 2 sets of 4#3/0 + 1#6GRD. in 3" C.


Table 36. MCC Calculations

MOTOR CONTROL CENTER: MCC LOCATION: MECHANICAL ROOM 137									
AMPS: 600 VOLTS: 480/277V 3 PH, 4 W, 60 Hz, NEMA: 2 AIC: 65,000									
UNIT NO.	CIRCUIT	HP/KVA	FLA	STARTER		CIRCUIT PROTECTION		FEEDER	NOTES
				TYPE	SIZE	TYPE	TRIP		
A1	MAIN CB	-	-	-	-	-	-	(2)3#350MCM+1#6GRD IN 3-1/2" C.	-
A2	PULL SECTION	-	-	-	-	-	-	-	-
A3	SPARE	-	-	-	-	-	-	-	-
B1	CWP-1	40 HP	68	FVR	3	MCCB	100	3#3 + 1#8GRD. IN 1-1/4" C.	-
B2	CWP-2	40 HP	68	FVR	3	MCCB	100	3#3 + 1#8GRD. IN 1-1/4" C.	-
B3	HWP-3	30 HP	52	FVR	3	MCCB	70	3#4 + 1#8GRD. IN 1-1/4" C.	-
C1	HWP-4	30 HP	52	FVR	3	MCCB	70	3#4 + 1#8GRD. IN 1-1/4" C.	-
C2	HWP-1	7.5 HP	15	FVR	1	MCCB	25	3#12 + 1#12GRD. IN 3/4" C.	-
C3	HWP-2	7.5 HP	15	FVR	1	MCCB	25	3#12 + 1#12GRD. IN 3/4" C.	-
D1	PWP	7.5 HP	15	FVR	1	MCCB	25	3#12 + 1#12GRD. IN 3/4" C.	-
D2	DWP-1	7.5 HP	15	FVR	1	MCCB	25	3#12 + 1#12GRD. IN 3/4" C.	-
D3	DWP-2	7.5 HP	15	FVR	1	MCCB	25	3#12 + 1#12GRD. IN 3/4" C.	-
D4	BP-1	3 HP	7	FVR	0	MCCB	15	3#12 + 1#12GRD. IN 3/4" C.	-
E1	RTU-1 RETURN	3 HP	7	AFD	0	MCCB	15	3#12 + 1#12GRD. IN 3/4" C.	-
E2	BP-2	3 HP	7	FVR	0	MCCB	15	3#12 + 1#12GRD. IN 3/4" C.	-
E3	BP-3	3 HP	7	FVR	0	MCCB	15	3#12 + 1#12GRD. IN 3/4" C.	-
F1	RTU-1 SUPPLY	15 HP	28	AFD	2	MCCB	45	3#8 + 1#10GRD. IN 3/4" C.	-
F2	RTU-3 RETURN	15 HP	28	AFD	2	MCCB	45	3#8 + 1#10GRD. IN 3/4" C.	-
F3	RTU-2 RETURN	15 HP	28	AFD	2	MCCB	45	3#8 + 1#10GRD. IN 3/4" C.	-
G1	RTU-3 SUPPLY	25 HP	45	AFD	2	MCCB	70	3#6 + 1#8GRD. IN 1" C.	-
G2	RUT-2 SUPPLY	20 HP	36	AFD	2	MCCB	70	3#8 + 1#10GRD. IN 3/4" C.	-


Table 37. MCC Schedule



Drawing 14. MCC Elevation



Drawing 15. MCC Isometric View





Drawing 16. Mechanical Room Floor Plan

Electrical Depth 2– SKM Analysis


Description

This depth will use the Electrical Engineering Software known as SKM Power Tool Analysis. This program allows the user to input the main electrical components of the electrical system and run an extensive study on the equipment. This study includes short circuit analysis and arc fault studies. The model used for this analysis was based off of the riser diagram used in Tech Report II and includes all motors listed in the Motor Control Center in Electrical Depth 1. The following tables and screen shots from the program will show further details on the model and analysis completed.

Riser Model*Drawing 17. SKM Riser Diagram Part I*



Drawing 18. SKM Riser Diagram Part II



Drawing 19. SKM Riser Diagram Part III

Short Circuit Analysis

Bus Name	Voltage (L-L)	kAIC Rating	3-Phase (A)	X/R	Line/ Ground (A)	X/R	Protected
MDS	480	65	27,975	6.1	31,243	5.5	Yes
MLP	480	35	26,956	5.2	29,153	4.2	Yes
LPA	480	25	24,149	3.4	24,247	2.4	Yes
LPB	480	25	17,571	1.7	14,498	1.1	Yes
LPC	480	14	5,776	0.5	3,576	0.3	Yes
ELP	480	25	23,719	2.2	22,580	1.4	Yes
SLP	480	14	6,437	0.4	3,963	0.3	Yes
SITE	480	25	17,571	1.7	14,498	1.1	Yes
MRP	208	10	3,059	1.6	3,078	1.6	Yes
MRPA	208	10	1,649	0.7	1,676	0.6	Yes
RPA	208	35	6,907	1.6	7,054	1.5	Yes
RPB	208	35	3,008	1.7	3,044	1.6	Yes
RPC	208	10	1,588	0.6	1,633	0.6	Yes
FRP	208	10	3,617	0.7	2,649	0.5	Yes
CRP	208	10	2,135	0.9	1,751	0.7	Yes
ARP	208	35	8,797	2.4	9,519	2.4	Yes
ERP	208	10	1,751	0.7	1,744	0.7	Yes
ERPA	208	10	1,741	0.7	1,728	0.7	Yes

Table 38. SKM Fault Analysis

Data Summary

The Short Circuit Study conducted by SKM illustrated that the specified fault current bus ratings on the equipment are higher than the simulated fault currents. This means that in the unlikely event of a fault, the equipment will not explode or create further damage to the system. There is, however, one section that draws attention and that is Panel LPA. Panel LPA's fault current bus rating is 25,000A, which is very near the simulated fault current that SKM is predicting could happen at this Panel. This may require Panel LPA to increase its rating to a higher one of 35,000A.

Arc Flash Evaluation

Project: Susquehanna Center, Base Project

Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Bus Arcing Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground	Equip Type	Gap (mm)	Arc Flash Boundary (in)	Working Distance (in)	Incident Energy (cal/cm2)	Required Protective FR Clothing Category	Label #
1	ARP	0.208	8.80	3.38	8.80	3.38	2	0.000	Yes	PNL	25	101	18	20	Category 3 (*N3)	# 0001
2																
3	CRP	0.208	2.14	1.47	2.14	1.47	2	0.000	Yes	PNL	25	59	18	8.3	Category 3 (*N9)	# 0002
4																
5	ELP	0.48	23.72	13.71	23.72	13.71	0.013	0.000	Yes	PNL	25	12	18	0.61	Category 0	# 0003
6																
7	ERP	0.208	1.75	1.28	1.75	1.28	2	0.000	Yes	PNL	25	54	18	7.2	Category 2 (*N9)	# 0004
8																
9	ERPA	0.208	1.74	1.27	1.74	1.27	2	0.000	Yes	PNL	25	54	18	7.1	Category 2 (*N9)	# 0005
10																
11	FRPM	0.208	3.62	2.13	3.62	2.13	0.02	0.000	Yes	PNL	25	5	18	0.12	Category 0	# 0006
12																
13	LPA	0.48	24.15	13.93	24.15	13.93	0.01	0.000	Yes	PNL	25	10	18	0.47	Category 0	# 0007
14																
15	LPB	0.48	17.57	10.61	17.57	10.61	0.01	0.000	Yes	PNL	25	9	18	0.35	Category 0	# 0008
16																
17	LPC	0.48	5.78	4.10	5.78	4.10	0.016	0.000	Yes	PNL	25	6	18	0.20	Category 0	# 0009
18																
19	MDS	0.48	27.98	14.84	2.27	1.20	0.083	0.000	Yes	SWG	32	42	24	2.7	Category 1 (*N2)	
20	MDS	0.48	27.98	14.84	1.95	1.03	0.083	0.000	Yes	SWG	32	42	24	2.7	Category 1 (*N2)	
21	MDS	0.48	27.98	14.84	0.21	0.11	0.083	0.000	Yes	SWG	32	42	24	2.7	Category 1 (*N2)	
22	MDS	0.48	27.98	14.84	0.21	0.11	0.083	0.000	Yes	SWG	32	42	24	2.7	Category 1 (*N2)	
23	MDS	0.48	27.98	14.84	0.21	0.11	0.083	0.000	Yes	SWG	32	42	24	2.7	Category 1 (*N2)	
24	MDS	0.48	27.98	14.84	0.21	0.11	0.083	0.000	Yes	SWG	32	42	24	2.7	Category 1 (*N2)	
25	MDS	0.48	27.98	14.84	22.92	12.57	2	0.000	Yes	SWG	32	321	24	54	Dangerous! (*N2)	# 0010
26																
27	MLP	0.48	26.96	15.30	25.01	14.19	0.019	0.000	Yes	PNL	25	16	18	1.00	Category 0	# 0011

Table 39. SKM Arc Flash Analysis Part I

Equations used with permission from IEEE 1584 *Copyright 2004*, by IEEE. The IEEE disclaims any responsibility or liability resulting from the placement and use in the described manner.

Page 1

Arc Flash Evaluation Arc Flash Evaluation IEEE 1584 - 2002/2004a Edition Bus Report Project: Susquehanna Center, Base Project

Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Bus Arcing Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Tripp/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground	Equip Type	Gap (mm)	Arc Flash Boundary (in)	Working Distance (in)	Incident Energy (cal/cm2)	Required Protective FR Clothing Category	Label #
28	MLP		0.48	26.96	15.30	0.02	0.01	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
29	MLP		0.48	26.96	15.30	0.02	0.01	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
30	MLP		0.48	26.96	15.30	0.02	0.01	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
31	MLP		0.48	26.96	15.30	0.31	0.17	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
32	MLP		0.48	26.96	15.30	0.31	0.17	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
33	MLP		0.48	26.96	15.30	0.06	0.03	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
34	MLP		0.48	26.96	15.30	0.06	0.03	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
35	MLP		0.48	26.96	15.30	0.06	0.03	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
36	MLP		0.48	26.96	15.30	0.06	0.03	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
37	MLP		0.48	26.96	15.30	0.23	0.13	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
38	MLP		0.48	26.96	15.30	0.23	0.13	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
39	MLP		0.48	26.96	15.30	0.12	0.07	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
40	MLP		0.48	26.96	15.30	0.15	0.09	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
41	MLP		0.48	26.96	15.30	0.19	0.11	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
42	MLP		0.48	26.96	15.30	0.12	0.07	0.083	0.000	Yes	PNL	25	19	1.3	Category 1	
43																
44	MRP		0.208	3.06	1.61	3.06	1.61	1.115	0.000	Yes	PNL	25	44	5.1	Category 2 (*N3)	# 0012
45																
46	MRPA		0.208	1.65	1.04	1.65	1.04	2	0.000	Yes	PNL	25	47	5.7	Category 2 (*N3) (*N9)	# 0013
47																
48	RPA		0.208	6.91	2.85	6.91	2.85	1.894	0.000	Yes	PNL	25	87	16	Category 3 (*N3)	# 0014
49																
50	RPB		0.208	3.01	1.87	3.01	1.87	1.965	0.000	Yes	PNL	25	68	11	Category 3	# 0015
51																
52	RPC		0.208	1.59	1.19	1.59	1.19	2	0.000	Yes	PNL	25	51	6.7	Category 2 (*N9)	# 0016
53																
54	SITE		0.48	17.57	10.61	17.57	10.61	0.012	0.000	Yes	PNL	25	10	0.43	Category 0	# 0017
55																

Equations used with permission from IEEE 1584 *Copyright 2004*, by IEEE. The IEEE disclaims any responsibility or liability resulting from the placement and use in the described manner.
Page 2

Table 40. SKM Arc Flash Analysis Part II

Arc Flash Evaluation Arc Flash Evaluation IEEE 1584 - 2002/2004a Edition Bus Report Project: Susquehanna Center, Base Project

	Bus Name	Protective Device Name	Bus kV	Bus Bolted Fault (kA)	Bus Arcing Fault (kA)	Prot Dev Bolted Fault (kA)	Prot Dev Arcing Fault (kA)	Trip/ Delay Time (sec.)	Breaker Opening Time (sec.)	Ground	Equip Type	Gap (mm)	Arc Flash Boundary (in)	Working Distance (in)	Incident Energy (cal/cm ²)	Required Protective FR Clothing Category	Label #
56	SLP	SLP MCB	0.48	6.44	4.50	6.44	4.50	0.01	0.000	Yes	PNL	25	5	18	0.14	Category 0	# 0018
57																	
58	SRP	SRP MCB	0.208	1.61	1.21	1.61	1.21	2	0.000	Yes	PNL	25	52	18	6.7	Category 2 (*N9)	# 0019
59																	
60	Category 0: Nonmelting, Flammable Materials with Weight >= 4.5 oz/sq yd	0.0 - 1.2 cal/cm ²													#Cat 0 = 8	(*N2) < 80% Cleared Fault Threshold	
61	Category 1: Arc-rated FR Shirt & Pants	1.2 - 4.0 cal/cm ²													#Cat 1 = 0	(*N3) - Arcing Current Low Tolerances Used	
62	Category 2: Arc-rated FR Shirt & Pants	4.0 - 8.0 cal/cm ²													#Cat 2 = 6	(*N9) - Max Arcing Duration Reached	
63	Category 3: Arc-rated FR Shirt & Pants & Arc Flash Suit	8.0 - 25.0 cal/cm ²													#Cat 3 = 4		
64	Category 4: Arc-rated FR Shirt & Pants & Arc Flash Suit	25.0 - 40.0 cal/cm ²													#Cat 4 = 0		
65	Category Dangerous: No FR Category Found	Device with 80% Cleared Fault Threshold													#Danger = 1	IEEE 1584 - 2002/2004a Edition Bus Report (80% Cleared Fault Threshold, include Ind. Motors for 5.0 Cycles), mis-coordination not checked	

Table 41. SKM Arc Flash Analysis Part III

Data Summary

The Arc Flash Evaluation conducted by SKM demonstrated that most of protective devices fell into the appropriate category of protection. The main gear and higher ampacity Panels attained higher Personal Protective Equipment (PPE) ratings than Panels of smaller ampacity. One area of interest is the Main Switchboard, MDS, in which the rating was Dangerous, the highest possible rating, meaning that working on this piece of gear is of extreme hazard and no PPE clothing can protect you. This should raise a red flag and further analysis of this section needs to be conducted to further illustrate the effects.