

Technical Report #2

Pro-Con Structural Study of Alternate Floor Systems



Indiana Regional Medical Center

Indiana, PA

Cody A. Scheller

The Pennsylvania State University

Architectural Engineering

Structural Option

Faculty Adviser: Dr. Linda Hanagan

October 19th, 2011

Executive Summary

The Indiana Regional Medical Center's existing conditions and structural system was analyzed for this technical report. Gravity loads and lateral loads were evaluated throughout the typical portions of the structure using design codes.

Indiana Regional Medical Center is a full service healthcare facility that resides in Indiana, Pennsylvania. It is made up of 6 separate buildings, but is mostly one seven story 146 ft high building that lies in the core of the other five. The entire structure has an orange brick façade and is used mostly as a hospital for the public. It is a constructed moment frame made mostly of steel with metal deck and lightweight concrete.

Gravity loads for calculations in this assignment were taken from ASCE 7-10. All calculations were compared to the actual loads on the plans used in the actual design of the building. Winds loads were also calculated using ASCE 7-10 along with a preliminary analysis of seismic loads.

Spot checks were done on a typical bay within the building. A composite beam and girder were both analyzed and the results showed that they meet all design standards. Both an exterior and interior column were spot checked along the entire height of the building. These were then compared to the actual design forces given.

Alternative floor systems were also analyzed in this technical report. A Precast Hollow Core Plank System, Two Way Post-Tensioned System, and Two Way Flat Plate System were all designed and compared to the existing Composite Deck System. Even though positive results were not obtained from the plank system and flat plate system, the post-tensioned system should be looked into further.

Table of Contents

Executive Summary.....	2
Introduction.....	4
Framing & Lateral Loading.....	5
Foundation.....	5
General Structural Information.....	6
Determination of Loads.....	7
Gravity Loads.....	7
Wind Loads.....	8
Seismic Loads.....	9
Other Loads.....	10
Evaluation of Systems.....	10
Floor System of Typical Bay.....	10
Typical Columns.....	11
Alternate System Pro-Con Study.....	13
Existing Floor System.....	13
Precast Hollow Core Planks.....	14
Two Way Post-Tensioned.....	16
Two Way Flat Plate System.....	18
Conclusion.....	20
Appendices.....	21

Introduction

Indiana Regional Medical Center (IRMC) is a 130,000 square foot hospital that resides in the heart of western Pennsylvania. It was first introduced to the public in November of 1914 and has seen many renovations and additions throughout its years. It is now the only full service health facility in its county. An elevation can be seen in Figure 1 and an aerial view in Figure 2.



Figure 1 – Current Entrance to IRMC

This technical report collects and analyzes the existing structural conditions of the Indiana Regional Medical Center in Indiana, Pennsylvania. An analysis of gravity loads, lateral loads, and the overall structural system of this building has been included with this report along with visual aids to help with the understanding of each concept.




Figure 2 – Site of Indiana Regional Medical Center

Framing & Lateral Loading

The hospital consists of one large seven story building with five smaller buildings branching off from all sides. Each building is rectangular in shape with a brick façade and has a flat roof. The largest building stands 146 feet in the air and has a rigid frame skeleton of steel. Along its North-South length, the hospital consists of 5 typical bays made up of W10, W14, and W16 steel. Moment frames allow more flexibility with the floor plan and awareness of moment connections throughout the structure. A sketch of the moment frame can be seen in Figure 3.




Figure 3 – Moment Frame Sketch

Other Structural Elements

Minor and secondary structural elements are not needed to be analyzed at this phase, but have to be recognized for their importance. Wind pressures and lateral soil pressures on existing walls do affect the overall loading on the building and should be taken into account. The fact that the building has had several renovations over the past 70 years should not be ignored and should always be involved when doing an analysis.

Foundation

IRMC rests on a shallow layer of bedrock so the foundation of the overall building is very shallow. The current level of grade is actually higher than initially since the foundation could not be placed deep into the ground. Concrete footings and columns make up the entire base of the




Figure 4 – Concrete Footing




Figure 5 – Anchor Bolt

building and our attached to the upper steel skeleton by anchor bolts as seen in Figure 4 and Figure 5.

Since the building rests on a shallow foundation it is very important to check load impact and load transfer. This foundation makes the building very vulnerable and could be easily affected by wind and

seismic loadings. It may also be relevant to check the current foundation for any damages since this building has been renovated several times in the past.

General Structural Information

The following codes were used throughout the entire technical report for the identification of loads, wind load calculations, seismic load calculations, spot checking, and overall accuracy of research.

Design Codes

1. AISC Manual of Steel Construction Ninth Edition (ASD)
2. AISC Manual of Steel Construction Load and Resistance Factor Design Second Edition
3. ASCE 7-98 Minimum Design Loads for Buildings and Other Structures
4. International Building Code 2003
5. AISC Manual of Steel Construction Thirteenth Edition
6. AISC 7-10
7. International Building Code 2010

Determination of Loads

Live Loads

Location	Design (IBC 2003)	Thesis (ASCE 7-10)
Office	50 psf	50 psf
Restaurants	100 psf	100 psf
Retail	100 psf	100 psf
Mechanical Rooms	200 psf	-
<u>Hospitals</u>		
Operating rooms/Laboratories	60 psf	60 psf
Patient Rooms	40 psf	40 psf
Corridors Above First Floor	80 psf	80 psf
Roof	30 psf	20 psf
Stairs & Lobby	100 psf	100 psf
Corridors	80 psf	80 psf

Roof Dead Load = 20 psf

Floor Dead Loads	
Composite Decking	44 psf
Superimposed Dead Load	30 psf
Total	74 psf

Snow Loads

Snow load criteria were obtained from section 7.3 of ASCE 7-10. It was found that P_f would be 17.325 lb/ft². Calculations can be seen below in Figure 6.

The image shows a handwritten calculation on a whiteboard. At the top, 'Snow Load' is written and underlined. Below it, '#7.3 Flat Roof Snow Load' is also underlined. The main equation is $P_f = 0.7 C_e C_t I_s P_g$. Below this, the values for each variable are listed: 'where $C_e = 0.9$ ', ' $C_t = 1.0$ ', ' $I_s = 1.1$ ', and ' $P_g = 25$ '. The final calculation is $P_f = (0.7)(0.9)(1.0)(1.1)(25) = 17.325 \text{ lb/ft}^2$, with the result boxed.

$$P_f = 0.7 C_e C_t I_s P_g$$

where $C_e = 0.9$
 $C_t = 1.0$
 $I_s = 1.1$
 $P_g = 25$

$$P_f = (0.7)(0.9)(1.0)(1.1)(25) = 17.325 \text{ lb/ft}^2$$


Figure 6 – Snow Load Calculation

Wind Loads

ASCE 7-10 was used when determining the wind load analysis for the Indiana Regional Medical Center. Chapter 27 of this design code is the enclosed and partially enclosed section and aided in the calculations. An analysis was done for both North-South and East-West directions.

To begin, it needed to be decided if the IRMC was calculated under a rigid structure or flexible structure. The calculations for this result are located in Appendix A and proved that this specific building should be calculated as a rigid structure.

When considering the actual calculations for the wind loads, only the 146 ft tower of the hospital was taken into account. From Figure 7 shown below, it is evident that East-West direction produces the strongest wind forces of 668.74 psf due to larger surface area.



In Appendix A there is a set of hand calculations showing the analysis of base shear and overturning moment. Governing lateral force can be determined by comparing these values to the seismic calculations.

Seismic Loads

Seismic calculations are not required by the location in which Indiana Regional Medical Center resides. Necessary information to analyze the seismic loads on the building have been requested to the architects and engineers that were responsible for the resurrection of this building. Once this information is obtained it will be used in all necessary seismic calculations and compared to the wind pressures on the building.

Evaluation of Systems

Floor System for Typical Bay

Spot checks were done to determine the result of gravity loads on the structure. A typical bay from the second floor of the building was used and can be seen in Figure 8. Detailed hand calculations for this bay are located in Appendix B. The 1st spot check was that of the composite slab. The slab used throughout the building is




Figure 8 – Typical Bay

a Composite Steel Deck with 3 ½” of lightweight 3000 psi concrete fill netting and a total thickness of 5 ½” as seen in Appendix C. Vulcraft Decking Catalog was used to check the values of the decking. After all necessary calculations were completed; it was found that the composite decking used met all standard requirements.

Two more spot checks were done next. One was evaluating a W14x38 composite beam and the other was evaluating a W16x40 composite girder. The calculations in Appendix B show that the beam is more than adequate for the specific loads it needs to carry. When checking the shear stud requirements it was found that the calculated number was slightly less than what was used in the plans. This could come from conservative reasoning or manufacturer changes. The beam also met deflection checks for both live and wet concrete. Results from the composite girder checked yielded positive results as well. They were not as conservative as the beam’s numbers were, but it was still adequate for the loading.

Typical Columns

The final two checks were that of an interior and an exterior column. Column F3 was selected to be spot checked as an interior column and Column F2 was selected for an exterior column as seen in Figure 9. Tributary Area calculations for these spot checks are located in Appendix D. The live load selected for each floor was 80 to be




Figure 9 – Tributary Area for Interior Column

conservative and the dead load consisted of 44 psf for the slab and 30 psf for superimposed load. Self weight of each column was taken into account as well as the 24' splice length that is used throughout the building. Figure 10 and Figure 11 below show the resultant forces on these specific columns.

Figure 10 – Interior Column Check

Interior Column Column Check						
Floor	Area	DL	LL	Column Size	Splice	Pu
3	416	74	80	95	24	92468.8
4	416	74	80	95	24	92468.8
5	416	74	80	87	24	92276.8
6	416	74	80	87	24	92276.8
7	416	74	80	87	24	92276.8
Roof	416	74	20		24	50252.8
Total =						512.02 kips

Figure 11 – Exterior Column Check

Exterior Column						
Column Check						
Floor	Area	DL	LL	Column Size	Splice	Pu
3	208	74	80	95	24	47374.4
4	208	74	80	95	24	47374.4
5	208	74	80	87	24	47182.4
6	208	74	80	87	24	47182.4
7	208	74	80	87	24	47182.4
Roof	208	74	20		24	25126.4
Total =						261.42 kips

Alternate System Pro-Con Study

- Existing Floor System: Composite Deck

The existing floor system for the Indiana Regional Medical Center consists Composite Steel Deck with 3 ½” of lightweight 3000 psi concrete fill netting and a total thickness of 5 ½”. A description of this system is located on Page 11 of this technical assignment along with detailed calculations in Appendix B.

Pro-Con Analysis

Composite deck systems are very appealing because they keep the weight of the building extremely low compared to other systems. It allows for shallower depth of members as well as giving the overall building a low profile. Some serviceability considerations include deflections and vibrations. Vibrations were not calculated in this report, but deflections met the allowable limits. A comparison between advantages and disadvantages can be seen in Figure 12.

Conclusion	
Advantages	Disadvantages
Two Hour Fire Rating	Steel Requires Spray-on Fire Proofing
Smaller Beam Sizes	
Low Building Weight Impact	
Quick Constructability	

Figure 12- Composite Deck Advantages & Disadvantages

The composite deck floor system was an excellent choice for the Indiana Regional Medical Center. It leaves a lot of flexibility with floor plans and allows the ability to span long distances that other systems cannot achieve. That does not mean that other systems are not reliable and these will be looked at later in the report.

- Precast Hollow Core Planks




Figure 13 – Plank Layout

The first alternative floor system analyzed for Indiana Regional Medical Center was precast hollow core planks. PCI load tables received from the handbook were used in the design of this system. It was found that 4'-10" Normal Weight Concrete Hollow Core Plank would be used according to the safe superimposed service loads from PCI.

Girders were then calculated after the plank size was decided. They were determined to be W27x94 girders. The layout can be found in Figure 13. The typical 26'-0" x 16'-0" bay was changed to a 30'-0" x 20'-0" for this particular system. See Appendix E for detailed calculations.

Pro-Con Analysis

Overall, the hollow core planks do not provide a reduction of total weight when




Figure 14 – Plank Detail

compared to the existing composite system. A detailed image of the planks can be seen in Figure 14. This difference in weight is mainly a result of the normal weight concrete used in the planks versus the lightweight concrete used in the composite system.

Larger girders are even needed to carry the exerted loads from the planks. This system would not produce any savings from a building weight perspective.

From an architectural stand point, the modular 4' sizes would lead to many changes in the bay dimensions. This would create changes in the overall floor plan of the building, which would disrupt the functionality of most of the building due to its current layout. A comparison between advantages and disadvantages can be seen in Figure 15.

Conclusion	
Advantages	Disadvantages
Two Hour Fire Rating	Column Grid Changes
Pre-manufactured	Leveling For Planks
Ease of Constructability	Lead Time Requirement
Low Noise Transmission	

Figure 15- Plank Advantages & Disadvantages

The Precast Hollow Core Planks are easy to rule out because of the affect it would have on the architecture of the building. It has some advantages, but changing the actual architecture of the building is not something that can be considered.

- Two Way Post-Tensioned

The second alternative floor system analyzed for Indiana Regional Medical Center was the Two Way Post-Tensioning Slab. The existing bay dimensions of 16'-0" by 26'-0" were able to be used with this specific system. Portland Cement Association and ACI



318-08 were used to design the system. An example of a Two Way Post-Tensioned System can be seen in Figure 16. It was found that a two way slab was needed because the existing bay dimensions satisfied the equation $L2/L1 < 2$. The post-tensioning comes from the 1/2", 7-wire tendons used throughout the design and the overall slab thickness used was 10.5". The tendons in the 26' side of the bay will be laid out uniformly and the tendons on the 16' side of the bay will be banded together over the column strip. Detailed calculations can be seen in Appendix F.

Figure 16 – Example of a Post-Tensioned System

Pro-Con Analysis

The Two Way Post-Tensioned System is successful because it does not alter the layout of the existing bays. This system would not affect the current floor plan of the building if it was implemented. This is a huge advantage because the other alternative floor

systems chosen would change the current dimensions of the typical bay. This specific design would also create greater floor to floor heights compared to the existing composite system. The slab also provides the required two hour fire ratings from its clear cover.

A disadvantage of the system includes the complexity involved with the construction of the system. A specialized contractor would be needed during the erection. The lateral systems and foundation would also need to be reevaluated due to the increase in weight that would be present. A comparison between advantages and disadvantages can be seen in Figure 17.

Conclusion	
Advantages	Disadvantages
Two Hour Fire Rating	Specialized Construction
Floor Depths	Formwork
Maintaining Existing Dimensions	
Long Spans	

Figure 17- Post-Tensioned Advantages & Disadvantages

The Two Way Post-Tensioned System seems to be a valid alternative floor system for the Indiana Regional Medical Center and should have further investigation.

- Two Way Flat Plate System

The third alternative floor system analyzed for Indiana Regional Medical Center was the Two Way Flat Plate System. It consists of a two way reinforced concrete slab to transfer loads to columns. ACI 318-08 for structural steel was used in the design of this system. An existing typical bay of the building has dimensions of 16'-0" by 26'-0", but these spans were found to be too large for this specific system. Each span was cut in half to make a new dimensioned bay of 8'-0" by 13'-0". This bay was assumed to meet all design reinforcement requirements while allowing for a consistent slab thickness. A slab thickness of 5" was found and used throughout the calculations. An example of a Two Way Flat Plate is shown in Figure 18 and a set of detailed calculations can be found in Appendix G.

Pro-Con Analysis

The Two Way Flat Plate System's advantages do not out-weigh its disadvantages. Its slab thickness would allow for much greater floor to floor heights, which could result in a higher building overall. Besides that, the system's weight is greater than any other alternative system analyzed in this report and new spaces for MEP systems would need provided.




Figure 18- Two Way Flat Plate Example

From an architectural aspect, the system is very large and would double the amount of columns that are already placed throughout the facility. This would put a strain on the layout of the building and on the lateral system. Both the lateral system and foundation would need reevaluated if this system was implemented. All open spaces within the building would also be invaded with columns.

Even if this system was more convenient, it failed to meet many design reinforcement requirements. The calculations in Appendix G show both dimensions being cut in half, but other calculations were also done with only reducing one length of the bay. All calculations failed to meet the required reinforcement for design. A comparison between advantages and disadvantages can be seen in Figure 19.

Conclusion	
Advantages	Disadvantages
Two Hour Fire Rating	Span Length
Ease of Constructability	Addition of Columns
Floor to Floor Height	System Weight
	Construction Time
	Failure to meet Design Requirements

Figure 19– Post-Tensioned Advantages & Disadvantages

A Two Way Flat Plate system does not seem to be appropriate for the Indiana Regional Medical Center and will not be evaluated any further. The negative changes it would create to the building as a whole well not be beneficial.

Conclusion

From the analysis of the Indiana Regional Medical Center, it is safe to conclude that it can withstand all applied loads that were calculated. All typical layouts of the structural system were spot checked for any failures: including a composite slab, composite girder, interior column, and exterior column. All beams and girders have also met deflection standards

The lateral forces due to wind and seismic were also analyzed throughout the report. It was shown that the East-West direction had the strongest wind pressures due to large surface area. The seismic calculations are not needed for this specific location and there was not an adequate amount of information obtained from the engineer to calculate the minimum ground acceleration, but it has been requested and will be compared to the wind calculations when the information is acquired.

Three alternative floor systems were evaluated and compared to each other to the existing floor system. Out of the three alternative systems evaluated, the Two Way Post-Tensioned System is the one that needs to be looked into further. Figure 20 below compares all four systems that are present in the report.

Floor System	Weight	Architectural Impact	Fireproofing	Fire rating	Cost	Constructability	Future Investigation
Composite Deck	44psf	No	Spray on	2 hr	33.20/sqft	Easy	Yes
Two-Way Flat Slab	125psf	Yes	Built In	2 hr	16.85/sqft	Medium	No
Hollow Core Planks	93psf	Yes	Built In	2 hr	23.48/sqft	Easy	No
Two-Way PT	144psf	No	Built In	2 hr	17.18/sqft	Difficult	Yes

Figure 20- Floor System Comparisons

The loads used in the actual design of the building were not significantly different than the loads discovered in ASCE 7-10. In comparing the results, it is easy to see that some characteristics seemed to be over designed, but this error could be related to documents that were not included on the actual floor and structural plans.

Appendix

Appendix A: Wind Load Calculations

	Tech. #1 Calc.			
<u>Wind Loads</u>				
Risk Category: III				
Directionality Factor: $k_d = 0.85$				
Exposure Category: B				
Topographic Factor: $k_{zt} = 1.0$				
Wind Speed: 120 mph				
<u>Section 26.9.5</u>				
$g_a = 3.4 \quad g_v = 3.4$ $g_n = \sqrt{2 \ln(3600n_1)} + \frac{0.577}{\sqrt{2 \ln(3600n_1)}}, \text{ where } n_1 = \frac{1}{T_a}$ <p style="text-align: center;">$T_a = \text{natural period}$</p>				
<u>Section 12.8.2.1</u>				
$T_a = C_t h_n^x \rightarrow C_t = 0.02 \quad \& \quad x = 0.75$				
$T_a = (0.02)(146)^{0.75}$				
$T_a = 0.84$				
$n_1 = \frac{1}{0.84} = 1.19$				
$\hookrightarrow \text{greater than one} \rightarrow \therefore \text{rigid structure.}$				

Tech. #1 Calc.

Wind Loads

Section 27

$$g_R = \sqrt{2 \ln[(31000)(1.19)]} + \frac{0.577}{\sqrt{2 \ln[(31000)(1.19)]}} =$$

$$g_R = 4.0897 + 0.1411 = \underline{4.231}$$

$$I_z = C \left(\frac{33}{z} \right)^{1/6}$$

$$z = 0.6 (\text{height}) = 0.6 (146') =$$

$$z = 87.6'$$

$$C = 0.30$$

$$I_z = (0.30) \left(\frac{33}{87.6} \right)^{1/6} = \underline{0.255}$$

$$L_z = l \left(\frac{z}{33} \right)^e \quad \begin{matrix} l = 320 \\ e = 1/3 \end{matrix}$$

$$L_z = (320) \left(\frac{87.6}{33} \right)^{1/3} = \underline{443.08}$$

$$Q = \frac{1}{\sqrt{1 + 0.63 \left(\frac{B+h}{L_z} \right)^{0.63}}} = \frac{1}{\sqrt{1 + 0.63 \left(\frac{226' + 146'}{443.08} \right)^{0.63}}}$$

$$\underline{Q = 0.7996}$$

Tech. #1 Calc.

Wind Loads

$$R = \sqrt{\frac{1}{\beta} R_n R_h R_B (0.53 + 0.47 R_L)}$$

$$R_n = \frac{7.47 N_1}{(1 + 10.3 N_1)^{5/3}}, \quad N_1 = \frac{n \cdot L \bar{V}_z}{\bar{V}_z}, \quad \bar{V}_z = \bar{b} \left(\frac{\bar{z}}{33}\right)^2 \left(\frac{88}{60}\right) \cdot V$$

$$\rightarrow \text{Solve } \bar{V}_z: \quad \bar{a} = 1/4 \quad \bar{b} = 0.45$$

$$\bar{V}_z = 0.45 \left(\frac{87.6}{33}\right)^{1/4} \left(\frac{88}{60}\right) (120) = 91.9$$

$$\rightarrow \text{Solve } N_1 = \frac{(1.19)(443.08)}{91.9} = 5.737$$

$$\rightarrow \text{Solve } R_n = \frac{(7.47)(5.737)}{[1 + 10.3(5.737)]^{5/3}} = \frac{42.855}{921.8995} = 0.04649$$

$$R_L: \quad n = 15.4 n \cdot L / \bar{V}_z = 15.4(1.19)(92) / (91.9) = 18.35$$

$$R_L = \frac{1}{18.35} - \frac{1}{2(18.35)^2} (1 - e^{-2(18.35)}) = 0.05301$$

$$R_B: \quad n = 4.6 n \cdot B / \bar{V}_z = 4.6(1.19)(226) / (91.9) = 13.46$$

$$R_B = \frac{1}{13.46} - \frac{1}{2(13.46)^2} (1 - e^{-2(13.46)}) = 0.0715$$

$$R_h: \quad n = 4.6 n \cdot h / \bar{V}_z = 4.6(1.19)(146) / (91.9) = 8.696$$

$$R_h = \frac{1}{8.696} - \frac{1}{2(8.696)^2} (1 - e^{-2(8.696)}) = 0.1084$$

$\rightarrow \beta = 1.5\%$ for steel and concrete buildings

$$R = \sqrt{\frac{1}{0.015} (0.04649)(0.1084)(0.0715)[0.53 + 0.47(0.05301)]}$$
$$R = 0.1155$$


Tech. #1 Calc.

Wind Loads

$$G_F = 0.925 \left(\frac{1 + 1.7 I_z \sqrt{g_Q^2 Q^2 + g_R^2 R^2}}{1 + 1.7 g_v I_z} \right) =$$

$$G_F = (0.925) \left(\frac{2.197419}{2.4739} \right) = 0.822$$

→ Enclosure Classification → Enclosed → $G_{Cp} = \pm 0.18$



$$L/B = 92 / 226 = 0.407$$

Windward Wall → 0.8
Leeward Wall → -0.5

$$p = q G_F C_p - q_i (G_{C_{pi}}) \quad K_z = 1.3728$$

$$q = 0.00256 (1.3728) (1.0) (0.85) (120)^2 = 43.0159$$

windward: $p = 28.78 - 28.78 (-0.18) = 33.96 \text{ psf}$

leeward: $p = -14.39 - 28.78 (0.18) = -19.57 \text{ psf}$

→ Wind Loads calculated for the parts of the building over two stories.

Appendix B: Floor System Calculations

Tech. #1 Calc.

Typical Bay with Typical Floor

Composite Slab

- 2" x 18 G.A. Steel Deck
- 3/2" Lightweight Concrete
- 3000 psi Fill

⇒ Use Vulcraft Decking Catalog

↳ use 2VLI18 → Max. unshored clear span
↳ 2 span = 10'-4"

Actual Bay Clear Span = 8'-0" < 10'-4" ∴ OK ✓

Superimposed Live Load = 8'-0" span = 30 psf

Loading ASCE 7-10:

- Operating Rooms = 60 psf
- Patient Rooms = 40 psf
- Corridors = 80 psf
- S.I. Dead Load = 30 psf

Total = 210 psf

210 psf + 30 psf → ∴ OK ✓

↳ The decking designed is ok. It is over designed for this loading, but it is not the controlling load factor.

Tech. #1 Calc.

Composite Beam \rightarrow W14x38

$A_g = 11.2$

$I_x = 428$

$F_y = 50 \text{ ksi}$

$LL = 80$

- not reduced for conservation

$DL = 44 \text{ psf}$

$SW = 44 \text{ plf}$


$SDL = 30 \text{ psf}$

$W_u = 1.2D + 1.6L$

Dead = $(44 + 30)(8') + 44 = 636 \text{ plf}$

Live = $80(8) = 640 \text{ plf}$

$W_u = 1.2(636) + 1.6(640) = 1787.2 \text{ plf} = 1.787 \text{ k/ft}$



$V_u = 1.787(26)(\frac{1}{2}) = 23.23 \text{ k}$

$M_u = 1.787(26)^2(\frac{1}{8}) = 151 \text{ k}$

$b_{eff} = \begin{cases} \text{span}/4 = 6.5 \rightarrow \text{controls} \\ \text{min spacing} = 8' \end{cases}$

$\phi V_n = 131 \text{ k} > 23.23 \text{ k} \therefore \text{OK}$

$PNA = 7 \quad \Sigma Q_n = 140 \quad a = \frac{\Sigma Q_n}{0.85(f'_c)(b_{eff})} = \frac{140}{0.85(3)(6.5 \times 12)}$

$a = 0.704 < 1$

$Y_2 = \text{thickness slab} - \frac{a}{2} = 5.5 - \frac{1}{2} = 5 \rightarrow \text{treat } a = 1$

$\phi M_n = 231 \text{ k} \rightarrow \text{greater than } 151 \text{ k} \therefore \text{OK}$

$Q_n = \frac{140}{17.2} = 8.14 \rightarrow 9 \text{ studs required}$


Deflection

$\Delta_{LL} = \frac{L}{360} = \frac{26(12)}{360} = 0.867 \text{ in} \rightarrow \text{max deflection}$

$\Delta_{LL} = \frac{5W_{LL} L^4}{384EI} = \frac{5(0.64)(26)^4}{384(29000)(428)} (1728) = 0.53 \text{ in}$
 $0.53 \text{ in} < 0.867 \text{ in} \therefore \text{OK}$

	Tech. #1 Calc.		
<p>Deflection of wet concrete:</p> $\Delta_{max} = \frac{l}{240} = \frac{26(12)}{240} = 1.3 \text{ in}$ $I_{req} = \frac{5wL^4}{384 \Delta_{max} E} \quad w = \frac{(44 \times 8) + 44}{1000} = 0.396$ $= \frac{5(0.396)(26)^4}{384(1.3)(29000)} (1728) = 108 \text{ in}^4.$ $108 \text{ in}^4 < 385 \text{ in}^4 \therefore \text{ok } \checkmark$			

Composite Girder = W16x40



→ assume pin supports

→ assume load: $p = 38 \text{ k}$

$$w_u = \frac{80}{1000} = 0.08 \text{ k/ft}$$

$$V_u = \frac{38}{2} + \frac{0.08(16)}{2} = 19.64 \text{ k}$$

$$M_u = \frac{0.08(16)^2}{8} + 38(8) = 306.56 \text{ k}$$

$$PNA = 7 \quad \Sigma Q_n = 147$$

$$b_{eff} = \begin{cases} 16/4 = 4 \rightarrow \text{controls.} \\ \text{spacing} = 8 \end{cases}$$

$$a = \frac{147}{0.85(3)(4)(12)} = 1.2 \quad \hookrightarrow \text{use } a = 1.2$$


$$Y_2 = 5.5 - 0.5 = 5$$

$$\phi M_n = 309 \text{ k} > 306.56 \text{ k}$$

$$\phi V_n = 14 \text{ k} > 19.64 \text{ k}$$

> ∴ ok.

Appendix C: Floor System



Appendix D: Column Check

Tech. #1 Calc.
Columns

→ Looking at column F3


Tributary Area
 $(16')(26') = 416 \text{ ft}^2$

LL: Floors = 80psf

Appendix E: Precast Hollow Core Planks

Tech. #2 Calc.

Precast Hollow Core Planks



26'-0"

19'-0"

Typical Bay

PCI Design Handbook → 4'x10" NWC

SDL = 25


LL = 100 100 + 25 = 125

PCI uses unfactored loads

→ Would change bay dimensions to 30'-0" x 20'x0" to allow for easy fitting of planks.

→ Span of 30'

→ 2" topping for 2 hour fire rating



30'-0"

20'-0"

New Typical Bay

58-5 → DL = 93psf with 2" topping

93 + 25 = 118 psf, LL = 100

1.2(118) + 1.6(100) = 301.6 psf

Tributary Width → 30'(301.6) = 9048 = 9.05 k/ft

$M_u = \frac{w_u l^2}{8} = \frac{(9.05)(30)^2}{8} = 1018.12 k \rightarrow \text{Try}$

@ 30' → $\Delta_{LLmax} = \frac{l}{360} = 1.0"$

↳ $\frac{5(100 \cdot 20)(30)^4(1728)}{384(29000)(I)(1000)} \geq 1257$

Tech. #2 Calc.

Precast Hollow Core Planks

$$@ 30' \rightarrow \Delta_{DL} = \frac{q}{240} = 1.5'' = \frac{5(118+100)(20)(30)^4 (1728)}{384(29000)(I)(1000)}$$

$$\hookrightarrow I \geq 1827$$

$$W27 \times 94 \rightarrow \phi M_n = 1040 \geq 1018.12^k \therefore \text{OK}$$

$$I = 3270 > 1827 \therefore \text{OK}$$

→ use W27×94 girders with hollow
core plank

↳ 4'-0" × 10" w/ 2" topping, 58-5

Appendix F: Two Way Post-Tension System

Tech. #2 Calc.

Two-Way Post Tension

Loads: selfweight
SDL = 25
LL = 100

2 Hour Fire Rating

Rectangular Spans:
→ Bonds in short direction over columns
→ Uniform in long direction

Rebar: $F_y = 60,000 \text{ psi}$

Normal Weight Concrete: 150 pcf
→ $f'_c = 5000 \text{ psi}$
→ $f'_{ci} = 3000 \text{ psi}$

PT: unbonded tendons → $\frac{1}{2}'' \text{ } \phi$, 7 wire strands, ($A = 0.153 \text{ in}^2$)
 $f_{pu} = 270 \text{ ksi}$
 Prestress losses = 15 ksi
 $f_{ce} = 0.7(270) - 15 = 174 \text{ ksi}$
 $P_{eff} = 0.153(174) = 26.6 \text{ k}/\text{tendon}$

Preliminary Slab Thickness: $l/n = 30 \quad h = \frac{26(12)}{30} = 10.4$
 $\hookrightarrow \approx 10.5''$

$DL = \frac{10.5}{12} (150) = 131.25 \text{ psf} \quad \text{SDL} = 25 \text{ psf}$

LL reduction Exterior Bay $A_T = 116(26) = 416$
 $K_{LL} = 1$
 $LL = 0.67(100) = 67$

$a_{int} = 9.5 - 1 = 8.5''$ $a_{end} = \left(\frac{5.25 + 8.5}{2} \right) - 1.25 = 5.625''$

Tech. #2 Calc.

Two-Way Post Tension

→ E-W Direction

→ Prestress force to balance 60% of SW DL

$$w_D = 0.6(131.25)(26) = 2.048 \text{ k/ft}$$

$$P = \frac{2.048 (16)^2}{8 \left(\frac{5.625}{12} \right)} = 139.81 \quad \frac{139.81}{26.6} = \boxed{6 \text{ tendons}}$$

$$P_{act} = 6(26.6) = 159.6 \quad \text{Balance Load} = \frac{159.6}{139.81} (2.048)$$

↳ 2.34 k/ft

$$\text{Actual Precompression Stress} = \frac{159.6}{(10.5 \cdot 26 \cdot 12)} = 48.7 \text{ psi}$$

→ N-S Direction

→ Prestress force to balance 95% of SW DL

$$w_D = 0.95(131.25)(13) = 1.62 \text{ k/ft}$$


$$P = \frac{(16)^2}{8 \left(\frac{5.625}{12} \right)} = 68.27 \text{ k} \quad \frac{68.27}{26.6} = \boxed{3 \text{ tendons}}$$

$$P_{act} = 3(26.6) = 79.8 \quad \text{Balance Load} = \frac{79.8}{68.27} = 1.17 \text{ k/ft}$$

$$\text{Actual Precompression Stress} = \frac{79.8}{(10.5 \cdot 13 \cdot 12)} = 48.7 \text{ psi}$$

→ DL Moments N-S

$$w_{DL} = (131.25 + 25)(13) / 1000 = 2.03$$




Tech. #2 Calc.


Two-Way Post Tension

→ LL Moments N-S

$$W_{LL} = 13(13)/1000 = 0.169$$




→ Balance Moments → 1.17




E-W


→ DL Moments → $w_{DL} = 2.5$



→ LL Moments E-W → $w_{LL} = 2$



→ Balance Moment → $w_B = 1.122$



Tech. #2 Calc.

Two-Way Post Tension

$$S = \frac{(13)(10.5)^2(12)}{6} = 28666.5$$

N-S → Stage 1:

→ Int. Span

$$F_{top} = \left[\frac{(-13 + 7.5)(12)(1000)}{28666.5} \right] - 48.7$$

$$= \boxed{-71.7 \text{ psi} \rightarrow \text{OK}}$$

$$F_{bot} = \left[\frac{(13 - 7.5)(12)(1000)}{28666.5} \right] - 48.7$$

$$= \boxed{-25.7 \text{ psi} \rightarrow \text{OK}}$$

→ End Span

$$F_{top} = \left[\frac{(-41.57 + 24)(12000)}{28666.5} \right] - 48.7$$

$$= \boxed{-122.3 \text{ psi} \rightarrow \text{OK}}$$

$$F_{bot} = \left[\frac{(41.57 - 24)(12000)}{28666.5} \right] - 48.7$$

$$= \boxed{24.9 \text{ psi} \rightarrow \text{OK}}$$

→ Support stress

$$F_{top} = \left[\frac{(51.97 - 30)(12000)}{28666.5} \right] - 48.7$$

$$= \boxed{43.3 \text{ psi} \rightarrow \text{OK}}$$

$$F_{bot} = \left[\frac{(-51.97 + 30)(12000)}{28666.5} \right] - 48.7$$

$$= \boxed{-140.7 \text{ psi} \rightarrow \text{OK}}$$

N-S → Stage 2: Stress at Service (DL+LL+PT)

→ Int. Span

$$F_{top} = \left[\frac{(-13 - 0.0042 + 7.5)(12000)}{28666.5} \right] - 48.7$$

$$= \boxed{-71.7 \text{ psi} \rightarrow \text{OK}}$$

$$F_{bot} = \left[\frac{(13 + 0.0042 - 7.5)(12000)}{28666.5} \right] - 48.7$$

$$= \boxed{-25.7 \text{ psi} \rightarrow \text{OK}}$$

Tech. #2 Calc.

Two-Way Post Tension

→ End Span

$$F_{top} = \frac{[-41.57 - 0.014 + 24](12000)}{29666.5 - 48.7} = -122.31 \text{ psi} \rightarrow \text{ok}$$

$$F_{bot} = \frac{[41.57 + 0.014 - 24](12000)}{29666.5 - 48.7} = 24.9 \text{ psi} \rightarrow \text{ok}$$

→ Support Stress


$$F_{top} = \frac{[51.97 + 4.33 - 30](12000)}{29666.5 - 48.7} = 61.4 \text{ psi} \rightarrow \text{ok}$$

$$F_{bot} = \frac{[-51.97 - 4.33 + 30](12000)}{29666.5 - 48.7} = -158.8 \text{ psi} \rightarrow \text{ok}$$

Ultimate Strength:

$$M_i = P \cdot e = (79.8)(3")/12 = 20.0$$

$$M_{sec} = 48.7 - 20.0 = 28.7 \text{ at int. supports.}$$



$$M_u \text{ @ midspan} = 1.2(41.57) + 1.6(0.014) + 1.0\left(\frac{28.7}{2}\right) = 64.3 \text{ k}$$

$$M_u \text{ @ support} = 1.2(51.97) + 1.6(4.33) + 1.0\left(\frac{28.7}{2}\right) = -55 \text{ k}$$

Tech. #2 Calc.

Two-Way Post Tension

→ Min. Bonded Reinforcement

Positive Moment: Interior Span $f_t = - \leq 2\sqrt{f'_c} = 141 \text{ psi}$

→ none required

End Span $f_t = 69 \text{ psi} \leq 141 \text{ psi}$

→ none required

Negative Moment:

Int. Supports → $A_{smin} = 0.00075A_{cf}$ $A_{cf} = (10.5)(\frac{16}{2})(12)$

$A_{smin} = 0.756 \text{ in}^2$ $\hookrightarrow 1008$

↳ 4- #4 bars top (0.80 in^2)

Ext. Supports: $A_{smin} = 1.5 \text{ in}^2$ 4- #4 bars top (0.80 in^2)

Check Min. Reinforcement

$$M_n = (A_s f_y + A_p f_{ps}) (d - a/2) \quad d = 9.5$$

$$A_p = 0.153(25) = 3.83$$

$$f_{ps} = 174000 + 10000 + [(5000)(26)(12)(9.5)] / [300 \cdot 3.83]$$

$$\hookrightarrow 196,898.$$

$$a = [(1.6)(160) + (3.83)(196)] / (0.85 \cdot 5 \cdot 26 \cdot 12) = 0.64$$

$$\phi M_n = 0.9 [(1.6)(160) + (3.83)(196)] (9.5 - \frac{0.64}{2}) / 12$$

$$\phi M_n = 582.9$$

N-S Summary

@ Neg. Moment 8- #4 top bars

(25) 1/2" ϕ , 7-wire strands along col. strips

Tech #2 Calc.

Two-Way Post Tension

E-W → Stage 1: (DL+PT) $w_p = 1.62 w_o = 2.5$ $w_L = 2$

End Span $S = \frac{(12)(12)(10.5)^2}{6} = 3528$

$F_{TOP} = \frac{[-118 + 77](12000)}{3528 - 48.7} = -188.2$ psi tension → not ok → ignore for preliminary design

$F_{BOT} = \frac{[118 - 77](12000)}{3528 - 48.7} = 90.8$ psi → Comp. → ok.

Support Stress

$F_{TOP} = \frac{[211 - 137](12000)}{3528 - 48.7} = 203$ psi → C → ok

$F_{BOT} = \frac{[-211 + 137](12000)}{3528 - 48.7} = -300$ psi → T → not ok but ignore

E-W → Stage 2: (bL+LL+PT)

End Span

$F_{TOP} = \frac{[-118 - 95 + 77](12000)}{3528 - 48.7} = -150.1$ → not ok, T

$F_{BOT} = \frac{[118 + 95 - 77](12000)}{3528 - 48.7} = 52.7$ → C → ok.

Support Stress

$F_{TOP} = \frac{[211 + 109 - 137](12000)}{3528 - 48.7} = 777.8$ psi - C - ok

$F_{BOT} = \frac{[-211 - 109 + 137](12000)}{3528 - 48.7} = -875$ → T - not ok.

→ Some tension values are off but decided they are ok for preliminary design.

→ Model as 3 span in future.


Tech. #2 Calc.

Two-Way Post Tension

Ultimate Strength

$$M = P \cdot e = 159.6(3) / 12 = 39.9$$

$$M_{sec} = 48.7 - 39.9 = 8.8$$



$$M_u @ \text{midspan} = 1.2(118) + 1.6(95) + 1.0\left(\frac{8.8}{2}\right) = 298 \text{ k.}$$

$$M_u @ \text{support} = 1.2(-211) + 1.6(-169) + 8.8 = -514.8 \text{ k.}$$

→ Neglecting interior span for preliminary design.

Neg. Moment Region.

$$A_{cf} = 10.5(26) / 2(12) = 11638.$$

$$A_{smin} = 1.23 \text{ in}^2$$


Use 4 - #5 bars top (1.24 in²)

Summary E-W

4 - #5 bars top

(45) 1/2" Ø 7-wire strands,

Final



Appendix G: Two Way Flat Plate System

Tech. #2 Calc.

Two-Way Flat Plate System

→ Designed using ACI 318.08
 → Use typical bay floor plan: See Below ↓ change
 ↳ assume 18" x 18" columns

→ Critical bay size would be 8' x 20' (Table 9.5c)

Min. Slab thickness: $t = \frac{d_n}{33} = \frac{13 - \frac{13}{12}}{33} = 4.7'' \rightarrow$ use 5" slab

∴ DL = $150 \left(\frac{5}{12}\right) = 62.5 + 25 = 87.5$ psf

$1.2(D) + 1.6(L) = 1.2(87.5) + 1.6(100) = 265 \Rightarrow 0.27$ ksf

$V_0 = (0.265) [(13 \times 8) - (1.5)^2] = 26.69$ k

Punching Shear → Assume #5 bars

→ $d = 5'' - 0.75 - 0.125 = 3.625''$

→ $b_0 = (18 + 3.625)4 = 86.5''$

$V_c = \left\{ \begin{aligned} &4\sqrt{f'_c} b_0 d = 4\sqrt{5000} (86.5)(3.625) = 89 \text{ k} \\ &\left(2 + \frac{4}{\beta_c}\right)\sqrt{f'_c} b_0 d = \left(2 + \frac{4}{1.63}\right)\sqrt{5000} (86.5)(3.625) = 99 \text{ k} \\ &\left(\frac{\phi \times d}{b_0} + 2\right)\sqrt{f'_c} b_0 d = \left(\frac{40 \times 3.625}{86.5} + 2\right)(86.5)(3.625)\sqrt{5000} = 82 \text{ k} \end{aligned} \right.$

min. $\beta_c = \frac{13}{8} = 1.63$ $V_c = 82 \text{ k}$

Tech. #2 Calc.

Two-Way Flat Plate System

$\phi V_c = (0.75)(82) = 61.5 \text{ k} \therefore \text{OK}$

→ No Drop Panel needed

Direct Design Method

$M_0 = \frac{q_u}{8} l_2 l_n^2 \quad q_u = 1.2 \left(\frac{5}{12} 87.5 + 25 \right) + 1.6(100) = 234$


→ Frame A: $\frac{0.234}{8} (8)(13-1.5)^2 = 30.95 \text{ k}$

→ Frame B: $\frac{0.234}{8} (13)(8-1.5)^2 = 16.1 \text{ k}$


Distribution of M_u :

$-M = 0.65 M_0 \quad +M = 0.35 M_0 \quad (13.6.3.2)$

Frame A:



Frame B:



Distribution to Column Strip:

Frame A:

$-M_{nt} = 0.75M = 15.1 \text{ k}$ to C.S.
5 k to M.S.

$+M_{nt} = 0.60M = 6.5 \text{ k}$ to C.S.
4.3 k to M.S.

Frame B:

$-M_{nt} = 7.9 \text{ k}$ to C.S.
2.6 k to M.S.

$+M_{nt} = 3.4 \text{ k}$ to C.S.
2.2 k to M.S.

Tech. #2 Calc.

Two-Way Flat Plate System

→ Summary of Moments:


Frame A:

Total M	20.1	10.8
CS M	15.1	6.5
MS M	5	4.3

Frame B:

Total M	10.5	5.6
CS M	7.9	3.4
MS M	2.6	2.2

→ Assume d



Frame A: $d = 5 - 0.75 - \frac{0.025}{2} = 3.94"$

Frame B: $d = 3.94 - 0.025 = 3.31"$

Design Reinforcement

Frame A:	Description	-Mcs	-Mms	+Mcs	+Mms
	Moment	-15.1	-5	6.5	4.3
	width b	48"	48"	48"	48"
	Eff d	3.94"	3.94"	3.94"	3.94"
	$M_n = M_u / \phi$	-16.8	-5.6	7.2	4.8
	$R = M_n / d^2 b \times 12000$	271	90	116	77
	ρ	0.0047	0.0015	0.00197	0.00129
	$A_s = \rho b d$	0.89	0.28	0.373	0.243
	$A_{smin} = b t (.002)$	0.48	0.48x	0.48x	0.48x
	$N = A_s / A_{sbar}$	3	1	2	1
	$N_{min} = w / 2t$	5x	5x	5x	5x

→ #5 bars → $A_s = 0.31$

Tech. #2 Calc.

Two-Way Flat Plate System

Frame B: description	-M _{cs}	-M _{ms}	+M _{cs}	+M _{ms}
Moment	-7.9	-2.6	3.4	2.2
width, b	78"	78"	78"	78"
Eff, d	3.31"	3.31"	3.31"	3.31"
M _n = M _u /φ	-8.8	-2.9	3.8	2.4
R _n = M _n /d ² b × 12000	124	41	53	34
p	0.0021	0.00069	0.00089	0.00057
A _s = pbd	0.542	0.18	0.229	0.147
A _{smin} = bt(0.02)	0.78x	0.78x	0.78x	0.78x
N = A _s /A _{smin}	1	1	1	1
N _{min} = w/2t	8x	8x	8x	8x

- Results do not satisfy requirements,
- Two-way Flat plate is not acceptable for IRMC.