

Bentworth Middle School

Bentleyville, PA



Technical Report One

An analysis of ASHRAE Standard 62.1-2007
and ASHRAE Standard 90.1-2007



Prepared By | Kyle Courtney
Mechanical Option
Advisor | Dr. James D. Freihaut
Date | October 4, 2010

Table of Contents

Executive Summary	3
ASHRAE Standard 62.1-2007 Evaluation.....	4
Section 5 Compliance – Systems and Equipment.....	4
Section 6 Compliance – Procedures.....	6
ASHRAE 62.1-2007 Summary.....	9
ASHRAE Standard 90.1-2007 Evaluation.....	10
Section 5 Building Envelope.....	10
Section 6 Heating, Ventilating, and Air Conditioning.....	11
Section 7 Service Water Heating	12
Section 8 Power.....	13
Section 9 Lighting	13
ASHRAE Standard 90.1-2007 Summary.....	13
References.....	15
Appendix A – Ventilation Load Calculations.....	16

Executive Summary

The purpose of this report is to determine whether Bentworth Middle School complies with ASHRAE Standard 62.1-2007 and ASHRAE Standard 90.1-2007.

The newly built Bentworth Middle School is located Bentleyville, PA. The school is considered a state-of-the-art facility and just opened its doors to students grades five through eight in January 2009. Ensuring that the students and staff were provided with a comfortable and functional learning and working environment was a priority. Directly related to this is air quality and energy efficiency of the building as clean, fresh air is ideal in any environment and schools are always looking to save money on energy expenditure in order to provide more money allowance to go into furthering student education. Therefore, ASHRAE Standards 62.1 and 90.1 are very relevant design parameters.

The evaluation of ASHRAE Standard 62.1-2007 showed that the building just fell short of complete compliance with the standard. The two primary sections of this standard that were evaluated were *Section 5 Systems and Equipment* and *Section 6 Procedures*. Bentworth Middle School complied with all parts of Section 5, displaying the school's excellence in system design and equipment use. However, when the school's ventilation rates were studied under the procedures outlined in Section 6 a discrepancy was found. It appeared that one of the rooftop heat pumps was not capable of providing the required amount of ventilation air. Since this rooftop unit is providing outdoor air to the heat pumps in the classroom wing, it is believed that it will still be able to provide adequate ventilation air to spaces as it is very unlikely that all of the spaces will require peak ventilation air rates at the same time. It is also believed that ASHRAE assumed a higher number of occupants in some of the spaces than what was actually designed for.

It was also determined that Bentworth Middle School was just shy of compliance with ASHRAE Standard 90.1-2007. The two primary areas where the building fell short were *Fan Power Limitation* and the flooring U-value. It was also difficult to differentiate whether or not the building's heat pumps met the minimum efficiency requirements outlined in this standard because the entering water temperatures ASHRAE used to determine the minimum COP and EER values were different than the design entering water temperatures at Bentworth Middle School.

Although Bentworth Middle School did not achieve complete compliance with either of the standards this report shows that the school's design was still incredibly accurate and energy efficient. If some additional considerations had been given to ASHRAE Standards 62.1 and 90.1 early on in the design process or if a few minor alterations are made to the building, Bentworth Middle School would easily be in accordance with the standards.



ASHRAE Standard 62.1-2007 Evaluation

Section 5 Compliance – Systems and Equipment

5.1 Natural Ventilation

Although many of the spaces are designed to include operable double hung windows, they were not intended to be the sole source for fresh air. However, many of the spaces, such as the classrooms, are capable of being naturally ventilated given the right outdoor air conditions as the amount of openable window area is at least 4% of the floor area and is within 25 feet of the space.

5.2 Ventilation Air Distribution

The specifications state that the various mechanical equipment responsible for providing ventilation have controls able to maintain an adjustable minimum ventilation rate under any load condition as required by Section 6 of ASHRAE 62.1. A full analysis of Section 6 can be found in this report.

5.3 Exhaust Duct Location

Spaces that contain potentially harmful contaminants are equipped with exhaust fans. Each of these fans exhaust air at high speeds of over 1000 fpm. Such speeds will create a negative pressure in the duct relative to the room, ensuring that the space is not polluted by the contaminant. Furthermore, all ducts are sealed in accordance with SMACNA standards.

5.4 Ventilation System Controls

The mechanical ventilation of the building is mainly provided by six rooftop heat pumps. Two of these rooftop units simply provide ventilation air to the heat pumps serving the classrooms, library, and office area. When any of these zones are in an occupied mode, the rooftop units will energize and operate to provide tempered ventilation air as required. This requirement is determined by a static pressure sensor installed in the ductwork which will increase the variable frequency drive supply and return fans' speed when the static pressure in the duct decreases or it will decrease the fans' speed if the static pressure increases. The remaining four rooftop units provide air to large spaces and use a demand controlled ventilation sequence which is dictated by CO₂ sensor in the space. This sensor measures the differential CO₂ level between the outdoor and indoor environments. If this differential rises above 700 ppm, then the outdoor air damper will modulate open as needed to maintain a differential below 700 ppm. As the differential CO₂ level drops below 700 ppm the outdoor air damper will close. As an energy saving feature, the enthalpy economizer controls are able to override the demand controlled ventilation controls if economizer cooling is available.

5.5 Airstream Surfaces

The specifications for basic mechanical requirements state that all product materials must be UL listed and the duct specifications require that all ductwork fabrication and support must be in accordance with

SMACNA HVAC Duct Construction Standards. These standards state that a minimum resistance to mold growth and erosion must be met, satisfying this section.

5.6 Outdoor Air Intakes

All air intakes are located either in the mechanical mezzanine or on the roof and abide by the minimum separation distance. Both the wall louvers and mechanically operated dampers comply with AMCA 500. The wall louvers also have bird screens conforming to this section. This is all the information pertaining to this section available at this time.

5.7 Local Capture of Contaminants

Any equipment that produces building contaminants is equipped with an exhaust fan which routes the exhaust direct out of the building through the roof.

5.8 Combustion Air

All combustion equipment is provided with sufficient combustion air and is adequately exhausted. Specifically, the natural gas fired emergency generator was provided with a wall louver by the general contractor and it is specified that it was to be provided with a Schedule 40 black steel pipe exhaust.

5.9 Particulate Matter Removal

The rooftop heat pumps have pleated air filters with an atmospheric efficiency between 25% and 30% located upstream of their cooling coils. This is equivalent to a MERV 6 or MERV 7 filter and is therefore in compliance.

5.10 Dehumidification

The heat pumps are equipped with humidity sensors that maintain a relative humidity within the space at 60% or less. Additionally, a pressure sensor ensures that the room pressure remains at +0.05 in wg relative to the outdoor pressure in order to prevent infiltration.

5.11 Drain Pans

It is specified that all rooftop heat pumps be constructed of 20-gauge stainless steel, sloped, and positioned under the evaporator coil and meet all requirements of ASHRAE 62.1.

5.12 Finned-Tube Coils and Heat Exchangers

Drain pans have been provided as necessary and in compliance with 5.11 and there are no finned-tube coils in series.

5.13 Humidifiers and Water-Spray Systems

No humidifiers or water-spray systems are used in the building so this section is not applicable.

5.14 Access for Inspection, Cleaning, and Maintenance

Appropriate clearances to allow unobstructed access to all equipment doors and panels as indicated in this section have been specified for the purposes of inspection, cleaning, and maintenance.

5.15 Building Envelope and Interior Surfaces

In order to prevent moisture penetration of the foundation, both a modified bituminous membrane sheet waterproofing and cold towel-applied asphalt bituminous dampproofing were used. A vapor barrier below the slab on grade is also provided. Within the exterior wall assembly there is 1 ½ inch rigid insulation board applied to the block in full bed mastic which acts as the vapor barrier. All exterior and interior joints and openings have been specified to be sealed or caulked.

All duct and pipe surfaces within the building that may fall to a temperature capable of producing condensation on their surface have been properly insulated in order to prevent moisture collection both on the exposed surface and within the insulating material.

5.16 Buildings with Attached Parking Garages

This section is not applicable as there is no parking garage attached to Bentworth Middle School.

5.17 Air Classification and Recirculation

All building air has a Class 1 designation which allows it to be recirculated or transferred to any space. The only exception to this would be the kitchen air, which is simply exhausted to the exterior of the building through the kitchen hood.

5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas

The property on which Bentworth Middle School is located is designated a tobacco free zone. Therefore, this section does not apply.

Section 6 Compliance – Procedures

Summary of Section 6

The purpose of ASHRAE Standard 62.1 Section 6 is to outline the proper procedure for calculating the outdoor air intake rates based on “space type/application, occupancy level, and floor area.” This calculation procedure is very stringent and involves many considerations and equations. Therefore, the procedure for the calculations for Bentworth Middle School are outlined on the next page.

Breathing Zone Outdoor Airflow

$$V_{bz} = R_p * P_z + R_a * A_z \quad (\text{Equation 6-1})$$

where: $A_z =$ zone floor area: the net occupiable floor area of the zone (ft²)

$P_z =$ zone population: the largest number of people expected to occupy the zone during typical usage. If the number of people expected to occupy the zone fluctuate, P_z may be estimated based on averaging approaches described in Section 6.2.6.2. If P_z cannot be accurately predicted during design, it shall be an estimated value based on the zone floor area and the default occupant density listed in Table 6-1.

$R_p =$ outdoor airflow rate required per person as determined from Table 6-1

$R_a =$ outdoor airflow rate required per unit area as determined from Table 6-1

Zone Air Distribution Effectiveness

$E_z = 1$ as determined by Table 6-2 of ASHRAE Standard 62.1

Zone Outdoor Airflow

$$V_{oz} = V_{bz} / E_z \quad (\text{Equation 6-2})$$

Single-Zone Systems

$$V_{ot} = V_{oz} \quad (\text{Equation 6-3})$$

100% Outdoor Air Systems

$$V_{ot} = \sum_{\text{all zones}} V_{oz} \quad (\text{Equation 6-4})$$

Primary Outdoor Air Fraction

$$Z_p = V_{oz} / V_{pz} \quad (\text{Equation 6-5})$$

System Ventilation Efficiency

E_v shall be determined using Table 6-3 of ASHRAE Standard 62.1 which is shown on the next page.

Uncorrected Outdoor Air Intake

$$V_{ou} = D \sum_{\text{all zones}} (R_p * P_z) + \sum_{\text{all zones}} (R_a * A_z) \quad (\text{Equation 6-6})$$

where: $D = P_s / \sum_{\text{all zones}} P_z \quad (\text{Equation 6-7})$

$P_s =$ system population: is the total population in the area served by the system

Outdoor Air Intake

$$V_{ot} = V_{ou} / E_v$$

TABLE 6-3 System Ventilation Efficiency

Max (Z_p)	E_v
≤ 0.15	1.0
≤ 0.25	0.9
≤ 0.35	0.8
≤ 0.45	0.7
≤ 0.55	0.6
> 0.55	Use Appendix A

1. "Max Z_p " refers to the largest value of Z_p , calculated using Equation 6-5, among all the zones served by the system.
2. For values of Z_p between 0.15 and 0.55, one may determine the corresponding value of E_v by interpolating the values in the table.
3. The values of E_v in this table are based on a 0.15 average outdoor air fraction for the system (i.e., the ratio of the *uncorrected outdoor air intake* V_{ou} to the total *zone primary airflow* for all the zones served by the air handler). For systems with higher values of the average outdoor air fraction, this table may result in unrealistically low values of E_v and the use of Appendix A may yield more practical results.

Seven units provide ventilation air to Bentworth Middle School including six rooftop heat pump units and one energy recovery ventilator (ERV). However, for this analysis only five of the rooftop heat pump units were seen as critical pieces of ventilation equipment and therefore were considered to evaluate the building's compliance with Section 6. The ERV was not considered because it only provides a small amount of outdoor air (1300 cfm) to the locker room areas and ASHRAE Standard 62.1 does not specifically outline ventilation rates for this type of space. Rooftop heat pump B5 was also not considered because it only provides make-up air for the kitchen hood and does not actually ventilate the space.

Section 6 Compliance Results

An Excel spreadsheet was used to determine whether or not Bentworth Middle School's ventilation rates met ASHRAE's Standard 62.1 Section 6 expectations. This Excel spreadsheet uses the equations outlined above and user input values for a space's square footage, room occupancy type, and supply air. The complete results of these calculations are located in Appendix A, but below is a table summarizing the building's compliance.

As can be seen on the next page, not all of the rooftop heat pumps meet the ventilation requirements of the zones that they are supplying. It is worrisome that RTHP-A1 seems to be grossly undersized, but there could be reasons behind this and there is only a small discrepancy between the design and required outdoor air values for RTHP-B3 so this is not very bothersome as the unit should still be able to do its job.

Table 1 – Summary of Ventilation Rate Calculations

RTHP	Design Max CFM	Design OA CFM	ASHRAE 62.1 Min OA	Compliance?
A1	11,500	11,500	18,487	No
B1	3,500	3,500	3,175	Yes
B2	6,000	4,110	3,538	Yes
B3	2,100	1,110	1,176	No
B4	10,000	8,000	4,791	Yes

ASHRAE 62.1-2007 Summary

The design of Bentworth Middle School is completely compliant with Section 5 of ASHRAE 62.1 but one of the rooftop heat pumps appears to not meet its peak ventilation requirements as outlined by Section 6. This is troubling, further investigation will have to be done to see why this is. Perhaps, it is because it is unlikely that all of the spaces served by RTHP-A1 with require peak ventilation at the same time and that the average number of people that ASHRAE assumes to be the space is larger than what the building spaces were actually designed for.

ASHRAE Standard 90.1-2007 Evaluation

Section 5 Building Envelope

5.1.4 Climate

Using Figure B-1 from ASHRAE 90.1, shown below, it was determined that Bentworth Middle School, located in Bentleyville, PA, is in climate Zone 5A.




Figure B-1

5.4 Mandatory Provisions

The building is specified to have all joints, seams, fenestrations, and all other openings sealed or caulked. The main entrance to the building has a vestibule where the exterior and interior doors are separated by a distance of 20 feet. This distance is greater than the 7 foot minimum requirement. Bentworth Middle School has no cargo or loading dock doors.

5.5 Prescriptive Building Envelope Option

There are two ways to achieve compliance for the building envelope. The prescriptive path option was chosen over the trade-off path for this analysis. The two primary parameters that must be followed for this path are meeting the minimum building envelope requirements and having no more than the allowable 40% fenestration area. Both of these requirements were met. A summary of the necessary calculations needed to reach this conclusion are below in Table 2 and Table 3.

Table 2 – Minimum Building Envelope Requirements

Area	Construction Method	Prescribed Nonresidential		Designed Assemblies		Compliance?
		Assembly Maximum	Insulation Minimum	Assembly Maximum	Insulation Minimum	
Roof	Attic	U-0.027	R-38.0	U-0.025	R-40	Yes
Walls Above Grade	Mass	U-0.090	R-11.4	0.076	R-13.2	Yes
Walls Below Grade	Below-Grade Wall	C-0.119	R-7.5	C-0.121	R-8.3	Yes
Floors	Mass	U-0.074	R-10.4	U-0.45	R-2.2	No
Slab on Grade Floors	Unheated	F-0.730	NR	F-0.721	NR	Yes
Fenestration	Metal Framing (storefront)	U-0.45	SHGC-0.40	U-0.42	SHGC-0.36	Yes
	Metal Framing (all other)	U-0.55	SHGC-0.40	U-0.51	SHGC-0.34	Yes

Table 3 – Building Fenestration Percentage Calculation

Fenestration Area	Wall Area	Percent Fenestration	Compliance?
5,800 ft ²	35,080 ft ²	16.5%	Yes

Section 6 Heating, Ventilating, and Air Conditioning

6.2 Compliance Path

There are two compliance paths that may be followed. For this analysis the Mandatory Provisions path shall be used as Bentworth Middle School is more than two stories and over 25,000 ft².

6.4 Mandatory Provisions

The primary mechanical equipment used in Bentworth Middle School is heat pumps, which are governed by this section. Although COP's and EER's were given for the heat pumps, without having the manufacturer information for these pieces of equipment it is hard to differentiate whether they satisfy this section or not. Table 6.8.1B of ASHRAE 90.1 mandates that all ground source heat pumps in cooling mode with an entering water temperature of 59 °F have an EER of 16.2 and while in heating mode with an entering water temperature of 32 °F have COP of 3.1. Bentworth Middle School's design is based on entering water temperatures of 75 °F and 42 °F for cooling and heating respectively. Nonetheless, at the design temperatures most of the given COP's for each of the heat pumps meet the set standard of 3.1, while very few of the heat pumps achieved an EER of 16.2.

Bentworth Middle School's rooftop heat pumps would be considered packaged terminal heat pump units which are also regulated by this section. Table 6.8.1D requires that these units have a minimum EER of 9.1. Unfortunately, the EER's for these units are unavailable at this time.

It is specified that there be a 5 °F dead band as well as the appropriate amount of insulation be applied to all ductwork, plenums, and piping. The motorized dampers for all vents and air intakes have the appropriate controls as outlined in this section.

6.5 Prescriptive Path

Economizers are required on cooling equipment over 135,000 Btu/h in climate zone 5A. However, there are no economizers on the rooftop heat pumps which are over the specified cooling rate, but there are water economizers on the heat pumps serving the classroom spaces despite them being under the specified cooling rate.

All rooftop heat pumps are equipped with an enthalpy wheel for energy recovery from exhausted air. This is in compliance with this section of ASHRAE 90.1. It is also specified that all heat pumps have the capability to switch off their compressor should the refrigerant pressure drop below a safe operating point.

Table 4, below, shows how Bentworth Middle School meets ASHRAE 90.1's *Fan System Power Limitation*. Six out of the 13 analyzed fans do not comply with this section of ASHRAE's 90.1.

Table 4 – Fan System Power Limitation Calculations

Equipment	HP	CFM	CFM*0.0011	Compliance?
RTHP-A1 Supply	15	11,500	12.56	No
RTHP-A1 Exhaust	15	11,500	12.56	No
RTHP-B1 Supply	3	3,500	3.85	Yes
RTHP-B1 Exhaust	3	3,500	3.85	Yes
RTHP-B2 Supply	5	6,000	6.60	Yes
RTHP-B2 Exhaust	5	6,000	6.60	Yes
RTHP-B3 Supply	5	2,100	2.31	No
RTHP-B3 Exhaust	3	2,100	2.31	No
RTHP-B4 Supply	15	10,000	11.00	No
RTHP-B4 Exhaust	10	10,000	11.00	Yes
RTHP-B5 Supply	15	4,270	4.70	No
EF-A1	1.5	3,800	4.18	Yes
EF-B3	3	4,500	4.95	Yes

6.7 Submittals

All building drawings and manuals were provided to the building owner within the required 90 days and it is specified that all HVAC systems were to be balanced.

Section 7 Service Water Heating

Four gas-fired storage water heaters provide domestic hot water to Bentworth Middle School. Each of the water heaters has an efficiency of 90% or more which exceeds this section's minimum requirement of an efficiency of 80%. The water heaters are also equipped with a thermostat with adjustable temperature range from 110 F to 180 F. The service hot-water piping is specified to be insulated with a minimum of one inch of insulation which is the same amount that is required by this section.

Section 8 Power

No information pertaining to the maximum voltage drop for the feeders or branch circuits is available at this time. All design documents were submitted to the building owner within the specified amount of time in this section.

Section 9 Lighting

This section outlines the requirement for both interior and exterior lighting. There are two separate ways in which the interior lighting system can achieve compliance through lighting power density. In this analysis, the building area method is used opposed to the space-by-space method. Table 5, on the next page, shows that the Bentworth Middle School has a lighting power density of 1.11 W/ft² which is in compliance as schools must have a lighting power density equal to or less than 1.2 W/ft². Let it also be known that most of the spaces are controlled with both a wall switch and occupancy sensor.

ASHRAE Standard 90.1-2007 Summary

Bentworth Middle School was largely compliant with ASHRAE Standard 90.1. The areas in which it did not meet the requirements of the standard were in fan power limitation and the overall U-value for the floors. Although it is obvious that the building designers were designing in an environmentally conscientious fashion, they were not trying to acquire any building accolades such as a LEED certification. Therefore, ASHRAE Standard 90.1 may have been overlooked during the design process, but with a few changes to the building's structural system and mechanical equipment, complete compliance should be easily attainable. Nonetheless, Bentworth Middle School's near compliance with ASHRAE Standard 90.1 further exemplifies the school as not only a great learning and working environment, but also as an energy efficient building.

Table 5 – Lighting Power Density Calculation

Fixture	Floor			Watts/Fixture	Total Watts
	1st	2nd	3rd		
A/70	0	8	0	70	560
A/100	0	5	0	100	500
B/70	11	14	11	70	2520
B/100	0	13	0	100	1300
B/140	0	1	0	140	140
C/70	27	68	13	70	7560
C/100	0	0	113	100	11300
D/70	0	5	0	70	350
E/70	0	45	0	70	3150
E/100	118	124	0	100	24200
G/35	2	4	2	35	280
G70	0	1	0	70	70
H/40	52	97	52	40	8040
H/70	4	4	4	70	840
I/70	31	12	7	70	3500
I/100	3	0	0	100	300
I/140	0	16	0	140	2240
J/375	0	8	0	375	3000
K/70	2	4	2	70	560
L/500	0	1	0	500	500
M/70	0	12	4	70	1120
M/105	0	46	4	105	5250
O/360	0	29	0	360	10440
P/70	0	26	0	70	1820
P/100	0	22	0	100	2200
Q/48	1	0	0	48	48
R/70	0	8	0	70	560
R/35	0	4	0	35	140
S/40	2	2	2	40	240
U/15	0	6	0	15	90
AA/50	0	1	0	50	50
Total Building Watts					92868
Building Square Footage					83800
Lighting Power Density					1.11

References

ANSI/ASHRAE. (2007). *Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality*. Atlanta, GA: American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ANSI/ASHRAE. (2007). *Standard 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings*. Atlanta, GA: American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

Hayes Large Architects, LLP. Architectural Construction Documents. Hayes Large Architects, LLP., Altoona, PA.

Hayes Large Architects, LLP. Mechanical Construction Documents. Hayes Large Architects, LLP., Altoona, PA.

Hayes Large Architects, LLP. Electrical Construction Documents. Hayes Large Architects, LLP., Altoona, PA.

Hayes Large Architects, LLP. Architectural Specifications. Hayes Large Architects, LLP., Altoona, PA.

Hayes Large Architects, LLP. Mechanical Specifications. Hayes Large Architects, LLP., Altoona, PA.

Hayes Large Architects, LLP. Electrical Specifications. Hayes Large Architects, LLP., Altoona, PA.

Appendix A – Ventilation Load Calculations

Building: Bentworth Middle School		System	
System Tag/Name: RTHP-A1		33341	
Operating Condition Description: Occupied Operation Mode		As	
Units (select from pull-down list)		sf	
Inputs for System		Ps	
Floor area served by system	33341	Vpsd	
Population of area served by system (including diversity)	872	Ras	
Design primary supply fan airflow rate	34,280	Rps	
OA req'd per unit area for system (Weighted average)	0.11	Zone Name	
OA req'd per person for system area (Weighted average)	9.4	Zone Tag	
Inputs for Potentially Critical zones			
Zone Name		Zone Name	
Zone Tag		Zone Tag	
Space type		Space type	
Floor Area of zone		Floor Area of zone	
Design population of zone		Design population of zone	
Design total supply to zone (primary plus local recirculated)		Design total supply to zone (primary plus local recirculated)	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	
Local recirc. air % representative of ave system return air		Local recirc. air % representative of ave system return air	
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed		Percent of total design airflow rate at conditioned analyzed	
Air distribution type at conditioned analyzed		Air distribution type at conditioned analyzed	
Zone air distribution effectiveness at conditioned analyzed		Zone air distribution effectiveness at conditioned analyzed	
Primary air fraction of supply air at conditioned analyzed		Primary air fraction of supply air at conditioned analyzed	
Results			
Ventilation System Efficiency		Ev	
Outdoor air intake required for system		Vol	
Outdoor air per unit floor area		Vol/As	
Outdoor air per person served by system (including diversity)		Vol/Ps	
Outdoor air as a % of design primary supply air		Ypd	
Ev		0.83	
Vol		14184	
Vol/As		0.43	
Vol/Ps		16.3	
Ypd		41%	
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	=	VpdDs
Uncorrected OA requirement for system	Vou	=	Rps Ps + Ras As
Uncorrected OA req'd as a fraction of primary SA	Xs	=	Vou / Vps
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	=	VpdDs / (Floor Area)
OA rate per person	Rpz	=	VpdDs / (Design Pop)
Total supply air to zone (at condition being analyzed)	Vdz	=	VpdDs + (Local Recirc)
Unused OA req'd to breathing zone	Vbz	=	Vdz - (OA req'd)
Unused OA requirement for zone	Voz	=	Vbz - (OA req'd)
Fraction of zone supply not directly recirc. from zone	Fa	=	Voz / Vdz
Fraction of zone supply from fully mixed primary air	Fb	=	Ep + (1-Ep)Er
Fraction of zone OA not directly recirc. from zone	Fc	=	Ep
Unused OA fraction required in supply air to zone	Zd	=	1 - (1-Ez)(1-Ep)(1-Er)
Unused OA fraction required in primary air to zone	Zp	=	Voz / Vpz
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz	=	(Fa + FbXs - Fcz) / Fa
System Ventilation Efficiency (App A Method)	Ev	=	min(Evz)
Ventilation System Efficiency (Table 6.3 Method)	Ev	=	Value from Table 6.3
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	=	Vou / Ev
OA intake req'd as a fraction of primary SA	Y	=	Vot / Vps
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	=	18487
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y	=	0.54
OAT temp at which Min. OA provides all cooling			
OAT below which OA Intake flow is @ minimum	Deg F	=	{(Tp-dTspf)-(1-Y)} / (Tr+dTrf)
		=	31

Building:	Bentworth Middle School
System Tag/Name:	RTHP-A1
Operating Condition Description:	Occupied Operation Mode
Units (select from pull-down list)	IP

Name	Units	System
Floor area served by system	sf	33341
Population of area served by system (including diversity)	Ps	872
Design primary supply fan airflow rate	Vpsd	34.280
OA req'd per unit area for system (Weighted average)	Ras	0.11
OA req'd per person for system area (Weighted average)	Rps	9.4

Inputs for Potentially Critical Zones

Zone Name	Learning Support	Computer Lab	IPC	Work Room	Corridor
Zone Tag	A107	A109	A114	A117	A127
Space type	Classrooms (age 9 plus)	Computer lab	Office space	Office space	Corridors
Floor Area of zone	766	820	433	155	780
Design population of zone	26.81	20.5	4	0.775	0
Design total supply to zone (primary plus local recirculated)	800	1020	560	100	360
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?					
Local recirc. air % representative of ave system return air					

Zone file turns purple italic for critical zone(s)

Inputs for Operating Condition Analyzed	Units	Value
Percent of total design airflow rate at conditioned analyzed	%	100%
Air distribution type at conditioned analyzed		CS
Zone air distribution effectiveness at conditioned analyzed		1.00
Primary air fraction of supply air at conditioned analyzed		1.00

Results	Units	Value
Ventilation System Efficiency		0.83
Outdoor air intake required for system	Vot	14184
Outdoor air per unit floor area	Vot/As	0.43
Outdoor air per person served by system (including diversity)	Vot/Ps	16.3
Outdoor air as a % of design primary supply air	Ypd	41%

Detailed Calculations

Initial Calculations for the System as a whole	Units	Value
Primary supply air flow to system at conditioned analyzed	Vps	34280
Uncorrected OA requirement for system	You	11752
Uncorrected OA req'd as a fraction of primary SA	Xs	0.34
OA rate per unit area for zone	Raz	0.12
Total supply air to zone (at condition being analyzed)	Rpz	10.00
Unused OA req'd to breathing zone	Vdz	800
Unused OA requirement for zone	Vbz	360.0
Fraction of zone supply not directly recirc. from zone	Voz	360
Fraction of zone OA not directly recirc. from zone	Fa	1.00
Fraction of zone OA not directly recirc. from zone	Fb	1.00
Unused OA fraction required in supply air to zone	Fc	1.00
Unused OA fraction required in primary air to zone	Zd	0.45
Zone Ventilation Efficiency (App A Method)	Zp	0.45
System Ventilation Efficiency (App A Method)	Evs	0.89
Ventilation System Efficiency (Table 6.3 Method)	Ev	0.83
Minimum outdoor air intake airflow	Vot	14184
Outdoor Air Intake Flow required to System	Y	0.41
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	18487
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y	0.54
OA Temp at which Min OA provides all cooling	Deg F	31

OAT below which OA intake flow is @ minimum

Building: Bentworth Middle School		System	
System Tag/Name: RTHP-A1		Name	Units
Operating Condition Description: Occupied Operation Mode		As	sf
Units (select from pull-down list)		Ps	P
		Vpsd	cfm
		Ras	cfm/sf
		Rps	cfm/p
Inputs for System		System	33341
Floor area served by system			872
Population of area served by system (including diversity)			34,280
Design primary supply fan airflow rate			0.11
OA req'd per unit area for system (Weighted average)			9.4
OA req'd per person for system area (Weighted average)			
Inputs for Potentially Critical zones			
Zone Name			
Zone Tag			
Space type			
Floor Area of zone			
Design population of zone			
Design total supply to zone (primary plus local recirculated)			
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave system return air			
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed			
Air distribution type at conditioned analyzed			
Zone air distribution effectiveness at conditioned analyzed			
Primary air fraction of supply air at conditioned analyzed			
Results			
Ventilation System Efficiency			0.83
Outdoor air intake required for system			14184
Outdoor air per unit floor area			0.43
Outdoor air per person served by system (including diversity)			16.3
Outdoor air as a % of design primary supply air			41%
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	=	VpddS
Uncorrected OA requirement for system	Vou	=	Rps Ps + Ras As
Uncorrected OA req'd as a fraction of primary SA	Xs	=	Vou / Vps
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	=	cfm/sf
Total supply air to zone (at condition being analyzed)	Vdz	=	cfm/p
Unused OA requirement for zone	Vbz	=	cfm
Fraction of zone supply not directly recirc. from zone	Fa	=	cfm
Fraction of zone supply from fully mixed primary air	Fb	=	cfm
Fraction of zone OA not directly recirc. from zone	Fc	=	cfm
Unused OA fraction required in supply air to zone	Zd	=	cfm
Unused OA fraction required in primary air to zone	Zp	=	cfm
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz	=	(Fa + Fbx - Fcz) / Fa
System Ventilation Efficiency (App A Method)	Ev	=	min (Evz)
Ventilation System Efficiency (Table 6.3 Method)	Ev	=	Value from Table 6.3
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	=	Vou / Ev
OA intake req'd as a fraction of primary SA	Y	=	Vot / Vps
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	=	Vou / Ev
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y	=	Vot / Vps
OA Temp at which Min OA provides all cooling			
OA T below which OA Intake flow is @ minimum	Deg F	=	{(Tp-dTsp)-(1-Y)} / (Tr+dTrf)
			31

Classroom	Classroom	Classroom	Classroom	Science Classroom	Classroom
A118	A124	A123	A126	A125	A125
Classrooms (age 9 plus)	Classrooms (age 9 plus)	Classrooms (age 9 plus)	Classrooms (age 9 plus)	Classrooms (age 9 plus)	Classrooms (age 9 plus)
766	766	766	883	766	
26.81	26.81	26.81	30.905	26.81	
800	700	800	1060	700	

100%	100%	100%	100%	100%	100%
CS	CS	CS	CS	CS	CS
1.00	1.00	1.00	1.00	1.00	1.00

Zone title turns purple italic for critical zone(s)

Select from pull-down list
 sf
 P (default value listed; may be overridden)
 cfm
 Select from pull-down list or leave blank if N/A

Select from pull-down list
 %
 Select from pull-down list

0.83
 14184
 0.43
 16.3
 41%

Vps	=	VpddS	=	34280
Vou	=	Rps Ps + Ras As	=	11752
Xs	=	Vou / Vps	=	0.34
Raz	=	cfm/sf		
Vdz	=	cfm/p		
Vbz	=	cfm		
Fa	=	cfm		
Fb	=	cfm		
Fc	=	cfm		
Zd	=	cfm		
Zp	=	cfm		
Evz	=	(Fa + Fbx - Fcz) / Fa	=	0.83
Ev	=	min (Evz)	=	0.83
Vot	=	Vou / Ev	=	14184
Y	=	Vot / Vps	=	0.41
Vot	=	Vou / Ev	=	18487
Y	=	Vot / Vps	=	0.54
Deg F	=	{(Tp-dTsp)-(1-Y)} / (Tr+dTrf)	=	31

Building:	Bentworth Middle School
System Tag/Name:	RTHP-A1
Operating Condition Description:	Occupied Operation Mode
Units (select from pull-down list)	IP

Inputs for System	Name	Units	System
Floor area served by system	As	sf	33341
Population of area served by system (including diversity)	Ps	P	872
Design primary supply fan airflow rate	Vpsd	cfm	34,280
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.11
OA req'd per person for system area (Weighted average)	Rps	cfm/p	9.4

Inputs for Potentially Critical zones	Name	Units	System
Floor area served by system	As	sf	33341
Population of area served by system (including diversity)	Ps	P	872
Design primary supply fan airflow rate	Vpsd	cfm	34,280
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.11
OA req'd per person for system area (Weighted average)	Rps	cfm/p	9.4

Inputs for Operating Condition Analyzed	Name	Units	System
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%
Air distribution type at conditioned analyzed	Ez		CS
Zone air distribution effectiveness at conditioned analyzed	Ep		1.00

Results	Name	Units	System
Ventilation System Efficiency	Ev		0.83
Outdoor air intake required for system	Vot	cfm	14184
Outdoor air per unit floor area	Vot/As	cfm/sf	0.43
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/p	16.3
Outdoor air as a % of design primary supply air	Ypd	cfm	41%

Detailed Calculations

Initial Calculations for the System as a whole	Name	Units	System
Primary supply air flow to system at conditioned analyzed	Vps	cfm	34280
Uncorrected OA requirement for system	Vou	cfm	11752
Uncorrected OA req'd as a fraction of primary SA	Xs		0.34

Initial Calculations for Individual zones	Name	Units	System
OA rate per unit area for zone	Raz	cfm/sf	0.12
OA rate per person	Rpz	cfm/p	0.00
Total supply air to zone (at condition being analyzed)	Vdz	cfm	140
Unused OA req'd to breathing zone	Vbz	cfm	25.4
Unused OA requirement for zone	Voz	cfm	26
Fraction of zone supply not directly recirc. from zone	Fa		1.00
Fraction of zone supply from fully mixed primary air	Fb		1.00
Fraction of zone OA not directly recirc. from zone	Fc		1.00
Unused OA fraction required in supply air to zone	Zd		0.19
Unused OA fraction required in primary air to zone	Zp		0.19

System Ventilation Efficiency	Name	Units	System
Zone Ventilation Efficiency (App A Method)	Evz		1.15
System Ventilation Efficiency (App A Method)	Ev		0.83
Ventilation System Efficiency (Table 6.3 Method)	Ev		0.64

Minimum outdoor air intake airflow	Name	Units	System
Outdoor Air Intake Flow required to System	Vot	cfm	14184
OA intake req'd as a fraction of primary SA	Y		0.41
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	18487
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		0.54

OA Temp at which Min OA provides all cooling	Name	Units	System
OAT below which OA intake flow is @ minimum	Deg F		31

Building: Bentworth Middle School																			
System Tag/Name: RTHP-A1																			
Operating Condition Description: Occupied Operation Mode																			
Units (select from pull-down list)																			
Inputs for System	<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>As</td> <td>sf</td> <td>33341</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>872</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>34,280</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.11</td> </tr> <tr> <td>Rps</td> <td>cfm/lp</td> <td>9.4</td> </tr> </table>	Name	Units	System	As	sf	33341	Ps	P	872	Vpsd	cfm	34,280	Ras	cfm/sf	0.11	Rps	cfm/lp	9.4
Name	Units	System																	
As	sf	33341																	
Ps	P	872																	
Vpsd	cfm	34,280																	
Ras	cfm/sf	0.11																	
Rps	cfm/lp	9.4																	
Floor area served by system																			
Population of area served by system (including diversity)	100% diversity																		
Design primary supply fan airflow rate																			
OA req'd per unit area for system (Weighted average)																			
OA req'd per person for system area (Weighted average)																			
Inputs for Potentially Critical Zones																			
Zone Name																			
Zone Tag																			
Space type																			
Floor Area of zone																			
Design population of zone																			
Design total supply to zone (primary plus local recirculated)																			
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?																			
Local recirc. air % representative of ave system return air																			
Inputs for Operating Condition Analyzed																			
Percent of total design airflow rate at conditioned analyzed	100%																		
Air distribution type at conditioned analyzed	CS																		
Zone air distribution effectiveness at conditioned analyzed	1.00																		
Primary air fraction of supply air at conditioned analyzed	1.00																		
Results																			
Ventilation System Efficiency	0.83																		
Outdoor air intake required for system	14184																		
Outdoor air per unit floor area	0.43																		
Outdoor air per person served by system (including diversity)	16.3																		
Outdoor air as a % of design primary supply air	41%																		
Detailed Calculations																			
Initial Calculations for the System as a whole																			
Primary supply air flow to system at conditioned analyzed	Vps = 34280																		
Uncorrected OA requirement for system	Vou = 11752																		
Uncorrected OA req'd as a fraction of primary SA	Xs = 0.34																		
Initial Calculations for individual zones																			
OA rate per unit area for zone	Raz = cfm/sf																		
OA rate per person	Rpz = cfm/lp																		
Total supply air to zone (at condition being analyzed)	Vdz = cfm																		
Unused OA req'd to breathing zone	Vbz = cfm																		
Unused OA requirement for zone	Voz = cfm																		
Fraction of zone supply not directly recirc. from zone	Fa = cfm																		
Fraction of zone supply from fully mixed primary air	Fb = cfm																		
Fraction of zone OA not directly recirc. from zone	Fc = cfm																		
Unused OA fraction required in supply air to zone	Zd = cfm																		
Unused OA fraction required in primary air to zone	Zp = cfm																		
System Ventilation Efficiency																			
Zone Ventilation Efficiency (App A Method)	Evz = (Fa + Fbx - Fcz) / Fa = 1.05																		
System Ventilation Efficiency (App A Method)	Ev = min(Evz) = 0.83																		
Ventilation System Efficiency (Table 6.3 Method)	Ev = Value from Table 6.3 = 0.64																		
Minimum outdoor air intake airflow																			
Outdoor Air Intake Flow required to System	Vot = cfm																		
OA intake req'd as a fraction of primary SA	Y = cfm																		
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot = 18487																		
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y = 0.54																		
OA Temp at which Min. OA provides all cooling																			
OAT below which OA Intake flow is @ minimum	Deg F = 31																		

Building: Bentworth Middle School																			
System Tag/Name: RTHP-A1																			
Operating Condition Description: Occupied Operation Mode																			
Units (select from pull-down list)																			
Inputs for System	<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>AS</td> <td>sf</td> <td>33341</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>872</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>34.280</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.11</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>9.4</td> </tr> </table>	Name	Units	System	AS	sf	33341	Ps	P	872	Vpsd	cfm	34.280	Ras	cfm/sf	0.11	Rps	cfm/p	9.4
Name	Units	System																	
AS	sf	33341																	
Ps	P	872																	
Vpsd	cfm	34.280																	
Ras	cfm/sf	0.11																	
Rps	cfm/p	9.4																	
Floor area served by system																			
Population of area served by system (including diversity)	100% diversity																		
Design primary supply fan airflow rate																			
OA req'd per unit area for system (Weighted average)																			
OA req'd per person for system area (Weighted average)																			
Inputs for Potentially Critical zones																			
Zone Name																			
Zone Tag																			
Space type																			
Floor Area of zone																			
Design population of zone																			
Design total supply to zone (primary plus local recirculated)																			
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?																			
Local recirc. air % representative of ave system return air																			
Inputs for Operating Condition Analyzed																			
Percent of total design airflow rate at conditioned analyzed	100%																		
Air distribution type at conditioned analyzed																			
Zone air distribution effectiveness at conditioned analyzed																			
Primary air fraction of supply air at conditioned analyzed																			
Results																			
Ventilation System Efficiency	0.83																		
Outdoor air intake required for system	14184																		
Outdoor air per unit floor area	0.43																		
Outdoor air per person served by system (including diversity)	16.3																		
Outdoor air as a % of design primary supply air	41%																		
Detailed Calculations																			
Initial Calculations for the System as a whole																			
Primary supply air flow to system at conditioned analyzed	Vps = 34280																		
Uncorrected OOA requirement for system	Vou = 11752																		
Uncorrected OA req'd as a fraction of primary SA	Xs = 0.34																		
Initial Calculations for individual zones																			
OA rate per unit area for zone	Raz = cfm/sf																		
OA rate per person	Rpz = cfm/p																		
Total supply air to zone (at condition being analyzed)	Vbz = cfm																		
Unused OA req'd to breathing zone	Voz = cfm																		
Unused OA requirement for zone	Fa = cfm																		
Fraction of zone supply not directly recirc. from zone	Fb = cfm																		
Fraction of zone supply from fully mixed primary air	Fc = cfm																		
Fraction of zone OA not directly recirc. from zone	Zd = cfm																		
Unused OA fraction required in supply air to zone	Zp = cfm																		
Unused OA fraction required in primary air to zone	Evz = cfm																		
System Ventilation Efficiency																			
Zone Ventilation Efficiency (App A Method)	Ev = 0.83																		
System Ventilation Efficiency (App A Method)	Ev = 0.64																		
Ventilation System Efficiency (Table 6.3 Method)																			
Minimum outdoor air intake airflow																			
Outdoor Air Intake Flow required to System	Vot = 14184																		
OA intake req'd as a fraction of primary SA	Y = 0.41																		
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot = 18487																		
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y = 0.54																		
OA Temp at which Min OA provides all cooling																			
OAT below which OA intake flow is @ minimum	Deg F = 31																		

Potentially Critical Zones

Work Room	AV Room	Computer Lab	IPC	Work Room
A212	A211	A213	A215	A218
Office space	Storage rooms	Computer lab	Office space	Office space
150	220	827	435	156
0.75	0	20.675	4	0.775
150	225	1020	680	100
100%	100%	100%	100%	100%
CS	CS	CS	CS	CS
1.00	1.00	1.00	1.00	1.00

Zone title turns purple italic for critical zone(s)

Select from pull-down list

(default value listed; may be overridden)

Select from pull-down list or leave blank if N/A

Select from pull-down list

Building: Bentworth Middle School		System Tag/Name: RTHP-A1	
Operating Condition Description: Occupied Operation Mode		Units	
Units (select from pull-down list)		System	
Name	As	33341	
Population of area served by system (including diversity)	P	872	
Design primary supply fan airflow rate	Vpsd	34.280	
OA req'd per unit area for system (Weighted average)	Ras	0.11	100% diversity
OA req'd per person for system area (Weighted average)	Rps	9.4	
Inputs for Potentially Critical zones			
Zone Name	Zone Tag	Space type	Floor Area of zone
Design population of zone	Pz	Design total supply to zone (primary plus local recirculated)	Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?
Local recirc. air % representative of ave system return air	Er		
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%
Air distribution type at conditioned analyzed	Ez	Select from pull-down list	
Zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed	Ev		0.83
Ventilation System Efficiency	Vot	cfm	14184
Outdoor air intake required for system	Vot/As	cfm/sf	0.43
Outdoor air per unit floor area	Vot/Ps	cfm/p	16.3
Outdoor air per person served by system (including diversity)	Ypd	cfm	41%
Outdoor air as a % of design primary supply air			
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= 34280
Uncorrected OA requirement for system	Vou	cfm	= 11752
Uncorrected OA req'd as a fraction of primary SA	Xs		= 0.34
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	cfm/sf	=
OA rate per person	Rpz	cfm/p	=
Total supply air to zone (at condition being analyzed)	Vdz	cfm	=
Unused OA req'd to breathing zone	Vbz	cfm	=
Unused OA requirement for zone	Voz	cfm	=
Fraction of zone supply not directly recirc. from zone	Fa		=
Fraction of zone supply from fully mixed recirc. from zone	Fb		=
Fraction of zone OA not directly recirc. from zone	Fc		=
Unused OA fraction required in supply air to zone	Zd		=
Unused OA fraction required in primary air to zone	Zp		=
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	EvZ		=
System Ventilation Efficiency (App A Method)	Ev		= 0.83
Ventilation System Efficiency (Table 6.3 Method)	Ev		= 0.64
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	= 14184
OA intake req'd as a fraction of primary SA	Y		= 0.41
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= 18487
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= 0.54
OA Temp at which Min OA provides all cooling			
OAT below which OA Intake flow is @ minimum	Deg F		= 31

Building:		Bentworth Middle School	
System Tag/Name:		RTHP-A1	
Operating Condition Description:		Occupied Operation Mode	
Units (select from pull-down list)		IP	
Inputs for System			
Floor area served by system	As	33341	sf
Population of area served by system (including diversity)	Ps	872	P
Design primary supply fan airflow rate	Vpsd	34.280	cfm
OA req'd per unit area for system (Weighted average)	Ras	0.11	cfm/sf
OA req'd per person for system area (Weighted average)	Rps	9.4	cfm/p
Inputs for Potentially Critical Zones			
Zone Name			
Zone Tag			
Space type			
Floor Area of zone	Az	883	sf
Design population of zone	Pz	0	P
Design total supply to zone (primary plus local recirculated)	Vdtd	110	cfm
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave system return air	Er		%
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	100%	%
Air distribution type at conditioned analyzed	Ez	CS	CS
Zone air distribution effectiveness at conditioned analyzed	Ep	1.00	
Primary air fraction of supply air at conditioned analyzed			
Ventilation System Efficiency	Ev	0.83	
Outdoor air intake required for system	Vol	14184	cfm
Outdoor air per unit floor area	Vol/As	0.43	cfm/sf
Outdoor air per person served by system (including diversity)	Vol/Ps	16.3	cfm/p
Outdoor air as a % of design primary supply air	Ypd	41%	cfm
Results			
Storage	Storage	100%	100%
Classroom	Classroom	CS	CS
Corridor	Corridor	1.00	1.00
Storage	Storage	1.00	1.00
Classroom	Classroom	CS	CS
Corridor	Corridor	1.00	1.00
Classrooms (age 9 plus)	Classrooms (age 9 plus)	1.00	1.00
A304	A304	100%	100%
A302	A302	CS	CS
A303	A303	1.00	1.00
A303A	A303A	1.00	1.00
A302	A302	1.00	1.00
A304	A304	1.00	1.00
Classrooms	Classrooms	1.00	1.00
Classrooms (age 9 plus)	Classrooms (age 9 plus)	1.00	1.00
766	766	1.00	1.00
220	220	1.00	1.00
780	780	1.00	1.00
0	0	1.00	1.00
26.81	26.81	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905	1.00	1.00
920	920	1.00	1.00
100	100	1.00	1.00
360	360	1.00	1.00
800	800	1.00	1.00
0	0	1.00	1.00
30.905	30.905		

Building:	Bentworth Middle School
System Tag/Name:	RTHP-A1
Operating Condition Description:	Occupied Operation Mode
Units (select from pull-down list)	IP

Inputs for System	Name	Units	System
Floor area served by system	As	sf	33341
Population of area served by system (including diversity)	Ps	P	872
Design primary supply fan airflow rate	Vpsd	cfm	34,280
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.11
OA req'd per person for system area (Weighted average)	Rps	cfm/p	9.4

Inputs for Potentially Critical zones	Name	Units	System
Floor area of zone	Az	sf	766
Design population of zone	Pz	P	26.81
Design total supply to zone (primary plus local recirculate d)	Vzd	cfm	800
Induction Terminal Unit, Dual Fan Duct or Transfer Fan?			
Local recirc. air % representative of ave system return air	Er	%	100%

Inputs for Operating Condition Analyzed	Name	Units	System
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%
Air distribution type at conditioned analyzed	Ez	Select from pull-down list	CS
Zone air distribution effectiveness at conditioned analyzed	Ep	Select from pull-down list	1.00

Results	Name	Units	System
Ventilation System Efficiency	Ev		0.83
Outdoor air intake required for system	Vot	cfm	14184
Outdoor air per unit floor area	Voi/As	cfm/sf	0.43
Outdoor air per person served by system (including diversity)	Voi/Ps	cfm/p	16.3
Outdoor air as a % of design primary supply air	Ypd	cfm	41%

Detailed Calculations

Initial Calculations for the System as a whole	Name	Units	System
Primary supply air flow to system at conditioned analyzed	Vps	cfm	34280
Uncorrected OA requirement for system	Vou	cfm	11752
Uncorrected OA req'd as a fraction of primary SA	Xs	= Vou / Vps	0.34
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	cfm/sf	0.12
OA rate per person	Rpz	cfm/p	10.00
Total supply air to zone (at condition being analyzed)	Vdz	cfm	800
Unused OA req'd to breathing zone	Vbz	cfm	360.0
Unused OA requirement for zone	Voz	cfm	360
Fraction of zone supply not directly recirc. from zone	Fa	= Ep + (1-Ep)Er	1.00
Fraction of zone supply from fully mixed primary air	Fb	= Ep	1.00
Fraction of zone OA not directly recirc. from zone	Fc	= 1-(1-Ez)(1-Ep)(1-Er)	1.00
Unused OA fraction required in supply air to zone	Zd	= Voz / Vdz	0.45
Unused OA fraction required in primary air to zone	Zp	= Voz / Vpz	0.45
System Ventilation Efficiency	Evz	= (Fa + FbXs - FcZ) / Fa	0.89
Zone Ventilation Efficiency (App A Method)	Ev	= min (Evz)	0.83
System Ventilation Efficiency (App A Method)	Ev	= Value from Table 6.3	0.64
Ventilation System Efficiency (Table 6.3 Method)			
Minimum outdoor air intake airflow	Vot	cfm	14184
Outdoor Air Intake Flow required to System	Y	= Vou / Vps	0.41
OA intake req'd as a fraction of primary SA	Vot	= Vou / Ev	18487
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Y	= Vou / Vps	0.54
OA intake req'd as a fraction of primary SA (Table 6.3 Method)			
OA Temp at which Min OA provides all cooling	Deg F	= {(Tp-d)Tsfr-(1-Y) (Tr+d)Trf}	31
OA below which OA intake flow is @ minimum			

Building: Bentworth Middle School	
System Tag/Name: RTHP-A1	
Operating Condition Description: Occupied Operation Mode	
Units (select from pull-down list)	IP

Inputs for System	Name	Units	System
Floor area served by system	As	sf	33341
Population of area served by system (including diversity)	Ps	P	872
Design primary supply fan airflow rate	Vpsd	cfm	34,280
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.11
OA req'd per person for system area (Weighted average)	Rps	cfm/p	9.4

Inputs for Potentially Critical zones	Name	Units	System
Floor area served by system	As	sf	33341
Population of area served by system (including diversity)	Ps	P	872
Design primary supply fan airflow rate	Vpsd	cfm	34,280
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.11
OA req'd per person for system area (Weighted average)	Rps	cfm/p	9.4

Inputs for Operating Condition Analyzed	Name	Units	System
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%
Air distribution type at conditioned analyzed	Ez		CS
Zone air distribution effectiveness at conditioned analyzed	Ep		1.00

Results	Name	Units	System
Ventilation System Efficiency	Ev		0.83
Outdoor air intake required for system	Vot	cfm	14184
Outdoor air per unit floor area	Vot/As	cfm/sf	0.43
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/p	16.3
Outdoor air as a % of design primary supply air	Ypd	cfm	41%

Detailed Calculations

Initial Calculations for the System as a whole	Name	Units	System
Primary supply air flow to system at conditioned analyzed	Vps	cfm	34280
Uncorrected OA requirement for system	Vou	cfm	11752
Uncorrected OA req'd as a fraction of primary SA	Xs		0.34

Initial Calculations for Individual zones	Name	Units	System
OA rate per unit area for zone	Raz	cfm/sf	0.06
OA rate per person	Rpz	cfm/p	0.06
Total supply air to zone (at condition being analyzed)	Vdz	cfm	5.00
Unused OA req'd to breathing zone	Vbz	cfm	580
Unused OA requirement for zone	Voz	cfm	46.1
Fraction of zone supply not directly recirc. from zone	Fa		46
Fraction of zone supply from fully mixed primary air	Fb		1.00
Fraction of zone OA not directly recirc. from zone	Fc		1.00
Unused OA fraction required in supply air to zone	Zd		0.08
Unused OA fraction required in primary air to zone	Zp		0.08

System Ventilation Efficiency	Name	Units	System
Zone Ventilation Efficiency (App A Method)	Evz		1.26
System Ventilation Efficiency (App A Method)	Ev		0.83
Ventilation System Efficiency (Table 6.3 Method)	Ev		0.64

Minimum outdoor air intake airflow	Name	Units	System
Outdoor Air Intake Flow required to System	Vot	cfm	14184
OA intake req'd as a fraction of primary SA	Y		0.41
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	18487
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		0.54

OA Temp at which Min OA provides all cooling	Name	Units	System
OAT below which OA intake flow is @ minimum	Deg F		31

Building: Bentworth Middle School		System: RTHP-B1	
Operating Condition Description: Occupied Operation Mode		System	
Units (select from pull-down list)		Units	
Floor area served by system	AS	sf	9220
Population of area served by system (including diversity)	Ps	P	172
Design primary supply fan airflow rate	Vpsd	cfm	10,110
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.08
OA req'd per person for system area (Weighted average)	Rps	cfm/p	8.0
Inputs for Potentially Critical zones			
Zone Name	<i>Zone title turns purple italic for critical zone(s)</i>		
Zone Tag	100% diversity		
Space type	Select from pull-down list		
Floor Area of zone	Az	sf	
Design population of zone	Pz	P	(default value listed; may be overridden)
Design total supply to zone (primary plus local recirculated)	Vzsd	cfm	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Er		Select from pull-down list or leave blank if N/A
Local recirc. air % representative of area system return air			
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%
Air distribution type at conditioned analyzed	Ez		Select from pull-down list
Zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed			
Results			
Ventilation System Efficiency	Ev		0.73
Outdoor air intake required for system	Vot	cfm	2916
Outdoor air per unit floor area	Vot/As	cfm/sf	0.32
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/p	16.9
Outdoor air as a % of design primary supply air	Ypd	cfm	29%
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= 10110
Uncorrected OA requirement for system	You	cfm	= 2116
Uncorrected OA req'd as a fraction of primary SA	Xs		= 0.21
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	cfm/sf	= 0.12
OA rate per person	Rpz	cfm/p	= 10.00
Total supply air to zone (at condition being analyzed)	Vdz	cfm	= 800
Unused OA req'd to breathing zone	Vbz	cfm	= 386.8
Unused OA requirement for zone	Voz	cfm	= 387
Fraction of zone supply not directly recirc. from zone	Fa		= 1.00
Fraction of zone supply from fully mixed primary air	Fb		= 1.00
Fraction of zone OA not directly recirc. from zone	Fc		= 1.00
Unused OA fraction required in supply air to zone	Zd		= 0.48
Unused OA fraction required in primary air to zone	Zp		= 0.48
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz		= 0.73
System Ventilation Efficiency (App A Method)	Ev		= 0.67
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	= 2916
OA intake req'd as a fraction of primary SA	Y		= 0.29
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= 3175
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= 0.31
OA Temp at which Min OA provides all cooling			
OAT below which OA Intake flow is @ minimum	Deg F		= 13

Building: Bentworth Middle School		System Tag/Name: RTHP-B1	
Operating Condition Description: Occupied Operation Mode		Units (select from pull-down list)	
Inputs for System			
Name	Units	System	
As	sf	9,220	
Ps	P	172	
Vpsd	cfm	10,110	
Ras	cfm/sf	0.08	
Rps	cfm/p	8.0	
Population of area served by system (including diversity) <input type="text" value="100%"/> diversity Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average)			
Inputs for Potentially Critical Zones			
Zone Name	Zone title turns purple italic for critical zone(s)		
Zone Tag	Select from pull-down list		
Space type	Select from pull-down list		
Floor Area of zone	Az	sf	124.6
Design population of zone	Pz	P	0
Design total supply to zone (primary plus local recirculated)	Pz	P	43.81
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Vzdz	cfm	450
Local recirc. air-% representative of ave. system return air	Er	%	
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	100%
Air distribution type at conditioned analyzed	Ez	Select from pull-down list	
Zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed			
Results			
Ventilation System Efficiency	Ev		0.73
Outdoor air intake required for system	Vot	cfm	2916
Outdoor air per unit floor area	Vot/As	cfm/sf	0.32
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/p	16.9
Outdoor air as a % of design primary supply air	Ypd	cfm	29%
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= 10110
Uncorrected OA requirement for system	You	cfm	= 2116
Uncorrected OA req'd as a fraction of primary SA	Xs		= 0.21
Initial Calculations for Individual Zones			
OA rate per unit area for zone	Raz	cfm/sf	= 0.06
OA rate per person	Rpz	cfm/p	= 10.00
Total supply air to zone (at condition being analyzed)	Vdz	cfm	= 80
Unused OA req'd to breathing zone	Vbz	cfm	= 6.8
Unused OA requirement for zone	Voz	cfm	= 7
Fraction of zone supply not directly recirc. from zone	Fa		= 1.00
Fraction of zone supply from fully mixed primary air	Fb		= 1.00
Fraction of zone OA not directly recirc. from zone	Fc		= 1.00
Unused OA fraction required in supply air to zone	Zd		= 0.11
Unused OA fraction required in primary air to zone	Zp		= 0.38
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz		= 1.10
System Ventilation Efficiency (App A Method)	Ev		= 0.73
Ventilation System Efficiency (Table 6.3 Method)	Ev		= 0.67
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	= 2916
OA intake req'd as a fraction of primary SA	Y		= 0.29
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= 3175
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= 0.31
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum	Deg F		= 13

Building:	Bentworth Middle School
System Tag/Name:	RTHP-B1
Operating Condition Description:	Occupied Operation Mode
Units (select from pull-down list)	IP

Inputs for System	Name	Units	System
Floor area served by system	As	sf	9270
Population of area served by system (including diversity)	Ps	P	172
Design primary supply fan airflow rate	Vpsd	cfm	10,110
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.08
OA req'd per person for system area (Weighted average)	Rps	cfm/p	8.0

Inputs for Potentially Critical zones

Zone Name

Zone Tag

Space type

Floor Area of zone

Design population of zone

Design total supply to zone (primary plus local recirculated)

Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?

Local recirc. air % representative of air system return air

Er

Zone title turns purple italic for critical zone(s)

Inputs for Operating Condition Analyzed

Percent of total design airflow rate at conditioned analyzed

Air distribution type at conditioned analyzed

Zone air distribution effectiveness at conditioned analyzed

Primary air fraction of supply air at conditioned analyzed

Ep

Results

Ventilation System Efficiency

Ev

Outdoor air intake required for system

Vot

Outdoor air per unit floor area

Vot/As

Outdoor air per person served by system (including diversity)

Vot/Ps

Outdoor air as a % of design primary supply air

Ypd

0.73

2916

0.32

16.9

29%

Detailed Calculations

Initial Calculations for the System as a whole

Primary supply air flow to system at conditioned analyzed

Vps = VpdDs = 10110

Uncorrected OA requirement for system

Vou = Rps Ps + Ras As = 2116

Uncorrected OA req'd as a fraction of primary SA

Xs = Vou / Vps = 0.21

Initial Calculations for individual zones

OA rate per unit area for zone

OA rate per person

OA rate per unit area for zone

Raz = cfm/sf

OA rate per person

Rpz = cfm/p

Total supply air to zone (at condition being analyzed)

Vdz = cfm

Unused OA req'd to breathing zone

Vbz = cfm

Unused OA requirement for zone

Voz = cfm

Fraction of zone supply not directly recirc. from zone

Fa = Eb + (1-Ep)Er

Fraction of zone supply from fully mixed primary air

Fb = Ep

Fraction of zone OA not directly recirc. from zone

Fc = 1-(1-Ez)(1-Ep)(1-Er)

Unused OA fraction required in supply air to zone

Zd = Voz / Vdz

Unused OA fraction required in primary air to zone

Zp = Voz / Vpz

System Ventilation Efficiency

Zone Ventilation Efficiency (App A Method)

Evz = (Fa + FbXs - FcZ) / Fa = 1.15

System Ventilation Efficiency (App A Method)

Ev = min(Evz) = 0.73

Ventilation System Efficiency (Table 6.3 Method)

Ev = Value from Table 6.3 = 0.67

Minimum outdoor air intake airflow

Outdoor Air Intake Flow required to System

Vot = cfm

OA intake req'd as a fraction of primary SA

Y = Vou / Ev = 2916

Outdoor Air Intake Flow required to System (Table 6.3 Method)

Vot = cfm

OA intake req'd as a fraction of primary SA (Table 6.3 Method)

Y = Vou / Vps = 3175

OA Temp at which Min OA provides all cooling

Y = cfm

OA Temp at which OA intake flow is @ minimum

Deg F = ((Tp-dTsb)-(1-y))(Tr+dTr) = 13

Office space	Storage	Exam	Health	Cots	Corridor	File Room
B203E	B203D	B203C	B203	B203A	B202D	B202B
Office space	Storage rooms	Office space	Office space	Office space	Corridors	Storage rooms
70	48	83	175	178	214	84
0.35	0	0.415	2	3	0	0
100	50	50	100	85	170	50
100%	100%	100%	100%	100%	100%	100%
CS	CS	CS	CS	CS	CS	CS
1.00	1.00	1.00	1.00	1.00	1.00	1.00

Building: Bentworth Middle School	
System Tag/Name: RTHP-B2	
Operating Condition Description: Occupied Operation Mode	
Units (select from pull-down list): IP	
Inputs for System	System
Floor area served by system	As sf 4059
Population of area served by system (including diversity)	Ps P 219
Design primary supply fan airflow rate	Vpsd cfm 5,600
OA req'd per unit area for system (Weighted average)	Ras cfm/sf 0.18
OA req'd per person for system area (Weighted average)	Rps cfm/p 7.5
Inputs for Potentially Critical Zones	
<i>Zone title turns purple italic for critical zone(s)</i>	
Zone Name	Potentially Critical Zones
Zone Tag	Cafeteria B219 Kitchen B232 Office B230
Space type	Cafeteria/fast-food dining Cafeteria/fast-food dining Office space
Floor Area of zone	2,090 1800 169
Design population of zone	209 9 0.845
Design total supply to zone (primary plus local recirculated)	4,000 1500 100
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	
Local recirc. air %, representative of ave system return air	
Inputs for Operating Condition Analyzed	
Percent of total design airflow rate at conditioned analyzed	100%
Air distribution type at conditioned analyzed	Ds %
Zone air distribution effectiveness at conditioned analyzed	Ez
Primary air fraction of supply air at conditioned analyzed	Ep
Results	
Ventilation System Efficiency	Ev 0.93
Outdoor air intake required for system	Vot cfm 2517
Outdoor air per unit floor area	Vot/As cfm/sf 0.62
Outdoor air per person served by system (including diversity)	Vot/Ps cfm/p 11.5
Outdoor air as a % of design primary supply air	Ypd cfm 45%
Detailed Calculations	
Initial Calculations for the System as a whole	
Primary supply air flow to system at conditioned analyzed	Vps cfm = 5600
Uncorrected OA requirement for system	Vou cfm = 2350
Uncorrected OA req'd as a fraction of primary SA	Xs = Vou / Vps = 0.42
Initial Calculations for individual zones	
OA rate per unit area for zone	Raz cfm/sf
OA rate per person	Rpz cfm/p
Total supply air to zone (at condition being analyzed)	Vdz cfm
Unused OA req'd to breathing zone	Vbz cfm
Unused OA requirement for zone	Voz cfm
Fraction of zone supply not directly recirc. from zone	Fa = Ep + (1-Ep)Er
Fraction of zone supply from fully mixed primary air	Fb = Ep
Fraction of zone OA not directly recirc. from zone	Fc = 1 - (1-Ez)(1-Ep)(1-Er)
Unused OA fraction required in supply air to zone	Zd = Voz / Vdz
Unused OA fraction required in primary air to zone	Zp = Voz / Vpz
System Ventilation Efficiency	
Zone Ventilation Efficiency (App A Method)	Evz = (Fa + FbXs - FcZ) / Fa = 0.93
System Ventilation Efficiency (App A Method)	Ev = min (Evz) = 0.93
Ventilation System Efficiency (Table 6.3 Method)	Ev = Value from Table 6.3 = 0.66
Minimum outdoor air intake airflow	
Outdoor Air Intake Flow required to System	Vot cfm = 2517
OA intake req'd as a fraction of primary SA	Y = Vot / Vps = 0.45
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot cfm = 3538
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y = Vot / Vps = 0.63
OA Temp at which Min OA provides all cooling	
OAT below which OA intake flow is @ minimum	Deg F = $\frac{((T_p - dT_{sf}) - (1 - Y)) \cdot (T_r + dT_{Trf})}{0.93}$ = 34

Building: Bentworth Middle School	
System Tag/Name: RTHP-B3	
Operating Condition Description: Occupied Operation Mode	
Units (select from pull-down list) IP	
Inputs for System	
Floor area served by system	As sf 1,548
Population of area served by system (including diversity)	Ps P 108
Design primary supply fan airflow rate	Vpsd cfm 2,100
OA req'd per unit area for system (Weighted average)	Ras cfm/sf 0.08
OA req'd per person for system area (Weighted average)	Rps cfm/p 10.0
Inputs for Potentially Critical Zones	
Zone Name	Zone title turns purple italic for critical zone(s)
Zone Tag	
Space type	
Floor Area of zone	Az sf 1,548
Design population of zone	Pz P 108.36
Design total supply to zone (primary plus local recirculated)	Vdzd cfm 2,100
Induction Terminal Unit, Dual Fan Duct or Transfer Fan?	
Local recirc. air % representative of ave. system return air	Er
Inputs for Operating Condition Analyzed	
Percent of total design airflow rate at conditioned analyzed	Ds % 100%
Air distribution type at conditioned analyzed	Ez
Zone air distribution effectiveness at conditioned analyzed	Ep
Primary air fraction of supply air at conditioned analyzed	
Results	
Ventilation System Efficiency	Ev 1.00
Outdoor air intake required for system	Vot cfm 1176
Outdoor air per unit floor area	Vot/As cfm/sf 0.76
Outdoor air per person served by system (including diversity)	Vot/Ps cfm/p 10.9
Outdoor air as a % of design primary supply air	Ypd % 56%
Detailed Calculations	
Initial Calculations for the System as a whole	
Primary supply air flow to system at conditioned analyzed	Vps = VpdDs = 2100
Uncorrected OA requirement for system	Vou = Rps Ps + Ras As = 1176
Uncorrected OA req'd as a fraction of primary SA	Xs = Vou / Vps = 0.56
Initial Calculations for individual zones	
OA rate per unit area for zone	Raz cfm/sf
OA rate per person	Rpz cfm/p
Total supply air to zone (at condition being analyzed)	Vdz cfm
Unused OA req'd to breathing zone	Vbz cfm
Unused OA requirement for zone	Voz cfm
Fraction of zone supply not directly recirc. from zone	Fa = Rpz Pz + Raz Az = 0.08
Fraction of zone supply from fully mixed primary air	Fb = Ep + (1-Ep)Er = 1.00
Fraction of zone OA not directly recirc. from zone	Fc = 1-(1-Ez)(1-Ep)(1-Er) = 1.00
Unused OA fraction required in supply air to zone	Zd = Voz / Vdz = 0.56
Unused OA fraction required in primary air to zone	Zp = Voz / Vpz = 0.56
System Ventilation Efficiency	
Zone Ventilation Efficiency (App A Method)	EvZ = (Fa + FbXs - FcZ) / Fa = 1.00
System Ventilation Efficiency (App A Method)	Ev = min (EvZ) = 1.00
Ventilation System Efficiency (Table 6.3 Method)	Ev = Value from Table 6.3 = n/a
Minimum outdoor air intake airflow	
Outdoor Air Intake Flow required to System	Vot cfm = 1176
OA intake req'd as a fraction of primary SA	Y = Vou / Vps = 0.56
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot cfm = n/a
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y = Vou / Vps = n/a
OA Temp at which Min OA provides all cooling	
OAT below which OA intake flow is @ minimum	Deg.F = ((Tp-dT)sf)/(1-Y)*(Tt+dTr) = 42

Building: Bentworth Middle School																			
System Tag/Name: RTHP-B4																			
Operating Condition Description: Occupied Operation Mode																			
Units (select from pull-down list)																			
Inputs for System	<table border="1"> <thead> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>AS</td> <td>sf</td> <td>6,809</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>410</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>10,000</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.24</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>4.1</td> </tr> </tbody> </table>	Name	Units	System	AS	sf	6,809	Ps	P	410	Vpsd	cfm	10,000	Ras	cfm/sf	0.24	Rps	cfm/p	4.1
Name	Units	System																	
AS	sf	6,809																	
Ps	P	410																	
Vpsd	cfm	10,000																	
Ras	cfm/sf	0.24																	
Rps	cfm/p	4.1																	
Inputs for Potentially Critical Zones	<p>Zone Name: 100% diversity</p> <p>Zone Tag: 100% diversity</p> <p>Space type: Select from pull-down list</p> <p>Floor Area of zone: 5,093 sf</p> <p>Design population of zone: 1716 P</p> <p>Design total supply to zone (primary plus local recirculated): 152.78 cfm</p> <p>Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? 5,000</p> <p>Local recirc. air % representative of ave. system return air: Select from pull-down list or leave blank if N/A</p> <p>Er: Select from pull-down list</p>																		
Inputs for Operating Condition Analyzed	<p>Percent of total design airflow rate at conditioned analyzed: 100%</p> <p>Air distribution type at conditioned analyzed: Select from pull-down list</p> <p>Zone air distribution effectiveness at conditioned analyzed: CS</p> <p>Primary air fraction of supply air at conditioned analyzed: 1.00</p>																		
Results	<p>Ev: 0.95</p> <p>Vot: 3751</p> <p>Vot/As: 0.56</p> <p>Vot/PS: 9.1</p> <p>Ypd: 38%</p>																		
Detailed Calculations	<p>Initial Calculations for the System as a whole</p> <p>Primary supply air flow to system at conditioned analyzed: Vps = 10000</p> <p>Uncorrected OA requirement for system: Vou = 3861</p> <p>Uncorrected OA req'd as a fraction of primary SA: Xs = 0.36</p> <p>Initial Calculations for individual zones</p> <p>OA rate per unit area for zone: Raz = cfm/sf</p> <p>OA rate per person: Rpz = cfm/p</p> <p>Total supply air to zone (at condition being analyzed): Vdz = cfm</p> <p>Unused OA req'd to breathing zone: Vbz = cfm</p> <p>Unused OA requirement for zone: Voz = cfm</p> <p>Fraction of zone supply not directly recirc. from zone: Fa = cfm</p> <p>Fraction of zone supply from fully mixed primary air: Fb = cfm</p> <p>Fraction of zone OA not directly recirc. from zone: Fc = cfm</p> <p>Unused OA fraction required in supply air to zone: Zd = 0.31</p> <p>Unused OA fraction required in primary air to zone: Zp = 0.31</p> <p>System Ventilation Efficiency</p> <p>Zone Ventilation Efficiency (App A Method): Evz = 1.05</p> <p>System Ventilation Efficiency (App A Method): Ev = 0.95</p> <p>Ventilation System Efficiency (Table 6.3 Method): Ev = 0.74</p> <p>Minimum outdoor air intake airflow</p> <p>Outdoor Air Intake Flow required to System: Vot = 3751</p> <p>OA intake req'd as a fraction of primary SA: Y = 0.38</p> <p>Outdoor Air Intake Flow required to System (Table 6.3 Method): Vot = 4781</p> <p>OA intake req'd as a fraction of primary SA (Table 6.3 Method): Y = 0.48</p> <p>OA Temp at which Min OA provides all cooling</p> <p>OAT below which OA intake flow is @ minimum: Deg.F = 27</p>																		