

BENTWORTH MIDDLE SCHOOL

BENTLEYVILLE, PENNSYLVANIA



INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION

INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOTHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH



FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION




Building Name: Bentworth Middle School
Location: Bentleyville, PA
Building Owner: Bentworth School District
Architect and MEP Engineer: Hayes Large Architects
Occupancy Type: Educational
Size: 83,800 Square Feet
Stories Above Grade: 3 Stories
Start Construction Date: May 2007
End Construction Date: January 2009
Cost: \$18 Million
Project Delivery Method: Design-Bid-Build



Front Entrance View



Rear View



INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOTHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH




FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION

Mechanical System Overview

- 96 bore (350' deep each) geothermal loop field
- 2 DOAS rooftop heat pump units
- Terminal heat pump units located in the academic and administrative areas
- 3 single zone rooftop heat pump units
- Design heating thermostat setpoint is 70°F
- Design cooling thermostat setpoint is 75°F
- Hydronic side is driven by 2 VSD pumps in parallel
- Entering water temperature from loop field for heating is 42°F
- Entering water temperature from loop field for cooling is 75°F



INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOTHERMAL HYBRID SYSTEM



DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION




Goals of Redesigned Air System

- Eliminate mechanical mezzanine
 - Reduce ductwork
 - Reduce fan energy
 - Provide additional usable space
- Ensure proper ventilation but reduce the amount of conditioned outdoor air
- Achieve energy savings through the use of a higher efficiency flat plate heat exchanger
- Improved air quality
- Maintain ease of maintenance access
- Maintain remote location of heat pumps for acoustical purposes



Design Considerations

- Location
- Tower construction
- Component selections
 - Outdoor air intake control
 - Energy recovery core selection and usage
- A slightly modified version of this system could also be used in the Administration area



Mechanical Plan of as Designed Typical Classrooms

Tower Locations



Mechanical Plan of Redesigned Typical Classrooms

INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION

Energy Analysis

- Carrier HAP was used as the modeling tool
- All heat pumps in the building were considered
- Schedule

System	Cooling	Heating	Air System Fans	Pumps	Total Consumption
	(kWh)	(kWh)	(kWh)	(kWh)	(kWh)
Designed	59,538	27,048	71,872	17,992	183,585
Redesigned	64,339	1,282	40,900	15,648	122,171

Result Analysis

- 33% reduction in the building's mechanical energy consumption
- Unanticipated increase in cooling load
- Unusually low heating load

Cost Analysis

Material	Unit	Total Price/Unit	Total Price
	SF/LF/Unit	\$	\$
Ductwork	180	4.41	794
Split Face Masonry Wall	2785	7.87	21,918
CO ₂ Sensor	39	800	31,200
Insulation	2785	0.63	1,755
Roofing	740	9.70	7,178
Energy Wall	5019	1.44	7,227
Piping	960	30.65	29,424
Exhaust Fans	30	1465	43,950
RTHP-A1	1	44,475	-44,475
RTHP-B1	1	18,250	-18,250
		Total Cost	80,721

Cost Analysis Results

- System costs total to \$80,721
- Annual electric savings of \$6,755
- Simple payback period of 12 years

INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN


CONCLUSION

Goals of Natural Ventilation System

- Reduce mechanical system loads
- Improved air quality
- Maintain thermal barrier


Design Considerations

- ASHRAE Standard 62.1 requirements
- System operation
- Window selection and placement



System Analysis

- Analyzed through the use of Carrier HAP and Excel
- Appropriate outdoor conditions for natural ventilation



Cost Analysis

- Excel analysis resulted in a \$1200 annual electric savings
- “Green light” system cost approximately \$8000
- Window upgrade cost approximately \$10,000
- Simple payback period of 15 years

INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN


CONCLUSION

Analysis Results

- 89 bores needed for cooling
- 60 bores needed for heating
- 27 ton cooling tower needed to cover the difference

Cost Analysis

- Based on an average price of \$6350 per well, \$184,450 can be saved on initial upfront cost
- Cooling tower cost is equal to \$90,000
- Assumed pumping savings due to 10' less head
- Cooling tower only used 8% of the total system operation time



Schematic of Hydronic System with Supplemental Cooling Tower

INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION

Goals of Decentralized Pump System

- Reduce overall required pumping energy
- Minimize the introduction of noise into areas adjacent to pump locations

Disadvantages of System

- Increase in maintenance costs
- No redundancy
- Additional mechanical space required


System Analysis

- Hourly profiles exported from Carrier HAP to Excel
- Based upon a 3gpm/ton load
- Affinity laws and pump curves

Analysis Results

- Unexpected that the decentralized pumps used more than twice the amount of energy
- Possible explanation – high amount of head
- Second alternative – primary/secondary system also used much more energy
- Due to the infeasibility of the design no cost analysis was performed


Central Pumping System



Central System - 2 VSD Pumps in Parallel

Pump Location	Total Head	Total GPM	Pump Selection					GPM	Head	Annual Hours of Operation	Annual kW
			Manuf	Size	RPM	Impeller Size	Efficiency				
Mechanical Room	130	275	B&G 1510	2G	1750	13 in	0.58	0-180	56	3480	11389
	56	180	B&G 1510	2G	1150	13 in	0.58	180-275	130	663	7695
								275-360	112	319	4176
								360-455	186	55	1511
							455-550	260	10	464	
Total										25236	

Decentralized Pumping System



Decentralized Pump Calculations

Pump Location	Piping PD	Unit PD	Well Field PD	Total Head	Total GPM	Pump Selection					Annual Hours of Operation	Annual kW
						Manuf	Size	Impeller Size	RPM	Efficiency		
Tower 1	20'	6'	90'	130	40	Arm 4300IVS	1.5x1.5x6	6.19 in	3500	0.46	2328	4956
				32	20	Arm 4300IVS	1.5x1.5x6	6.19 in	1740	0.47	550	141
Tower 2	20'	6'	90'	130	40	Arm 4300IVS	1.5x1.5x6	6.19 in	3500	0.46	2238	4764
				32	20	Arm 4300IVS	1.5x1.5x6	6.19 in	1740	0.47	687	176
Tower 3	20'	6'	90'	130	40	Arm 4300IVS	1.5x1.5x6	6.19 in	3500	0.46	2359	5022
				32	20	Arm 4300IVS	1.5x1.5x6	6.19 in	1740	0.47	645	165
Tower 4	20'	6'	90'	130	40	Arm 4300IVS	1.5x1.5x6	6.19 in	3500	0.46	2240	4768
				32	20	Arm 4300IVS	1.5x1.5x6	6.19 in	1740	0.47	752	193
Tower 5	15'	6'	90'	125	40	Arm 4300IVS	1.5x1.5x6	6.19 in	3500	0.45	2692	5633
				31	20	Arm 4300IVS	1.5x1.5x6	6.19 in	1740	0.47	232	58
Interior Area	19'	6'	90'	115	85	Arm 4300IVS	2x2x6	5.81 in	3500	0.53	1757	6102
				28	42	Arm 4300IVS	2x2x6	5.81 in	1740	0.51	1648	716
Admin Area	25'	3'	90'	115	65	Arm 4300IVS	2x2x6	5.81 in	3500	0.42	2139	7169
				28	33	Arm 4300IVS	2x2x6	5.81 in	1740	0.45	1056	408
RTHP-B2	20'	6.2'	90'	125	69	Arm 4300IVS	2x2x6	5.81 in	3500	0.44	1746	6445
				31	34	Arm 4300IVS	2x2x6	5.81 in	1740	0.46	42	18
RTHP-B3	20'	5.4'	90'	125	26	Arm 4300IVS	1.5x1.5x6	5.89 in	3500	0.32	3526	6743
				31	13	Arm 4300IVS	1.5x1.5x6	5.89 in	1740	0.41	0	0
RTHP-B4	20'	7.1'	90'	125	102	Arm 4300IVS	2x2x6	5.81 in	3500	0.55	1755	7661
				31	51	Arm 4300IVS	2x2x6	5.81 in	1740	0.58	677	348
Total										61138		

INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOTHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION


Goals of Redesigned Façade

- Provide area for redesigned mechanical system
- Allow for natural ventilation
- Incorporate elements previously used in the building
- Maintain views
- Balance vertical and horizontal elements
- Provide structural support



Disadvantages of Redesigned Façade

- Additional material and construction costs
- Concerns about removable panels

As Designed Building Renderings




Redesigned Building Renderings



Building Elevations


As Designed Elevations



As Designed Elevations



As Designed Windows



Redesigned Windows



INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOTHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION



Goals of Redesigned Façade

- Provide area for redesigned mechanical system
- Allow for natural ventilation
- Incorporate elements previously used in the building
- Maintain views
- Balance vertical and horizontal elements
- Provide structural support



Disadvantages of Redesigned Façade

- Additional material and construction costs
- Concerns about removable panels

As Designed Building Renderings



Redesigned Building Renderings



Building Elevations


As Designed Elevations



As Designed Elevations



As Designed Windows



Redesigned Windows



INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOTHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM

ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION



Goals of Redesigned Roof

- Reduce the overall height of the academic wing
- Tie the two wings of the building together
- Give the roof a lighter appearance
- Utilize previously used materials
- Design with appropriate slope to maintain proper water drainage



Disadvantages of Redesigned Roof

- Possibly more expensive

As Designed Building Renderings



Redesigned Building Renderings



Building Elevations

As Designed Elevations



As Designed Elevations



As Designed Windows



Redesigned Windows



INTRODUCTION

BUILDING OVERVIEW

MECHANICAL SYSTEM OVERVIEW

MECHANICAL DEPTHS

AIR SYSTEM MODIFICATIONS

NATURAL VENTILATION SYSTEM

GEOHERMAL HYBRID SYSTEM

DECENTRALIZED PUMPS SYSTEM


ARCHITECTURAL BREADTH

FAÇADE REDESIGN

ROOF REDESIGN

CONCLUSION

30 Life Cycle Cost Analysis



Life Cycle Cost Assumptions

Baseline

- Maintenance - \$1900/year
- Periodic Cost - \$30,000 every 20 years

Terminal Unit Redesign

- Maintenance - \$1900/year
- Periodic Cost - \$30,000 every 20 years

Natural Ventilation System

- Maintenance - \$1950/year
- Periodic Cost - \$30,000 every 20 years

Hybrid System

- Maintenance - \$2200/year
- Periodic Cost - \$90,000 every 17 years
- Periodic Cost - \$30,000 every 20 years

Recommendations

- All of the proposed systems are viable options with reasonable payback periods

ACKNOWLEDGEMENTS




- The Pennsylvania State University Architectural Engineering Faculty and Staff
- Thesis Advisor: Dustin Eplee
- Professor William Bahnfleth, Ph.D., PE
- Project Sponsor: Hayes Large Architects
- Sponsor Contact: Donald Goodman, PE
- David Barto and Barton Associates
- Alyssa Adams and McClure Company
- My fellow classmates who have supported me over the last five years, especially the gentlemen and ladies of 612
- My friends and family for all their love and encouragement



QUESTIONS?



APPENDICES



January DESIGN COOLING DAY, 1400






TABLE 1: SYSTEM DATA

Component	Location	Dry-Bulb Temp (°F)	Specific Humidity (lb/lb)	Airflow (CFM)	CO2 Level (ppm)	Sensible Heat (BTU/hr)	Latent Heat (BTU/hr)
Ventilation Air	Inlet	45.8	0.00605	2303	400	-14602	-19927
Ventilation Reclaim	Outlet	70.3	0.01377	2303	400	-58407	-80714
Vent - Return Mixing	Outlet	0.0	0.00000	0	0	-	-
Ventilation Fan	Outlet	70.3	0.01377	2303	400	0	0
Cold Supply Duct	Outlet	70.3	0.01377	2303	400	0	0
Zone Air	-	75.7	0.01567	2303	1223	45343	32390
Return Plenum	Outlet	75.7	0.01567	2303	1223	0	0
Exhaust Fan	Outlet	76.4	0.00000	2303	1223	1707	0

Air Density x Heat Capacity x Conversion Factor: At sea level = 1.080; At site altitude = 1.033 BTU/(hr-CFM-F)
Air Density x Heat of Vaporization x Conversion Factor: At sea level = 4746.6; At site altitude = 4540.4 BTU/(hr-CFM-F)
Site Altitude = 1224.0 ft

TABLE 2: ZONE DATA

Component	Location	Dry-Bulb Temp (°F)	Specific Humidity (lb/lb)	Airflow (CFM)	CO2 Level (ppm)	Sensible Heat (BTU/hr)	Latent Heat (BTU/hr)
Zone 1 (Cooling)							
Ventilation Air	-	-	-	392	-	-	-
Cooling Coil Inlet	-	73.9	0.01486	815	0	-	-
Cooling Coil Outlet	-	66.4	0.01418	815	0	6317	2556
Heating Coil Inlet	-	66.4	0.01418	815	0	-	-
Heating Coil Outlet	-	66.4	0.01418	815	0	0	0
Zone Air	-	75.7	0.01588	815	1195	7858	-
Zone 2 (Cooling)							
Ventilation Air	-	-	-	342	-	-	-
Cooling Coil Inlet	-	73.6	0.01418	634	0	-	-
Cooling Coil Outlet	-	64.3	0.01313	634	0	6056	3027
Heating Coil Inlet	-	64.3	0.01313	634	0	-	-
Heating Coil Outlet	-	64.3	0.01313	634	0	0	0
Zone Air	-	75.8	0.01466	634	1277	7476	-
Zone 3 (Cooling)							
Ventilation Air	-	-	-	483	-	-	-
Cooling Coil Inlet	-	73.2	0.01473	803	0	-	-
Cooling Coil Outlet	-	66.8	0.01438	803	0	5387	1300
Heating Coil Inlet	-	66.8	0.01438	803	0	-	-
Heating Coil Outlet	-	66.8	0.01438	803	0	0	0
Zone Air	-	75.7	0.01618	803	1145	7445	-
Zone 4 (Cooling)							
Ventilation Air	-	-	-	351	-	-	-
Cooling Coil Inlet	-	74.1	0.01377	784	0	-	-
Cooling Coil Outlet	-	63.2	0.01254	784	0	8878	4390
Heating Coil Inlet	-	63.2	0.01254	784	0	-	-
Heating Coil Outlet	-	63.2	0.01254	784	0	0	0
Zone Air	-	75.8	0.01376	784	1289	10255	-
Zone 5 (Cooling)							
Ventilation Air	-	-	-	392	-	-	-
Cooling Coil Inlet	-	74.0	0.01559	898	0	-	-
Cooling Coil Outlet	-	68.7	0.01547	898	0	4907	529
Heating Coil Inlet	-	68.7	0.01547	898	0	-	-
Heating Coil Outlet	-	68.7	0.01547	898	0	0	0
Zone Air	-	75.5	0.01702	898	1195	6304	-
Zone 6 (Cooling)							
Ventilation Air	-	-	-	342	-	-	-
Cooling Coil Inlet	-	73.9	0.01498	699	0	-	-
Cooling Coil Outlet	-	67.5	0.01477	699	0	4612	709
Heating Coil Inlet	-	67.5	0.01477	699	0	-	-
Heating Coil Outlet	-	67.5	0.01477	699	0	0	0
Zone Air	-	75.8	0.01615	699	1277	6005	-




APPENDICES

CURVE BOOKLET B-260G

1150 RPM PUMP CURVES

SERIES 1510



SERIES 1510

1750 RPM PUMP CURVES

CURVE BOOKLET B-260G

