# Coppin State University Physical Education Complex - Technical Report 2



**Building and Plant Energy Analysis Report** 

Kaylee M Damico Advisor: Dr. Jelena Srebric Location: Baltimore, MD

# **Table of Contents**

# Contents

Executive Summary
Mechanical System Overview3
System Design Load Estimation
Block Load Assumptions3
Results4
Energy Consumption and Operating Costs5
Assumptions5
Results5
Building Emission Rates
Appendix A - Energy Model Schedules10
Appendix B – Weather Data13
Appendix C – HAP Templates

# **Executive Summary**

The purpose of this report is to complete a building load energy analysis on the Coppin State University Physical Education Complex, as well as to analyze the annual energy consumption, operating costs and emissions of the building. Carrier's Hourly Analysis Program (HAP) version 4.50 was used to perform the energy load analysis and the energy consumption based on the design documents provided by the architects and engineers.

The modeled design loads were compared to the design loads performed by the mechanical engineer. Most of the results for the design load model were relatively close to those modeled by the mechanical engineer. The main reason for these discrepancies was due to the fact that a block load analysis was used for the model while the engineer used a space by space method.

Annual energy consumption, operating costs and emissions for the complex were also calculated using the same model as the design load. The costs and emissions of natural gas and electricity were the only factors considered in this part of the analysis. Overall the Complex's annual energy consumption was reasonably close to the national average of buildings with the same square feet.

# **Mechanical System Summary**

The Complex is served by a total of fourteen air handling units (AHUs) all utilizing variable air volume (VAV) terminal units. For large spaces, such as the arena and auxiliary gym, a single zone VAV system was used. The remaining units were zoned off per floors and architectural zones. There are also two energy recovery units that serve the locker rooms located throughout the complex.

A future central utility plant located on the first level houses two 500 ton chillers, three dual fuel 250HP boilers and space for future expansion. The cooling tower is located close to the central utility plant, on the roof of the complex. The boilers are operated with natural gas or oil while the remaining equipment utilizes electricity.

# **System Design Load Estimation**

Carrier's Hourly Analysis Program (HAP) version 4.50 was used to determine the design load energy consumption of the Coppin State University Physical Education Complex in Baltimore, MD. Information from the architectural and mechanical design documents were used to build and determine heating and cooling loads. The mechanical engineer performed an energy model utilizing an older version of HAP, version 3.2. The model created for this report was compared to the design engineer's model in the sections below.

# **Block Load Assumptions**

A block load analysis was performed for this assignment to help reduce the model calculation time and allowing the model file size to be more manageable. The results are still accurate within reason with the assumptions listed below being considered.

#### **Exterior Walls**

The wall construction was simplified to either a typical concrete masonry unit (CMU) wall with face brick or a CMU wall with a metal finish. The actual building has multiple varieties of face brick walls, but these two versions were used for simplification.

#### **Occupancy and Ventilation**

All ventilation rates were taken from the design schedules provided by the mechanical engineer. Design occupancies were already calculated in Technical Report 1, which were taken from the architectural drawings. Most of the spaces had an occupancy activity level of typical office work which has a sensible load of 245 BTU/hr/person and a latent load of 205 BTU/hr/person. In other spaces where people are performing physical activities, such as the dance studio and auxiliary gym, an occupancy activity of athletics was used with a sensible load of 710 BTU/hr/person and a latent load of 1090 BTU/hr/person. The occupancy schedules used in the model are summarized in Appendix A.

#### Infiltration

The Complex was designed to maintain a total building pressurization; this is typically between 3% and 5%, in order to prevent unconditioned air from entering the building. Infiltration was not considered in this model due to the design constraint specified above by the mechanical engineer.

#### **Lighting and Equipment Loads**

The electrical loads in the Complex varied so much from space to space that the actual lighting loads given by the electrical engineer were used. Equipment found in each space was input using the actual watts given by the mechanical engineer. Using the actual data in this model will help provide a more accurate result.

#### Weather Data

Indoor and outdoor air conditions for heating and cooling in Baltimore, MD were used for this analysis. The values summarized in Appendix B were referenced by HAP from the 2001 ASHRAE Handbook.

#### **Results**

Tables 1 and 2 below summarize the results of the energy model and compare the results to the engineer's design. The block load energy model resulted in different values than those designed for each air handling unit and energy recovery unit. Templates of typical spaces and components used can be found in Appendix C. The differences in these values could be consequences of the safety factors applied by the mechanical engineer or the details put into each space. The main reason for these differences is most likely due to the fact that a block load analysis was used in the model while the mechanical engineer used a space by space method for the design.

		AHU-1	AHU-2	AHU-3	AHU-4	AHU-5/6	AHU-7	AHU-8
Cooling	Designed	621	397	650	637	6540	509	1029
(MBH)	Modeled	281.4	267.8	411.8	362.1	3084.2	245.1	481.9
Supply Air	Designed	12250	9000	13750	14750	80000	11500	19600
(cfm)	Modeled	5023	8453	12411	11426	72892	7316	16290
Ventilation	Designed	4000	1975	3800	3400	62000	2800	7500
Air (cfm)	Modeled	2062	1362	1694	1190	10800	762	1399
Heating	Designed	529	389	594	637	1728	497	847
(MBH)	Modeled	127.5	91.3	142	161.5	899.7	122.1	182.7

#### *Table 1 – Modeled vs. Designed Energy Analysis*

		0	0,	2	1			
		AHU-9/10	AHU-11	AHU-12	AHU-13	AHU-14	ERU-1	ERU-2
Cooling	Designed	958	1404	539	596	-	733	1091
(MBH)	Modeled	779.9	8601.1	418.8	430.6	-	267	488.8
Supply Air	Designed	23000	28000	13000	13950	4800	9820	14100
(cfm)	Modeled	19057	22157	10162	8453	4773	9765	14022
Ventilation	Designed	4600	9150	2600	2500	480	9820	1410
Air (cfm)	Modeled	4295	5140	2168	2329	136	401	1190
Heating	Designed	497	1210	562	603	207	283	404
(MBH)	Modeled	386.9	352.2	201.8	185.9	140.4	71.5	162.4

#### Table 2 - Modeled vs. Designed Energy Analysis (continued)

# **Energy Consumption and Operating Costs**

Annual energy consumption and operating costs were modeled using the same model as the heating and cooling loads. The chiller plant was modeled using a primary/secondary distribution system with the secondary being variable speed. The chillers are centrifugal while to cooling tower was modeled after the details given by the mechanical engineer. The boiler plant was modeled simply as natural gas instead of the actual dual-fuel installed.

# Assumptions

The electrical and natural gas rates for the local Baltimore area were used for the energy consumptions and operating costs shown in Table 3 below. These values were taken from the US Energy Information Administration (EIA).

#### Table 3 - Energy Rates

	Local Rates
Electricity Cost (\$/kWh)	0.12
Natural Gas Cost (\$/Therm)	1.138

Equipment efficiencies were determined by those listed by the manufacturer. The efficiencies were assumed to be constant, not a part load curve for simplification of the model. Supply and exhaust fans were modeled based on the horsepower listed in the design documents.

# **Results**

Table 4 below shows the annual energy consumption used by the complex broken down by component type. Referencing Figure 1, the largest consumer of energy in the building is the cooling tower fans. This large percentage is due to the large flow rate of the condenser at 1,015 GPM. The cooling tower for the complex is a very large tower and was sized with expansion in mind. The lights, electrical equipment, and air system fans consume the next largest amount of energy.

This annual energy consumption was compared to the Commercial Buildings Energy Consumption Survey (CBECS) 2003. In Table E2A (Major Fuel Consumption Intensities by End Use for all Buildings) of CBECS a building with the same ranger of square footage as the complex consumed an average of 100,200 BTU/SF. When comparing this value to the complex at approximately 92,000 BTU/SF the numbers produced by the model appear accurate.

# Table 4 - Annual Energy Consumption

	Energy (kWh)
Air Systems Fans	1,434,527
Cooling	1,010,456
Heating	751,846
Pumps	201,676
Cooling Tower Fans	3,653,707
Lights	1,621,230
Electrical Equipment	1,289,010
Misc. Electric	150,600
Grand Total	10,113,052





In Table 5 and Figure 2 the annual cost is illustrated and Figure 3 breaks down the cost in detail showing a month by month cost. The month by month analysis illustrates accurate results. The electrical costs are much greater in the summer during the peak cooling season while the natural gas cost increases during the winter during the peak heating season. The electrical consumption is consistently larger than the natural gas due to the high miscellaneous equipment operating throughout the complex.

# Table 5 - Annual Energy Costs

	Cost per year (\$)	Cost per SF (\$/SF)
Air Systems Fans	182,762	0.873
Cooling	127,354	0.609
Heating	30,009	0.143
Pumps	25,681	0.123
Cooling Tower Fans	46,526	0.222
Lights	204,333	0.977
Electrical Equipment	164,142	0.785
Misc. Electric	18,981	0.091
Grand Total	799,699	3.822

# Figure 2 - Annual Energy Cost Percentages







# **Building Emission Rates**

The emission rates for pollutants such as  $CO_2$ ,  $NO_x$ , and  $SO_x$  were calculated based on the total energy consumption of the complex. The total amount of electricity and natural gas amounts from the HAP model previously discussed were used. Maryland is located in the Eastern Region according to the National Renewable Energy Laboratory (NREL), shown in pink below, in Figure 4.

## Figure 4- Monthly Energy Costs



The total source pollution emissions that are generated by the Complex are illustrated in Tables 6 and 7. The amount of pollutant per amount of energy source was taken from Tables 3 and 6 of the NREL Energy and Emissions Report. As seen in the tables, most of the pollutants come from electricity. This is due to the drastic efficiency difference of natural gas and electricity. The natural gas is burnt and used in the boilers which are 80% efficient versus the electricity which has an efficiency of approximately 30% from the original utility provided.

# Table 6 - Annual Emission Rates

Pollutants	lb of Pollutant per kWh of electricity	kWh of electricity per year	Amount of Pollutant per year (lb)
CO2	1.64	24,511,204	40,198,375
Nox	0.003	24,511,204	73,534
Sox	0.00857	24,511,204	210,061

# Table 7 - Annual Emission Rates (continued)

Pollutants	lb of Pollutant per 1000 cubic feet of Natural gas	Natural Gas per year (1000 cubic feet)	Amount of Pollutant per year (lb)
CO2	11.6	30,486	353,638
Nox	0.0164	30,486	500
Sox	1.22	30,486	37,193

# Appendix A – Energy Model Schedules

#### Air Handling Units Schedule (Most Spaces)



#### Hourly Profiles:

1:	Profile (	Jne																							
	Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
	Value	50	50	50	50	50	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	50	50
2:	Profile 1	ſwo																							
	Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
	Value	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
3:1	Profile 1	Three																							
	Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23

# Hour 00 01 02 03 04 05 06 07 08 09 10 11 12 13 14 15 16 17 18 19 20 21 22 23 Value 100

Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Auq	Sep	Oct	Nov	Dec
Design	3	3	3	3	3	3	3	3	3	3	3	3
Monday	1	1	1	1	1	1	1	1	1	1	1	1
Tuesday	1	1	1	1	1	1	1	1	1	1	1	1
Wednesday	1	1	1	1	1	1	1	1	1	1	1	1
Thursday	1	1	1	1	1	1	1	1	1	1	1	1
Friday	1	1	1	1	1	1	1	1	1	1	1	1
Saturday	2	2	2	2	2	2	2	2	2	2	2	2
Sunday	2	2	2	2	2	2	2	2	2	2	2	2
Holiday	2	2	2	2	2	2	2	2	2	2	2	2

#### 24/7 Equipment Schedule



#### 1:Profile One

Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100

2:F	Profile 1	wo																							
	Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
	Value	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100

#### 3:Profile Three

Hour	00	01	02	03	04	05	06	07	<b>08</b>	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value 1	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100

#### 4:Profile Four

Hour	00	01	02	03	04	05	06	07	<b>08</b>	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Value	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100

#### Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	1	1	1	1	1	1	1
Monday	2	2	2	2	2	2	2	2	2	2	2	2
Tuesday	2	2	2	2	2	2	2	2	2	2	2	2
Wednesday	2	2	2	2	2	2	2	2	2	2	2	2
Thursday	2	2	2	2	2	2	2	2	2	2	2	2
Friday	2	2	2	2	2	2	2	2	2	2	2	2
Saturday	3	3	3	3	3	3	3	3	3	3	3	3
Sunday	4	4	4	4	4	4	4	4	4	4	4	4
Holiday	4	4	4	4	4	4	4	4	4	4	4	4

# Gym Schedule

🛄 Schedu	le P	rop	ertie	es -	[Gy	m L	ight	ting	]				X	
<u>S</u> chedule 1	Schedule Type Hourly Profiles Assignments													
				м	on	i t k	1:Profile One 2:Profile Two							
	J	F	м	A	м	J	J	A	S	0	N	D		
Design	1	1	1	1	1	1	1	1						
Mon.	2	2	FEILUREIENENENENENENENENENENENENENENENENENENE											
Tue.	Image: Type     Image:													
Wed.	Wed. 2 2 2 3 3 3 3 3 2 2 2													
Thu.	2	2	2	3	3	3	3	3	3	2	2	2		
Fri.	2	2	2	3	3	3	3	3	3	2	2	2	5:Profile Five 6:Profile Six	
Sat.	2	2	2	3	3	3	3	3	3	2	2	2		
Sun.	3	3	3	3	3	3	3	3	3	3	3	3		
Holiday	3	3	3	3	3	3	3	3	3	3	3	3	7-Profile Seven 8:Profile Fight	
U bl	se ti ock prof	he m of c ile to	ious ells ) ass	e or and sign	the pres it to	arro s a thos	w ke num se da							
										[		OK	Cancel <u>H</u> elp	

# Hourly Profiles:

1:6	rotile	Jne																							
	Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
	Value	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
_																									
2:F	Profile 1	wo																							
	Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
	Value	0	0	0	0	0	0	0	0	30	30	30	30	30	30	30	30	30	30	30	100	100	100	100	30
3:F	Profile 1	Three							_	_	_						_					_			
	Hour	00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23
	Value	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

#### Assignments:

	Jan	Feb	Mar	Apr	May	Jun	Jul	Auq	Sep	Oct	Nov	Dec
Design	1	1	1	1	1	1	1	1	1	1	1	1
Monday	2	2	2	3	3	3	3	3	3	2	2	2
Tuesday	2	2	2	3	3	3	3	3	3	2	2	2
Wednesday	2	2	2	3	3	3	3	3	3	2	2	2
Thursday	2	2	2	3	3	3	3	3	3	2	2	2
Friday	2	2	2	3	3	3	3	3	3	2	2	2
Saturday	2	2	2	3	3	3	3	3	3	2	2	2
Sunday	3	3	3	3	3	3	3	3	3	3	3	3
Holiday	3	3	3	3	3	3	3	3	3	3	3	3

# **Appendix B – Weather Data**

Weather Properties - [Baltimore]	x
Design Parameters   Design Temperatures   De	sign Solar   Simulation
Begion: U.S.A. ▼   Location: Maryland ▼   City: Baltimore ▼   Latitude: 39.2 deg   Longitude: 76.7 deg   Elevation: 154.0 ft   Summer Design DB 93.0 °F   Summer Coincident WB 75.0 °F	Atmospheric Clearness   Number   Average Ground   Average Ground   Beflectance   Soil Conductivity   Design Clg   Calculation Months   Jan   Ime Zone (GMT +/-)   Soil Savings   Or Yes
Summer Daily Range	DST Begins Apr - 1 DST Ends Oct - 31
Winter Design DB 11.0 F Winter Coincident WB 8.6 F	Data Source: 2001 ASHRAE Handbook
	OK Cancel <u>H</u> elp

#### Design Day Maximum Solar Heat Gains

(The MSHG values are expressed in BTU/(hr-ft²) )

Month	N	NNE	NE	ENE	E	E SE	SE	SSE	S
January	19.9	19.9	19.9	83.1	153.9	210.8	240.9	250.7	253.7
February	24.3	24.3	47.8	131.8	190.2	234.0	248.2	244.2	239.0
March	29.1	29.1	102.3	166.2	219.3	238.4	236.0	215.6	202.9
April	33.8	67.9	142.1	194.8	219.4	224.8	200.1	167.9	149.0
May	37.1	103.1	163.5	206.7	219.0	206.8	170.1	128.8	107.0
June	46.7	113.7	171.1	208.4	214.5	197.7	156.5	112.2	90.7
July	38.1	99.0	163.2	202.4	212.3	202.8	167.1	125.8	104.7
August	35.5	66.2	138.6	186.6	213.6	216.8	193.9	162.4	144.4
September	30.1	30.1	96.7	156.2	206.1	229.2	225.8	208.3	195.5
October	25.1	25.1	53.4	118.9	186.2	223.8	241.4	237.6	231.1
November	20.2	20.2	20.2	84.1	150.2	205.2	237.5	249.4	248.6
December	17.9	17.9	17.9	65.8	135.4	196.6	231.7	248.4	252.0
Month	SSW	SW	WSW	w	WNW	NW	NNW	HOR	Mult
January	253.6	243.0	205.2	156.3	81.7	19.9	19.9	137.1	1.00
February	243.9	248.3	235.2	191.0	128.3	54.4	24.3	183.6	1.00
March	213.9	232.4	240.5	214.0	171.2	100.0	29.1	225.2	1.00
April	166.9	199.0	224.0	221.6	195.6	139.7	72.0	252.4	1.00
May	128.1	171.1	206.0	220.1	206.4	161.8	104.3	265.0	1.00
June	110.8	158.3	195.4	216.7	207.0	168.6	116.0	267.7	1.00
July	124.3	167.8	199.8	216.3	201.6	159.1	104.4	262.8	1.00
August	160.9	192.3	215.9	213.9	188.9	135.6	71.3	248.2	1.00
September	208.4	226.0	228.9	206.5	155.1	96.7	30.1	216.2	1.00
October	237.5	240.9	223.1	185.1	125.2	46.8	25.1	179.5	1.00
November	248.3	234.2	207.1	147.2	84.6	20.2	20.2	135.4	1.00
December	250.0	230.6	196.4	130.6	67.7	17.9	17.9	116.0	1.00

Mult. = User-defined solar multiplier factor.

# **Appendix C – HAP Templates**

## **Typical Wall Template**

Wall Properties - [W	all 1]					X
Wall Assembly <u>N</u> ame:	Wall 1					•
Outside Surface <u>C</u> olor:	Dark	•			Absorptivity:	0.900
Layers: Inside to 0	Dutside	Thickness	Density Ib/ft <sup>g</sup>	Specific Ht. BTU/Ib/F	R-Value hr-ft²-F/BTU	Weight Ib/ft²
Inside surface res	istance	0.000	0.0	0.00	0.68500	0.0
Gypsum board	-	0.625	50.0	0.26	0.56000	2.6
8-in HW concrete	block 🔻	8.000	61.0	0.20	1.11111	40.7
R-7 board insulati	ion 🔻	2.000	2.0	0.22	9.47000	0.3
Air space	•	0.000	0.0	0.00	0.91000	0.0
Face brick		4.000	125.0	0.22	0.33333	41.7
Outside surface re	esistance	0.000	0.0	0.00	0.33300	0.0
Totals		14.625			13.40	85.3
			Οv	verall U-Value:	0.075	BTU/hr/f۴/F
				04	Connect	Lista I
						<u>H</u> eib

# Metal Wall Template

Wall Properties - [Wall Metal]					×							
Wall Assembly <u>N</u> ame: Wall Me	tal				•							
Outside Surface <u>C</u> olor: Dark	-			Absorptivity:	0.900							
Layers: Inside to Outside	Thickness in	Density Ib/ft³	Specific Ht. BTU/Ib/F	R-Value hr-fi²-F/BTU	Weight Ib/ft <sup>e</sup>							
Inside surface resistance	Inside surface resistance 0.000 0.0 0.00 0.68500 0.0											
8-in HW concrete block	▼ 8.000	61.0	0.20	1.11111	40.7							
R-7 board insulation	▼ 1.000	2.0	0.22	14.46000	0.2							
Air space	• 0.000	0.0	0.00	0.91000	0.0							
22 gage steel deck	▼ 0.034	489.0	0.12	0.00011	1.4							
Outside surface resistance	0.000	0.0	0.00	0.33300	0.0							
Totals	9.034			17.50	42.2							
		Οv	/erall U-Value:	0.057	BTU/hr/ft⁰/F							
			OK	Cancel	<u>H</u> elp							

# **Roof Template**

50	R	Roof Properties - [Ro	oof]					X					
	Ro	oof Assembly <u>N</u> ame:	Roof					•					
Ŀ	Οι	utside Surface <u>C</u> olor:	Light	-			Absorptivity:	0.450					
		Layers: Inside to (	Dutside	Thickness in	Density Ib/ft <sup>e</sup>	Specific Ht. BTU/Ib/F	R-Value hr-ft²-F/BTU	Weight Ib/ft²					
		Inside surface res	istance	0.000	0.0	0.00	0.68500	0.0					
	Þ	Steel deck	•	0.034	489.0	0.12	0.00011	1.4					
		Board insulation	•	4.500	2.0	0.22	23.40000	0.8					
		Built-up roofing	•	0.376	70.0	0.35	0.33200	2.2					
		Outside surface re	esistance	0.000	0.0	0.00	0.33300	0.0					
		Totals		4.910			24.75	4.3					
					0\	/erall U-Value:	0.040	BTU/hr/f۴/F					
	Totals   4.910   24.75   4.3     Overall U-Value:   0.040   0.040   BTU/hr/f8/l												
L						ок	Cancel	<u>H</u> elp					

# Window Template

H Window Prop	erties - [Windo	w]			×
Window Details	W	indow			
Detailed Input:					
H <u>e</u> ight:	1.0	<b>00</b> ft		<u>W</u> idth	n: <b>1.00</b> ft
Erame Type:					-
Internal Shade	Гуре:				-
Overall <u>U</u> -Value	0.4	<b>430</b> BT	U/hr/ft²/F		
Overall Shade <u>C</u>	oefficient: 0.3	290			
<u>Glass Details</u>					
Glazing	Glass T	уре	Transmissivity	Reflectivity	Absorptivity
Outer Glazing		-			
Glazing #2		-			
Glazing #3		-	]		
Gap <u>T</u> ype:		•	]		
			OK	Cancel	<u>H</u> elp

# Auxiliary Gym Template

🗊 Space Properties - [109 - Aux Gym]	×
General Internals Walls, Windows, Doors	Roofs, Skylights   Infiltration   Floors   Partitions
Overhead Lighting   Eixture Type Recessed, unvented   Wattage 3.70   Ballast Multiplier 1.00   Schedule AHU 5,6,8,9,12   Task Lighting   Wattage 0.00   Wattage 0.00   Schedule (none)	People   □ccupancy 100.0 People   △ctivity Level Athletics ▼   Activity Level Athletics ▼   Sensible 710.0 BTU/hr/person   Latent 1090.0 BTU/hr/person   Schedule AHU 5,6,8,9,12 ▼   Miscellaneous Loads BTU/hr   O BTU/hr
Electrical Equipment	Schegule AHU 5,6,8,9,12
Wattage 14000.0 Watts -	Latent 0 BTU/hr
Schedule AHU 5,6,8,9,12	Schedule (none)
	OK Cancel <u>H</u> elp

# **Typical Office Template**

deneral monta			Dors, Skylights	minidadori r	ioois   Faituor
– Overhead Lighti	ng				
<u>F</u> ixture Type	Recessed, unvented	•	Uccupancy	1.0	People 💽
<u>W</u> attage	0.75 W/ft <sup>e</sup>	•	Activity Level	Office Work	•
<u>B</u> allast Multiplier	1.00	_	Sensi <u>b</u> le	245.0	BTU/hr/perso
<u>S</u> chedule	Zoned AHUs	-	<u>L</u> atent	205.0	BTU/hr/perso
Task Lighting	,	_	Sch <u>e</u> dule	Zoned AHUs	•
W <u>a</u> ttage	0.00 W/ft <sup>e</sup>	-	_ Miscellaneou:	s Loads	
S <u>c</u> hedule	(none)	-	Sensible	0	BTU/hr
- Electrical Equipr	nent		Sche <u>d</u> ule	Zoned AHUs	-
Wa <u>t</u> tage	150.0 Watts	-	Late <u>n</u> t	0	BTU/hr
Sc <u>h</u> edule	Zoned AHUs	•	Sched <u>u</u> le	(none)	•

# **Typical Facilities Maintenance Space Schedule**

Space Properties - [194 - Plumbing Shop]				
General Internals Walls, Windows, Doors	Roofs, Skylights   Infiltration   Floors   Partitions			
Overhead Lighting   Eixture Type Recessed, unvented   Wattage 1.00   W/ft <sup>2</sup> Ballast Multiplier   Ballast Multiplier 1.00   Schedule Zoned AHUs   Task Lighting Wattage   Wattage 0.00   W/ft <sup>2</sup> Electrical Equipment   Wattage 2000.0	People   Occupancy 5.0 People ▼   Activity Level Office Work ▼   Sensible 245.0 BTU/hr/person   Latent 205.0 BTU/hr/person   Schedule Zoned AHUs ▼   Miscellaneous Loads Sensible 0 BTU/hr   Schedule Zoned AHUs ▼   Latent 0 BTU/hr			
	OK Cancel <u>H</u> elp			

#### **Typical Conference Room Schedule**

🚮 Space Properties - [222 - Conf Room]	X			
General Internals Walls, Windows, Doors Roofs, Skylights Infiltration Floors Partitions				
Overhead Lighting	People			
Eixture Type Recessed, unvented 💌	Occupancy 14.0 People -			
Wattage 1.00 W/ft <sup>2</sup>	Activity Level Office Work			
Ballast Multiplier 1.00	Sensible 245.0 BTU/hr/person			
Schedule Zoned AHUs	Latent 205.0 BTU/hr/person			
Task Lighting	Schedule Zoned AHUs			
Wattage 0.00 W/ft -	Miscellaneous Loads			
Schedule (none)	Sensible 0 BTU/hr			
Electrical Equipment	Schedule Zoned AHUs			
Wattage 1300.0 Watts -	Latent 0 BTU/hr			
Schedule Zoned AHUs	Schedule (none)			
4	OK Cancel <u>H</u> elp			

## **Typical Classroom Schedule**

Space Properties - [226 - Classroom]				
General Internals Walls, Windows, Doors Roofs, Skylights Infiltration Floors Partitions				
Overhead Lighting   Fixture Type Recessed, unvented   Wattage 1.20   Wattage 1.20   Ballast Multiplier 1.00   Schedule Zoned AHUs   Task Lighting   Wattage 9.00	People   Occupancy 40.0 People   Activity Level Office Work ▼   Sensible 245.0 BTU/hr/person   Latent 205.0 BTU/hr/person   Schedule Zoned AHUs ▼			
Schedule (none)	Sensible 0 BTU/hr			
Electrical Equipment	Schedule Zoned AHUs			
Wattage 1800.0 Watts 💌	Latent 0 BTU/hr			
Schedule Zoned AHUs	Schedule (none)			
	OK Cancel <u>H</u> elp			

## **References**

Administration, E.I. (n.d.). *Energy Star*. Retrieved October 23, 2010, from: http://www.eia.doe.gov/emeu/cbecs/cbecs2003/detailed\_tables\_2003/2003set19/2003pdf/e02.pdf.

ASHRAE.2007, ANSI/ASHRAE, <u>Standard 62.1-2007</u>, <u>Ventilation for Acceptable Indoor Air Quality</u>. American Society of Heating Refrigeration and Air-Conditioning Engineer, Inc. Atlanta, GA.

ASHRAE. 2007, ANSI/ASHRAE, Standard 90.1-2007, <u>Energy Standard for Building except Low-Rise</u> <u>Residential Buildings.</u> American Society of Heating Refrigeration and Air-Conditioning Engineers, Inc. Atlanta, GA.

James Posey Associates, Inc. 2008. <u>LEED Documentation</u>. James Posey Assoc., Inc. Baltimore, MD.

Previous Senior Thesis Reports 2009-2010

Torcellini, M.D. (June 2007). Source Energy Emission Factors for Energy Use in Buildings. Golden, Colorado: National Renewable Energy Laboratory (NREL).

US Energy Information Administration. EIA. Retrieved October 23,2010, from: http://www.eia.doe.gov/dnav/404error.asp?qFlag=y.