


Presentation Outline


- Introduction
- System Optimization Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Thesis Final Presentation



Presentation Outline

•Introduction


- Building Overview
- Mechanical Overview
- Goals
- System Optimization Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option

Building Overview

Location:	Arlington, VA
Size: 8 Levels	251,000 SF
Total Cost:	\$100,000,000
Occupancy:	Administrative/Office
Delivery Method:	Design-Bid-Build with Lump Sum
Architect:	CH2MHILL
Engineers:	AECOM DMJM H&N
Owner:	Army National Guard
Construction Period:	Dec. 2008 to March 2011



Presentation Outline

•Introduction

- Facility Information
- Mechanical Overview
- Goals
- System Optimization Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option

Mechanical Overview

Air Delivery System:

Hydronic 4 Pipe VAV
17 AHU with FCU

Chilled Water System:


(2) 400 Ton Water Cooled Chillers

Hot Water System:

(5) 1000 MBH Natural Gas Boilers

Control System:

Direct Digital Control using BAS




Presentation Outline

•Introduction

- Facility Information
- Mechanical Overview
- Goals
- System Optimization Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

**Army National Guard
Readiness Center Addition**
Arlington, VA

Mitchell E. Peters
Mechanical Option



Cooling	
Supply (cfm/SF)	5.03
Ventilation (cfm/SF)	1.43
Load(SF/ton)	789

Heating	
Design Load (SF/ton)	543

Annual Energy Use(kBTU/SF*yr)	
Cooling	19.11
Heating	25.18
Pump	5.65
Fan	17.6
TOTAL	67.54

Annual Operating Costs	
Electricity(45.3%)	221,231.40
Chilled Water(16.3%)	79,780.35
Hot Water(18.7%)	91,527.15
Domostic Water(19.8%)	96,911.10
TOTAL	489,450
Total/SF	1.95



Presentation Outline

•Introduction

- Facility Information
- Mechanical Information
- Goals
- System Optimization Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions


Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option

Redesign Goal:

Reduce Operating Costs as well as Energy
Consumption at a reasonable first cost.

Accomplish with DOAS with incorporated
ACB system.



Presentation Outline

- Introduction

- System Optimization Analysis**

- DOAS Analysis**

- Design Conditions
 - Sensible Load
 - Reductions

- Energy Cost Savings

- Cost Analysis

- Acoustical Breadth


- Conclusion

- Acknowledgements

- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Dedicated Outdoor Air System

1. Less Ventilation Air
2. Indoor Air Quality
3. Decoupled Loads





Presentation Outline

- Introduction
- **System Optimization Analysis**
 - DOAS Analysis
 - Design Conditions
 - Sensible Load
 - Reductions
 - Energy Cost Savings
 - Cost Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Active Chilled Beams



Presentation Outline

- Introduction

- System Optimization Analysis**

- DOAS Analysis

- Design Conditions
 - Sensible Load
 - Reductions

- Energy Cost Savings

- Cost Analysis

- Acoustical Breadth



- Conclusion

- Acknowledgements

- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Presentation Outline


•Introduction

•System Optimization Analysis

- DOAS Analysis
 - Design Conditions
 - Sensible Load
 - Reductions
- Energy Cost Savings
- Cost Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Indoor Design Conditions:

Cooling:

Dry Bulb: 77°F
Relative Humidity: 50%
Dew Point: 57.3°F
Humidity Ratio: 72.27°F
ACB Surface Temp: 62°F

Heating:

ACB Temp: 95°F
Inlet: 97°F
Outlet: 93°F



Presentation Outline

•Introduction

•System Optimization Analysis

•DOAS Analysis

•Design Conditions

•Sensible Load

•Reductions

•Energy Cost Savings

•Cost Analysis

•Acoustical Breadth


•Conclusion

•Acknowledgements

•Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Supply Air:

Required: 52,100 CFM

$$Q_L = 0.68 V_{SA} (\Delta W), \text{ or } W_{SA} = W_{SP} - Q_L / (0.68 V_{SA})$$

W_{SA} = Supply Air Humidity Ratio (gr/lb of dry air)

W_{SP} = Space Humidity Ratio (gr/lb of dry air)

Q_L = Space Latent Load (BTU/hr)

V_{SA} = Supply Air Flow Rate (CFM)

Humidity Ratio:

42.1 gr/lb dry air



Presentation Outline

•Introduction

•System Optimization Analysis

•DOAS Analysis

•Design Conditions

•Sensible Load

•Reductions

•Energy Cost Savings

•Cost Analysis

•Acoustical Breadth


•Conclusion

•Acknowledgements

•Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Sensible Load:

Temperature difference: $77-45=32^{\circ}\text{F}$

$$Q_s = 1.08V_{SA}(\Delta T)$$

Q_s = Space Sensible Load (BTU/hr)

V_{SA} = Supply Air Flow Rate (CFM)

ΔT = Difference between Room Air DB and Supply Air DB ($^{\circ}\text{F}$)

ACB cooling capacity: 2,200 BTU/hr

ACB required: 1,277



Presentation Outline

•Introduction

•System Optimization Analysis

•DOAS Analysis


- Design Conditions
- Sensible Load

•Reductions

- Energy Cost Savings
- Cost Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



System	CFM	OA%	Reduction
ACB	52,100	100	148,700
Existing VAV	200,800		

System	Cooling (TONS)	Heating (MBH)
ACB	656	4957.3
Existing VAV	728	6320



Presentation Outline


- Introduction

- System Optimization Analysis**

- DOAS Analysis
 - Design Conditions
 - Sensible Load
 - Reduction
- Energy Cost Savings**
- Cost Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

**Army National Guard
Readiness Center Addition
Arlington, VA**

**Mitchell E. Peters
Mechanical Option**



Annual Energy Use (kBtu/SF*yr)		
Cooling	19.11	14.52
Heating	25.18	19.14
Pump	5.65	12.34
Fan	17.60	14.11
Total:	67.54	60.11

Over 11% reduction in Energy Consumption



Presentation Outline

•Introduction

•System Optimization Analysis

•DOAS Analysis

- Design Conditions
- Sensible Load
- Reduction


•Energy Cost Savings

•Cost Analysis

- Acoustical Breadth
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Initial Cost	
Equip. Type	Costs(\$)
AHU	-200,000
VAV	-18,434
FCU	0
PUMP	167,264
FAN	-15,645
ACB's	510,800
Total:	443,985

Resulting payback of 25 years

Daily operating cost/SF reduced from 1.95-1.83



Presentation Outline

- Introduction
- System Optimization Analysis
- Acoustical Breadth**
 - SCIF Area Overview
 - Soundproofing Considerations
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option

SCIF:

Sensitive Compartmented Information Facility

SCI storage

Door: requirements


single entry (fire escape) min. 1-3/4" thick

Walls: Ceilings, floors and walls must all be connected

Required STC of 50 or better-very loud noise can faintly heard

ArNG doors- STC 55

ArNG walls- STC 56 with welded metal mesh




Presentation Outline

- Introduction
- System Optimization Analysis
- Acoustical Breadth**
 - SCIF Area Overview
 - Soundproofing Considerations**
- Conclusion
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Soundproofing Considerations:

Current wall construction: 4 layers 5/8" GWB with welded mesh

STC 55
Cost: \$12.02/SF

Redesign: 2 layers 5/8" GWB with resilient channel
STC 44 sound class 3-appropriate for SCIF
Cost: \$7.18/SF- \$30,000 in savings
Use in conjunction with sound masking device
Single unit covers 6,000 SF- costs less than savings



Presentation Outline

- Introduction
- System Optimization Analysis
- Acoustical Breadth
- Conclusion**
 - Recommendations
- Acknowledgements
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA


Mitchell E. Peters
Mechanical Option

Conclusion:

More Energy Efficient
DOAS and its use of 100% OA inherently has a higher IAQ
Maintenance benefits
Maintained Thermal Comfort

Savings not as beneficial as hoped: First costs not overcome by operating costs.

VAV system as designed is cheap and economical




Presentation Outline

- Introduction
- System Optimization Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements**
- Questions

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Acknowledgements:

Special Thanks To:
AE Faculty
&
Family and Friends




Presentation Outline

- Introduction
- System Optimization Analysis
- Acoustical Breadth
- Conclusion
- Acknowledgements
- **Questions**

Army National Guard
Readiness Center Addition
Arlington, VA

Mitchell E. Peters
Mechanical Option



Questions

