

Resubmitted Thesis Proposal



Matthew R Peyton

This Document is Thesis Proposal for 5th year senior thesis in the Architectural Engineering Departments at The Pennsylvania State University.

Structural Option

Professor Behr

Hospital Patient Tower

Virginia, U.S.A.

12/10/2010

Table of Contents

Executive Summary	2
Introduction	3
Structural Systems.....	4
Foundations	4
Columns	5
.....	6
Floor System.....	7
Roof System	8
Lateral System.....	9
Design & Code Review.....	9
Design Codes and References	9
Thesis Codes and References	9
Deflection Criteria	9
Floor Deflection Criteria.....	9
Material Specifications	10
Problem Statement	10
Problem Solution.....	10
Breadth Issues.....	11
Task and Tools.....	12
Proposed Schedule.....	13
Appendix I.....	14

Executive Summary

The following is a proposed in-depth study for the redesign of a structural system for the Patient tower. The Patient Tower is part of the 2015 Capital Improvement Project, of which the Tower Expansion is one of the earlier phases. The new Patient Tower will connect with an existing patient tower by a bank of elevators. The Tower will also await the connection of a women's health facility that is one of the next phases of the Capital Improvement Project.

The existing structural system is a two – way reinforced concrete slab supported by concrete columns with reinforced concrete shear walls to resist the lateral loads that are applied to the tower.

The proposed structural change for the Patient tower is changing the gravity system of the tower from two-way concrete to a steel frame with hollow concrete plank will help with the weight of the system and the construction duration. The lateral system for the tower will remain the same for the existing system.

Breath studies will explore constructability and serviceability impacts. The Change in the gravity resisting system from a two – way flat plate reinforced concrete slab to a steel frame with precast concrete plank decking will produce a change in the Construction management of the project. With the change in system there will be a decrease the weight of the tower which would decrease the need for such a bearing ability of the foundations elements. With the faster erection time for steel shortening the length of construction should yield a lower cost of the structure.

With the change for a concrete gravity system to a steel system there are a few serviceability criteria that will need to be checked. In a hospital vibration, acoustics and floor deflection will all be very important criteria that will need to be kept with in close tolerances to not affect the patients. The existing concrete system has inherited properties that will handle these criteria where the new system may need the addition of other materials to help it satisfy the criteria.



Figure 1: Rendering by Wilmot Sanz

Introduction

The Patient Tower is part of the 2015 Capital Improvement Project, of which the Tower Expansion is one of the earlier phases. The new Patient Tower will connect with an existing patient tower by a bank of elevators separated into two sections, one for visitors and the other for patients at every floor. The Tower will also await the connection of a women's health facility that is one of the next phases of the Capital Improvement Project. The Façade of the Patient Tower will blend in with the existing buildings by keeping some of the red brick on the exterior, but also by taking on a more modern look by incorporating an aluminum curtain wall and precast concrete panels. The new tower consists of 12 stories above grade with one level below grade. The patient tower is 216,000 square feet with 174 patient rooms, an operation area and a mechanical level. The contract for this tower was awarded to Turner Construction, the general contractor, in a Design-Bid-Build method with a contact value of \$161 million.

One of the main design considerations is individual patient rooms. Based on the hospital's goals for care the individual patient rooms were a large factor in the design of the floor plan. During the design phases the project team requested input from the physicians, nurses and staff to help make the design as efficient as possible. Medical/surgical patients aging 65 years and older were the focus of this tower, with a special emphasis on their safety and a good healing environment. With the hospital team input the placements for monitoring stations were optimized to ensure patient privacy as well as enhancing the monitoring capabilities.

One of the hospital's goals, along with excellent patient care, is also to lower the hospital's impact on the environment. The hospital's plan for this new tower included green features such as living roofs, low flow water fixtures, and rain gardens. The design also calls for no/low VOC building materials to be used in construction of the tower. The tower design has been submitted for a LEED Silver certification.



Figure 2: Sketch by Wilmot Sanz

Structural Systems

Foundations

The geotechnical report was prepared by Schnabel Engineering, LLC, on March 25, 2010. The foundation of the patient tower is set on piles, with pile caps and grade beams. Each column location has a range of 4 to 12 piles. The slab on grade for the tower is 5" with integrated slab pile caps in locations of high stress, such as the elevator shaft and stair well. During the excavation for the new tower the existing basement and caissons supporting the connecting structure were exposed. The existing 66" caissons will support a small portion of the tower connection while the rest will be supported by new piles. In a few locations where no basement exists, piles were drilled to reach up to the ground floor level to support irregular building features.





Figure 3: Foundation plan from Cagley & Associates

Columns

The column layout of the patient tower is very regular with a few variations on the 1st through 3rd floors. The bay spacing in the patient tower is mostly square 29' x 29' with a few exceptions as see in Figure 6. The columns are reinforced concrete ranging in size from 30" x 30" to 12" x 18". The typical column size is 24" x 24" with vertical reinforcing of #11 bars numbering from 4 bars to 12 bars as they move through the structure. The vertical reinforcing is tied together with #4 bars placed every 18". The columns on the basement level up through the 4th floor are poured with 7,000 psi concrete and from the 5th floor up they are 5,000 psi concrete. The structural system of the Patient Tower utilizes column capitals to resist punching shear within the slab. The typical capital in the tower is 10' x 10' x 6" depth, making the slab thickness at the capitals 15 1/2".



3 COLUMN TIE ARRANGEMENTS AND SPACING

N.T.S.


MECH ROOM FLOOR					
MAIN ROOF					
ELEVENTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
TENTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
NINTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
EIGHTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
SEVENTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
SIXTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
FIFTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
FOURTH FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
THIRD FLOOR		24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
SECOND FLOOR	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"	24" x 24" 4#11 #4@18"
FIRST FLOOR	24" x 24" 4#11 #4@18"	24" x 24" 8#11 #4@18"	24" x 24" 8#11 #4@18"	24" x 24" 8#11 #4@18"	24" x 24" 12#11 #4@18"
GROUND FLOOR	24" x 24" 4#11 #4@18"	24" x 24" 8#11 #4@18"	24" x 24" 8#11 #4@18"	24" x 24" 12#11 #4@18"	24" x 24" 12#11 #4@18"
BASEMENT FLOOR TOP OF FOUNDATION		24" x 24" 12#11 #4@18"		30" x 30" 20#11 #4@18"	26" x 26" 16#11 #4@18"

Figure 5: Partial Column Schedule from Cagley & Associates

Figure 4: Column Reinforcing Detail from Cagley & Associates

Floor System

The floor system for this patient tower is a 9.5" 2-way flat plate. For the ground floor through the 4th floor the slab is 5000 psi concrete with the remaining floors at 4000 psi concrete. The largest span for this flat plate is 29' in each direction with square bays. The flat plate system has both top and bottom steel reinforcing. The top steel placed at regions of negative moment is typical notated with a number of #5 bars. The bottom reinforcing is a 2-way mat of #5 bars at 12" on center. In the end bays of the slab there are extra bottom bars added to handle the carry over moments for the interior span. On the 5th floor of the tower is the mechanical level, which increases the loading on the slab giving it a 10.5" concrete slab. See figure 7 below for details.




3 TWO-WAY FLAT SLAB NOTATION

1/8" = 1'-0"

Figure 7: Two-way Flat Slab Detail from Cagley & Associates

Roof System

The roof system for the patient tower is designed with the same conditions at a typical floor, a 9.5" Two-way flat plate with mat and bar reinforcing detailed in the above section. The roof does have a few variations from a typical floor; the roof area that will support the mechanical penthouse has been increased to a 14" slab to support the extra weight of the equipment and there were supports added to the main slab to support the new helipad (Figure 8) for the tower.



4

HELIPAD SUPPORT POST

Figure 8: Helipad Support detail from Cagley & Associates

3/4" = 1'-0"

Lateral System

The lateral system in the new patient tower consists of seven 12” reinforced concrete shear walls. These walls are located in different locations throughout the building depicted to the right. The shear walls consists of 5000 psi concrete and were run continuously through the tower from the foundations up to the roof with the northern core extending through the penthouse. This system of two shear wall cores resists lateral loads in both the north-south and east-west direction based on the orientation of the wall. The towers main structural system is a concrete two-way flat plate. This system will also act a concrete moment frame which will also resist lateral forces. Between this two system all of the lateral forces applied to this tower can be resisted.

Design & Code Review

Design Codes and References

- International Building Code – 2006 “International Code Council”.
- ASCE 7 – 05 “Minimum Design loads for Buildings and Other Structures” American Society of Civil Engineers.
- ACI 318-05 “Building Code Requirements for Structural Concrete” American Concrete Institute.
- ACI Manual of Concrete Practice.
- AISC “Manual of Steel Construction – Allowable Stress Design”.

Thesis Codes and References

- International Building Code – 2006 “International Code Council”.
- ASCE 7 – 10 “Minimum Design loads for Buildings and Other Structures” American Society of Civil Engineers.
- ACI 318-08 “Building Code Requirements for Structural Concrete” American Concrete Institute.

Deflection Criteria

Floor Deflection Criteria

Typical Live load Deflection limited to $L/360$

Typical Total load Deflection limited to $L/240$

Material Specifications

Materials	Grade	Strength
Concrete		
• Piles	-	$f'_c = 4,000$ psi
• Foundations	-	$f'_c = 3,000$ psi
• Slab-on-grade	-	$f'_c = 3,500$ psi
• Shear Walls	-	$f'_c = 5,000$ psi
• Columns	-	$f'_c = 5,000/7,000$ psi
• Floor Slabs	-	$f'_c = 4,000/5,000$ psi
W Flange Shapes	ASTM A992	$F_y = 65,000$ psi
HSS Round	ASTM A53 grade B	$F_y = 35,000$ psi
HSS Rectangular	ASTM A500 grade B	$F_y = 46,000$ psi
Reinforcing bars	ASTM 615 grade 60	$F_y = 60,000$ psi
Steel Decking	ASRM A653 SS Grade 33	$F_y = 33,000$ psi

Table 1: Material Specifications

Problem Statement


The Patient Tower is currently a two – way flat plate reinforced concrete slab supported by reinforced concrete columns. This system is the main gravity load bearing system that transfers each floor load to the foundation of slab on grade and drilled piles. The tower’s current lateral system is reinforced concrete shear walls cores. There are two cores located around the central stair case and the elevator shaft. The strength of concrete used in the shear walls is 5000 psi, with the gravity system using both 5000 and 7000 psi concrete.

The Patient Tower is an addition to an existing hospital campus to provide updated equipment and facilities for care while being integrally connected to the existing patient tower. The goal of this thesis is to decrease the overall cost of the new tower and to decrease the construction time while maintaining the functionality of the tower.

Problem Solution

In order to decrease the overall cost of the tower, decreasing the construction time and the overall building weight are the two main ways that this challenge is confronted. Changing the gravity system of the tower from two-way concrete to a steel frame with hollow concrete plank should help reduce the weight of the structural system and the construction duration.

The new proposed floor system would be hollow core concrete plank ranging from 8" to 12" supported with W-shape steel beams. These planks would be placed in the beam as shown in the figure and not placed on top of them as is traditionally done. Since the plank and beams will be placed in conjunction with each other the floor system will be low in depth allowing for the Patient Tower to maintain its floor to floor heights so that it will be able to make the connection to the existing tower. The current floor system depth is 9.5", giving the tower enough space in the ceiling cavity for all of the mechanical system, so there should not be many issues with ceiling cavity space in the proposed new design.



SECTION
1" = 1'-0"

PLANK THICKNESS (D)	MIN. BEARING (B)
8"	2½"
10"	2½"
12"	2½"
16"	4"

With this changing in floor system the columns for the tower would also need to be redesigned to account for the change in material and loading of the floor system. ASCE7-10 will be used to determine the correct floor loads for the tower as evaluated in Tech Report #2.

The lateral resisting system will remain the same as that in the original design, with the two shear cores surrounding the stairway and the elevator shaft. With the changes to the building weight it may be found that the lateral system is over designed with the new gravity system, but will be maintained during this assignment. If it is found that the shear walls are insufficient in the new design they will be redesigned to carry the higher loads.

Breadth Issues

The change in the gravity resisting system from a two – way flat plate reinforced concrete slab to a steel frame with precast concrete plank decking will produce a change in the construction management of the project. While steel structural elements are prefabricated and have a longer lead time we are trying to decrease the weight of the tower, which would decrease the need for such a bearing ability of the foundations elements. With the faster erection time for steel shortening the length of construction, a structural system cost reduction would be realized.


With the change for a concrete gravity system to a steel system the acoustical criteria will need to be checked for areas of importance. In a hospital acoustics will be very important criteria that will need to be kept with in close tolerances to not affect the patients. With a concrete system this criteria is satisfied by the mass and rigidity of the system but with a steel system these criteria will need to be checked. For this study I would like to check the acoustical performance of the ICU. The ICU sits above the café that is open to the public so there is a concern that the noise will be carried and disrupts the

ICU above. The Patient Tower uses the fifth floor to house the mechanical systems directly below the mechanical floor is the Neuro ICU floor. The acoustics will need to be check for the mechanical floor to make sure that the noise is not transferred to the ICU located below.

Task and Tools


- 1) Evaluate all gravity loads
 - a) Dead loads
 - b) Live loads
 - c) Snow loads
- 2) Redesign the gravity system
 - a) Choose appropriate slab
 - b) Design girder system
 - c) Design steel column
- 3) Reevaluate lateral system
 - a) Wind loads
 - b) Seismic
- 4) Construction management Investigation
 - a) Cost of the new system
 - b) Construction time
- 5) Acoustics Evaluation
 - a) ICU vs. Public café
 - b) Mechanical floor at level 5 vs. Neuro ICU at level 4
- 6) Final Presentation Preparation
 - a) Organize, format and finalize presentation
 - b) Prepare for final presentation

Proposed Schedule




Appendix I


This section is where the supplementary information for the layout and design for the Hospital Patient Tower can be found.




North Ground Floor Plan




South Ground Floor Plan




North 1st Floor Plan



South 1st Floor Plan



North Typical Floor Plan



South Typical Floor Plan