

Technical Report I

ASHRAE Standard 62.1 and 90.1 Evaluations

Charles E. Smith Center Renovation

Washington, DC



Paul Hallowell
Mechanical Option

Adviser: Treado
4 October 2010

Table of Contents

Executive Summary	3
ASHRAE Standard 62.1 Evaluation	4
Section 5	4
Section 6	6
Conclusions	6
ASHRAE Standard 90.1 Evaluation	7
Section 5	7
Section 6	7
Section 7	7
Section 8	8
Conclusions	8
References	9
Appendix	10

Executive Summary

The Charles E. Smith Center is the newly renovated arena for George Washington University. It includes a basketball arena, natatorium, locker rooms, fitness center, weight room, offices, and suites in over 100,000SF. Construction has taken approximately 2 years.

The purpose of this technical report is to determine if the Smith Center Complies with both ASHRAE Standard 62.1 and ASHRAE Standard 90.1. Standard 62.1 showed that the air supply and exhaust system both were compliant as well as the ventilation rates. Standard 90.1 showed that the Smith Center also had compliance with its other utilities as well.

ASHRAE Standard 62.1 Evaluation

Section 5 Evaluation

Section 5.1 ☐ Natural Ventilation

This section does not apply as this project does not utilize natural ventilation because of the high humidity of a sports complex.

Section 5.2 ☐ Ventilation Air Distribution

This system should meet all ventilation requirements assuming that all of the equipment is calibrated correctly and the occupied spaces do not exceed the maximum number of people for the designated area.

Section 5.3 ☐ Exhaust Duct Location

All exhaust systems that contain potentially harmful contaminants from the kitchen or bathroom/shower areas are negatively pressurized at 3in W.G so as to prevent the cross contamination to supply systems.

Section 5.4 ☐ Ventilation System Controls

This control system consists of a Building Automated System with direct digital control to all field panels. All field panels are to communicate back to the Operator's Work Station and are to utilize interchangeable parts for ease of replacement.

Section 5.5 ☐ Airstream Surfaces

The system employed here uses mostly sheet metal and metal fasteners which are resistant to mold and erosion.

Section 5.6 ☐ Outdoor Air Intakes

All of the intake locations are above ground level and meet the required distance from any potential contaminants. Intakes are also properly designed to keep out rain and birds from the airflow.

Section 5.7 ☐ Local Capture of Contaminants

This section does not apply as this project does not utilize non-combustion equipment.

Section 5.8 ☐ Combustion Air

Paul Hallowell

All equipment that require combustion have an exhaust to the outside to remove potential contaminants from the building.

Section 5.9 ▯ Particulate Matter Removal

Air filters for the Smith Center have a minimum MERV rating of 8 which exceeds the required MERV rating of 6.

Section 5.10 ▯ Dehumidification Systems

Most environmental conditions are set to have a relative humidity level of 35% - 50% or 40% - 60% in the racquetball court which are both under the required 65%. The spaces that do not adhere to this are the pool and sauna areas that are exempt from this requirement.

Section 5.11 ▯ Drain Pans

All drain pans are of 18 or 20 gauge galvanized steel or zinc chromate treated and are self-draining to eliminate buildup or overflow.

Section 5.12 ▯ Finned-Tube Coils and Heat Exchangers

All cooling coils and heat exchangers have the necessary drain pans underneath them.

Section 5.13 ▯ Humidifiers and Water-Spray Systems

Humidifiers have type K or L copper pipe running to 304 stainless steel dispersion tubes that have total steam absorption in a maximum of 3 feet. Associated dielectric fittings are used and potable water.

Section 5.14 ▯ Access for Inspection, Cleaning, and Maintenance

All access panels are a minimum of 12" x 16" and have a steel construction frame of 16 USG and 14 USG panel door. Doors are sized to be able to fully open. Any type of concealed cleanout, valve, union, etc. also has an access panel.

Section 5.15 ▯ Building Envelope and Interior Surfaces

The Smith Center has the appropriate vapor and liquid barriers on the exterior of the building along with insulation covering any pipe or duct that could potentially cause condensation buildup.

Section 5.16 ▯ Buildings with Attached Parking Garages

This section does not apply as this project does not contain an attached parking garage.

Section 5.17 ▯ Air Classification and Recirculation

Most of the air is classified as Class 1 in the offices and circulations and Class 2 in the locker rooms and fitness areas. All of the Class 4 air from the kitchen is exhausted.

Section 5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas

This section does not apply as the Smith Center is a non-smoking facility with a minimum smoking distance of 25ft away from the exterior of the building.

Section 6 Evaluation

Ventilation Rate Procedure:

Breathing Zone Outdoor Airflow (V_{bz})

$$V_{bz} = R_p * P_z + R_a * A_z \quad (6-1)$$

Where: R_p = outdoor airflow rate required per person

P_z = the largest number of people expected to occupy the zone

R_a = outdoor airflow rate required per unit area

A_z = the net occupiable floor area of the zone

Zone Outdoor Airflow (V_{oz})

$$V_{oz} = V_{bz} / E_z \quad (6-2)$$

Where: $E_z = 1.0$

100% Outdoor Air Systems (V_{ot})

$$V_{ot} = \sum_{\text{all zones}} V_{oz} \quad (6-4)$$

Primary Outdoor Air Fraction (Z_p)

$$Z_p = V_{oz} / V_{pz} \quad (6-5)$$

Where: V_{pz} = the zone primary airflow

Using these equations and the chart in the Appendix you are able to determine the ventilation rate of each AHU and the zones associated with it.

ASHRAE Standard 62.1 Conclusion


From the findings found in both Section 5 and Section 6 we can conclude that the Charles E. Smith Center is compliant with ASHRAE 62.1.

ASHRAE Standard 90.1 Evaluation

Section 5 - Building Envelope

5.1.4 - Climate

From the figure below the project site is located in climate zone 4.



5.4 - Mandatory Provisions

All joints around fenestration and door frames are to be sealed to decrease any infiltration. All service doors are to have replaceable, adjustable, continuous, and compressible weather-stripping on both the top and bottom. The main entrances are all through vestibules greater than 7ft from exterior door to interior door.

5.5 - Prescriptive Building Envelope Option

The Smith Center has its minimum R-Values above the required R-Values and maximum U-Values below the required U-Values for walls, roofs, floors, and fenestration.

Section 6 - HVAC

Section 7 - Service Water Heating

The hot water heater has a greater efficiency than the required 85% and there is also a heat recovery system to help save energy as well.

Section 8 - Power

All feeders and branch circuits are sized to cohere with a maximum voltage drop of 2% and 3% respectively at design loads.

ASHRAE Standard 90.1 Conclusion

From the findings found in Sections 5 and Section 8 we can conclude that the Charles E. Smith Center is compliant with ASHRAE 90.1.

References

- ANSI/ASHRAE Standard 62.1-2007 Ventilation for Acceptable Indoor Air Quality
- ANSI/ASHRAE/IESNA Standard 90.1-2007 Energy Standard for Buildings Except Low-Rise Residential Buildings

Appendix

Building:		Charles E. Smith Center Renovation	
System Tag/Name:			
Operating Condition Description:			
Units (select from pull-down list)			
Inputs for System Floor area served by system Population of area served by system (including diversity) Design primary supply fan airflow rate OA req'd per unit area for system (Weighted average) OA req'd per person for system area (Weighted average)			
Inputs for Potentially Critical Zones Zone Name Zone Tag Space Type Floor Area of zone Design population of zone Design total supply to zone (primary plus local recirculated) Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Name		Units	System
As	sf		
Ps	P	100% diversity	
Vpsd	cfm		
Ras	cfm/sf		
Rps	cfm/p	0.00	
climp	cfm/p	0.0	
Potentially Critical Zones enter name new zone new zone enter tag enter tag New zone ID Restaurant Office space Office space ID dining rooms 0 0 0 0 0 0 0 0 0			
Zone life turns purple italic for critical zone(s) Select from pull-down list (default value listed, may be overridden) Select from pull-down list or leave blank if N/A			
Ds		%	100%
Ez		Selected from pull-down list	100%
Ev		cfm	100%
Vot		volts	100%
VotPs		cfm/p	100%
Ypd		cfm	100%
Results Ventilation System Efficiency Outdoor air intake required for system Outdoor air per unit floor area Outdoor air per person served by system (including diversity) Outdoor air as a % of design primary supply air			
Vps		cfm	0
Vou		cfm	0
Xs			0.00
Raz		cfm/sf	0.18
Rvz		cfm/p	7.50
Vvz		cfm	0
Voz		cfm	0
Fa		cfm	0
Fb		cfm	1.00
Fc		cfm	1.00
Fd		cfm	1.00
Zd		cfm	0.00
Zp		cfm	0.00
Ez		cfm	1.00
Ev		cfm	1.00
Vot		cfm	1.00
Y		cfm	1.00
Detailed Calculations for the System as a whole Primary supply air flow to system at conditioned analyzed Unconditioned OA requirement for system Unconditioned OA intake as a fraction of primary SA Unconditioned OA intake as a fraction of primary SA			
Initial Calculations for Individual Zones OA rate per person Total supply air to zone (at condition being analyzed) Unused OA requirement for breathing zone Fraction of zone supply not directly recirc. from zone Fraction of zone supply from fully mixed primary air Fraction of zone OA not directly recirc. from zone Unused OA fraction required in supply air to zone Unused OA fraction required in primary air to zone			
System Ventilation Efficiency Zone Ventilation Efficiency (App. A Method) System Ventilation Efficiency (App. A Method) Ventilation System Efficiency (Table 6.3 Method)			
Minimum outdoor air intake airflow Outdoor air intake flow required for system OA intake req'd as a fraction of primary SA Outdoor air intake flow required to system (Table 6.3 Method) OA intake req'd as a fraction of primary SA (Table 6.3 Method)			
OA Temp at which Min OA provides all cooling OA intake flow at which OA intake provides all cooling			