

# SHA HEADQUARTERS

707 N. Calvert St. | Baltimore, MD



## Technical Report Two

### Building and Plant Energy Analysis



**Stephanie Kunkel** | [www.engr.psu.edu/ae/thesis/portfolios/2011/sik5061](http://www.engr.psu.edu/ae/thesis/portfolios/2011/sik5061) | Mechanical Option

Dr. Bahnfleth | October 27, 2010

# Table of Contents

|   |    |
|---|----|
| EXECUTIVE SUMMARY .....                           | 3  |
| MECHANICAL SYSTEM SUMMARY .....                   | 3  |
| SYSTEM DESIGN LOAD ESTIMATION.....                | 4  |
| Block Load Elements .....                         | 4  |
| Load Sources and Modeling Information.....        | 4  |
| Design Occupancy and Ventilation .....            | 4  |
| Infiltration .....                                | 4  |
| Electrical Loads.....                             | 5  |
| Weather Information .....                         | 5  |
| System Load Analysis Results.....                 | 6  |
| SYSTEM ENERGY CONSUMPTION & OPERATING COSTS ..... | 7  |
| System Energy Classification.....                 | 7  |
| Building Energy Cost Analysis .....               | 9  |
| Environmental Impact Analysis.....                | 10 |
| Building Energy and Cost Analysis Results .....   | 11 |
| REFERENCES.....                                   | 12 |
| APPENDIX A – TRACE DATA TEMPLATES.....            | 13 |
| APPENDIX B – TRACE SYSTEM SCHEMATIC.....          | 16 |
| APPENDIX C – WEATHER INFORMATION .....            | 17 |

## EXECUTIVE SUMMARY

The objective of Technical Report II is to determine the results of an entire building block load energy analysis of the Maryland State Highway Administration (SHA) Headquarters – 707 Building. Trane TRACE 700 Version 6.2 was utilized to calculate the office building load data, as well as the yearly energy consumption, of the 707 building. TRACE inputs were selected from the building design specifications and drawings as well as additional information provided by the design engineer.

The generated block load energy model for the 707 building calculated the total annual energy consumption for cooling and heating loads to be 44.305 MBtu/year. The total load calculated by the design engineer was 42.232 MBtu/year, which indicates that the load energy consumptions are within 4.9% of each other. The annual utility cost that was totaled for the consumed electricity and natural gas was \$200,808 or 1.17 \$/sf. In order to provide a redesigned mechanical system with reduced energy consumptions, the current features of the building's utility usage must be analyzed.

## MECHANICAL SYSTEM SUMMARY

The 707 building's mechanical system is comprised of two low pressure central station air handling units (AHUs) serving the central core of the building and one high pressure central station AHU serving the central core of the building. Cooling is provided by a chilled water plant, utilizing a centrifugal chiller and an updraft cooling tower, while heating is provided by two low pressure steam boilers and a steam-to-hot water heat exchanger. Overall, the components of the system include 3 constant volume built-up AHUs, 534 perimeter induction units with no operating fans on the 6 office levels, 18 VAV boxes that serve individual areas, a chilled water/hot water indoor unit, and a chilled water/steam indoor unit.

## SYSTEM DESIGN LOAD ESTIMATION

To simulate the design load energy consumption of the Maryland State Highway Administration (SHA) 707 Building located in Baltimore, MD, Trane TRACE 700 Version 6.2 was implemented. Operator experience and previously performed analyses were determinants for using TRACE for this energy study. A yearlong energy evaluation was executed to find the peak design heating and cooling loads of the system. A schematic of the system is located in Appendix B.

### Block Load Elements

There are multiple advantages for a block load analysis to be performed, including model calculation time reduction, manageable model file sizes, and accurate results. The inputs, such as room areas, equipment characteristics, and building construction materials, were taken from the building design specifications and drawings; additional information was provided by the design engineer.

### Load Sources and Modeling Information

Occupants, ventilation, infiltration, artificial lights, electrical and mechanical equipment, ambient conduction/convection and direct solar gain are the core load sources for the 707 building model. TRACE data templates are located in Appendix A.

### Design Occupancy and Ventilation

As design occupancy was provided for each space in the 707 building, the ASHRAE recommended occupancies were not utilized. The low-rise office schedule in TRACE was used to determine the fraction of cooling needed during the weekdays; Table 1 depicts these times and percentages. TRACE produced all ventilation rates used in the energy analysis in accordance with ASHRAE Standard 62.1 - 2007.

**Table 1: Weekday Cooling Design for People Loads**

| Start Time | End Time | Percentage |
|------------|----------|------------|
| Midnight   | 7 a.m.   | 0          |
| 7 a.m.     | 8 a.m.   | 30         |
| 8 a.m.     | 11 a.m.  | 100        |
| 11 a.m.    | Noon     | 80         |
| Noon       | 1 p.m.   | 40         |
| 1 p.m.     | 2 p.m.   | 80         |
| 2 p.m.     | 5 p.m.   | 100        |
| 5 p.m.     | 6 p.m.   | 30         |
| 6 p.m.     | 9 p.m.   | 10         |
| 9 p.m.     | Midnight | 5          |

### Infiltration

0.2 cfm/ft<sup>2</sup> of the wall for cooling and 0.4 cfm/ft<sup>2</sup> of the wall for heating are the typical infiltration rates used for office space in the 707 simulation.

### Electrical Loads

Since it is required to “use lights and equipment electrical loads on a W/sf basis,” the typical office space heat gain from recessed fluorescent, non-vented 80% load to space lighting was calculated to be 1.45 W/ft<sup>2</sup> by the design engineer. The lighting schedule of a low-rise office building was selected in TRACE; the weekday schedule timings and percentages can be seen in Table 2 below. The miscellaneous loads were 1 W/ft<sup>2</sup> to account for medium sized computer loads in the open office space.

**Table 2: Weekday Cooling Design for Lighting Loads**

| Start Time | End Time | Percentage |
|------------|----------|------------|
| Midnight   | 7 a.m.   | 5          |
| 7 a.m.     | 8 a.m.   | 80         |
| 8 a.m.     | 10 a.m.  | 90         |
| 10 a.m.    | Noon     | 95         |
| Noon       | 2 p.m.   | 80         |
| 2 p.m.     | 4 p.m.   | 90         |
| 4 p.m.     | 5 p.m.   | 95         |
| 5 p.m.     | 6 p.m.   | 80         |
| 6 p.m.     | 7 p.m.   | 70         |
| 7 p.m.     | 8 p.m.   | 60         |
| 8 p.m.     | 9 p.m.   | 40         |
| 9 p.m.     | 10 p.m.  | 30         |
| 10 p.m.    | Midnight | 20         |

### Weather Information

The weather data was taken from the 2009 ASHRAE Handbook of Fundamentals (HOF), and they represent the 0.4% and 99.6% values, respectively. Below, Table 3 shows these values used in the building analysis. Actual weather conditions that were used in TRACE are displayed in the TRACE schedules in Appendix C. The entire Baltimore, MD weather data from ASHRAE 2009 HOF can also be found in Appendix C.

**Table 3: ASHRAE Weather Data – Baltimore, MD**

| ASHRAE Values    | Summer Design Cooling (0.4%) | Winter Design Heating (99.6%) |
|------------------|------------------------------|-------------------------------|
| OA Dry Bulb (°F) | 93.9                         | 12.9                          |
| OA Wet Bulb (°F) | 78.1                         | -                             |

### System Load Analysis Results

Below, Table 4 indicates cooling, heating, supply, and ventilation rates for the TRACE block load compared to the original loads calculated by the design engineer. The block load values are greater than those of the original calculations; this is most likely due to the simplified load estimations and assumptions of the block load. Specific information for every single room/space must be known and analyzed exactly to obtain the most accurate cooling and heating loads for 707. Nonetheless, even with the simplifications that were made for the block load, the findings show a plausible portrayal of the loads that the design engineer calculated.

**Table 4: Block Loads vs. Original Loads and Ventilation**

|                       | Cooling<br>(ft <sup>2</sup> /ton) | Heating<br>(Btu/h*ft <sup>2</sup> ) | Supply Air<br>(cfm/ft <sup>2</sup> ) | Ventilation Air<br>(cfm/ft <sup>2</sup> ) |
|-----------------------|-----------------------------------|-------------------------------------|--------------------------------------|---|
| <b>707 Block Load</b> | 405.4                             | 27.9                                | 0.85                                 | 0.15                                      |
| <b>707 Original</b>   | 535.2                             | 21.6                                | 0.37                                 | 0.14                                      |

## SYSTEM ENERGY CONSUMPTION & OPERATING COSTS


A year-long energy simulation was composed by the TRACE model that was used to find the building design cooling and heating loads. Cooling is provided by a chilled water plant operated by electricity, while heating is provided by two low pressure steam boilers and a steam-to-hot water heat exchanger.

### System Energy Classification

According to the energy analysis results, the 707 building consumes 1,743,765 kWh of energy annually. The breakdown of this energy consumption is shown in both Table 5 and Figure 1 below. Typical for an office building in this region, space heating and lighting are large energy consumers. Since there are no fans within any of the 534 induction units for the cooling system, the amount of energy expended is reduced when compared to a standard office building.

**Table 5: Energy Consumption Breakdown**

|                | Energy<br>(kBtu/yr) | Total Energy<br>(%) |
|----------------|---------------------|---------------------|
| Lighting       | 2951.2              | 35                  |
| Space Heating  | 2533.5              | 30                  |
| Receptacles    | 1986.7              | 24                  |
| Space Cooling  | 566.2               | 7                   |
| Heat Rejection | 310.4               | 4                   |



*Figure 1: Energy Consumption Pie Chart*

A monthly breakdown of the electrical and natural gas energy consumption can be seen in Figures 2 and 3, respectively. Typically, winter months and peak summer months consume the most energy, since the building is most heavily heated and cooled during those times. Since the heating system runs on natural gas and not electricity, Figure 2 shows the greatest electrical energy use during the summer months when the maximum AHU use occurs. Similarly, Figure 3 displays peaks in energy of the natural gas usage in the winter months.

### Monthly Energy Consumption




Figure 2: Monthly Electrical Energy Consumption Chart

### Monthly Energy Consumption




Figure 3: Monthly Natural Gas Energy Consumption Chart



## Building Energy Cost Analysis

Knowing the monthly energy usages, an annual building operating cost analysis can be performed. Tables 5 and 6 display the utility rates for both electricity and natural gas, respectively, from the Baltimore Gas and Electric Company (BGE) website. These values were manually inserted into TRACE in the form of utility schedules, seen in Table 7, so that the energy consumption could be calculated in a yearlong energy simulation. Table 7 below shows the schedule of BGE Off-Peak, Mid-Peak, and Peak rates.

**Table 5: BGE Electric Rates**

|                    | Demand Charge<br>(\$/kW) | Peak<br>(\$/kWh) | Mid-Peak<br>(cents/kWh) | Off-Peak<br>(cents/kWh) |
|--------------------|--------------------------|------------------|-------------------------|-------------------------|
| <b>Electricity</b> | 3.95                     | 0.1155           | 0.0927                  | 0.0882                  |

**Table 6: BGE Natural Gas Rates**

|                    | Up to first 10,000 therms<br>(\$/therm) | Above 10,000 therms<br>(\$/therm) |
|--------------------|---|-----------------------------------|
| <b>Natural Gas</b> | 0.198                                   | 0.095                             |

**Table 7: Schedule of BGE Rates**

| Start Time | End Time | Rate     |
|------------|----------|----------|
| 11 p.m.    | 7 a.m.   | Off-Peak |
| 7 a.m.     | 10 a.m.  | Mid-Peak |
| 10 a.m.    | 8 p.m.   | Peak     |
| 8 p.m.     | 11 p.m.  | Mid-Peak |

The total annual utility cost that was totaled for the consumed electricity and natural gas is \$200,808 or 1.17 \$/sf. TRACE's monthly breakdown of this analysis is shown in Figure 4. As displayed below, the highest monthly cost occurred in August. The reasoning for the drastic cost differentiations between the winter and summer months is most likely due to the low natural gas rate.




Figure 4: Monthly Building Electricity Costs by Equipment Chart

## Environmental Impact Analysis

As well as the energy consumption assessment, the environmental impact of the emissions from the building is another vital element to consider. Average annual carbon dioxide, sulfur dioxide, nitrogen oxide emissions, and particulates were calculated manually. Using the given regional emissions coupled with the delivered electric energy for the 707 building location and emissions profiles associated with the boiler, the annual existing emissions footprint was determined. The assessed emissions summaries for the 707 building are shown in Tables 8 and 9, below.

Table 8: Combustion Emissions Produced by Electricity

| Emission        | Eastern Emission Factors (lbm/kWh) | Total Electricity Usage (kWh) | Total Emissions for Delivered (lbm/yr) |
|-----------------|------------------------------------|-------------------------------|--|
| CO <sub>2</sub> | 1.64                               | 1,743,765                     | 2,859,775                              |
| SO <sub>x</sub> | 8.57E-3                            |                               | 14,944                                 |
| NO <sub>x</sub> | 3.00E-3                            |                               | 5,231                                  |
| PM10            | 9.16E-5                            |                               | 160                                    |

According to the RegionalGridemissionfactors2007.pdf,

The PM factors are for direct emissions and do not include the effect of particulate formation in the atmosphere from chemical reactions of sunlight with emissions of NO<sub>x</sub>, SO<sub>x</sub>, [and CO<sub>2</sub>]. The PM composition and emission levels are complex functions of boiler firing configuration, boiler operation, pollution control equipment, and fuel properties.

**Table 9: Combustion Emissions Produced by Natural Gas**

| Emission        | Natural Gas (lbm/1000ft <sup>3</sup> ) | Natural Gas Usage (MBtu/year) | Conversion Factor (Btu/ft <sup>3</sup> ) | Total Emissions for Delivered (lbm/yr) |
|-----------------|--|-------------------------------|--|--|
| CO <sub>2</sub> | 11.6                                   | 44.305                        | 1010                                     | 508,850                                |
| SO <sub>x</sub> | 1.22                                   |                               |  | 53,517                                 |
| NO <sub>x</sub> | 1.64E-2                                |                               |  | 719                                    |
| PM10            | 8.17E-4                                |                               |  | 36                                     |

As learned in the Penn State Building Thermal Load Simulation and Energy Utilization Estimation course, only about 30% of original electricity produced is delivered to a building, where an efficient boiler delivers the energy more directly. The emissions from electricity are significantly greater than those from the natural gas because the majority of the building energy comes from electricity.

### Building Energy and Cost Analysis Results

The generated block load energy model for the 707 building calculated the total annual energy consumption for cooling and heating loads to be 44.305 MBtu/year. The total load calculated by the design engineer was 42.232 MBtu/year, which indicates that the load energy consumptions are within 4.9% of each other. No energy cost analysis was run by the design engineer, therefore results could not be compared.

An estimated operating cost was determined by using individual utility consumptions. The total annual utility cost that was totaled for the consumed electricity and natural gas is \$200,808 or 1.17 \$/sf. The final operating cost per square foot will provide a unit of measurement that can be used to compare the building's energy performance to the redesign. The same combustion emissions analysis for the operation of the redesign will be performed in order to quantify the emissions footprint enhancements of the redesigned building.

## REFERENCES

ANSI/ASHRAE (2007), Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., Atlanta, GA, 2007.

ANSI/ASHRAE (2007), Standard 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc., Atlanta, GA, 2007.

ASHRAE (2009), 2009 ASHRAE Handbook of Fundamentals

Baltimore Gas and Electric (BGE). [www.bge.com](http://www.bge.com).

Johnson, Mirmiran & Thompson (JMT). Engineering Reports and TRACE Documents.

RegGridemissionfactors2007.pdf.

## APPENDIX A – TRACE DATA TEMPLATES

| Construction... |                      | U-factor<br>Btu/h·ft <sup>2</sup> ·°F |
|-----------------|----------------------|---------------------------------------|
| Slab            | 4" L/W Concrete      | 0.212615                              |
| Roof            | 8" H/W Conc, 2" Ins  | 0.115167                              |
| Wall            | 4" L/W Block, 1" Ins | 0.160678                              |
| Partition       | 0.75" Gyp Frame      | 0                                     |

| Glass type... |                                     | U-factor<br>Btu/h·ft <sup>2</sup> ·°F | Shading<br>coeff |
|---------------|-------------------------------------|---------------------------------------|------------------|
| Window        | 3mm Dbl Low-E (e2=.04) Clr 13mm Air | 0.295                                 | 0.5              |
| Skylight      | Single Clear 1/4"                   | 0.95                                  | 0.95             |
| Door          | Standard Door                       | 0.2                                   | 0                |

| Height...  |       | Pct wall area to<br>underfloor plenum | Room type   |
|------------|-------|---------------------------------------|-------------|
| Wall       | 10 ft |                                       | Conditioned |
| Flr to flr | 10 ft |                                       |             |
| Plenum     | 2 ft  |                                       |             |

*Construction Information for 707*

| Description  |  |
|--------------|--|
| Office Space |  |

| Main supply... |                  | Auxiliary supply... |                  |
|----------------|------------------|---------------------|------------------|
| Cooling        | To be calculated | Cooling             | To be calculated |
| Heating        | To be calculated | Heating             | To be calculated |

| Ventilation...                 |                      | Std 62.1-2004/2007... |        |
|--------------------------------|----------------------|-----------------------|--------|
| Apply ASHRAE Std62.1-2004/2007 | No                   | Clg Ez                | Custom |
| Type                           | General Office Space | Htg Ez                | Custom |
| Cooling                        | 20 cfm/person        | Er                    | Custom |
| Heating                        | 20 cfm/person        | DCV Min OA Intake     | None   |
| Schedule                       | Available (100%)     |                       |        |

| Infiltration... |                       | Room exhaust... |                  |
|-----------------|-----------------------|-----------------|------------------|
| Type            | None                  | Rate            | 0 air changes/hr |
| Cooling         | 0.2 cfm/sq ft of wall | Schedule        | Available (100%) |
| Heating         | 0.4 cfm/sq ft of wall |                 |                  |
| Schedule        | Available (100%)      |                 |                  |

| VAV minimum... |                  |
|----------------|------------------|
| Rate           | % Clg Airflow    |
| Schedule       | Available (100%) |
| Type           | Default          |

*Typical Office Airflows*

Thermostat settings...

|                    |      |    |
|--------------------|------|----|
| Cooling dry bulb   | 75   | °F |
| Heating dry bulb   | 70   | °F |
| Relative humidity  | 50   | %  |
| Cooling driftpoint | 90   | °F |
| Heating driftpoint | 55   | °F |
| Cooling schedule   | None |    |
| Heating schedule   | None |    |

Sensor Locations...

|            |      |
|------------|------|
| Thermostat | Room |
| CO2 sensor | None |

Humidity...

|                      |        |
|----------------------|--------|
| Moisture capacitance | Medium |
| Humidistat location  | Room   |

*Thermostat Settings for 707 Office Space*

Description: Office Space

People...

|          |                      |              |                                    |
|----------|----------------------|--------------|------------------------------------|
| Type     | General Office Space |              |                                    |
| Density  | 143                  | sq ft/person | Schedule: People - Low Rise Office |
| Sensible | 250                  | Btu/h        | Latent: 200 Btu/h                  |

Workstations...

|         |   |                    |
|---------|---|--------------------|
| Density | 1 | workstation/person |
|---------|---|--------------------|

Lighting...

|           |   |         |                                    |
|-----------|---|---------|------------------------------------|
| Type      | Recessed fluorescent, not vented, 80% load to space |         |                                    |
| Heat gain | 1.45  | W/sq ft | Schedule: Lights - Low rise office |

Miscellaneous loads...

|              |                      |         |                                  |
|--------------|----------------------|---------|----------------------------------|
| Type         | Std Office Equipment |         |                                  |
| Energy       | 1                    | W/sq ft | Schedule: Misc - Low rise office |
| Energy meter | Electricity          |         |                                  |

*Typical Office Internal Loads*

Cooling Equipment - Alternative 1

Cooling plant 
Equipment tag 
Category 
Equipment type 
Sequencing type 
Energy source 
Reject condenser heat 
Reject heat to plant

Heat Rejection

Type 
Hourly ambient wet bulb offset  °F

Thermal Storage

Type 
Capacity  
Schedule

| Operating mode                | Capacity | Energy rate |
|-------------------------------|----------|-------------|
| Cooling                       | tons     | 0.52 kW/ton |
| Heat recovery                 | tons     | kW/ton      |
| Tank charging                 | tons     | kW/ton      |
| Tank charging & heat recovery | tons     | kW/ton      |

| Pumps                          | Type                               | Full load consumption |
|--------------------------------|------------------------------------|-----------------------|
| Primary chilled water          | Eq5001 - Cnst vol chill water pump | 0 ft water            |
| Condenser water                | Eq5010 - Cnst vol cnd water pump   | 0 ft water            |
| Heat recovery or aux condenser | None                               | 0 ft water            |

Cooling Plant Summary

Heating Equipment - Alternative 1

Heating plant 
Equipment tag 
Category 
Equipment type

Thermal Storage

Type 
Capacity  
Schedule

Controls


Equipment schedule 
Demand limiting priority

Hot Water Pump

Type 
Full load consumption

Heating Plant Summary

## APPENDIX B – TRACE SYSTEM SCHEMATIC

*System Schematic*



## APPENDIX C – WEATHER INFORMATION

|                               |             |            |              |                     |               |
|-------------------------------|-------------|------------|--------------|---------------------|---------------|
| Region                        |             | Subregion  |              | Location            |               |
| United States                 |             | North East |              | Baltimore, Maryland |               |
| Filename                      |             |            |              |                     |               |
| Latitude                      | 39          | deg        | Time zone    | 5                   |               |
| Longitude                     | 76          | deg        | Design month | July                |               |
| Altitude                      | 146         | ft         | QA pressure  | 29.75               | in. Hg        |
|                               | QADB        | QAWB       | Clearness    | Ground reflect      | Wind velocity |
|                               | °F          | °F         |              |                     | mph           |
| Summer                        | 91          | 77         | 0.85         | 0.2                 | 10            |
| Winter                        | 13          |            | 0.85         | 0.2                 | 15            |
| Saturation Curve Coefficients |             |            |              |                     |               |
|                               | Coef A      | Coef B     | Coef C       | Coef D              |               |
|                               | -0.31432088 | 0.92774457 | -0.013444782 | 0.00032957462       |               |
| Comments                      |             |            |              |                     |               |
| Created by C.D.S. Marketing   |             |            |              |                     |               |

|   |           |                 |       |
|---|-----------|-----------------|-------|
| ASHRAE Climatic Data                    |           |                 |       |
| Station WMO #                           | 724060    | Select Location |       |
| Station Name                            | Baltimore |                 |       |
| Winter Design                           | 99.6 %    | 99 %            |       |
| Dry Bulb                                | 12.3      | 16.7            |       |
| Cooling Maximum DB / Mean Coincident WB |           |                 |       |
|   | 0.4 %     | 1 %             | 2 %   |
| Dry Bulb                                | 93.6      | 90.9            | 88.2  |
| Wet Bulb                                | 75        | 74.3            | 73.1  |
| Dew Point                               | 67.44     | 67.49           | 66.72 |
| Dehumid Maximum DB / Mean Coincident DB |           |                 |       |
|   | 0.4 %     | 1 %             | 2 %   |
| Dry Bulb                                | 82.4      | 81.2            | 80.1  |
| Wet Bulb                                | 77.21     | 76.02           | 74.92 |
| Dew Point                               | 75.4      | 74.1            | 72.9  |

*Weather Conditions for Baltimore, MD*

2009 ASHRAE Handbook - Fundamentals (IP)

Copyrighted Materials  
Copyright © 2009 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.  
Baltimore 2009 www.ashrae.org

© 2009 ASHRAE, Inc.

## BALTIMORE BLT-WASHNGTN INT'L, MD, USA

WMO#: 724060

Lat: 39.17N Long: 76.68W Elev: 154 StdP: 14.61 Time Zone: -5.00 (NAE) Period: 82-06 WBAN: 93721

## Annual Heating and Humidification Design Conditions

| Coldest Month | Heating DB |      | Humidification DP/MCDB and HR |     |      |     |     |      | Coldest month WS/MCDB |      |      |      | MCWS/PCWD to 99.6% DB |      |
|---------------|------------|------|-------------------------------|-----|------|-----|-----|------|-----------------------|------|------|------|-----------------------|------|
|               |            |      | 99.6%                         |     |      | 99% |     |      | 0.4%                  |      | 1%   |      |                       |      |
|               | 99.6%      | 99%  | DP                            | HR  | MCDB | DP  | HR  | MCDB | WS                    | MCDB | WS   | MCDB | MCWS                  | PCWD |
| 1             | 12.9       | 17.3 | 3.3                           | 4.6 | 17.8 | 1.3 | 5.9 | 22.1 | 26.2                  | 31.6 | 24.2 | 32.1 | 8.7                   | 290  |

## Annual Cooling, Dehumidification, and Enthalpy Design Conditions

| Hottest Month                   | Hottest Month DB Range | Cooling DB/MCWB |      |       |      |      |       | Evaporation WB/MCDB |               |      |      |      |      | MCWS/PCWD to 0.4% DB |                      |
|---------------------------------|------------------------|-----------------|------|-------|------|------|-------|---------------------|---------------|------|------|------|------|----------------------|----------------------|
|                                 |                        | 0.4%            |      | 1%    |      | 2%   |       | 0.4%                |               | 1%   |      | 2%   |      |                      |                      |
|                                 |                        | DB              | MCWB | DB    | MCWB | DB   | MCWB  | WB                  | MCDB          | WB   | MCDB | WB   | MCDB | MCWS                 | PCWD                 |
| 7                               | 18.7                   | 93.9            | 74.9 | 91.2  | 74.2 | 88.5 | 73.1  | 78.1                | 88.6          | 76.8 | 86.5 | 75.6 | 84.3 | 10.2                 | 280                  |
| Dehumidification DP/MCDB and HR |                        |                 |      |       |      |      |       |                     | Enthalpy/MCDB |      |      |      |      |                      | Hours 8 to 4 & 55/69 |
| 0.4%                            |                        |                 | 1%   |       |      | 2%   |       |                     | 0.4%          |      | 1%   |      | 2%   |                      |                      |
| DP                              | HR                     | MCDB            | DP   | HR    | MCDB | DP   | HR    | MCDB                | Enth          | MCDB | Enth | MCDB | Enth | MCDB                 |                      |
| 75.3                            | 133.3                  | 82.1            | 74.1 | 127.9 | 80.8 | 73.0 | 123.1 | 79.8                | 41.5          | 89.1 | 40.2 | 86.5 | 39.1 | 84.5                 | 723                  |

## Extreme Annual Design Conditions

| Extreme Annual WS |      |      | Extreme Max WB | Extreme Annual DB |      |                    |     | n-Year Return Period Values of Extreme DB |       |            |       |            |       |            |       |
|-------------------|------|------|----------------|-------------------|------|--------------------|-----|---|-------|------------|-------|------------|-------|------------|-------|
|                   |      |      |                | Mean              |      | Standard deviation |     | n=5 years                                 |       | n=10 years |       | n=20 years |       | n=50 years |       |
| 1%                | 25%  | 5%   |                | Min               | Max  | Min                | Max | Min                                       | Max   | Min        | Max   | Min        | Max   | Min        | Max   |
| 22.4              | 19.2 | 17.3 | 84.6           | 5.1               | 98.0 | 6.3                | 3.3 | 0.6                                       | 100.3 | -3.1       | 102.2 | -6.7       | 104.0 | -11.3      | 106.4 |

## Monthly Climatic Design Conditions

|  |          | Annual | Jan   | Feb   | Mar   | Apr   | May   | Jun   | Jul   | Aug   | Sep   | Oct   | Nov   | Dec   |
|--|----------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Temperatures,<br>Degree-Days<br>and<br>Degree-Hours                              | Tavg     | 55.9   | 33.9  | 36.9  | 44.2  | 54.2  | 63.6  | 72.7  | 77.6  | 75.7  | 68.3  | 56.8  | 47.3  | 37.8  |
|  | Sd       |        | 10.07 | 8.67  | 9.29  | 8.30  | 7.49  | 6.31  | 5.08  | 5.20  | 6.95  | 7.72  | 8.51  | 9.29  |
|  | HDD50    | 1726   | 507   | 376   | 231   | 45    | 1     | 0     | 0     | 0     | 22    | 152   | 392   |       |
|  | HDD65    | 4567   | 964   | 787   | 649   | 339   | 119   | 12    | 0     | 2     | 45    | 275   | 532   | 843   |
|  | CDD50    | 3861   | 8     | 9     | 50    | 171   | 424   | 680   | 855   | 796   | 550   | 232   | 71    | 15    |
|  | CDD65    | 1228   | 0     | 0     | 4     | 15    | 77    | 242   | 390   | 333   | 145   | 21    | 1     | 0     |
|  | CDH74    | 11317  | 0     | 1     | 42    | 195   | 792   | 2240  | 3853  | 2963  | 1071  | 148   | 11    | 1     |
|  | CDH80    | 4315   | 0     | 0     | 8     | 57    | 267   | 849   | 1669  | 1125  | 317   | 23    | 0     | 0     |
|  |          |        |       |       |       |       |       |       |       |       |       |       |       |       |
| Monthly Design<br>Dry Bulb<br>and<br>Mean Coincident<br>Wet Bulb<br>Temperatures | 0.4%     | DB     | 65.2  | 69.3  | 80.0  | 86.9  | 90.9  | 94.6  | 98.0  | 96.9  | 92.6  | 83.2  | 75.3  | 68.5  |
|  |          | MCWB   | 57.7  | 56.2  | 62.2  | 66.7  | 71.5  | 74.5  | 76.5  | 75.9  | 72.8  | 68.9  | 63.6  | 60.2  |
|  | 2%       | DB     | 59.5  | 61.4  | 71.1  | 79.6  | 86.8  | 91.3  | 94.7  | 92.6  | 87.1  | 78.1  | 69.8  | 62.1  |
|  |          | MCWB   | 54.5  | 53.5  | 58.1  | 63.2  | 69.3  | 73.9  | 75.7  | 75.0  | 71.7  | 66.9  | 60.2  | 55.3  |
|  | 5%       | DB     | 53.0  | 55.5  | 64.7  | 74.1  | 82.6  | 88.2  | 91.8  | 89.2  | 83.4  | 74.0  | 65.3  | 56.4  |
|  |          | MCWB   | 46.8  | 47.5  | 54.1  | 60.3  | 67.9  | 73.0  | 74.9  | 73.8  | 70.1  | 64.3  | 58.7  | 51.0  |
|  | 10%      | DB     | 47.6  | 50.4  | 59.4  | 69.3  | 78.1  | 85.1  | 88.7  | 86.1  | 80.2  | 70.2  | 61.4  | 51.6  |
|  |          | MCWB   | 42.7  | 44.3  | 50.1  | 57.3  | 65.5  | 71.8  | 74.0  | 72.5  | 69.0  | 62.5  | 55.6  | 46.1  |
|  |          |        |       |       |       |       |       |       |       |       |       |       |       |       |
| Monthly Design<br>Wet Bulb<br>and<br>Mean Coincident<br>Dry Bulb<br>Temperatures | 0.4%     | WB     | 60.1  | 60.1  | 64.6  | 68.9  | 74.8  | 78.8  | 80.2  | 79.4  | 77.0  | 72.2  | 66.5  | 62.1  |
|  |          | MCDB   | 63.2  | 66.0  | 76.5  | 80.5  | 86.0  | 88.3  | 91.3  | 90.0  | 85.0  | 77.8  | 70.8  | 67.1  |
|  | 2%       | WB     | 55.0  | 53.7  | 60.2  | 65.7  | 72.1  | 76.5  | 78.4  | 77.5  | 75.0  | 69.8  | 63.5  | 57.2  |
|  |          | MCDB   | 58.6  | 58.7  | 68.8  | 75.7  | 82.8  | 85.9  | 89.4  | 88.0  | 82.1  | 75.5  | 67.9  | 61.0  |
|  | 5%       | WB     | 47.9  | 49.1  | 55.7  | 62.4  | 69.7  | 75.2  | 77.2  | 76.2  | 73.3  | 66.6  | 60.1  | 52.1  |
|  |          | MCDB   | 50.9  | 54.0  | 62.1  | 71.4  | 79.4  | 84.2  | 87.6  | 85.0  | 79.2  | 71.9  | 64.1  | 55.5  |
|  | 10%      | WB     | 43.3  | 45.1  | 51.5  | 59.3  | 67.4  | 73.7  | 76.0  | 74.9  | 71.7  | 63.8  | 56.7  | 47.0  |
|  |          | MCDB   | 47.2  | 50.2  | 58.5  | 67.2  | 75.4  | 81.7  | 85.2  | 82.5  | 77.2  | 68.8  | 60.6  | 50.6  |
|  |          |        |       |       |       |       |       |       |       |       |       |       |       |       |
| Mean Daily<br>Temperature<br>Range   |          | MDBR   | 15.5  | 16.7  | 18.4  | 20.3  | 20.2  | 19.6  | 18.7  | 18.3  | 18.6  | 19.8  | 18.6  | 16.0  |
|  | 5% DB    | MCDDBR | 22.7  | 24.8  | 26.8  | 27.7  | 26.2  | 23.2  | 22.4  | 21.7  | 22.1  | 23.8  | 23.5  | 22.7  |
|  |          | MCWBR  | 17.1  | 17.3  | 16.6  | 14.6  | 12.2  | 9.6   | 8.1   | 8.3   | 9.7   | 13.7  | 16.1  | 17.5  |
|  | 5% WB    | MCDDBR | 20.1  | 21.3  | 23.7  | 24.0  | 22.7  | 19.6  | 19.1  | 18.6  | 17.7  | 19.3  | 19.6  | 19.8  |
|  |          | MCWBR  | 17.2  | 17.0  | 16.5  | 14.0  | 11.7  | 9.2   | 8.2   | 8.2   | 9.1   | 12.5  | 16.2  | 17.4  |
|  |          |        |       |       |       |       |       |       |       |       |       |       |       |       |
| Clear Sky<br>Solar<br>Irradiance   | taub     |        | 0.319 | 0.353 | 0.411 | 0.417 | 0.474 | 0.546 | 0.552 | 0.580 | 0.421 | 0.370 | 0.342 | 0.317 |
|  | taud     |        | 2.373 | 2.188 | 1.997 | 2.036 | 1.892 | 1.746 | 1.769 | 1.681 | 2.164 | 2.286 | 2.350 | 2.446 |
|  | Ebn,noon |        | 269   | 272   | 266   | 273   | 258   | 239   | 237   | 225   | 261   | 264   | 258   | 262   |
|  | Edh,noon |        | 30    | 40    | 52    | 53    | 62    | 72    | 69    | 74    | 44    | 36    | 31    | 27    |
|  |          |        |       |       |       |       |       |       |       |       |       |       |       |       |

ASHRAE 2009 HOF Weather Data for Baltimore, MD