# **Technical Report 2**

Building & Plant Energy Analysis

# Glen Burnie High School: Buildings D, E & F Glen Burnie, MD



Wade Myers; BAE Mechanical Option Thesis Advisor: William Bahnfleth 10/27/2010

# **Table of Contents**

Executive Summary	.2
Mechanical System Overview	.3
Building D:	.3
Building E:	.3
Building F:	.4
Design Load Estimation	.5
Assumptions:	.5
Design Loads vs. Model:	.5
Conclusions:	.7
Annual Energy Consumption and Operating Costs	.8
Assumptions:	.8
Building D Results:	.9
Building E Results:	11
Building F Results:	13
Conclusions:	15
Annual Carbon Footprint	16
References:	17
Appendix:	18

## **Executive Summary**

Glen Burnie High School is a campus style high school located in Glen Burnie, MD. The campus is comprised of 6 buildings, but for the purposes of this report, only Buildings D, E & F were evaluated. Building D is primarily served by unit ventilators, with fan coil units and cabinet unit heaters providing supplemental heating and cooling in corridors, stairways and storage areas. Building E is a constant air volume system served by 9 air handling units with convectors and cabinet unit heaters again serving as supplemental heat. There is also an individual unit ventilator serving the gymnastics area. Building F is the only variable air volume system of the three buildings and is served by 4 air handling units and 1 roof top unit. In the same manner as the previous 2 buildings, fan coil units and unit heaters are used for extra heating and cooling.

Using Trane Trace, the rooms of each building were modeled and templates for internal loads, airflow, thermostat settings, and construction were created. Rate structures were also obtained for Baltimore Gas & Electric, the assumed provider to Glen Burnie High School. These rates were entered into Trace as well, along with their rate schedules. Once this was completed, load calculations were performed resulting in HVAC load, energy, and cost data.

The results of the load calculations were fairly close to the actual design conditions with variances most likely occurring from the differences in the modeling process. The designer's models were created on an individual room basis with actual occupant and load densities used when available. The model which was created for this report was a block load model and load densities had to be assumed based on room type and Trace defaults.

The energy use calculations were not as accurate to what was anticipated. The heating energy use for the buildings was close to what was expected season but the energy use for cooling was grossly inaccurate. The incorrect values were used to complete the remaining calculations, carrying through the mistakes. The inaccuracy of the cooling system's energy use only affected the percentage of the total energy use by each building system, but not their actual values. The overall cost of operation for each building was much lower than was anticipated because of the low cooling rates, but the remaining individual values were approximately what was expected based on the assumed rates.

The carbon footprints of the buildings were calculated using the modeled building energy usages and values from the Regional Grid Emission Factors 2007 pdf supplied. Once again, the inaccuracy of the cooling loads lowered the overall combined emissions of the three buildings, but the calculated values are reasonable based on the modeled, albeit inaccurate, results for overall building energy use.

# **Mechanical System Overview**

## **Building D:**

Building D is a typical classroom building housing the arts and acting arts classrooms, as well as a handful of foreign language classrooms. In addition to classrooms, there are a few faculty planning and conference rooms located around the building. Building D's heating and cooling is supplied by 35 unit ventilators, 8 fan coil units, and 21 cabinet unit heaters. Unit ventilators are primarily located in classroom locations with the fan coil units serving the faculty areas and corridors. Supplemental heating is supplied to the corridors, stairwells and storage rooms by the cabinet unit heaters.

The block load for Building D was performed by splitting the building into 3 zones. Because the room types and mechanical equipment are all fairly similar, the building was zoned by floor. This resulted in separate zones for the 1<sup>st</sup>, 2<sup>nd</sup> and 3<sup>rd</sup> floors.

## **Building E:**

The primary school gymnasium is located in Building E. The building also contains locker rooms, a weight room and a gymnastics area. Heating and cooling is supplied to the building by 9 constant air volume air handling units, 9 hot water convectors, 3 cabinet unit heaters and a single unit ventilator.

Each system is designed to supply areas of similar occupancy and use so Building E was split into zones by system. This resulted in the following breakdown:

Building E Zone Summary								
System	Zone/Location							
AHU-1	Men's Lockers/Ground Floor							
AHU-2	Team Rooms/Ground Floor							
AHU-3	Women's Lockers/ Ground Floor							
AHU-4	Gymnasium/First Floor							
AHU-5	Gymnasium/First Floor							
AHU-6	Laundry Room/Ground Floor							
AHU-7	Lobby/First Floor							
AHU-8	Office/Second Floor							
AHU-9	Weight Room/Ground Floor							
UV-1	Gymnastics Area/Second Floor							
CUH & CONV	Various							

Table 1: Building E Zone Summary

#### **Building F:**

The most diverse of the 3 buildings is Building F which contains the auxiliary gym and locker rooms on the east end of the building and business education classrooms filling the rest. Building F is the only variable air volume system of the 3 buildings. Heating and cooling is supplied by 4 air handling units, 1 roof top unit, 2 fan coil units and 17 unit heaters.

In the same manner as Building E, the systems of Building F are serve areas of similar occupancy and use. In order to maintain consistency, Building F was also divided into zones by system. The flowing table shows the results:

Building F Zone Summary								
System	Zone/Location							
AHU-1	First Floor							
AHU-2	Second Floor							
AHU-3	Gymnasium							
AHU-4	Gymnasium							
RTU-1	Dance Studio							
FCU-1	Women's Locker Room							
FCU-2	Men's Locker Room							
Unit Heaters	Various							

Table 2: Building F Zone Summary

# **Design Load Estimation**

#### **Assumptions:**

As stated earlier, each building was divided into zones for the block load calculation. Building D was zoned by floor and Buildings E and F were zoned by system. The indoor and outdoor design air conditions for Baltimore, MD were used and obtained from ASHRAE Fundamentals 2009. Lighting power densities were based on the recommended values from ASHRAE Standard 90.1. Ventilation rates were taken from the design documents. Miscellaneous load densities and people loads came from the pre-sets in Trace for their respective cases. Whenever possible, actual room loads and people counts were used. Brief overviews of assumptions on air and load conditions are listed in the following tables:

Design Air Conditions										
Outdoor Design Conditions Indoor Design Conditions										
Su	mmer	Winter	Cooling	Heating	<b>Relative Humidity</b>					
DB (F)	MCWB (F)	DB (F)	DB (F)	DB (F)	%					
93.9	74.9	12.9	78	72	50					

Table 3: Design Air Conditions

Occupied Space Design Load Conditions											
Load	Classroom		Gym		Health		Locker Room		Office		
Lighting (W/SF)	1.4	1	1.4	1	1.5	5	0.9	Ð	1.1		
Misc (W/SF)	0.2	2	0		0.5		0		0.5		
Pooplo (BTU/br)	Sensible	Latent	Sensible	Latent	Sensible	Latent	Sensible	Latent	Sensible	Latent	
People (B10/11)	250	200	700	1000	250	200	275	275	250	200	
People	By Ro	om	By Room		By Room		By Ro	om	By Room		

Table 4: Occupied Space Design Load Conditions

These tables only list the occupied spaces because they account for the majority of the loads experienced in the building. For a more detailed breakdown of assumptions and templates used in the Trace calculations, including unoccupied spaces, see the appendix at the end of this report.

#### **Design Loads vs. Model:**

Both models were calculated using Trane Trace, but there are differences in the way that the designer's model was created in comparison to the one calculated for this report. The designer's model was created on a room by room basis, while this report dealt with a block load. There were also differences in the load assumptions. In order to obtain a more accurate model the default climate design values in Trace were replaced with values from ASHRAE Fundamentals. Lighting, miscellaneous, and people loads were also set up for different room types, instead of using a default value for all spaces.

The following tables show the comparisons by building between the design values and those of the newly calculated model for cooling loads, heating loads, supply airflows, and ventilation percentages:

Building D Comparisons											
7000	Cooling	Ventilat	ion %OA								
20110	Design	Model	Design	Model	Design	Model	Design	Model			
1st Floor	397.51	498.97	22.95	30.01	0.98	0.81	22	27.8			
2nd Floor	317.84	389.77	27.07	33.2	0.85	0.81	24	34.1			
3rd Floor	229.37	309.05	33.32	40.07	1.19	1.14	24	25.2			

Table 5: Building D Comparisons

Building E Comparisons											
Zono	Cooling	SF/ton	Heating	BTUh/SF	Supply	CFM/SF	Ventilation %OA				
2011	Design	Model	Design	Model	Design	Model	Design	Model			
AHU-1	217.72	449.64	56.84	34.77	0.92	0.61	100	48			
AHU-2	184.93	218.45	51.99	65.94	0.91	0.98	100	96.2			
AHU-3	219.69	385.33	52.75	32.24	1.09	0.8	100	37.1			
AHU-4	122 70	100 70	100.22	75 61	12 01	1 55	1.00	12	15 1		
AHU-5	133.70	109.22	75.01	42.04	1.55	1.99	42	13.1			
AHU-6	37.72	42.07	101.71	81.38	18.4	10.95	100	1.1			
AHU-7	245.33	341.47	50.44	17.73	0.75	0.38	27	17.7			
AHU-8	257.85	527.02	51.46	23.15	0.63	0.52	11	14.8			
AHU-9	246.15	396.77	47.37	29.16	0.65	0.63	100	47.6			
UV-1	221.3	361.47	64.11	41.46	0.77	0.64	28	46.9			
CUH & CONV			57.11	23.28							

Table 6: Building E Comparisons

	Building F Comparisons										
7000	Cooling SF/tor		Heating	BTUh/SF	Supply	CFM/SF	Ventilat	Ventilation %OA			
Zone	Design	Model	Design	Model	Design	Model	Design	Model			
AHU-1	307.09	384.94	19.01	16.01	1.05	0.77	28	36.3			
AHU-2	231.38	324.88	31.19	37.07	1.04	0.89	31	35			
AHU-3	20/ 16	170.01	26.67	10.1	1 00	2.07	20	1/1			
AHU-4	204.10	170.81	50.07	49.1	1.09	2.07	20	14.1			
RTU-1	238.81	254.07	42.05	41.76	1.24	1.1	18	26.6			
FCU-1	272.53	203.89	31.63	37.69	1.33	1.83	0	0			
FCU-2	322.94	236.63	34.41	34.43	1.49	1.64	0	0			
UH			8.99	17.51							

Table 7: Building F Comparisons

#### **Conclusions:**

As seen in the tables, the majority of the values from the model are very close to the values used in the design of the renovation, with a few exceptions. Building D's cooling loads are generally smaller than designed, while the heating loads are larger. The heating load being larger makes sense since the model created for this report was a block load compared to a room by room model for the design, but the cooling load should also be larger. Because it is not, it must be assumed the actual load conditions in the building are larger than assumed. The designer was able to use more accurate information for room occupancy and equipment loadings, but the model was based on standard load densities found in Trace and the occupant density was assumed based on room type. Supply airflow is also smaller, most likely due to the reduced cooling load in the model. A higher outdoor air percentage was calculated for the model but this can be attributed to the larger airflows used by the designer, meaning that a smaller percentage of this larger volume is needed to meet the same rate.

Building's E and F share similar conclusions. In these buildings both the cooling and heating loads are generally smaller, but the heating loads are slightly more accurate than for Building D. Again, this should be attributed to the difference in modeling techniques and load conditions used. Airflow rates are again a small amount lower except for in the AHUs which serve the gymnasiums. The changes with respect to these AHUs is most likely caused by modeling the two together since they serve the same area and have the load split between them. Because of this, the outdoor air percentages are again higher than designed except in cases where the OA percentage was intentionally increased by the designer, such as in the gym and laundry areas.

# **Annual Energy Consumption and Operating Costs**

#### **Assumptions:**

In order to keep the model as accurate as possible, each building was modeled separately in Trace. All room types were imported as accurately as possible. For room types in which Trace does not have presets or standards for, the values were found in ASHRAE Fundamentals 2009, ASHRAE Standard 62.1 and ASHRAE Standard 90.1, or the closest match was used/estimated. All room types which were shared between multiple buildings were modeled identically in the program. The cooling and heating plants in Trace were modeled as an air cooled chiller and gas-fired steam boiler, respectively, to match the type of equipment that is currently in operation or being installed as part of this renovation.

Actual energy use and utility bills were not available from the owner for use in this report. A major supplier of gas and electric in the Baltimore, MD area is Baltimore Gas & Electric, so it was assumed that BG&E was the supplier for Glen Burnie High School for these calculations. The following two tables list the rates for both electricity and gas during peak and non-peak times, as well as the rate schedules for when these different rates occur:

Baltimore Gas & Electric Rates										
	Electric		G	as						
Demand Charge	Peak	Off-Peak	≤10000 therms	>10,000 therms						
(\$/kW)	(¢/kWh)	(¢/kWh)	(¢/kWh)	(\$/therm)	(\$/therm)					
3.95	11.551	9.265	8.824	0.1975	0.0948					

BG&E Rate Schedule										
Start	Rate									
11:00 PM	7:00 AM	Off-Peak								
7:00 AM	10:00 AM	Mid-Peak								
10:00 AM	8:00 PM	Peak								
8:00 PM	11:00 PM	Mid-Peak								

Table 8: Baltimore Gas & Electric Rates

Table 9: BG&E Rate Schedule

At the time of this report, it was not discovered if an energy or cost analysis was performed by the designer for the mechanical renovation. Therefore, it is assumed to have not occurred. This could be because the project is a renovation and not new construction. Being so, the renovation could be sized to match the current conditions experienced by the owner, not creating any changes.

#### **Building D Results:**









Figure 3: Building D Monthly HVAC Energy

		ENERGY CONSUMPTION SUMMARY By ACADEMIC			
	Elect Cons. (kWh)	Gas Cons. (kBtu)	% ofTotal Building Energy	Total Building Energy (kBtu/vr)	Total Source Energy* (kBtu/yr)
Alternative 1					
Primary heating Primary heating Other Htg Accessories Heating Subtotal	6,011 <b>6,011</b>	973,361 973,361	68.4 % 1.4 % <b>69.8</b> %	973,361 20,514 <b>993,875</b>	1,024,590 61,548 <b>1,086,138</b>
Primary cooling Cooling Compressor Tower/Cond Fans Condenser Pump Other Clg Accessories Cooling Subtotal	33,352 4,219 298 <b>37,869</b>		8.0 % 1.0 % 0.0 % 0.1 % <b>9.1</b> %	113,830 14,400 0 1,017 <b>129,247</b>	341,523 43,204 0 3,052 387,778
Auxiliary Supply Fans Pumps Stand-alone Base Utilities Aux Subtotal			0.0 % 0.0 % 0.0 % 0.0 %	0 0 0	0 0 0 0
Lighting Lighting	69,748		16.7 %	238,049	714,218
Receptacle Receptacles	18,196		4.4 %	62,104	186,332
Cogeneration Cogeneration			0.0 %	0	0
Totals					
Totals**	131,824	973,361	100.0 %	1,423,274	2,374,466

## **Building E Results:**

			Μ	IONTH	ILY U	TILITY	соѕт	s					
					By A	CADEMIC	2						
						Monthly	Itility Cost						
Utility	Jan	Feb	Mar	Apr	Мау	June	July	Aug	Sept	Oct	Nov	Dec	Total
Alternative 1													
Electric						- 7		7 ( )	7//				
On-Pk Cons. (\$) Off-Pk Cons. (\$) Mid-Pk Cons. (\$)	416 66 162	377 60 146	569 67 173	720 50 147	1,197 33 270	1,552 33 384	1,181 35 462	204 31 30	1,140 32 257	668 47 158	589 53 152	405 66 157	9,018 574 2,498
On-Pk Demand (\$) Off-Pk Demand (\$) Mid-Pk Demand (\$)	143 17 113	214 17 113	319 17 113	343 17 114	505 11 354	648 11 466	629 15 555	151 7 58	553 11 387	349 17 113	326 17 113	289 17 113	4,468 175 2,614
Total (\$):	918	927	1,258	1,390	2,370	3,094	2,878	480	2,381	1,353	1,250	1,047	19,347
Gas													
On-Pk Cons. (\$) Off-Pk Cons. (\$) Mid-Pk Cons. (\$)	184 189 195	172 163 174	82 63 121	13 5 47	0 0 2	0 0 0	000	0 0	0 0 1	15 6 52	25 21 74	132 146 158	623 593 825
Total (\$):	568	509	266	65	2	0	0	0	1	73	121	437	2,042
Monthly Total (\$):	1,487	1,436	1,524	1,456	2,372	3,094	2,878	480	2,382	1,426	1,371	1,483	21,388
Building Area = 26, Utility Cost Per Area = 0.8	154 ft² 2 \$/ft²		_		_	_	_	_	_	r			









ENERGY CONSUMPTION SUMMARY	
By ACADEMIC	

_	Elect Cons. (kWh)	Gas Cons. (kBtu)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
Alternative 1					
Primary heating					
Primary heating		1,033,694	73.1 %	1,033,694	1,088,099
Other Htg Accessories	6,556		1.6 %	22,374	67,130
Heating Subtotal	6,556	1,033,694	74.7 %	1,056,069	1,155,229
Primary cooling					
Cooling Compressor	44,541		10.8 %	152,018	456,098
Tower/Cond Fans	6,093		1.5 %	20,794	62,390
Condenser Pump			0.0 %	0	0
Other Clg Accessories	410		0.1 %	1,398	4,194
Cooling Subtotal	51,043		12.3 %	174,210	522,682
Auxiliary					
Supply Fans			0.0 %	0	0
Pumps			0.0 %	0	0
Stand-alone Base Utilities			0.0 %	0	0
Aux Subtotal			0.0 %	0	0
Lighting					
Lighting	52,390		12.6 %	178,806	536,471
Receptacle					
Receptacles	1,548		0.4 %	5,284	15,855
Cogeneration					
Cogeneration			0.0 %	0	0
Totals					
Totals**	111,537	1,033,694	100.0 %	1,414,369	2,230,237
		Figure 8: Building E Energy Consumption Summary			

## **Building F Results:**

			Μ	IONTH	ILY UT By A		COST	S					
				_		Monthly U	tility Cost	s				_	
Utility	Jan	Feb	Mar	Apr	Мау	June	July	Aug	Sept	Oct	Nov	Dec	Tot
ternative 1													
Electric									7/1/				
On-Pk Cons. (\$) Off-Pk Cons. (\$) Mid-Pk Cons. (\$)	1,066 118 425	964 106 384	1,159 118 457	1,040 114 407	1,272 72 433	1,561 70 394	1,402 74 525	301 67 89	1,345 69 395	1,116 100 432	1,079 114 422	1,027 118 409	13,3 1,1 4,7
On-Pk Demand (S) Off-Pk Demand (S) Mid-Pk Demand (S)	317 32 315	317 32 315	326 32 316	335 32 318	525 32 333	776 24 446	790 24 606	309 13 126	694 24 441	389 32 320	341 32 317	319 32 315	5,4 3 4,1
Total (\$):	2,273	2,119	2,408	2,246	2,668	3,272	3,421	905	2,968	2,388	2,306	2,219	29,1
Gas On-Pk Cons. (\$) Off-Pk Cons. (\$)	286 249	270 233	116 95	33 23	1	0	0	0	0	43 29	70 60	182 186	1,0( 8
Mid-Pk Cons. (\$)	298	270	220	108	1	0	0	0	0	117	162	239	1,4
Total (\$):	833	773	431	165	2	0	0	0	0	188	291	607	3,2
Monthly Total (\$):	3,107	2,891	2,839	2,410	2,669	3,272	3,421	905	2,968	2,577	2,597	2,826	32,4
Building Area = 54	460 ft²												
Litility Cost Per Area = 0.6	400 It 0 ¢/ft2												
Utility Cost Fel Alea - 0.0	υφπ		Fig	uro Q. E	luilding	F Month	ly IItility	Costs		r			1





Figure 12: Building F Energy Consumption Summary

**Technical Report 2** 

10/27/2010

#### **Conclusions:**

The energy usage for the buildings appears to be reasonable for the heating season but grossly inaccurate for the cooling season. After several repeatedly failed attempts to find the error in the Trace files, the values were used to carry on with the rest of the calculations. Because the cooling system's energy use is so low, this affects the cost of operation. Values for energy use for the other building systems appear to be accurate, and the incorrect cooling values only affect the percentage of the total, the actual values themselves should not change if the cooling load is corrected.

For the cost analysis, the same issue exists. The overall cost of operation for each building was much lower than was anticipated, but the individual values, aside from cooling, were approximately what was expected based on the assumed rates. If the cooling load had been correct, a more balanced representation of the overall cost of operation for the building would be available.

# **Annual Carbon Footprint**

Values to calculate the carbon footprint for each building were obtained from the supplied pdf "Regional Grid Emission Factors 2007". Tables B-10 and 8 in the document gave the emission factors for the state of Maryland based on electricity and a natural gas-fired commercial boiler, respectively. The following tables show the breakdowns for each:

Emissie	on Factor	s for Electr	icity
	(lb/kWh)	(kWh/year)	(lb/year)
CO <sub>2</sub> e	1.82	423199	770222.2
CO2	1.71	423199	723670.3
CH <sub>4</sub>	4.02E-03	423199	1701.26
N <sub>2</sub> O	3.54E-03	423199	1498.124
NO <sub>x</sub>	3.10E-03	423199	1311.917
SO <sub>x</sub>	1.11E-02	423199	4697.509
CO	1.19E-03	423199	503.6068
TNMOC	7.74E-05	423199	32.7556
Lead	1.16E-07	423199	0.049091
Mercury	3.56E-08	423199	0.015066
PM10	9.25E-05	423199	39.14591
Solid Waste	1.69E-01	423199	71520.63

	Emission Factors for Natural Gas											
	(kBTU/CF)	(lb/year)										
CO <sub>2</sub> e	1.23E+02	3672.89	1.01	456283.1								
CO2	1.22E+02	3672.89	1.01	452573.5								
CH <sub>4</sub>	2.50E-03	3672.89	1.01	9.274047								
N <sub>2</sub> O	2.50E-03	3672.89	1.01	9.274047								
NO <sub>x</sub>	1.11E-01	3672.89	1.01	411.7677								
SO <sub>x</sub>	6.32E-04	3672.89	1.01	2.344479								
CO	9.33E-04	3672.89	1.01	3.461074								
VOC	6.13E-03	3672.89	1.01	22.73996								
Lead	5.00E-07	3672.89	1.01	0.001855								
Mercury	2.60E-07	3672.89	1.01	0.000965								
PM10	8.40F-03	3672.89	1.01	31,1608								

Table 10: Emission Factors for Electricity

Table 11: Emission Factors for Natural Gas

## **References:**

ASHRAE. 2007, ANSI/ASHRAE, <u>Standard 62.1-2007, Ventilation for Acceptable Indoor Air</u> <u>Quality.</u> American Society of Heating Refrigeration and Air-Conditioning Engineers, Inc., Atlanta, GA.

ASHRAE. 2007, ANSI/ASHRAE, <u>Standard 90.1-2007, Energy Standard for Buildings Except</u> <u>Low-Rise Residential Buildings.</u> American Society of Heating Refrigeration and Air-Conditioning Engineers, Inc., Atlanta, GA.

ASHRAE. 2009, *2009 ASHRAE Handbook-Fundamentals*. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc., Atlanta, GA.

Bid Documents and Project Specifications for Glen Burnie High School Buildings D, E & F

# **Appendix:**

The following appendix contains the Trace templates for each building used in the load calculations, including: Internal Loads, Airflow, Thermostat, and Construction.

Internal Load	Templates - Project					X
Alternative	Alternative 1	•	]			Apply
Description	Classroom	-				<u>C</u> lose
People						
Туре	Classroom				-	New
Density	0 People	▼ Sche	dule People - S	chool	-	С <u>о</u> ру
Sensible	250 Btu/h	Laten	t 200 B	tu/h		<u>D</u> elete
Workstations						Add <u>G</u> lobal
Density	1 workstation/pers	son 💌				
Lighting						
Туре	Recessed fluorescent, no	t vented, 80% load	to space		-	
Heat gain	1.4 W/sq.ft	▼ Sche	dule Lights - Sc	hool	•	
Miscellaneou	is loads					
Туре	Std School Equipment				-	
Energy	0.22 W/sq.ft	▼ Sche	dule Misc - Mid	dle School	•	
Energy meter	Electricity	•	,			
Internal	Load <u>A</u> irflow	<u> </u>	hermostat	Construction	]	<u>R</u> oom

Figure A1: Classroom Load Template

Internal Load	Template	es - Project						×
Alternative Description	Altern	ative 1 or		•				Apply
People								
Туре	None						-	<u>N</u> ew
Density	0	People	•	Schedule People	- Scho	ool	•	Сору
Sensible	0	Btu/h		Latent 0	Btu/	'n		<u>D</u> elete
Workstations								Add <u>G</u> lobal
Density	1	workstation/person	•					
Lighting								
Туре	Recesse	d fluorescent, not vent	ed, 80	% load to space			-	
Heat gain	0.5	W/sq ft	•	Schedule Lights -	Scho	ol	-	
Miscellaneou	us loads							
Туре	None						-	
Energy	0	W/sq ft	•	Schedule Misc - M	liddle	School	-	
Energy meter	None		•					
Internal	Load	Airflow		<u>T</u> hermostat		<u>C</u> onstruction		<u>B</u> oom

Figure A2: Corridor Load Template

Workstations... Density 1

Lighting..

Туре

Туре

Energy

Energy meter

Heat gain 1.5

Miscellaneous loads..

Internal Load

0.5

Electricity

workstation/person 💌

Airflow

W/sq.ft

Std Office Equipment

W/sq.ft

Recessed fluorescent, not vented, 80% load to space

•

•

Internal Load	Templat	es - Project					×
Alternative Description	Alter	native 1		<b>•</b>			Apply
People							
Туре	None					-	New
Density	0	People	-	Schedule People - 9	ichool	-	С <u>о</u> ру
Sensible	700	Btu/h		Latent 1000 E	3tu/h		<u>D</u> elete
Workstation:	s						Add <u>G</u> lobal
Density	1	workstation/perso	n 🔻				
Lighting		,	_				
Туре	Recess	ed fluorescent, not v	/ented, 8l	)% load to space		-	
Heat gain	1.4	W/sq.ft	-	Schedule Lights - Sc	chool	•	
Miscellaneo	s loads						
Туре	None					-	
Energy	0	W/sq ft	•	Schedule Misc - Mic	Idle School	-	
Energy	None		-	,		_	
motor	,		_				
<u>I</u> nternal	Load	Airflow		<u>T</u> hermostat	<u>Construction</u>		<u>R</u> oom
		F	igure .	A3: Gym Load Te	emplate		
			0	5			
Internal Load	Templat	es - Project					×
Alternative	Alterr	native 1		•			Apply
Description	Healt	h		•			<u>C</u> lose
People							
Туре	Hospital	Room				-	New
Density	0	People	•	Schedule People - 9	ichool	•	С <u>о</u> ру
Sensible	250	Btu/h		Latent 200 E	3tu/h		<u>D</u> elete
							Add <u>G</u> lobal

W Ihermostat Cons Figure A4: Health Load Template

Schedule Lights - School

Schedule Misc - Middle School

•

•

•

•

<u>R</u>oom

<u>Construction</u>

Internal Load	Template	s - Project					×
Alternative	Altern	ativa 1	-				Apply
Description	Locke	r Boom					
	1						<u></u>
People							New
lype	None		<b>–</b>			_	Сору
Density	075	People	Schedu	le People - S	chool	•	Delete
Sensible	275	Btu/h	Latent	2/5 B	tu/n		
Workstation	s						Add <u>G</u> lobal
Density	1	workstation/person	•				
Lighting							
Туре	Recesse	d fluorescent, not venti	ed, 80% load to	space		-	
Heat gain	0.9	W/sq.ft	- Schedu	ile Lights - Sc	hool	-	
Miscellaneo	us loads						
Туре	None					-	
Energy	0	W/sa ft	▼ Schedu	le Misc - Mid	dle School	-	
Energy	None			1			
meter	Interio						
<u>I</u> nternal	Load	Airflow	<u> </u>	ermostat			<u>R</u> oom
		Eiguno A	L L e elsen	D I			]
		EIOIII D D	5' I MCVDC	ROOM LO3	d Tomnlato		
		Figure A	5: LOCKER	Room Loa	d Template		
Internal Load	Template	s - Project	5: LOCKET	Room Loa	d Template		×
Internal Load	Template	s - Project	5: LOCKET	Room Loa	d Template		Apply
Internal Load	Template Alterna	s - Project	5: LOCKET	Koom Loa	d Template		
Internal Load Alternative Description	Template Alterna	rigure A s - Project ative 1	5: LOCKEP	Room Loa	d Template		Apply Close
Internal Load Alternative Description People	Template Alterna Office	s - Project	S: LOCKET	Room Loa	d Template		Apply Close New
Internal Load Alternative Description People Type	Template Alterna Office	Figure A s - Project ative 1	S: LOCKER	Room Loa	d Template	T	Apply Close New
Internal Load Alternative Description People Type Density	Template Alterna Office	Figure A s - Project ative 1 Office Space People	S: LOCKER	le People - S	d Template	<b>•</b>	Apply Close New Copy
Internal Load Alternative Description People Type Density Sensible	Alterna Office	Figure A s - Project ative 1 Diffice Space People Btu/h	Schedu Latent	lle People - S	d Template	•	Apply Close New Copy Delete
Internal Load Alternative Description People Type Density Sensible Workstations	Alterna Office	Figure A s - Project ative 1 Diffice Space People Btu/h	Schedu Latent	lle People - S 200 B	chool tw/h	T	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density	Template       Alterna       Office       General (0       0       250       8       1	Project ative 1 Office Space People Btu/h workstation/person	S: LOCKEP	le People - S 200 B	d Template	•	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting	Alterna       Alterna       Office       General 0       1	Project ative 1 Office Space People Btu/h workstation/person	S: LOCKEP	le People - S	chool tw/h	•	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting Type	Template Alterna Office General 0 250	Figure A s - Project ative 1 Diffice Space People Btu/h workstation/person	S: LOCKEP  Schedu Latent  d, 80% load to	le People - S 200 B	d Template	T T	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting Type Heat gain	Template Alterna Office General ( 0 250 1  Recesse 1.1	Project ative 1 Diffice Space People Btu/h workstation/person d fluorescent, not ventor W/sq ft	Schedu  d, 80% load to  Schedu  schedu	Ile People - S 200 B space Ile Lights - Sc	d Template	<b>•</b>	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting Type Heat gain	Template Alterna Office General ( 250	Project ative 1 Difice Space People Btu/h workstation/person d fluorescent, not vente W/sq ft	Schedu  dt  dt  dt  dt  dt  dt  dt  dt  dt	Ile People - S 200 B space Ile Lights - Sc	d Template	• •	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting Type Heat gain Miscellaneou Ture	Template Alterna Office General 0 250	Project ative 1 Difice Space People Btu/h workstation/person d fluorescent, not ventor W/sq ft	S: LOCKEP   Schedu Latent   d, 80% load to  Schedu	Ile People - S 200 B space	d Template	• •	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting Type Heat gain Miscellaneou Type Energy	Template       Alterna       Office       General ()       250       \$       1       Recesse       1.1       is loads       Std Office	Figure A s - Project ative 1 Diffice Space People Btu/h workstation/person d fluorescent, not vento W/sq ft Equipment W/sq ft	Schedu Catent  Catent	le People - S 200 B space le Lights - Sc	d Template	• •	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting Type Heat gain Miscellaneou Type Energy Energy	Template Alterna Office General (  General (  General (  Facesse 1.1  Std Office ( 0.5  Electic)	Figure A s - Project ative 1 Diffice Space People Btu/h workstation/person d fluorescent, not vente W/sq ft	S: LOCKEP  Schedu  d, 80% load to  Schedu  Schedu  Schedu  Schedu	Ile People - S 200 B space Ile Lights - Sc	d Template	• •	Apply Close New Copy Delete Add Global
Internal Load Alternative Description People Type Density Sensible Workstations Density Lighting Type Heat gain Miscellaneou Type Energy Energy meter	Template Alterna Office General ( 250 250 3 1 Recesse 1.1 s loads Std Office 0.5 Electricity	Project ative 1 Diffice Space People Btu/h workstation/person d fluorescent, not vente W/sq ft W/sq ft	S: LOCKEP  Schedu  Catent  Catent  Catent  Schedu  Catent  Schedu  Catent  Schedu  Sc	Ile People - S 200 B space Ile Lights - Sc	d Template	• •	Apply Close New Copy Delete Add Global

Figure A6: Office Load Template

Internal Load T	emplates	s - Project				×
Alternative Description	Alterna Storage	itive 1 e	• •			Apply
People Type [ Density [ Sensible ] Workstations Density [ Lighting	None 0 0 1 0 1 1 1 1 1	People    Btu/h  workstation/person	Schedule People - Latent 0	School Btu/h	•	New Copy Delete Add Global
Type	Recessed	d fluorescent, not vented, 8	30% load to space		•	
Heat gain	0.3	W/sq.ft  ▼	Schedule Lights - S	chool	•	
Miscellaneous	loads					
Type Energy Energy meter	None 0 /	W/sq ft _▼	Schedule Misc · Mi	ddle School	•	
Internal L	.oad	Airflow	<u>I</u> hermostat	Construction		<u>R</u> oom
		Figure A	7: Storage Load	Template		

Airflow Templat	es - Proj	ect				×
Alternative Description	Alternat	ive 1	•			Apply Close
Main supply Cooling		To be calculated 💌	Auxiliary supp Cooling	ly To be calculated _▼	]	New
Heating		To be calculated 💌	Heating	To be calculated -		С <u>о</u> ру
Ventilation			Std 62.1-2004	/2007	_	<u>D</u> elete
Apply ASHF	RAE Std62	2.1-2004/2007 No 💌	Clg Ez FI	loor clg supply, ceiling return 💌	%	Add Global
Туре	None	-	Htg Ez 🛛 FI	loor htg supply, ceiling returr 💌	%	
Cooling	0	cfm 👻	Er D	efault based on system type 💌	%	
Heating	0	cfm 🗨	DCV Min I	OA Intake None	-	
Schedule	Availab	le (100%) 🔹	Room exhaus	st		
Infiltration			Rate	0 air changes/hr 💌	]	
Туре	Pressuri	ized, Poor Const. 🛛 💌	Schedule	Available (100%)	I	
Cooling	0.5	air changes/hr 🔹	VAV minimum	ì		
Heating	0.5	air changes/hr 🔹	Rate	📃 🛛 🗶 Clg Airflow 💌	]	
Schedule	Availabl	le (100%) 🔹	Schedule	Available (100%)	]	
			Туре	Default		
Internal Lo	ad	Airflow	<u>T</u> hermostal	t <u>C</u> onstruction		<u>R</u> oom

Figure A8: Default Airflow Template

# Technical Report 2 10/27/2010

Thermostat Tem	plates -	Project						×
Alternative	Alterna	tive 1		•				Apply
Description	Default			<b>T</b>				
Thermostat sett	ings							
Cooling dry b	bulb	78	۴					New
Heating dry I	bulb	72	۴F					Сору
Relative hun	nidity	50	%					<u>D</u> elete
Cooling driftp	point	81	۴F					Add <u>G</u> lobal
Heating drift	point	64	۴					
Cooling sche	edule	None				•		
Heating sch	edule	None				-		
Sensor Location	าร							
Thermostat		Room				•		
CO2 sensor		None				•		
Humidity								
Moisture cap	pacitance	* Medium	n			•		
Humidistat lo	cation	Room				•		
Internal Loa	bt		<u>A</u> irflow	<u>T</u> hermos	tat	<u>C</u> onstructi	on	<u>R</u> oom

Figure A9: Default Thermostat Template

Construction Templates - Project					
Alternative Description	Alternative 1 Default	•			
Construction Slab 4'	, LW Concrete	•	U-factor Btu/h·ft**F 0.212615		<u>N</u> ew <u>Co</u> py
Hoor 4	'LW Conc	<u> </u>	0.213535		<u>D</u> elete
Partition 0.	75'' Gyp Frame		0.387955		Add <u>G</u> lobal
Glass type Window Si Skylight Si Door Si	ngle Clear 1/8'' ngle Clear 1/4'' andard Door	• • •	U-factor Btu/h:ft <sup>e.</sup> *F 1.04 0.95 0.2	Shading coeff 1 0.95 0	
Height Wall 10 Fir to fir 10 Plenum 2	ft ft ft	Pct wall area to underfloor plenum Room type	Conditioned	*	
Internal Lo	ad <u>A</u> irflow		ostat	Construction	<u>R</u> oom

Figure A10: Default Construction Template