

Glen Burnie High School Glen Burnie, MD

- II. Existing Mechanical System
- **III.** Proposed System Alterations
- **IV. CM Breadth**
- V. Conclusion
- VI. Acknowledgements

Glen Burnie High School Glen Burnie, MD

School Background

▷ 6 building; campus style high school ▷ Located in Glen Burnie, MD \triangleright Construction of first building started in 1934 ▷ Junior High School absorbed by campus in 1955 \triangleright Latest building added in 1976





Glen Burnie High School Crest

Glen Burnie High School Glen Burnie, MD

- Building Breakdown
- ➢ Building A: Media Building
- Building B: Industrial Arts Building
- ➢ Building C: Administration Building
- Building F: Business Building/ Secondary Gymnasium





Building A

Glen Burnie High School Glen Burnie, MD

- Building Breakdown
- ➢ Building A: Media Building
- ➢ Building B: Industrial Arts Building
- ➢ Building C: Administration Building
- Building F: Business Building/ Secondary Gymnasium





Building B

Glen Burnie High School Glen Burnie, MD

- Building Breakdown
- ➢ Building A: Media Building
- ➢ Building B: Industrial Arts Building
- ➢ Building C: Administration Building
- Building F: Business Building/ Secondary Gymnasium





Glen Burnie High School Glen Burnie, MD

- Building Breakdown
- ➢ Building A: Media Building
- ➢ Building B: Industrial Arts Building
- ➢ Building C: Administration Building
- ➢ Building F: Business Building/ Secondary Gymnasium





Glen Burnie High School Glen Burnie, MD

- Building Breakdown
- Building A: Media Building
- Building B: Industrial Arts Building
- ➢ Building C: Administration Building
- ➢ Building F: Business Building/ Secondary Gymnasium





Building F

Glen Burnie High School Glen Burnie, MD

- Building Breakdown
- Building A: Media Building
- ➢ Building B: Industrial Arts Building
- ➢ Building C: Administration Building
- Building F: Business Building/ Secondary Gymnasium

Wade Myers **Mechanical Option**



Glen Burnie High School Campus



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications





Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers Mechanical Option



Building E Ground Floor



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers **Mechanical Option**



Building E Ground Floor



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers **Mechanical Option**



Building E Ground Floor



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers **Mechanical Option**





Building E First Floor



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers Mechanical Option





Building E First Floor



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers Mechanical Option



Building E Second Floor



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers **Mechanical Option**

Mechanical Rooms





Building E Second Floor



Building E

Glen Burnie High School Glen Burnie, MD

Building Specifications

Wade Myers Mechanical Option



Building E Second Floor



Glen Burnie High School Glen Burnie, MD

Project Specifications			
Building Occupant	Anne Arundel County Public Schools		
Occupancy Type	Education—High School		
Size	110,000 Square Feet		
Number of Stories	3		
Project Team	Owner: Anne Arundel County Public Schools		
	Architect: JRS Architects		
	Mechanical & Electrical Engineer: JMT		
	Civil & Structural Engineer: Carroll Engineering		
	General Contractor: RWC Contracting		
	Mechanical Contractor: Chilmar		
Construction Dates	May 2010—August 2011		
Renovation Costs	\$6,000,000		
Project Delivery	Design-Bid-Build		

Wade Myers Mechanical Option



Building E Front

I. Introduction

- **III.** Proposed System Alterations
- **IV. CM Breadth**
- V. Conclusion
- VI. Acknowledgements

- ➢ Constant air volume system ▷ 9 Steam AHUs serve the building – No Cooling ➢ Gymnastics area served by own steam unit ventilator ▶ Extra heating in gymnasium by finned tube radiation ➢ Auxiliary heating supplied by convectors & CUHs ▷ Steam supplied by boilers in Building F

Glen Burnie High School Glen Burnie, MD

Existing Mechanical System

Wade Myers Mechanical Option

Building E Airflow Rates						
System	Service	Design Airflow (CFM)	Outdoor Air (CFM)	% O A		
AHU-1	Men's Lockers	2000	2000	100		
AHU-2	Team Rooms	2800	2800	100		
AHU-3	Women's Lockers	2000	2000	100		
AHU-4&5	Gymnasium	14400	6000	42		
AHU-6	Laundry Room	2500	2500	100		
AHU-7	Lobby	1300	350	26.9		
AHU-8	Wrestling Room	900	100	11.1		
AHU-9	Weight Room	1300	1300	100		
UV-1	Gymnastics Area	2000	550	27.5		
TOTAL		29200	17600	60.3		

Building E Airflow Rates

Building E Load Summary

System	Service	Cooling (Ton)	Heating (MBH)
AHU-1	Men's Lockers	5.7	101
AHU-2	Team Rooms	16.7	203.1
AHU-3	Women's Lockers	7.9	91.6
AHU-4&5	Gymnasium	84.4	696.8
AHU-6	Laundry Room	5	14.2
AHU-7	Lobby	4.2	80.4
AHU-8	Wrestling Room	3.5	72.9
AHU-9	Weight Room	7	93.1
UV-1 Gymnastics Area		6.4	164
1	TOTAL	140.8	1517.1

Building E Load Summary

▷ Chiller and enclosure added to serve Building E only ➢ Replace AHU's, unit ventilator, CUHs & convectors Energy recovery ventilating units added to 3 AHUs Install new chilled and heating water pipes ➢ Water/Glycol and Steam/Water Heat exchangers added ▷ Pumps added/replaced

Glen Burnie High School Glen Burnie, MD

Existing Mechanical System - Renovation



Wade Myers Mechanical Option

Ground Floor Mechanical Drawing

Introduction

II. Existing Mechanical System

- **IV. CM Breadth**
- V. Conclusion
- VI. Acknowledgements

- ➢ Monetary savings

Glen Burnie High School Glen Burnie, MD

Ground Source Heat Pump System

➢ Increasingly popular institutional option ➢ Abundance of usable ground on site ➢ Minimize or eliminate mechanical equipment ➢ Reduce energy use of the building

> Wade Myers Mechanical Option



Typical Vertical Ground Source Heat Pump System



Geologic Map of Maryland

Glen Burnie High School

Glen Burnie, MD

Site Ground Analysis



above quartz sandstone Sandstone used

Geologic Map of Glen Burnie, MD

Glen Burnie High School Glen Burnie, MD

Site Ground Analysis

- ▷ 7' of Patapsco-Fort-Mott-Urban Land Complex soil
- ▷ ASHRAE values for Heavy Sand, 5% Water and
- ➢ Ground Temperature of 57°F

GSHP System Ground Properties						
Туре	Material	Density (lb/CF)	Conductivity (BTU/h-ft-ºF)	Diffusivity (SF/Day)		
Soil	Heavy Sand, 5% Water	120	1.2 – 1.9	1.0 – 1.5		
Rock	Sandstone		1.2 – 2.0	0.7 – 1.2		
Grout	15% Bennonite/85% SiO ₂ Sand		1.0 – 1.1			

Wade Myers Mechanical Option

GSHP System Ground Properties



Athletic fields used for bores ▶ 23.6 acres = 1,023,016 SF available ➢ Bores placed close to building – Reduce extra piping

Glen Burnie High School Site Plan

Glen Burnie High School Glen Burnie, MD

Ground Source Heat Pump System

Wade Myers Mechanical Option

Where:

F_{sc}= short circuit heat loss factor $L_c = required bore length for cooling, ft$ PLF_m= part load factor during design month q_a= net annual average heat transfer to ground, Btu/h q_{lc}= building design cooling block load, Btu/h R_{ga}= effective thermal resistance of ground (annual pulse), h-ft-°F/Btu R_{ad}= effective thermal resistance of ground (daily pulse) , h-ft-°F/Btu R_{am}= effective thermal resistance of ground (monthly pulse) , h-ft-°F/Btu $R_{p} = thermal resistance of pipe and borehole, h-ft-°F/Btu$ $t_{\alpha} = undistributed ground temperature, °F$ $t_{n} = temperature penalty for interference of adjacent bores, °F$ I_{wi} = liquid temperature at heat pump inlet, °F t_{wo} = liquid temperature at heat pump at outlet, °F W_c= power input at design cooling load, Btu/h

Required Cooling Bore Length Equation



 \geqslant 27,246 feet of bores ➢ Reverse return piping

Typical Reverse-Return Piping

Glen Burnie High School Glen Burnie, MD

- Ground Source Heat Pump System
- ▶ 100 bores at 275 feet deep ▶ 10 x 10 grid layout; 20 foot spacing





Building E NEW Load Summary

System	Service	Cooling (Ton)	Heating (MBH)
AHU-1	Men's Lockers	3.7	61.8
AHU-2	Team Rooms	13.7	160.1
AHU-3	Women's Lockers	4.5	56
AHU-4&5	Gymnasium	80.1	394.9
AHU-6	Laundry Room	3.2	12.8
AHU-7	Lobby	1.7	28.3
AHU-8	Wrestling Room	2.7	32.8
AHU-9	Weight Room	3.3	57.3
UV-1 Gymnastics Area		7.5	95.1
1	TOTAL	120.4	899.7

Building E NEW Load Summary

➢ System sized for 105 tons ➢ Grid divided into 3 sections, each with own pump ▷ Pumps feature full redundancy ➢ Main header branches into sub-headers for each section Heat exchanger to cool chilled water

Glen Burnie High School Glen Burnie, MD

Ground Source Heat Pump System





GSHP Pumping & Piping Schematic

Gl

Grour

▷ Chiller reduce ▷ Chilled wate ▷ Cost savings ▶ 8 new pump

Building E Energy Reduction					
Cooling (kBTU/yr)		Heating (kBTU/yr)			
Before	After	Before	After		
174,210	47,163	1,056,069	644,483		

Building E Energy Reduction

en Burnie High School _{Glen Burnie, MD}
nd Source Heat Pump System
iced from 155 tons to 20 tons er pumps replaced s of \$71,470 iger added to system for ground loop ps added to the system; full redundancy

GSHP System Pump Schedule									
Design	ation		Model		Flow Rate (GPM)	To (1	tal He FT H ₂ C	ad))	RPM
GWI	P-1	Bell & Gos	sett Series	1531	. 126		80		1750
GWI	P-2	Bell & Gos	sett Series	1531	94.5		70		1750
GWI	P-3	Bell & Gos	sett Series	1531	94.5		75		1750
CHW	'P-1	Bell & Gos	sett Series	1531	. 360		65		1750
GSHP System New Chiller									
Desig.	N	lodel	Capacity (Tons)	EER	Ambient Te	mp.	EWT	ELT	Elec.
CH-1	Trane	CGAM 20	18.9	9.9	95∘F		50°F	40°F	460/3

Wade Myers Mechanical Option

New Pump & Chiller Schedules

I. Introduction

- II. Existing Mechanical System
- **III.** Proposed System Alterations

IV.CM Breadth

- I. Conclusion
- II. Acknowledgements

➢ Analyze schedule changes associated with alterations ➢ Determine potential monetary savings or added costs ▷ Calculate system payback periods

Glen Burnie High School Glen Burnie, MD

CM Breadth

GSHP System Schedule Variables

Component	Time	Amount	Total
Bores	1,000 L.F./Day	27,246 L.F.	28 Days
Piping	1,000 L.F./Day	27,246 L.F.	28 Days
Grout	1,000 L.F./Day	27,246 L.F.	28 Days
Pumps	1.5 Units/Day	8 Units	6 Days
Heat Exchanger	1 Unit/Day	1 Unit	1 Day

Window Renovation Schedule Variables

Component	Time	Amount	Total
Demo Existing Windows	200 S.F./Day	2,200 S.F.	12 Days
Install New Windows	90 S.F./Day	2,572.5 S.F.	29 Days

System Alteration Schedule Variables

len Burnie High School Glen Burnie, MD

Schedule

 \triangleright Changes to the schedule duration are minimal ➢ No interference by GSHP earthwork Window renovation long, but has no foreseen effects ➢ Chiller installation takes place of previous chiller ▷ Large time window for mechanical room installations



1Drill Ground Bores28 daysMon 5/3/10Wed2Install Ground Loop Piping28 daysTue 5/4/10Thu3Grout Boreholes28 daysWed 5/5/10Fri 6,4Install Headers17 daysThu 5/6/10Fri 5,5Install Pumps6 daysMon 5/17/10Mon6Install Heat Exchanger1 dayTue 5/25/10Tue 5/25/107Demo Existing Windows12 daysMon 5/3/10Tue 5/28Install New Windows29 daysTue 5/4/10Fri 6,av 2, '10May 9, '10May 16, '10May 23, '10May 30, '106Install New Windows10May 23, '10May 30, '107Install New Windows10May 23, '10May 30, '108Install New Windows29 daysTue 5/4/10Fri 6,9Install New Windows10May 23, '10May 30, '109Install New Windows10Install New TFSS MIT WIT FSS MI		Task Name	- Duration	Ŧ	Start 🚽	Finish 💂	Predecessors 🖕 🖡	R
2 Install Ground Loop Piping 28 days Tue 5/4/10 Thu 1 3 Grout Boreholes 28 days Wed 5/5/10 Fri 6, 4 Install Headers 17 days Thu 5/6/10 Fri 5, 5 Install Pumps 6 days Mon 5/17/10 Mon 6 Install Heat Exchanger 1 day Tue 5/25/10 Tue 5/ 7 Demo Existing Windows 12 days Mon 5/3/10 Tue 5/ 8 Install New Windows 29 days Tue 5/4/10 Fri 6, ay 2 '10 May 9, '10 May 16, '10 May 23, '10 May 30, '2 6 M T W T F S S M T W T F S S M T W T F S S M T W T F S S M T W T F S S M S M T W T F S S M T	1	Drill Ground Bores	28 days		Mon 5/3/10	Wed 6/9/10		
3 Grout Boreholes 28 days Wed 5/5/10 Fri 6, 4 Install Headers 17 days Thu 5/6/10 Fri 5, 5 Install Pumps 6 days Mon 5/17/10 Mon 6 Install Heat Exchanger 1 day Tue 5/25/10 Tue 2 7 Demo Existing Windows 12 days Mon 5/3/10 Tue 2 8 Install New Windows 29 days Tue 5/4/10 Fri 6, av 2, '10 May 9, '10 May 16, '10 May 23, '10 May 30,'2 1 M T W T F S S M T	2	Install Ground Loop Piping	28 days		Tue 5/4/10	Thu 6/10/10	1SS+1 day	
4 Install Headers 17 days Thu 5/6/10 Fri 5, 5 Install Pumps 6 days Mon 5/17/10 Mon 6 Install Heat Exchanger 1 day Tue 5/25/10 Tue 5/25/10 7 Demo Existing Windows 12 days Mon 5/3/10 Tue 5/ 8 Install New Windows 29 days Tue 5/4/10 Fri 6, ay 2, '10 May 9, '10 May 16, '10 May 23, '10 May 30, '5 5 M T W T F S S M T W T F S S M T W T F S S M T W T F S S M S M T W T F S S M T W T F S S M T W T F S S M T W T F S S M S M T W T F S	3	Grout Boreholes	28 days		Wed 5/5/10	Fri 6/11/10	2SS+1 day	
5 Install Pumps 6 days Mon 5/17/10 Mon 6 Install Heat Exchanger 1 day Tue 5/25/10 Tue 5/25/10 7 Demo Existing Windows 12 days Mon 5/3/10 Tue 5/25/10 8 Install New Windows 29 days Tue 5/4/10 Fri 6, ay 2, '10 May 9, '10 May 16, '10 May 23, '10 May 30, '5 5 M T W T F S S M T W T F S S M T W T F S S M T W T F S S M T W T F S S M S M T W T F S S M T W T F	4	Install Headers	17 days		Thu 5/6/10	Fri 5/28/10	3SS+1 day	
6 Install Heat Exchanger 1 day Tue 5/25/10 Tue 5/25/10 7 Demo Existing Windows 12 days Mon 5/3/10 Tue 5/25/10 8 Install New Windows 29 days Tue 5/4/10 Fri 6, ay 2, '10 May 9, '10 May 16, '10 May 23, '10 May 30, '5 5 M T W T F S S M T W T F S S 6 Install New Windows Image: State	5	Install Pumps	6 days		Mon 5/17/10	Mon 5/24/10		
7 Demo Existing Windows 12 days Mon 5/3/10 Tue 5/3/10 8 Install New Windows 29 days Tue 5/4/10 Fri 6, ay 2, '10 May 9, '10 May 16, '10 May 23, '10 May 30,' 5 M T W T F S M T W T F S M	6	Install Heat Exchanger	1 day		Tue 5/25/10	Tue 5/25/10	5	
8 Install New Windows 29 days Tue 5/4/10 Fri 6, Iay 2, '10 May 9, '10 May 16, '10 May 23, '10 May 30, ' 5 M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S M T W T F S	7	Demo Existing Windows	12 days		Mon 5/3/10	Tue 5/18/10		
lay 2, '10 May 9, '10 May 16, '10 May 23, '10 May 30, ' M T W T F S S M T W T F S S M T W T F S S M T W T F S S M	8	Install New Windows	29 days		Tue 5/4/10	Fri 6/11/10	7SS+1 day	
	ay 2, '10 5 M T	Μαγ9,'10 Μαγ1 W T F S S M T W T F S S M	.6, '10 M T W T F	M S S	ay 23, '10 M T W T F S	May 30, '10 S M T W T F	Jun 6, '10 S S M T W T F S	3

Building E Renovation Schedule

J	l	ļ	Ì	

GSHP System Cost			
Component	Cost (\$)		
Bores	47,408		
Piping	37,950		
Grout	5,995		
Pumps	38,390		
Heat Exchanger	3,000		
Removed Equipment Cost Savings	-71,470		
TOTAL	51,273		

Window Renovation Cost			
Component	Cost (\$)		
Demo Existing Windows	2,354		
Install New Windows	48,492		
TOTAL	50,846		

System Alteration Cost Schedules

 \triangleright GSHP cost of \$51,273

len Burnie High School

Glen Burnie, MD

Cost

- Original renovation cost of \$6,000,000
- ▷ Removed equipment savings included in GSHP ➢ Window renovation cost of \$50,846
- ➢ New Total Cost = \$6,102,119

GSHP System Cost		
Component	Cost (\$)	
Bores	47,408	
Piping	37,950	
Grout	5,995	
Pumps	38,390	
Heat Exchanger	3,000	
Removed Equipment Cost Savings	-71,470	
TOTAL	51,273	

	ų

➢ Total Cost = \$51,273 ➢ Savings = \$3,012.36

Window Renovation Cost			
Component	Cost (\$)		
Demo Existing Windows	2,354		
Install New Windows	48,492		
TOTAL	50,846		

System Alteration Cost Schedules

len Burnie High School Glen Burnie, MD

- Simple Payback Analysis GSHP
- ➢ Simple Payback = 17.1 Years

GSHP System Cost		
Component	Cost (\$)	
Bores	47,408	
Piping	37,950	
Grout	5,995	
Pumps	38,390	
Heat Exchanger	3,000	
Removed Equipment Cost Savings	-71,470	
TOTAL	51,273	

J	

➢ Total Cost = \$50,846 ➢ Savings = \$5,261.35

Window Renovation Cost		
Component	Cost (\$)	
Demo Existing Windows	2,354	
Install New Windows	48,492	
TOTAL	50,846	

System Alteration Cost Schedules

len Burnie High School Glen Burnie, MD

- Simple Payback Analysis Windows
- ➢ Simple Payback = 9.7 Years

GSHP System Cost		
Component	Cost (\$)	
Bores	47,408	
Piping	37,950	
Grout	5,995	
Pumps	38,390	
Heat Exchanger	3,000	
Removed Equipment Cost Savings	-71,470	
TOTAL	51,273	

\mathbf{C}	

➢ Total Cost = \$102,119 ➢ Savings = \$8,273.71

Window Renovation Cost		
Component	Cost (\$)	
Demo Existing Windows	2,354	
Install New Windows	48,492	
TOTAL	50,846	

System Alteration Cost Schedules

len Burnie High School Glen Burnie, MD

- Simple Payback Analysis Combined
- ➢ Simple Payback = 12.3 Years

Introduction

- **II.** Existing Mechanical System
- **III.** Proposed System Alterations
- **IV. CM Breadth**

VI. Acknowledgements

- ▷ GSHP system and window renovation have roughly the same first costs at \$51,273 & \$50,846, respectively. GSHP system's energy savings leads to a payback period of 17.1 years.

- ➢ Window renovation's energy savings leads to a payback period of 9.7 years.
- ▶ Recommend combining both alterations to maximize savings and average the payback period.

Glen Burnie High School Glen Burnie, MD

Conclusion

Wade Myers Mechanical Option



Building E Front

Introduction

- II. Existing Mechanical System
- **III. Proposed System Alterations**
- **IV. CM Breadth**
- V. Conclusion

Glen Burnie High School Glen Burnie, MD

Acknowledgements

- ➢ Sam Kulceski, and the rest of the design team at JMT who worked on Glen Burnie High School. ▷ AACPS for their permission to use their buildings. \triangleright My thesis advisor, Dr. Bahnfleth.
- ▷ The Penn State AE faculty for all of their help and support throughout my education.
- \triangleright My fellow 5th year classmates.

Wade Myers Mechanical Option



Building E Front

Glen Burnie High School Glen Burnie, MD







Original windows replaced with better performing units ▷ New windows added to façade ➢ Modern architecture \triangleright Match existing

Building E Front Before

Glen Burnie High School Glen Burnie, MD

Architectural Breadth

Window Replacement Load Changes			
Area	Load Before (tons)	Load After (tons)	
Building E	140.8	120.4	

Wade Myers **Mechanical Option**



Building E Front After



Building E Rear Before

Glen Burnie High School Glen Burnie, MD

Architectural Breadth





Building E Rear After



➢ Glazing added to southern wall ▷ Ambient light to gymnastics area ► Increases thermal load on area

Building E South Façade Before

Glen Burnie High School Glen Burnie, MD

Architectural Breadth

Window Replacement Load Changes			
Area	Load Before (tons)	Load After (tons)	
Gymnastics Area	6.4	7.5	



Wade Myers Mechanical Option

Building E South Façade After



Building E Gymnastics Area Before

Glen Burnie High School Glen Burnie, MD

Architectural Breadth





Building E East Façade Before

Building E West Façade Before



▷ Upgrades façade

Glen Burnie High School Glen Burnie, MD

Architectural Breadth

- ▷ Original windows replaced with single unit ➢ Increases ambient light to space
- Decreases thermal load on area

Window Replacement Load Changes

Area	Load Before (tons)	Load After (tons)
Gymnasium	84.4	80.1

Wade Myers Mechanical Option



Building E East Façade After

Building E West Façade After





Building E Gymnasium West Before

Glen Burnie, MD

Architectural Breadth





Glen Burnie High School Glen Burnie, MD

Architectural Breadth



