

The Edward St. John Student Center



Zachary Haupt

Faculty Advisor: Dr. William Bahnfleth
11 April 2011

Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Enthalpy Wheel
- Solarban 70XL Glass
- System Comparison
- Final Recommendations



Presentation Outline

- **Project Background**
- **Existing Mechanical Summary**
- **Design Objectives**
- **Alternative Descriptions**
- **Ground Source Heat Pumps**
- **Enthalpy Wheel**
- **Solarban 70XL Glass**
- **System Comparison**
- **Final Recommendations**



Project Information:


Delivery Method - Design-Bid-Build
Operational Date - September 2012
Occupancy - K-12 Boarding School
Size - 68,000 SF
Cost - \$16,000,000

Primary Project Team:

Owner - McDonogh School
Architect - Bowie Gridley Architects
Civil Engineer - Matis Warfield
MEP Engineer - James Posey Associates, Inc
Structural Engineer - Linton Engineers, LLC

Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Enthalpy Wheel
- Solarban 70XL Glass
- System Comparison
- Final Recommendations



Mechanical System:

- 8 indoor AHUs
 - 7 VAV units
 - 5 single zone VAV units
 - 2 multizone VAV units
 - 1 single zone CAV unit


Central Plant:

- Located on campus
- 3 Boilers
- 2 Chillers

Building Layout

Lower Level


- AHU – 3 Serves Lecture Hall
- AHU – 4 Serves Dance Studio
- AHU – 5 Serves LS Dining
- AHU – 1 Serves Lower & Quad Levels



Building Layout

Quad Level


- AHU 6 & 7 Serve US Dining
- AHU - 2 Serves Senior Dining
- AHU - 1 Serves Lower & Quad Levels



Building Layout

Upper Level

- AHU – 8 Serves Entire Floor



Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Enthalpy Wheel
- Solarban 70XL Glass
- System Comparison
- Final Recommendations



Improve System Performance

- Energy Consumption
- Emissions
- Total System Costs
- Minimize Payback Periods

Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- **Alternative Descriptions**
- **Ground Source Heat Pumps**
- **Enthalpy Wheel**
- **Solarban 70XL Glass**
- **System Comparison**
- **Final Recommendations**

Ground Source Heat Pumps

The Good

- ✓ Higher System Efficiencies
- ✓ Lower Carbon Footprint and Gas Emissions
- ✓ Decentralized systems
- ✓ Low Maintenance and Cleaning Choices
- ✓ Low Air Pressure Drop


Ground Source Heat Pumps

The Bad

- ❑ Increased Construction Costs
- ❑ Increased Seismic and Weighting AHU
- ❑ Impact of Loop on Ecosystem

Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- **Ground Source Heat Pumps**
- Enthalpy Wheel
- Solarban 70XL Glass
- System Comparison
- Final Recommendations



Implementing a GSHP

- Site Geology Study
- Calculations
- Pipe Sizing
- Pump & System Layout
- Results


Implementing a GSHP

- Site Geology Study
- Calculations
- Pipe Sizing
- Pump & System Layout
- Results



Located in Baltimore County

- Precambrian Soil Type
- 15% Water and Sandstone
- Soil Resistivity $\approx 0.6 \text{ BTU/hr} \cdot \text{ft} \cdot ^\circ\text{F}$



Implementing a GSHP

- Site Geology Study
- Calculations
- Pipe Sizing
- Pump & System Layout
- Results

Project: St. John Student Center			
Job Number:			
Date: 04/04/11			
User: Haupt			
INPUT DATA			
Total Building Load (Ton)=	247.4	Bldg Area	68000 Sq Ft
Outdoor Design Temp. (°F)=	95	Sq. Ft / Ton	275
Indoor Design Temp. (°F)=	75		
Balance Temp. (°F)=	65		

- Cooling Length

$$L_c = \frac{q_c R_a + (q_{lc} - 3.41 W_c)(R_b + PLF_m R_m + R_{gm} + R_{gd} F_{sc})}{t_g - \frac{t_{wi} - t_{wo}}{2} - t_p}$$


- Heating Length

$$L_c = \frac{q_c R_a + (q_{lc} - 3.41 W_c)(R_b + PLF_m R_m + R_{gm} + R_{gd} F_{sc})}{t_g - \frac{t_{wi} - t_{wo}}{2} - t_p}$$

90/95	333.99	8.11	nd Loop Heat Exchanger Length(Ft/Ton)=	201.71
85/90	272.14	15.42	Total Ground Loop Length=	49904.02
80/85	210.29	75.77		
75/80	148.44	58.90		
70/75	86.59	43.82	Bores Required: Depth (Ft) Number	
65/70	24.74	14.02	400	125
		216.05	375	133
			350	143
			325	154
			300	166
			250	200
			200	250
			600	83

McClure Company Spreadsheet & ASHRAE

- Vertical Loop Analysis
- Used to Determine # of Bores + Depths
- Cross Checked With ASHRAE



Implementing a GSHP

- Site Geology Study
- Calculations
- Pipe Sizing
- Pump & System Layout
- Results

Selected Pump Model


Manufacturer	Model	TC (MBtuh)	Power (kW)	THR (MBtuh)	LWT	EER
Carrier	50PSW360	313	16.08	367.9	61.1	19.5

Bores Per Pump

- 750 Total GPM – 125 Total Bores
- 6 GPM Per Bore


Cost Of Pipe

Pipe Size	Length Of Pipe	Cost Of Pipe/Ft	Cost Of Pipe
3	64000	\$ 0.033	\$2,112
2	16000	\$ 0.0275	\$440
1.5	8000	\$ 0.0165	\$132
1.25	16000	\$ 0.0125	\$200
			\$2,884




Implementing a GSHP

- Site Geology Study
- Calculations
- Pipe Sizing
- Pump & System Layout
- Results



Layout of System


- 5 Pumps
 - Each Pump Serves 12 Bores
- 5 Pumps
 - Each Pump Serves 13 Bores



Implementing a GSHP


- Site Geology Study
- Calculations
- Pipe Sizing
- Pump & System Layout
- Results

Annual Energy Consumption (Existing vs. GSHP)




Energy Savings

- 5.7 % Annual Heating Savings
- 12.4 % Annual Cooling Savings
- 9.9 % Total Annual Energy Savings



Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- **Enthalpy Wheel**
- Solarban 70XL Glass
- System Comparison
- Final Recommendations



Selecting a Wheel

- Determine supply air total flow (CFM)
- Use SEMCO wheel chart
 - Keep face velocity ≈ 800 (FPM)
- Calculate unit effectiveness
- Results


Selecting a Wheel

- Determine supply air total flow (CFM)
- Use SEMCO wheel chart
 - Keep face velocity ≈ 800 (FPM)
- Calculate unit effectiveness
- Results



AHU - 8

- Serves art classrooms
- Scheduled at 15,000 CFM




A diagram of a rotary heat exchanger, or "heat wheel" (From Uptime Technology BV)

Selecting a Wheel


- Determine supply air total flow (CFM)
- Use SEMCO wheel chart
 - Keep face velocity \approx 800 (FPM)
- Calculate unit effectiveness
- Results

TOTAL ENERGY RECOVERY WHEEL SIZE



AHU - 8

- Find desired CFM
- Read directly right until model intersection (closest to 800 FPM)
- Mark model # down
- Read directly down to find associated pressure loss



A diagram of a rotary heat exchanger, or "heat wheel" (From Uptime Technology BV)

Selecting a Wheel

- Determine supply air total flow (CFM)
- Use SEMCO wheel chart
 - Keep face velocity ≈ 800 (FPM)
- Calculate unit effectiveness
- Results

The exchanger heat transfer effectiveness e is defined as the amount of energy recovered, e.g. sensible or latent, divided by the maximum amount of energy that could theoretically be recovered.

The supply air volume heat transfer effectiveness e_s is defined as

$$e_s = \frac{V_s (X_1 - X_2)}{V_{\min} (X_1 - X_3)}$$

The return air volume heat transfer effectiveness e_r is defined as

$$e_r = \frac{V_r (X_4 - X_3)}{V_{\min} (X_1 - X_3)}$$

Based on the above definitions, the supply air condition X_2 can be calculated from

$$X_2 = X_1 - e_s \frac{V_{\min}}{V_s} (X_1 - X_3)$$

and the exhaust air condition X_3 can be calculated from

$$X_4 = X_3 + e_r \frac{V_{\min}}{V_r} (X_1 - X_3)$$

where V_s = Supply air volume, scfm

V_r = Return air volume, scfm

$V_{\min} = V_r$ if V_r is smaller than V_s or $V_{\min} = V_s$ if V_s is smaller than V_r

X = dry bulb temperature ($^{\circ}$ F) or moisture content (gr/lb) or enthalpy (Btu/lb)

The indices refer to the following airstreams, as indicated in the figure below:

1 = Outdoor air condition


2 = Supply air condition

3 = Return air condition

4 = Exhaust air condition

AHU - 8

- Use calculations to determine unit effectiveness
- $\approx 80\%$ Good




A diagram of a rotary heat exchanger, or "heat wheel" (From Uptime Technology BV)

Selecting a Wheel


- Determine supply air total flow (CFM)
- Use SEMCO wheel chart
 - Keep face velocity ≈ 800 (FPM)
- Calculate unit effectiveness
- Results

Annual Energy Consumption (Existing vs. Wheel)



Energy Savings

- 17.0 % Annual Heating Savings
- 3.4 % Annual Cooling Savings
- 8.4 % Total Annual Energy Savings



Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Enthalpy Wheel
- **Structural Breadth**
- Solarban 70XL Glass
- System Comparison
- Final Recommendations



Structural Check

- Calculate lb/ft² for each AHU
- Calculate new lb/ft² for AHU 8
- Check slab strength
 - Adjust accordingly
- Check beam strength
 - Adjust accordingly

Structural Check

- Calculate lb/ft² for each AHU
- Calculate new lb/ft² for AHU 8
- Check slab strength
 - Adjust accordingly
- Check beam strength
 - Adjust accordingly

$$\text{AHU-6] lb/ft}^2 = (4,200)/(5.125)(12) = \boxed{68.3 \text{ lb/ft}^2}$$

↳ Design for 70 lb/ft²
(safety)

$$\text{AHU-7 \& 8] = (7,600)/(8.3)(15) = \boxed{61 \text{ lb/ft}^2}$$

$$\text{AHU - 7} \rightarrow 7,600 \text{ lbs} \quad W=8.3' \quad H=5.6' \quad L=15'$$

$$\text{AHU - 8} \rightarrow 7,600 \text{ lbs} \quad W=8.3' \quad H=5.6' \quad L=15'$$

Calculations

- Locate AHU Schedule
- Mark Weight, Width, & Length of each AHU Located in Room
- Calculate lb/ft² of Each AHU



Structural Check

- Calculate lb/ft² for each AHU
- Calculate new lb/ft² for AHU 8
- Check slab strength
 - Adjust accordingly
- Check beam strength
 - Adjust accordingly

$$\underline{\text{AHU-7 \& 8}} = (7,600)/(8.3)(15) = \boxed{61 \text{ lb/ft}^2}$$

Enthalpy wheel will add 2' in length &
1,300 lbs.

$$\underline{\text{AHU-8 w/ wheel}} \text{ lb/ft}^2 = (8,900\text{lb})/(8.3')(17') = \boxed{63.1 \text{ lb/ft}^2}$$

↳ 65 lb/ft²
(safety)

Calculations

- AHU 6 Dropped
- Wheel Adds
 - 2' in Length
 - 1,300 lbs



Structural Check

- Calculate lb/ft² for each AHU
- Calculate new lb/ft² for AHU 8
- Check slab strength
 - Adjust accordingly
- Check beam strength
 - Adjust accordingly

Structural Breadth Final Report

ASCE 7-10

Slab Check

$$F_y = 60$$

$$f_c = 5000 \text{ psi}$$

$$\text{live load} = 40 \text{ lb/ft}^2$$

$$\text{Slab load} = 87.5 \text{ lb/ft}^2$$

$$\text{AHU-8} = 63.1 \text{ lb/ft}^2$$

$$\text{Load} = 1.2(D) + 1.6(L) \Rightarrow (65 + 87.5)(1.2) + (40)(1.6) = 247 \text{ lb/ft}$$

$$\#5 @ 14" \text{ O.C.} \quad \updownarrow 14" \quad (247 \text{ lb/ft}) \left(\frac{14}{12} \right) = 288 \text{ lb/ft}$$

$$\updownarrow \sim 7 - \frac{3}{4} - \frac{1}{2} \cdot \frac{5}{8} = 5.94"$$

$$m = \frac{wL^2}{8} \Rightarrow \frac{(0.288 \text{ klb/ft})(16)^2}{8} = 9.216 \text{ ftk}$$

$$A_s = 0.31 \text{ in}^2 \quad D = 5.94$$

$$a = \frac{A_s \times F_y}{0.85 \times F_c \times b} \Rightarrow \frac{(0.31)(60)}{(0.85)(5)(14)} = 0.3126$$

$$\phi M_n = 0.9(A_s)(F_y)(d - a/2) / 12 = 8.07 \text{ ftk}$$

$$8.07 \text{ ftk} < 9.216 \text{ ftk} \rightarrow \text{Slab fails.}$$

Calculations

- Rebar Spaced Every 14" O.C.
- Slab Fails Under New Load
- Space Rebar Every 12" O.C.
- Recheck Slab



Structural Check

- Calculate lb/ft² for each AHU
- Calculate new lb/ft² for AHU 8
- Check slab strength
 - Adjust accordingly
- Check beam strength
 - Adjust accordingly

Structural Breadth Final Report

Slab Check

Reposition bars every 12" on Center

$$\text{load} = 247 \text{ lb/ft}$$

$$(247 \text{ lb/ft}) \left(\frac{12}{12} \right) = 247 \text{ lb/ft}$$

$$M = \frac{wL^2}{8} = \frac{(.247 \text{ k/ft})(16)^2}{8} = 7.904 \text{ ft-k}$$

$$a = \frac{A_s (F_y)^{60}}{0.85 (F'_c) (b)} \Rightarrow \frac{(0.31)(60)}{(0.85)(5)(12)} = 0.3647$$

$$\phi M_n = 0.9 (A_s) (F_y) (d - a/2) / 12 = 8.031$$

$$\boxed{8.031 \text{ ft-k} > 7.904 \text{ ft-k}}$$

Calculations

- Slab Does Not Fail
- Adjust Rebar Spacing
- Analyze Beam



Structural Check

- Calculate lb/ft² for each AHU
- Calculate new lb/ft² for AHU 8
- Check slab strength
 - Adjust accordingly
- Check beam strength
 - ~~Adjust accordingly~~

[2] DESIGN RESULTS

Top Reinforcement

Units: Width (ft), Mmax (k-ft), Xmax (ft), As (in²), Sp (in)

Span Zone	Width	Mmax	Xmax	AsMin	AsMax	SpReq	AsReq	Bars
1 Left	2.70	105.26	0.833	0.954	14.477	8.933	0.692	4-#7 *3 *5
Middle	2.70	0.00	13.500	0.000	14.477	0.000	0.000	---
Right	2.70	105.26	26.167	0.954	14.477	8.933	0.692	4-#7 *3 *5

NOTES:
 *3 - Design governed by minimum reinforcement.
 *5 - Number of bars governed by maximum allowable spacing.

Top Bar Details

Units: Length (ft)

Span	Left		Continuous		Right	
	Bars	Length	Bars	Length	Bars	Length
1	2-#7	5.45	2-#7	3.67	---	---

Bottom Reinforcement

Units: Width (ft), Mmax (k-ft), Xmax (ft), As (in²), Sp (in)

Span	Width	Mmax	Xmax	AsMin	AsMax	SpReq	AsReq	Bars
1	1.67	309.57	13.500	2.409	44.722	3.600	2.030	5-#7 *3

NOTES:
 *3 - Design governed by minimum reinforcement.

Bottom Bar Details

Units: Start (ft), Length (ft)

Span	Long Bars			Short Bars		
	Bars	Start	Length	Bars	Start	Length
1	5-#7	0.00	27.00	---	---	---

Flexural Capacity

Units: x (ft), As (in²), PhiMn (k-ft)

Span	x	AsTop	AsBot	PhiMn-	PhiMn+
1	0.000	2.40	3.00	-358.73	456.31
	0.833	2.40	3.00	-358.73	456.31
	2.672	2.40	3.00	-358.73	456.31
	3.672	1.20	3.00	-181.65	456.31
	4.445	1.20	3.00	-181.65	456.31
	5.445	0.00	3.00	0.00	456.31
	9.700	0.00	3.00	0.00	456.31
	13.500	0.00	3.00	0.00	456.31
	17.300	0.00	3.00	0.00	456.31
	21.555	0.00	3.00	0.00	456.31
	22.555	1.20	3.00	-181.65	456.31
	23.328	1.20	3.00	-181.65	456.31
	24.328	2.40	3.00	-358.73	456.31
	26.167	2.40	3.00	-358.73	456.31
	27.000	2.40	3.00	-358.73	456.31


Calculations

- Beam Analyzed in spBeam
- Sized Beam Cross Checked With Scheduled Beam
- Scheduled Beam Well Oversized
- Beam Holds New Load



Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Enthalpy Wheel
- **Solarban 70XL Glass**
- System Comparison
- Final Recommendations



Installing Solarban 70XL Glass

- Calculate Total Amount of Glazing
- Calculate Cost of Glazing
- Analyze Glazing Properties
- Results

Installing Solarban 70XL Glass

- Calculate Total Amount of Glazing
- Calculate Cost of Glazing
- Analyze Glazing Properties
- Results

Fenestration Area			
Floor	Glass (SF)	Gross Wall (SF)	Percentage Glass
Lower Level:	736	12992	6
First Floor:	3842	12643	30
Second Floor:	2630	7462	35
Overall Total:	7208	33096	22

Total Glazing

- Review Architectural Drawings



Installing Solarban 70XL Glass

- Calculate Total Amount of Glazing
- Calculate Cost of Glazing
- Analyze Glazing Properties
- Results

Type	Cost/SF	Total SF	Cost
1" clear/clear	\$4.95	7208	\$35,679.60
1" Solarban 60	\$6.45	7208	\$46,491.60
1" Solarban 70 XL	\$7.45	7208	\$53,699.60

Cost

- Multiply Glass SF By \$/SF
- Analyze 3 Types of Glass

	1" Solarban 70 XL	1" Solarban 60	1" clear/clear
1st Floor	\$5,483.20	\$4,747.20	\$3,643.20
2nd Floor	\$28,622.90	\$24,780.90	\$19,017.90
3rd Floor	\$19,593.50	\$16,963.50	\$13,018.50
Total	\$53,699.60	\$46,491.60	\$35,679.60



Installing Solarban 70XL Glass

- Calculate Total Amount of Glazing
- Calculate Cost of Glazing
- Analyze Glazing Properties
- Results

Glass	U-Value	Shading Coefficient
Installed	0.588	0.811
Solarban 60	0.29	0.44
Solarban 70XL	0.26	0.27


Performance

- Installed Values Obtained From Drawings
- Upgraded Values Obtained From PPG Industries



Installing Solarban 70XL Glass

- Calculate Total Amount of Glazing
- Calculate Cost of Glazing
- Analyze Glazing Properties
- Results




Energy Savings


- 6.6 % Annual Heating Savings
- 16.7 % Annual Cooling Savings
- 13 % Total Annual Energy Savings




Presentation Outline



2.5 Year Payback Period




2.5 Year Payback Period



3 Year Payback Period

Presentation Outline

- Project Background
- Existing Mechanical Summary
- Design Objectives
- Alternative Descriptions
- Ground Source Heat Pumps
- Enthalpy Wheel
- Solarban 70XL Glass
- System Comparison
- Final Recommendations



Final Recommendations

- Maximize Distance Between Cost & Payback Period
- Analyze Owner's Intentions
- Make Suggestion



Special Thanks To:

- Justin Bem
- Dr. Bahnfleth
- Penn State AE Mechanical Faculty
- Family & Friends

Questions Or Comments

