

Technical Assignment 1

Kaiser Permanente- Medical Office Building

8008 West Park Drive McLean, VA 22102

Brooke Helgesen

Construction Management

Dr. Messner

September 23, 2011

Table of Contents

Executive Summary	
Project Schedule Summary	3
Building Systems Summary	4
Project Cost Evaluation Summary	11
Site Plans	13
Local Conditions	15
Client Information	18
Project Delivery System	19
Staffing Plan	20
Appendix A- Project Schedule	22
Appendix B- Cost Evaluation	23
Annendix C-Site Plan & Phasing Plans	37

Executive Summary

Exploration of the characteristics of the Kaiser Permanente MOB Project such as sustainability, schedule, cost, site layout and building systems is documented in this report. The project is located in McLean Virginia, right outside of Washington D.C. The scope of work for the project includes the renovation of an existing office building into a medical healthcare building along with the addition of a 75 foot mechanical tower.

This project is tracking points for the Green Guide to Healthcare version 2.0, incorporates sustainability features such as day-lighting with a storefront system and focuses on reducing energy consumption by researching other forms of temporary lighting. During construction sustainable practices such as having a paperless document system, maintaining a sustainable trailer complex and enacting a waste management plan on site were enforced.

The schedule highlighted key milestones and utilized sequencing in order to meet the Kaiser Permanente requirements of the first patient on September 14, 2012. In order to conduct a productive work flow, work progressed from the 5th floor down with a counter-clockwise work flow on each floor. Site layout was imperative to ensuring that not only the mechanical tower addition and existing building were being constructed but also the 8-floor parking garage on the KP site that was being erected simultaneously by Coakley Williams Construction.

The total construction cost for the project was originally \$44, 078, 649 although through many bulletins and change orders, the price increased. One factor that remained stringent was Kaiser Permanente's requirement that first patient date was September 14, 2012 despite the change orders and bulletins. A breakdown of the building system designs utilized in the renovation of the existing building and mechanical tower addition are researched. Also, the expectations of the owner, Kaiser Permanente and the project staff, relationships, and delivery methods employed on this project are explored.

Project Schedule Summary

**Please refer to Appendix A for further Project Schedule documents.

For the Kaiser Permanente project the major flow of work begins with the design phase and creating the BIM model, since BIM was heavily used on this project. The mechanical tower addition construction begins early in March by removing the precast panels on the existing building that share a face with the new mechanical tower. Continuing from March, work will be ongoing on the mechanical tower addition. Simultaneously the interior work on the existing building will begin with the 5th floor MEP rough-in and work down floor by floor through the building. Site work will mobilize early in May. The construction of the 8-story parking garage by Coakley Williams starts in late May and will sequence tasks accordingly throughout the project to allow for ease of work on site. Working down through the building in June and July will be finishes on each floor so that the glass and glazing replacement can begin in early August. Interior wall enclosure will be a crucial task so that inspections can be scheduled and the punch lists for each floor can be complete. Permanent power is available at the end of September so that temporary power sources may be removed. Commissioning is necessary before the first patient so KP and DPR will need to first complete their final inspection March 2, 2012. This will allow for substantial completion and occupancy of the building to be met by March 15, 2012. With this substantial completion date, it will allow for commissioning, testing and the Kaiser Permanente team to move into the building. First patient date will be met according to contract with Kaiser Permanente on September 14, 2012.

Building Systems Summary

Although The Kaiser Permanente MOB is not a LEED rated project, DPR Construction and Kaiser Permanente are taking the initiative to build a sustainable building and construction site. The Green Guide for Healthcare version 2.0 is being tracked on this project. The GGHC is modeled off the Green Building Council's LEED rating system and focuses on innovative technologies to reduce consumption, utilize design elements to enhance to healing process and eliminate toxic materials used during construction. The main sustainable features of the building include use of day-lighting with the storefront glazing system and ribbon windows. This design allows for more natural light and less artificial lighting, which helps promote healing.

During building construction, sustainable practices are enacted such as temporary LED lighting research to measure the consumption of LED temporary lights versus fluorescent temporary lights. If this LED system results in a successful outcome of reducing cost and consumption, these energy saving practices will be utilized on future Kaiser Permanente projects as well as DPR Projects. Also DPR as a company is emphasizing a paperless environment where all paper documents are replaced with electronic files when permitting. All RFI's and submittals are done electronically as well as plans and specs. The DPR trailer complex won the Resource Efficient Energy Saver Award for their sustainable practices and recycling efforts.

Yes	No	Work Scope	Questions/ Issues
Χ			Types of materials, lead paint, or asbestos?
		Demolition Required	
Χ			Type of bracing, composite slab, crane size, type,
		Structural Steel Frame	location
Χ		Cast in Place Concrete	Horiz. and vert. formwork types, concrete placement
			methods
	Х	Precast Concrete	Casting location, connection methods, crane size/type/
			location
Χ		Mechanical System	Mech. room location, system type, types of distribution
			systems, types of fire suppression
Χ		Electrical system	Size/ capacity, redundancy
	Χ	Masonry	Load bearing or veneer, connection details, scaffolding
Χ		Curtain Wall	Materials included, construction methods, design
			responsibility
Χ		Support of Excavation	Type of excavation support system, dewatering system,
			permanent vs. temporary

Demolition

Demolition on this project will be minor and only involve concrete. Primarily demolition will be of existing exterior concrete sidewalks and areas of concrete waffle slab within the building. Also, the removal of existing precast panels will take place where the new mechanical tower will be erected and attached to the existing building. No harmful/ toxic materials will need to be dealt with.

Cast-in-Place Concrete

Cast in place concrete will be used for the Slab on Grade of the new mechanical tower addition as well as a retaining wall around the mechanical tower, in-fills of the sanitary trenches in the basement, thickened MRI slabs, etc. The horizontal and vertical formwork types used were both smooth formed and rough formed consisting of plywood and metal. Ready mixed concrete was used and poured continuously in one layer or in horizontal layers. For in-fills and slabs, the concrete was finished with a hand trowel.

For larger areas, such as the retaining wall concrete, a machine trowel was utilized.

Precast Concrete

Although precast concrete panels will not be installed on this project, the existing building is constructed of 6" precast concrete panels that will remain as the enclosure of the building. As seen in the typical exterior wall detail (figure 1) precast panels and a storefront/ ribbon window will be the building enclosure. During construction these panels were removed to allow for the erection of the new mechanical tower, which will be made of insulated metal panels.




Figure 1

Structural Steel

Structural steel will primarily be used for the construction of the 75 foot mechanical tower. It will consist of HSS 8x8 X-bracing up the sides of the tower as evidenced in Figure 2. Horizontal bracing will be used inside of the tower for the framing using HSS8x4. There will be six perimeter HSS columns and three interior columns Figure 3. A line of interior rigid moment connections will exist closest to the connection of the tower to the existing structure. Insulated metal wall panels will be fastened directly to the HSS members for the exterior enclosure of the tower.




Figure 2





Figure 3

A concrete composite slab will be used for the mechanical tower floors as shown in Figure 4. As for the existing building, structural steel members are needed on varying floors for support of added loads from the medical equipment to be installed. Since the existing slab is a concrete waffle slab, steel members will be placed horizontally under the floor slab between the ribs or the ribs will be cut to fit the members. This



will occur in locations that require extra reinforcing, perimeters of new stairway openings and framing of mechanical shafts. Structural steel members will also be used vertically between floors as single story support posts.

A 90 ton hydraulic truck crane will be used by the subcontractor BG Crane to erect the structural steel. The main boom has an arm length of 140 ft. in order to reach the top of the 75 ft. mechanical tower and the top of the existing building. The crane will be located on the South East corner of the building near the mechanical tower in order to distribute the structural steel members for inside the existing structure as well as for the mechanical tower construction.

Mechanical

The air distribution system used in the KP MOB will consist of multiple Variable Air Volume Control Units located on the lower level, level 2, level 4 and the roof. There will be gas fired steam generators and electronic steam humidifiers in the mechanical room located in the basement.

		Courtesy of KP				
DESIG.	LOCATION	SERVICE	MAX	CURRENT CONNECTED LOAD	MIN. OA (CFM)	EXT. / TOTAL STATIC PRESSURE (IN. W.C.)
AHU-I	LOWER LEVEL	LOWER LEVEL AND LEVEL I INTERIOR ZONE	46,000	41,520	11,500	3.95 / 7.71
AHU-2	LEVEL 2	LEVEL 2 AND LEVEL 3 INTERIOR ZONE	50,000	44,665	12,500	3.95 / 7.26
AHU-3	LEVEL 4	LEVEL 4 INTERIOR ZONE	34,000	30,100	8,500	3.5 / 7.05
AHU-4	ROOF	LEVEL 2 THROUGH LEVEL 5 PERIMETER ZONE	54,000	50,745	13,500	5.0 / 7.86
AHU-5	ROOF	BASEMENT THROUGH LEVEL 5 PERIMETER ZONE	70,000	63,430	17,500	5.2 / 8.42
AHU-6	ROOF	LEVEL 5 O.R. SUITE	40,000	33,285	10,000 (NOTE 8)	4.0 / 8.24

Figure 5

AHU Schedule

The hot water system will be comprised of fire-tube gas boilers and clean steam boilers located in the basement boiler room. The water treatment system will be run by a twin tank alternating concept with a meter initiation method. Chilled water will be distributed from 500 ton minimum cooling capacity centrifugal water chiller located in the basement. Located on the roof will be the stainless steel cooling tower seen in Figure 5, which has an induced draft counter -flow and super-low sound fan.

The fire protection used in the building will be a combination of a wet type automatic sprinkler and standpipe system. The building and mechanical equipment rooms will utilize this standard sprinkler system design. However, the




Figure 5

Telecommunication Equipment Room and electrical rooms will have double interlock pre-action systems. The main entrance and loading dock areas have dry-pipe systems. The fire protection will also include installation of new fire stopping and smoke seals around the perimeters of the floors.

Electrical

Since the KP building is a healthcare facility, it will require advanced electrical systems to

be installed that the existing office building did not originally have. Because of this fact, the existing switchboard room in the basement will be remodeled to a MDP switchboard and paralleling low voltage switchgear. The new switchboard will be 5000A and a voltage of 480Y/277. The power source for interior lighting is a 120/277V circuit and the static uninterrupted power supply will have an output voltage of 208Y/120V and input voltage of 480V. The communications systems will be low voltage




Figure 6


electrical power conductors and cables. The different communications pathways throughout the building will include mass notification systems and nurse call stations. Throughout the

building will be 100A three phase enclosed bus-way assemblies with 200% neutral and are 4 pole at 208V. All temporary construction power will be used from the existing switchboard and transformer located in the basement level main electrical room. The permanent transformers to be installed will be low voltage floor mounted and ceiling mounted transformers.

The electrical work on this project also includes a duct bank for the Verizon communications line to be routed across the site and to feed into the TER room located in the basement. The Verizon line will use 4" conduit connecting from the junction box on West Park Drive to the North side of the building at the location of the TER room.


Curtain wall

A curtain wall system will not be used on this building although a storefront system will be used at the entrance vestibule. A storefront system is only comprised of one story versus a curtain wall which is multiple stories. The storefront system will be constructed of different types of glass including: insulated vision glass, monolithic glass and laminated vision glass. The storefront will be held up by an aluminum frame that will fasten to the glass panels. This system can be seen in Figure 7.



Plumbing Figure 7

Plumbing will include Medical Gas boxes dispersed throughout the building primarily on the fifth floor. The medical gas will either be wall mounted panels above patient beds providing ½" compressed air, ½" carbon dioxide, ½" nitrogen and ¾" vacuum piping. Also, ceiling mounted medical gas will be located in surgical suites above the operating tables supplying ¾" oxygen, ½" Medical air, ¾" vacuum, ¾" anesthesia and ½" nitrous Oxide piping. Plumbing will also include installing sanitary trenches in the basement and all overhead plumbing for chilled and hot water systems.



Support of Excavation:

The main excavation on site will be for the mechanical tower addition and the elevator pit located on the lower level of the existing building. The mechanical tower excavation will not use any support for excavation except a 1 to-1 slope step back. As for the elevator pit, an 8" x 8" timber shoring system engineered by the subcontractor will be used to support excavation.

No dewatering system is specified for this project and there has been no need thus far for any dewatering.

Project Cost Evaluation

**Please refer to Appendix B for further cost details and Building Assemblies Estimate.

The Direct Building Construction Cost:

This is excluding: land costs, site work, general conditions, taxes, insurance, and fee

\$37,868,053

The building is 240,000 SF so this cost comes to:

\$157.78 per SF

The Total project Cost is:

\$44,078,649

With the square footage at 240,00SF this comes to:

\$183.66 per SF

The Mechanical System Cost is:

\$14,375,000 or

\$59.90 per SF

Electrical System Cost is:

\$7,842,891 or

\$32.68 per SF

The Structural System Cost is:

\$2,323,100 or

\$9.68 per SF

The Total Assemblies Cost of the MEP systems (including plumbing, mechanical, electrical, communications cabling) is:

\$23,517,953

	Square Foot Cost Estimate Report	
Estimate Name:	Kaiser Permanente-MOB	
Building Type:	Hospital, 4-8 Story with Precast Concrete Panels With Exposed Aggregate / R/Conc. Frame	
Location:	FAIRFAX, VA	
Story Count:	6	CONTINUE OF THE PARTY OF THE PA
Story Height (L.F.):	14	TO PERSONAL PROPERTY OF THE PERSONAL PROPERTY
Floor Area (S.F.):	241175	
Labor Type:	Union	
Basement Included:	Yes	
Data Release:	Year 2010	Costs are derived from a building model with basic components.
Cost Per Square Foot:	\$190.52	Scope differences and market conditions can cause costs to vary significantly.
Building Cost:	\$45,947,500	
	Table 1	

The square foot cost estimate was developed using the RS Means Cost Works program. Some of the assumptions made for this estimate were that the Kaiser Permanente MOB is a renovation of the existing building. RS means does not provide square foot cost data for renovations so the estimate is based on new construction. The building type for the estimate was a 4-8 story hospital. The reason for this selection is to get the best possible estimate based on the structure of the building. RS means data does not provide information for Medical Office buildings with a concrete frame and precast concrete panels. The decision was made to follow cost data based on the structure, since the KP MOB will need to be able to support the weight of the medical equipment, much like a hospital. There are 5 above grade levels and 2 below grade levels on the KP project so a 6 story building with a basement was assumed for this estimate. Also, no architectural or designer fees were included in the estimate. The square foot estimate resulted in \$45, 947, 500, which is a fair cost compared to the direct building cost of \$37,868 053. Other factors that could have impacted this price are the building systems assumed in the estimate.

For the assemblies estimate evaluation, the results differ slightly then the actual assemblies cost because of some other influences. The assumptions made for this estimate were the quantities of each of the system's components. Generalizations were made based on

the most typical designs seen througout the contract drawings. There are other systems within the building that were minor in comparison to the systems selected, which results in cost fluctuation. The total for plumbing, fire protection, HVAC and electrical assemblies in the estimate came to \$13,054,090. This cost is about 10 million dollars less then the actural cost of \$23,517,953. It can be assumed that this is because communcations was included in the actual cost, where as in the estimate communications systems were not accounted for. Also, the takeoff of L.F. of mechanical duct work and plumbing piping were not taken into consideration. This assemblies estimate was meant to summarize the major systems and equiptment utilized in the building and perform an approximate cost evaluation.

Site Plans

**Please refer to Appendix C for existing conditions plan and phasing plans.

The site of the Kaiser Permanente MOB includes the existing office building to be turned into the healthcare facility, the existing parking garage and the proposed mechanical tower and parking garage. The Federal Home Loan Mortgage building is the closest surrounding structure and shares Private Drive with the site. The existing utilities are domestic water, electric and a communications line junction box. KP will not tap into the gas line but instead will supply their own propane tank source, further information about this utility has not been determined. Included in construction will be the propped Verizon line that will lead directly to the TER room in the basement of the building which is shown in yellow on the existing conditions plan. Egress in and out of the site is limited to personnel only and delivery traffic and vehicular traffic has designated locations as noted on the plan. The delivery circle on the north side of the building will change egress depending on the phase of construction. Private drive will remain open to the public and must remain clear at all times during construction. The trailers are located on the roof of the existing parking garage, which is also where all construction personnel will park.

The phasing for the Verizon line duct bank involved moving the site fencing on the North side of the building to block off one side of the delivery circle so that no traffic could affect digging the duct bank. Likewise, the other side of the delivery circle will be closed off once digging effects that area and site fencing will be open again on the original side. Another major issue is the material hoist crane must be disassembled in order to feed the duct bank into the TER room located in the basement. This affects deliveries so that all deliveries must be lifted through the window openings to the upper floors instead of using the hoist. Also, the north side pedestrian entrance into the building will need to be moved to a side door located on the north-east side of the building and the ramp from the parking garage will have kited pedestrian access depending on the location of duct bank work. Another change made is that Private Drive needed to be brought down to one-lane traffic so that the sidewalk could be demolished and the duct bank could be run underneath. This required the contractor to provide workers for traffic control so that private drive was not affected. The contractor thought the site plan through very well and tried to utilize the space that was available. Although not having the material hoist was an inconvenience, it was temporary and a necessary action to construct the duct bank.

During the erection of the mechanical tower, the site plan will need to be modified in order to accommodate the 90 ton hydraulic truck crane necessary for this phase. The crane will be located behind the mechanical tower in order to lift steel members for the framing and bracing of the tower. The crane has a main boom length of 140 ft. in order to reach the top of the 75 ft. mechanical tower. Access into the building via the entrance on the South side to the


lower level will no longer be available, so egress will need to be limited to the South east door into the basement. The site fencing on the south side will need to be moved to enclose the mechanical tower work from the lot where areas will be made on the south side. For safety and convenience purposes, all above ceiling rough-in work in the existing building will be complete on the face where the mechanical tower attaches.

An 8-story parking garage will be erected on the Kaiser Permanente site and will be constructed by Coakley Williams construction. Although the construction will not be done by DPR, they are still responsible for the entire site and need to plan accordingly to allow Coakley Williams to perform their work. During the excavation of the parking garage, the site plan for the Kaiser Permanente building needs to be altered by having site fencing at the North West corner of KP MOB to block any egress near that corner. This will allow for Coakley to have their equipment and deliveries come into their area of the site without any interruptions. As noted in the plan by the large blue arrow, the entrance into the site at this location is solely for Coakley Williams. A wash rack will also be installed at the entrance to the garage area to ensure that no dirt or debris is carried onto Private Drive, since it is a public road. This plan closely follows the plan that the contractor enacted although for this plan, site fencing was added at the South West corner of the building to keep parking garage construction and mechanical tower construction separate.

Local Conditions

Tysons Corner is known to be a highly populated business district right outside Washington D.C., which means that parking is scarce. With the Tysons I and II malls located minutes from the site, traffic congestion is an issue. Luckily with the KP project there is an

existing parking garage on site east of the building. This area allowed for four levels of parking for all parties involved in the project plus any extra room for visitors. Regulations are strict about parking on public access roads to the neighboring businesses so having this parking garage is crucial to site egress. Also, there is an existing delivery roundabout in the north area of the building which was used for delivery trucks so idling on




public roads is not an issue. There are no preferred methods of construction for Fairfax County. Since it is in a highly congested area, space can be limited and so construction sites need to plan accordingly.

To meet recycling guidelines of the county, a construction waste management plan is being utilized on this project. All construction and demolition waste will be disposed of on site in a comingled container (excluding chemical waste, aggregate and large quantities of glass). This waste will be sorted by a Con-Serv Industries and will be based on weight. These weights are identified by CSI after sorting a container and disseminated to DPR on a monthly basis. The reports will include a container-by-container breakdown, a monthly summary, and a project summary. There are recycling and tipping fees enforced for Fairfax County based on the materials and weight that construction sites must obey. Also, necessary permits for commercial renovations of existing buildings in Fairfax County are the building permit, electrical permit, mechanical permit and plumbing permit.

Tysons Corner is located in the central region of Fairfax County known as the Piedmont Upland region. This area is predominantly covered with soil and weathered rock. Bedrock is common and usually has soils that are thick plastic clays. The type of soil on site is mainly compromised of silt loam, loam, and gravelly sand to loam, according to Fairfax County Surveys. The typical solid profile is 0 to 8 inches of silt loam, 8 to 60 inches of loam and 50 to 62 inches of gravelly sand to loam. The depth of the water table is between 10 to 24 feet and the available water capacity is about 8.6 inches.

Fortunately on the KP project, no dewatering methods have been necessary since excavation is minimal and the existing building foundation is already present. The existing storm inlets are being monitored by a sediment and erosion plan during the construction phase. A gravel and wire mesh inlet protection system is being utilized, as seen in figure 10. Weekly sediment and erosion reports are documented to ensure any water runoff is not clogging storm sewers on site or that any dewatering action needs to be taken.



WHERE PONDING IN FRONT OF THE STRUCTURE IS NOT LIKELY TO CAUSE INCONVENIENCE OR DAMAGE TO ADJACENT STRUCTURES AND UNPROTECTED AREAS.

* GRAVEL SHALL BE VDOT #3, #357 OR 5 COARSE AGGREGATE.

Gravel Curb Inlet Sediment Filter P Figure 10

Client Information

Kaiser Permanente is the owner on this project. They are a company that is on the cutting edge of healthcare by offering several "Hubs" that provide health care to Kaiser Members. They are taking over the healthcare industry, especially in Northern VA, with KP Tysons being one of the eleven medical offices that offer primary/ specialty care and outpatient services (Kass). The purpose of this project is to continue promoting growth within the healthcare industry and making Kaiser Permanente an accessible and convenient place for healthcare.

The expectations that Kaiser Permanente has as a client for this project is that schedule is a critical factor. With a first patient date in place for September 14, 2012, it is crucial that construction is on time. This being said, quality is no way compromised in order to meet the schedule requirements. Daily inspections were enacted on the jobsite to ensure every detail of construction was according to standard. If assembly, product type or other discrepancies were found, further installation would stop until it was according to KP code. Since DPR has been a GC for Kaiser Permanente before, they were familiar with the higher standards that KP requires on their healthcare facilities. For instance, since the existing structure is an older structure it used an outdated waffle slab. With this, some discrepancy about quality ensued with the design for fire rating the coffers. The task wound up to be a severe hindrance on the schedule since KP had certain standards to be met and changes in design were back and forth. The issue was eventually handled although time needed to be made up since this set back wall framing and other trades installing above ceiling rough-in.

In addition to a strict schedule and high level quality, Kaiser Permanente issued many bulletins/ changes during construction. With these bulletins frequently being issued, increase in productivity was expected and overtime became a norm for some trades. As mentioned early, DPR drywall was required to work overtime and weekends in order to make up time for the coffer setback.


As for sequencing, Kaiser Permanente was specifically interested in the mock rooms being complete so that Kaiser Representatives could visualize the rooms and make changes as needed. The owner's satisfaction was mainly contingent on having everything be of highest quality and according to KP standard, having the building complete by final completion and having any bulletin/ change be done regardless of cost or overtime needed to complete it.

Project Delivery System

This project is being delivered as a Design-Bid-Build with contracted GMP. This approach was chosen because this is the typical system that Kaiser Permanente follows on their construction projects. A Design Build was not an option on this project because of the complexity of the MEP systems in a healthcare facility.

For this project the "just in time" delivery method was used. In order to increase productivity, the less materials stored on site is crucial. Deliveries were made on an as needed basis and it kept the jobsite more organized and safer. Also, construction was from the 5th floor down in order to keep a logical flow of work down and out of the building. Each floor consisted of five areas or quadrants and work flowed work counterclockwise from A2 to A1.

The general contractor on the Kaiser Permanente project is DPR Construction and the CM is Jacobs. Jacob's role was to act as the owner's representative and perform all duties and responsibilities that the owner would exercise, including changing contract documents, (please refer to project organizational chart on following page). The KP staff and Jacob's staff were housed in one trailer on site while DPR was in another. Jacobs and DPR worked closely so that any communication DPR would have with Kaiser Permanente would include Jacobs as well. Jacobs would also relay information from KP and in turn, DPR would then ensure it was followed through on site. DPR owned the entire site and therefore was liable for all subcontractors and onsite activity. They had full risk of any errors or omissions of the scope of all the subcontractors on site.




The contract held between DPR and Kaiser Permanente is a GMP. This contract entitles upon project completion that the contractor will receive 30% of unused portion of the GMP amount and the owner will retain 70%. DPR's general conditions cost, general requirements cost and direct cost of construction which they initially paid for will be reimbursed to them but not exceeding the GMP amount.


The general contractor under this agreement is responsible for providing insurance. They must furnish Kaiser Permanente with certificates of insurance completed. The types of insurance acquired on this project were: Commercial General Liability, Business auto insurance, workers compensation, umbrella liability insurance, contractor's equipment and contractor's pollution legal liability insurance.

Staffing Plan

DPR Construction



DPR functions not by "titles" but instead has "roles." An open floor and no cubicles in the DPR trailer means that everyone is on an equal playing field but are responsible for different tasks. An issue may be handled by a certain DPR individual although responsibility is on DPR as a team. As seen in the staffing plan, there are no lines to indicate hierarchy within the DPR staff because of DPR's beliefs and core values as a company. There was one superintendent with two assistant superintendents, a PM, certain MEP leads, PE's that take on specific trades, a PE for DPR SPW and a BIM engineer. The smaller subcontractors such as steel, roofing, site work/ demo, glass/glazing etc. were distributed among DPR staff in order for those subcontractors to report to with any issues while larger subs could report to any DPR member for daily issues



Appendix B

Square Foot Cost Estimate Report

Estimate	Kaiser Permanente-MOB	
	Hospital, 4-8 Story with Precast Concrete	
Building	Panels With Exposed Aggregate / R/Conc.	
Type:	Frame	
Location:	FAIRFAX, VA	
Count:	6	
Height	14	Kentralia
Area	241175	
Type:	Union	
Included:	Yes	
Release:	Year 2010	Costs are derived from a building model with basic components.
Square	\$190.52	Scope differences and market conditions can cause costs to vary significantly,
Cost:	\$45,947,500	

		0/ ET . I	Cost Per S.F.	
A Substr		% of Total 2.30%		Cost \$1,061,500
A Substr A1010	Standard Foundations	2.50%	\$4.40	\$549,000
AIUIU	KSF, 12" deep x 32" wide		JZ.Z 0	3343,000
	8' - 6" square x 27" deep			
A1030	Slab on Grade		\$0.72	\$173,500
A1030	Slab on grade, 4" thick, non industrial, reinforced		\$0.72	\$175,500
A2010	Basement Excavation		\$0.47	\$114,000
A2010			\$0.47	\$114,000
	site storage		40.00	4005 000
A2020	Basement Walls		\$0.93	\$225,000
2 (22)	thick	100000000000000000000000000000000000000	Annual Control	
B Shell		20.60%	5- more and	NAME OF TAXABLE PARTY.
B1010	Floor Construction		\$19.71	\$4,753,500
	height, 251 lbs/LF, 4000PSI			
	height, 394 lbs/LF, 4000PSI			
	15'x15' bay, 75 PSF superimposed load, 153 PSF total load			
	75 PSF superimposed load, 204 PSF total load			
B1020	Roof Construction		\$3.01	\$725,000
	16" deep beam, 14" slab, 174 PSF total load			
B2010	Exterior Walls		\$10.63	\$2,563,500
	insulation, low rise			
B2020	Exterior Windows		\$4.13	\$996,000
	Windows, aluminum, sliding, insulated glass, 5' x 3'			
B2030	Exterior Doors		\$0.75	\$180,000
	6'-0" x 10'-0" opening			
	hardware, 6'-0" x 10'-0" opening			
	0" opening			
B3010	Roof Coverings		\$1.03	\$249,000
	adhesive		100	, ,

	Insulation, rigid, roof deck, composite with 2" EPS, 1" perlite			
	Roof edges, aluminum, duranodic, .050" thick, 6" face			
D2020	Flashing, copper, no backing, 16 oz, < 500 lbs		ćo 02	¢¢ 000
B3020	Roof Openings		\$0.02	\$6,000
Clutovio	steel, 165 lbs	21 100/	¢40.10	£0.671.000
C Interior		21.10%	\$40.10	\$9,671,000
C1010	Partitions		\$6.33	\$1,526,000
	board base, 3-5/8" @ 24",s ame opposite face, no insulation			
64.020	Gypsum board, 1 face only, 5/8" with 1/16" lead		640.53	£2 F26 000
C1020	Interior Doors		\$10.52	\$2,536,000
	3'-0" x 7'-0" x 1-3/8"			
	0" x 1-3/8"			¥
C1030	Fittings		\$0.92	\$221,500
	Partitions, hospital curtain, ceiling hung, poly oxford cloth			
C2010	Stair Construction		\$1.20	\$290,500
	Stairs, steel, cement filled metal pan & picket rail, 12 risers, with la	anding	e	
C3010	Wall Finishes		\$6.30	\$1,518,500
	Glazed coating			
	primer & 2 coats			
	Vinyl wall covering, fabric back, medium weight			
	Ceramic tile, thin set, 4-1/4" x 4-1/4"			
C3020	Floor Finishes		\$8.53	\$2,058,000
	Composition flooring, epoxy terrazzo, maximum			
	Terrazzo, maximum			
	Vinyl, composition tile, maximum			
	Tile, ceramic natural clay			
C3030	Ceiling Finishes		\$6.30	\$1,520,500
	crc, 36" OC support			
	channel grid, suspended support			
D Service	s	47.50%	\$90.39	\$21,800,500
D1010	Elevators and Lifts		\$6.04	\$1,456,500
	200 FPM			
D2010	Plumbing Fixtures		\$10.83	\$2,612,000
	Water closet, vitreous china, bowl only with flush valve, wall hung			
	Urinal, vitreous china, wall hung			
	Lavatory w/trim, wall hung, PE on CI, 19" x 17"			
	Kitchen sink w/trim, raised deck, PE on Cl, 42" x 21" dual level, trip	ole bowl		
	compartment			
	Service sink w/trim, PE on Cl, wall hung w/rim guard, 22" x 18"			
	Bathtub, recessed, PE on CI, mat bottom, 5'-6" long			
	Shower, stall, baked enamel, terrazzo receptor, 36" square			
	Water cooler, electric, wall hung, wheelchair type, 7.5 GPH			
D2020	Domestic Water Distribution		\$6.43	\$1,551,000
	Electric water heater, commercial, 100< F rise, 1000 gal, 480 KW 1	970 GPH		


D2040	Rain Water Drainage	\$0.48	\$116,000
	Roof drain, Cl, soil,single hub, 5" diam, 10' high		
	Roof drain, CI, soil, single hub, 5" diam, for each additional foot add		
D3010	Energy Supply	\$3.19	\$769,500
	Hot water reheat system for 200,000 SF hospital		
D3020	Heat Generating Systems	\$0.35	\$85,500
	Boiler, electric, steel, steam, 510 KW, 1,740 MBH		
D3030	Cooling Generating Systems	\$2.51	\$606,500
	Chiller, reciprocating, water cooled, standard controls, 100 ton		
	Chiller, reciprocating, water cooled, standard controls, 150 ton		
	Chiller, reciprocating, water cooled, standard controls, 200 ton		
D3090	Other HVAC Systems/Equip	\$29.87	\$7,203,000
	Ductwork for 200,000 SF hospital model		
	Boiler, cast iron, gas, hot water, 2856 MBH		
	Boiler, cast iron, gas, hot water, 320 MBH		
	AHU, rooftop, cool/heat coils, VAV, filters, 5,000 CFM		
	AHU, rooftop, cool/heat coils, VAV, filters, 10,000 CFM		
	AHU, rooftop, cool/heat coils, VAV, filters, 20,000 CFM		
	VAV terminal, cooling, hot water reheat, with actuator / controls, 200 CFM		
	AHU, rooftop, cool/heat coils, VAV, filters, 30,000 CFM		
	draft damper, 1500 CFM		
	draft damper, 2750 CFM		
	Commercial kitchen exhaust/make-up air system, rooftop, gas, 5000 CFM		
	Plate heat exchanger, 400 GPM		
D4010	Sprinklers	\$2.38	\$574,000
	Wet pipe sprinkler systems, steel, light hazard, 1 floor, 10,000 SF 10,000 SF		
	Standard High Rise Accessory Package 8 story		
D4020	Standpipes	\$0.38	\$92,000
	Wet standpipe risers, class III, steel, black, sch 40, 4" diam pipe, 1 floor		
	floors		
	steel door & frame		
	Alarm, electric pressure switch (circuit closer)		
	Escutcheon plate, for angle valves, polished brass, 2-1/2"		
	Fire pump, electric, with controller, 5" pump, 100 HP, 1000 GPM		
	Fire pump, electric, for jockey pump system, add		
	Siamese, with plugs & chains, polished brass, sidewalk, 4" x 2-1/2" x 2-1/2"		
	Valves, angle, wheel handle, 300 lb, 2-1/2"		
	Cabinet assembly, includes. adapter, rack, hose, and nozzle		
D5010	Electrical Service/Distribution	\$3.28	\$791,500
	phase, 4 wire, 120/208 V, 2000 A		
	Feeder installation 600 V, including RGS conduit and XHHW wire, 2000 A		
	Switchgear installation, incl switchboard, panels & circuit breaker, 2000 A		
D5020	Lighting and Branch Wiring	\$18.08	\$4,361,500

User Fees	S	0.0076	70.00	30
		0.00%	\$0.00	\$0
Architect	tural Fees	0.00%	\$0.00	\$0
Contract	or Fees (General Conditions,Overhead,Profit)	0.00%	\$0.00	\$0
SubTotal		100%	\$190.52	\$45,947,500
		300,000,000	- Commission	
per men exercise entre	g Sitework	0.00%	\$0.00	\$0
F Special	Construction	0.00%	\$0.00	\$0
	per room			A0000000000000000000000000000000000000
E2020	Moveable Furnishings		\$3.96	\$955,000
E1090	Other Equipment		\$0.00	\$0
	sinks, washers & dry tables			
	Special construction, refrigerators, prefabricated, walk-in, 7'-6" h	igh, 6' x 6'		
	system, economy			
	burners, 2 ovens & 24" griddle			
	gallons			
	KW			
	semiautomatic, 50 racks/hr			
	hospital			
	double door, 28"x67"x52"			
	Fume hood, complex, including fixtures and ductwork			
	Architectural equipment, laboratory equipment eye wash, hand	held		
	Architectural equipment, sink, epoxy resin, 25" x 16" x 10"			
	distilled water, economy			
E1020	Institutional Equipment		\$12.38	\$2,986,500
E Equipm	nent & Furnishings	8.60%	\$16.34	\$3,941,500
	kW			
	engine with fuel tank, 400 kW			
	engine with fuel tank, 100 kW			
D5090	Other Electrical Systems		\$4.23	\$1,020,500
	Internet wiring, 8 data/voice outlets per 1000 S.F.			
	Fire alarm command center, addressable with voice, excl. wire &	conduit		
	detectors, includes outlets, boxes, conduit and wire			
D5030	Communications and Security		\$2.33	\$561,000
	fixtures @32 watt per 1000 SF			
	V 15 HP, 575 V 20 HP			
	Motor installation, three phase, 460 V, 15 HP motor size			
	Central air conditioning power, 4 watts			
	Miscellaneous power, 1.2 watts			
	Wall switches, 5.0 per 1000 SF			
	with transformer			

	\$13,054,090					Total of Assemblies
	\$888, 390					Total
356	55,100+\$11020= \$66,120	1	\$55,100/each (add 20% for 277/480V)	2000A, 277/ 480 V	5000A, 277/480V	Switchgear/Switchboard/Panels/ Circuit Breaker
357	\$819,995	241, 175	\$3.40/ sf	16 per 1000 S.F.	125 V, 2 Pole, 3 wire, 20 A	Duplex receptacle
354	\$2, 275	1	\$2, 275/each	3 phase, 4 wire,120/208 V, 100A	3 phase, 4 wire, 120/208 V, 100 A	Electric Service, 3 Phase, 4 wire
						Electrical
	\$748, 680					Total
345	\$748, 680	34,000 + 34,000 (6)	\$3.66/ SF (add'tl floors) \$3.06/SF	Ordinary hazard, one floor, 50,000 S.F.	Approx. 34,000 SF coverage on each floor	Wet sprinkler system
						Fire Protection
	\$11,210,545					Total
324	\$10,949,345	241,175 SF	\$45.40/SF (adjusted for 241,175 SF)	Medical Center 60,000 S.F., 140,000 ton	500 tons	Chilled Water/Cooling Tower system
317	\$84,400	1	\$84,400/unit	4720 MBH	4423 MBH	Steam Boiler
317	\$176, 800	2	\$88,400/unit	4720 MBH	4423 MBH	Gas Boiler
						HVAC
	\$206, 475					Total
270	\$69, 525	Approx. 45	\$1545/ each	Wall hung 20"x18"	Wall hung	Wall hung lavatory sinks
267	\$92,400	Approx. 40	\$2310/each	Wall hung, close couple	Wall hung, grouped side by side	Wall hung water closets
286	\$44,550	2	\$22,275/each	600 MBH, 576 GPH	1125 MBH, 1500 GPH, 500 Gallons	Domestic Hot Water Heater
						Plumbing
RS Means 2010 page#	Total	Quantity	Price / quantity	RS Means Parameters	System Components	Equipment/System
		ference 2010	Assemblies Estimate using RS Means Cost Data Reference 2010	s Estimate using R	Assemblie	

D20 Plumbing

D2020 Domestic Water Distribution




Units may be installed in multiples for increased capacity.

Included below is the heater with selfenergizing gas controls, safety pilots, insulated jacket, hi-limit aquastat and pressure relief valve.

Installation includes piping and fittings within 10' of heater. Gas heaters require vent piping (not included in these prices).

				COST EACH	
rstem Components	QUANTITY	UNIT	MAT.	INST.	TOTAL
SYSTEM D2020 250 1780					
GAS FIRED WATER HEATER, COMMERCIAL, 100° F RISE			1 1		
75.5 MBH INPUT, 63 GPH					
Water heater, commercial, gas, 75.5 MBH, 63 GPH	1.000	Ea.	1,725	445	2,170
Copper tubing, type L, solder joint, hanger 10' OC, 1-1/4" diam	30.000	L.F.	276	322.50	598.
Wrought copper 90° elbow for solder joints 1-1/4" diam	4.000	Ea.	53.20	166	219.
Wrought copper Tee for solder joints, 1-1/4" diam	2.000	Ea.	55	139	194
Wrought copper union for soldered joints, 1-1/4" diam	2.000	Ea.	137	89	226
Valve, gate, bronze, 125 lb, NRS, soldered 1-1/4" diam	2.000	Ea.	182	83	265
Relief valve, bronze, press & temp, self-close, 3/4" IPS	1.000	Ea.	137	22.50	159
Copper tubing, type L, solder joints, 3/4" diam	8.000	L.F.	33.68	65.60	99
Wrought copper 90° elbow for solder joints 3/4" diam	1.000	Ea.	3.60	33	36
Wrought copper, adapter, CTS to MPT, 3/4" IPS	1.000	Ea.	5.60	36.50	42
Pipe steel black, schedule 40, threaded, 3/4" diam	10.000	L.F.	47.10	102.50	149
Pipe, 90° elbow, malleable iron black, 150 lb threaded, 3/4" diam	2.000	Ea.	6.32	89	95
Pipe, union with brass seat, malleable iron black, 3/4" diam	1.000	Ea.	13.25	48	61
Valve, gas stop w/o check, brass, 3/4" IPS	1.000	Ea.	12.30	28.50	40
TOTA			2,687.05	1,670.10	4,357


D.04	200 050	Cus Fired Water Heaters Com	moreial Systems	(COST EACH	
D20	20 250	Gas Fired Water Heaters - Com	mercial systems	MAT.	INST.	TOTAL
1760	Gas fired water he	eater, commercial, 100°F rise				2/1/2004
1780		75.5 MBH input, 63 GPH		2,675	1,675	4,350
1860		100 MBH input, 91 GPH	RD2020	6,400	1,750	8,150
1980	83	155 MBH input, 150 GPH	-100	9,100	2,025	11,125
2060		200 MBH input, 192 GPH		9,725	2,450	12,175
2140		300 MBH input, 278 GPH		11,200	3,025	14,225
2180		390 MBH input, 374 GPH		13,100	3,050	16,150
2220		500 MBH input, 480 GPH		17,700	3,300	21,000
2260		600 MBH input, 576 GPH		18,700	3,575	22,275



Custom Components				COST EACH	
System Components	QUANTITY UNIT MAT. INST. TO	TOTAL			
SYSTEM D2010 110 1880					
WATER CLOSET, VITREOUS CHINA, ELONGATED					
TANK TYPE, WALL HUNG, TWO PIECE					
Water closet, tank type vit china wall hung 2 pc. w/seat supply & stop	1.000	Ea.	655	212	867
Pipe Steel galvanized, schedule 40, threaded, 2" diam.	4.000	L.F.	76	70.20	146.2
Pipe, CI soil, no hub, cplg 10' OC, hanger 5' OC, 4" diam.	2.000	L.F.	29.10	38.70	67.8
Pipe, coupling, standard coupling, Cl soil, no hub, 4" diam.	2.000	Ea.	45	68	113
Copper tubing type L solder joint, hangar 10' O.C., 1/2" diam.	6.000	L.F.	16.44	46.20	62.6
Wrought copper 90° elbow for solder joints 1/2" diam.	2.000	Ea.	3.20	62	65.2
Wrought copper Tee for solder joints 1/2" diam.	1.000	Ea.	2.74	48	50.7
Supports/carrier, water closet, siphon jet, horiz, single, 4" waste	1.000	Ea.	830	117	947
TOTAL			1,657.48	662.10	2,319.5

D20	010 110	Water Closet Systems			COST EACH	
DZ	110 110	water closet systems		MAT.	INST.	TOTAL
1800	Water closet, vitre	ous china, elongated				
1840		Tank type, wall hung				
1880		Close coupled two piece	RD2010	1,650	660	2,310
1920		Floor mount, one piece	-400	930	705	1,635
1960		One piece low profile		970	705	1,675
2000		Two piece close coupled		625	705	1,330
2040		Bowl only with flush valve				
2080		Wall hung		1,425	750	2,175
2120		Floor mount		750	715	1,465
2160		Floor mount, ADA compliant with 18" high bowl		770	735	1,505

267



Sustan Commonants				COST EACH	
System Components	QUANTITY	UNIT	MAT.	INST.	TOTAL
SYSTEM D2010 310 1560					
LAVATORY W/TRIM, VANITY TOP, P.E. ON C.I., 20" X 18"					
Lavatory w/trim, PE on CI, white, vanity top, 20" x 18" oval	1.000	Ea.	286	176	462
Pipe, steel, galvanized, schedule 40, threaded, 1-1/4" diam.	4.000	L.F.	48	50.60	98.6
Copper tubing type DWV, solder joint, hanger 10' OC 1-1/4" diam.	4.000	L.F.	43.20	41.60	84.8
Wrought copper DWV, Tee, sanitary, 1-1/4" diam.	1.000	Ea.	30.50	69.50	100
P trap w/cleanout, 20 ga., 1-1/4" diam.	1.000	Ea.	103	34.50	137.
Copper tubing type L, solder joint, hanger 10' OC 1/2" diam.	10.000	L.F.	27.40	77	104.
Wrought copper 90° elbow for solder joints 1/2" diam.	2.000	Ea.	3.20	62	65.
Wrought copper Tee for solder joints, 1/2" diam.	2.000	Ea.	5.48	96	101.4
Stop, chrome, angle supply, 1/2" diam.	2.000	Ea.	17.50	57	74.5
TOTAL			564.28	664.20	1,228.

D20	010 310	Lavatory System			COST EACH	
DZ(10 310	Lavatory System	15	MAT.	INST.	TOTAL
1560	Lavatory w/trim,	vanity top, PE on CI, 20" x 18", Vanity top by others.		565	665	1,230
1600		19" x 16" oval		475	665	1,140
1640		18" round	RD2010	550	665	1,215
1680		Cultured marble, 19" x 17"	-400	485	665	1,150
1720		25" x 19"		520	665	1,185
1760		Stainless, self-rimming, 25" x 22"		660	665	1,325
1800		17" x 22"		650	665	1,315
1840		Steel enameled, 20" x 17"	160	480	680	1,160
1880		19" round		475	680	1,155
1920		Vitreous china, 20" x 16"		585	695	1,280
1960		19" x 16"		585	695	1,280
2000		22" x 13"		595	695	1,290
2040	Wall hung	g, PE on Cl, 18" x 15"		845	730	1,575
2080		19" x 17"		845	730	1,575
2120		20" x 18"		815	730	1,545
2160		Vitreous china, 18" x 15"		700	755	1,455
2200		19" x 17"		645	755	1,400
2240		24" x 20"		915	755	1,670
2300		20" x 27", handicap	8	915	755	1,670

D30 HVAC

D3020 Heat Generating Systems



Boiler Selection: The maximum allowable working pressures are limited by ASME "Code for Heating Boilers" to 15 PSI for steam and 160 PSI for hot water heating boilers, with a maximum temperature limitation of 250°F. Hot water boilers are generally rated for a working pressure of 30 PSI. High pressure boilers are governed by the ASME "Code for Power Boilers" which is used almost universally for boilers operating over 15 PSIG. High pressure boilers used for a combination of heating/process loads are usually designed for 150 PSIG.

Boiler ratings are usually indicated as either Gross or Net Output. The Gross Load is equal to the Net Load plus a piping and pickup allowance. When this allowance cannot be determined, divide the gross output rating by 1.25 for a value equal to or greater than the next heat loss requirement of the building.


Table below lists installed cost per boiler and includes insulating jacket, standard controls, burner and safety controls. Costs do not include piping or boiler base pad. Outputs are Gross.

20000	Polloge Hot Water & Steam		COST EACH		
D3020	106 Boilers, Hot Water & Steam	MAT.	INST.	TOTAL	
0600 Boile	r, electric, steel, hot water, 12 K.W., 41 M.B.H.	4,125	1,300	5,425	
0620	30 K.W., 103 M.B.H.	4,925	1,425	6,350	
0640	60 K.W., 205 M.B.H.	6,025	1,550	7,575	
0660	120 K.W., 410 M.B.H.	6,750	1,900	8,650	
0680	210 K.W., 716 M.B.H.	7,900	2,850	10,750	
0700	510 K.W., 1,739 M.B.H.	18,900	5,275	24,175	
0720	720 K.W., 2,452 M.B.H.	22,900	5,950	28,850	
0740	1,200 K.W., 4,095 M.B.H.	29,600	6,850	36,450	
0760	2,100 K.W., 7,167 M.B.H.	56,500	8,600	65,100	
0780	3,600 K.W., 12,283 M.B.H.	87,000	14,500	101,500	
0820	Steam, 6 K.W., 20.5 M.B.H.	3,850	1,425	5,27	
0840	24 K.W., 81.8 M.B.H.	4,775	1,550	6,32	
0860	60 K.W., 205 M.B.H.	6,625	1,700	8,32	
0880	150 K.W., 512 M.B.H.	9,575	2,625	12,20	
0900	510 K.W., 1,740 M.B.H.	24,400	6,450	30,85	
0920	1,080 K.W., 3,685 M.B.H.	34,100	9,300	43,40	
0940	2,340 K.W., 7,984 M.B.H.	70,000	14,500	84,50	
0980	Gas, cast iron, hot water, 80 M.B.H.	1,975	1,625	3,60	
1000	100 M.B.H.	2,525	1,750	4,27	
1020	163 M.B.H.	3,100	2,375	5,47	
1040	280 M.B.H.	4,550	2,625	7,17	
1060	544 M.B.H.	9,025	4,675	13,70	
1080	1,088 M.B.H.	13,600	5,925	19,52	
1100	2,000 M.B.H.	19,700	9,250	28,95	
1120	2,856 M.B.H.	23,700	11,900	35,60	
1140	4,720 M.B.H.	72,000	16,400	88,40	
1160	6,970 M.B.H.	103,500	26,600	130,10	
1180	For steam systems under 2,856 M.B.H., add 8%				
1520	Oil, cast iron, hot water, 109 M.B.H.	2,175	1,975	4,15	
1540	173 M.B.H.	2,750	2,375	5,12	
1560	236 M.B.H.	3,525	2,800	6,32	
1580	1,084 M.B.H.	10,300	6,300	16,60	
1600	1,600 M.B.H.	13,300	9,050	22,35	
1620	2,480 M.B.H.	20,400	11,600	32,00	
1640	3,550 M.B.H.	26,300	13,900	40,20	
1660	Steam systems same price as hot water	***			

317

D30 HVAC

D3030 Cooling Generating Systems



General: Water cooled chillers are available in the same sizes as air cooled units. They are also available in larger capacities.

Design Assumptions: The chilled water systems with water cooled condenser


include reciprocating hermetic compressors, water cooling tower, pumps, piping and expansion tanks and are based on a two pipe system. Chilled water piping is insulated. No ducts are included and fan-coil units are cooling only. Area

distribution is through use of multiple fan coil units. Fewer but larger fan coil units with duct distribution would be approximately the same S.F. cost. Water treatment and balancing are not included.

System Components				COST EACH	
System Components	QUANTITY	UNIT	MAT.	INST.	TOTAL
SYSTEM D3030 115 1320					
PACKAGED CHILLER, WATER COOLED, WITH FAN COIL UNIT					
APARTMENT CORRIDORS, 4,000 S.F., 7.33 TON			1 1	- 1	
Fan coil air conditioner unit, cabinet mounted & filters, chilled water	2.000	Ea.	4,641.70	684.04	5,325.74
Water chiller, water cooled, 1 compressor, hermetic scroll,	1.000	Ea.	5,358.60	3,343.40	8,702
Cooling tower, draw thru single flow, belt drive	1.000	Ea.	1,312.07	141.84	1,453.9
Cooling tower pumps & piping	1.000	System	656.04	337.18	993.2
Chilled water unit coil connections	2.000	Ea.	2,600	2,800	5,400
Chilled water distribution piping	520.000	L.F.	9,282	22,360	31,642
TOTAL			23,850.41	29,666.46	53,516.8
COST PER S.F.			5.96	7.42	13.38
*Cooling requirements would lead to choosing a water cooled unit.					


D30	Chilled Water, Cooling Tower Sy	ctome	C	OST PER S.F.	
	,	siems	MAT.	INST.	TOTAL
1300	The state of the s				
1320	Apartment corridors, 4,000 S.F., 7.33 ton		5.98	7.43	13.4
1600	Banks and libraries, 4,000 S.F., 16.66 ton	RD3030	10.40	8.15	18.55
1800	60,000 S.F., 250.00 ton	-010	7.40	6.55	13.9
1880	Bars and taverns, 4,000 S.F., 44.33 ton		18.75	10.30	29.0
2000	20,000 S.F., 221.66 ton		18.50	8.55	27.05
2160	Bowling alleys, 4,000 S.F., 22.66 ton		12.45	8.95	21.40
2320	40,000 S.F., 226.66 ton	8	10.30	6.25	16.55
2440	Department stores, 4,000 S.F., 11.66 ton		6.75	8.05	14.8
2640	60,000 S.F., 175.00 ton		6.60	6	12.60
2720	Drug stores, 4,000 S.F., 26.66 ton		13.20	9.20	22.4
2880	40,000 S.F., 266.67 ton		10.20	7.05	17.2
3000	Factories, 4,000 S.F., 13.33 ton		8.95	7.75	16.70
3200	60,000 S.F., 200.00 ton		6.60	6.30	12.9
3280	Food supermarkets, 4,000 S.F., 11.33 ton		6.65	8	14.6
3480	60,000 S.F., 170.00 ton		6.55	6	12.5
3560	Medical centers, 4.000 S.F., 9.33 ton		5.70	7.35	13.05
3760	60,000 S.F., 140.00 ton		5.30	6.05	11.3
3840	Offices, 4,000 S.F., 12.66 ton		8.65	7,70	16.35
4040	60,000 S.F., 190.00 ton		6.35	6.25	12.6
4120	Restaurants, 4,000 S.F., 20.00 ton		11.10	8.30	19.4
4320	60,000 S.F., 300.00 ton		8.30	6.80	15.1
4400	Schools and colleges, 4,000 S.F., 15.33 ton		9.85	8	17.85
4600			6.80	6.35	13.15

D401	D4010 Sprinklers Wet Pipe Sprinkler Systems COST PER S.F.										
D4010		Wet Pipe Sprinkler Systems									
0680		1000 S.F.	MAT. 1.29	INST.	TOTAL						
0700		2000 S.F.	1.20	2.24	3.5						
0720		5000 S.F.	.96	1.71	2.6						
0740		10,000 S.F.	.93	1.60	2.5						
0760	0 1	50,000 S.F.	.80	1.24	2.0						
1000	Ordin	ary hazard, one floor, 500 S.F. 1000 S.F.	2.76 3.56	3.02 2.85	5.78						
1040		2000 S.F.	3.83	3.07	6.9						
1060		5000 S.F.	2.16	2.19	4.3						
1080		10,000 S.F.	1.79	2.32	4.1						
1100		50,000 S.F.	1.47	2.19	3.6						
1140		Each additional floor, 500 S.F.	1.77	2.71	4.4						
1160 1180		1000 S.F. 2000 S.F.	1.25 1.35	2.20	3.4						
1200		5000 S.F.	1.35	2.10	3.4						
1220		10,000 S.F.	1.34	2.16	3.50						
1240		50,000 S.F.	1.14	1.92	3.06						
1500	Extra	hazard, one floor, 500 S.F.	6.65	4.69	11.34						
1520		1000 S.F.	4.53	4.07	8.60						
1540 1560		2000 S.F. 5000 S.F.	4.17 3.15	4.14 3.58	6.73						
1580		10,000 S.F.	2.61	3.44	6.0						
1600		50,000 S.F.	2.81	3.32	6.13						
1660		Each additional floor, 500 S.F.	2.02	3.38	5.40						
1680		1000 S.F.	1.95	3.21	5.16						
1700		2000 S.F.	1.80	3.20	5						
1720 1740		5000 S.F. 10,000 S.F.	1.61 1.67	2.82	4.43						
1760		50,000 S.F.	1.66	2.49	4.15						
2020	Grooved steel	black sch. 40 pipe, light hazard, one floor, 2000 S.F.	3.37	2.46	5.83						
2060		10,000 S.F.	1.30	1.59	2.89						
2100		Each additional floor, 2000 S.F.	.89	1.61	2.50						
2150 2200	Outin	10,000 S.F.	.60	1.36	1.96						
2250	Ordin	ary hazard, one floor, 2000 S.F. 10,000 S.F.	3.41	2.62 1.95	6.03 3.19						
2300		Each additional floor, 2000 S.F.	.93	1.77	2.70						
2350		10,000 S.F.	.79	1.79	2.58						
2400	Extra	hazard, one floor, 2000 S.F.	3.68	3.38	7.06						
2450		10,000 S.F.	1.68	2.53	4.21						
2500		Each additional floor, 2000 S.F. 10,000 S.F.	1.34	2.62	3.96						
3050	Grooved steel	black sch. 10 pipe, light hazard, one floor, 2000 S.F.	3.31	2.45	5.76						
3100	diooved steel	10,000 S.F.	1.02	1.51	2.53						
3150		Each additional floor, 2000 S.F.	.83	1.60	2.43						
3200		10,000 S.F.	.56	1.34	1.90						
3250	Ordin	ary hazard, one floor, 2000 S.F.	3.36	2.60	5.96						
3350		10,000 S.F. Each additional floor, 2000 S.F.	1.18	1.93	3.11						
3400		10.000 S.F.	.73	1.75	2.63						
3450	Extra	hazard, one floor, 2000 S.F.	3.63	3.38	7.01						
3500		10,000 S.F.	1.56	2.49	4.05						
3550		Each additional floor, 2000 S.F.	1.29	2.62	3.91						
3600 4050	0 11	10,000 S.F.	1.04	2.23	3.27						
4100	Copper tubing	, type M, light hazard, one floor, 2000 S.F. 10.000 S.F.	3.97	2.45	6.42						
4150		10,000 S.F. Each additional floor, 2000 S.F.	1.63 1.51	1.51 1.63	3.14						
4200		10,000 S.F.	1.17	1.35	2.52						
4250	Ordin	ary hazard, one floor, 2000 S.F.	4.15	2.75	6.9						




ystem Components				COST EACH	
ysiem components	QUANTITY	UNIT	MAT.	INST.	TOTAL
SYSTEM D5010 120 0220					
SERVICE INSTALLATION, INCLUDES BREAKERS, METERING, 20' CONDUIT & WIRE					
3 PHASE, 4 WIRE, 60 A					
Circuit breaker, enclosed (NEMA 1), 600 volt, 3 pole, 60 A	1.000	Ea.	695	208	903
Meter socket, single position, 4 terminal, 100 A	1.000	Ea.	48.50	182	230
Rigid galvanized steel conduit, 3/4", including fittings	20.000	L.F.	62.80	146	208
Wire, 600V type XHHW, copper stranded #6	.900	C.L.F.	87.75	80.55	168
Service entrance cap 3/4" diameter	1.000	Ea.	11.55	45	56
Conduit LB fitting with cover, 3/4" diameter	1.000	Ea.	15.75	45	60
Ground rod, copper clad, 8' long, 3/4" diameter	1.000	Ea.	33.50	110	143
Ground rod clamp, bronze, 3/4" diameter	1.000	Ea.	7.35	18.20	25
Ground wire, bare armored, #6-1 conductor	.200	C.L.F.	31	65	96
TOTAL			993.20	899.75	1.892

D50	10 12	20	Electric Service, 3 Phase - 4 Wire			COST EACH	
D O O	710 12		Electric Service, 5 Pilase - 4 Wire		MAT.	INST.	TOTAL
0200	Service inst	tallation, i	includes breakers, metering, 20' conduit & wire				
0220	3	phase, 4	wire, 120/208 volts, 60 A		995	900	1,895
0240			100 A		1,200	1,075	2,275
0280			200 A		1,825	1,675	3,500
0320			400 A	RD5010	4,300	3,050	7,350
0360			600 A	-110	8,100	4,150	12,250
0400			800 A		10,400	4,975	15,375
0440			1000 A		12,900	5,750	18,650
0480			1200 A		16,000	5,850	21,850
0520			1600 A		29,300	8,400	37,700
0560			2000 A		32,400	9,600	42,000
0570		Add	d 25% for 277/480 volt				
0580	11:						
0610	1;	phase, 3	wire, 120/240 volts, 100 A		525	980	1,505
0620			200 A		1,100	1,425	2,525



system Components				COST EACH	
your compensions	QUANTITY	UNIT	MAT.	INST.	TOTAL
SYSTEM D5010 240 0240					
SWITCHGEAR INSTALLATION, INCL SWBD, PANELS & CIRC BREAKERS, 600 A			1		
Panelboard, NQOD 225A 4W 120/208V main CB, w/20A bkrs 42 circ	1.000	Ea.	2,425	2,075	4,50
Switchboard, alum. bus bars, 120/208V, 4 wire, 600V	1.000	Ea.	4,775	1,175	5,95
Distribution sect., alum. bus bar, 120/208 or 277/480 V, 4 wire, 600A	1.000	Ea.	2,500	1,175	3,67
Feeder section circuit breakers, KA frame, 70 to 225 A	3.000	Ea.	4,125	546	4,67
the street					
TOTAL			13,825	4,971	18,79

D50	010 240		Switchgear			
			_	MAT.	INST.	TOTAL
	Switchgear inst., i	ncl. swbd., panels & circ bkr, 400 /	A, 120/208volt	4,425	3,675	8,100
0240		600 A		13,800	4,975	18,775
0280		800 A	RD5010	17,500	7,075	24,575
0320		1200 A	-110	21.000	10,900	31,900
0360		1600 A		28,300	15,200	43,500
0400		2000 A		35,700	19,400	55,100
0410	Add 20%	for 277/480 volt		10,100	23,100	30,200



ystem Components	QUANTITY	UNIT	COST PER S.F.			
ysiem components			MAT.	INST.	TOTAL	
SYSTEM D5020 110 0200						
RECEPTACLES INCL. PLATE, BOX, CONDUIT, WIRE & TRANS. WHEN REQUIRED				- 1		
2.5 PER 1000 S.F., .3 WATTS PER S.F.				- 1		
Steel intermediate conduit, (IMC) 1/2" diam	167.000	L.F.	.35	.98	1.3	
Wire 600V type THWN-THHN, copper solid #12	3.382	C.L.F.	.04	.18	.2	
Wiring device, receptacle, duplex, 120V grounded, 15 amp	2.500	Ea.		.04	.0.	
Wall plate, 1 gang, brown plastic	2.500	Ea.		.02	.0.	
Steel outlet box 4" square	2.500	Ea.	.01	.07	.08	
Steel outlet box 4" plaster rings	2.500	Ea.	.01	.02	.0.	
TOTAL			.41	1.31	1.73	

D50	D5020 110 Receptacle (by Wattage)		COST PER S.F.			
230	20 110	Ketepiutie (b)	wanage/	MAT.	INST.	TOTAL
0190	Receptacles inclu	de plate, box, conduit, wire & transformer when required				
0200	2.5 per 1000 S.F., .3 watts per S.F.		.41	1.31	1.72	
0240	With transformer RD5010		.48	1.37	1.85	
0280	4 per 10	000 S.F., .5 watts per S.F.	-110	.47	1.53	2
0320		With transformer		.57	1.63	2.20
0360	5 per 10	000 S.F., .6 watts per S.F.		.55	1.80	2.35
0400		With transformer		.68	1.93	2.61
0440	8 per 10	000 S.F., .9 watts per S.F.		.58	1.99	2.57
0480		With transformer	4	.76	2.17	2.93
0520	10 per 1	000 S.F., 1.2 watts per S.F.		.61	2.16	2.77
0560		With transformer		.91	2.45	3.36
0600	16.5 pe	1000 S.F., 2.0 watts per S.F.	*	.70	2.70	3.40
0640		With transformer		1.22	3.20	4.42
0680	20 per 1	000 S.F.,2.4 watts per S.F.	100	.74	2.93	3.67
0720		With transformer		1.34	3.51	4.85