
# Technical Report 4


Lateral System Analysis

Macenzie Ceglar Structural Option Advisor: Heather Sustersic




University of Virginia's College at Wise -New Library-

## **Elements Modeled**




# **Elements Modeled**




# **Base Conditions**

### • Pin Conditions

#### • Fixed Conditions






# Diaphragm Type

### Rigid

- Composite steel floor system with composite metal deck
- Ensures the shear forces are transmitted to the shear walls and not resisted by the diaphragm

# **Distribution of Forces: Wind**

- Horizontal
  - Applied at center of pressure
- Vertical
  - Applied at each story level



ASCE7-05 requires four different wind loading conditions be applied in order to account for quartering winds and torsion. Pressures were calculated for these four cases and applied as forces each story level using tributary area in order to transfer the load through the diaphragm to lateral elements.


# **Distribution of Forces: Seismic**

#### Horizontal

Applied at center of mass


Vertical

Applied at each story level




ASCE7-05 requires that accidental torsion be considered for both orthogonal directions, and orthogonal interaction effects are permitted to be neglected base on the seismic category B. Forces along with moments due to torsion were applied at each story level in order to transfer the load through the diaphragm to lateral elements.


# **Distribution of Forces: Soil**



- Max Soil Depth: 60 FT
- Equivalent Lateral Fluid Pressure: 47 PCF



## **Distribution of Forces: Soil**



# **Distribution of Forces: Soil**

#### Horizontal


 Applied at center of each wall section

#### Vertical

 Applied at each story level below grade

The equivalent lateral fluid pressure was converted into multiple point loads at each level based on tributary area and soil depth. Forces were applied at each story level in order to transfer the load through the diaphragm to lateral elements.


# Animation: Seismic X-Direction (+Moment)




## **Moment Diagram – Critical Members**

### Shear Wall 2

- Wall thickness at base: 33"
- Loading Condition: Soil Loads in the x-direction
- Maximum Moment: 65,214 K-FT







## **Moment Diagram** – Critical Members

### Shear Wall 6

- Wall thickness at base: 12"
- Loading Condition: Soil Loads in the x-direction
- Maximum Moment: 51,194 K-FT





# **Member Utilization Ratios**



### Criteria for Acceptability

- Strength
- Drift Wind
- Drift Seismic
- Overturning Moment

Strength

Controlling Load Combination:

0.9D + 1.0E +1.6H

Shear Wall 2

 $ightarrow \phi$ Vn = 14,140k > 4,585 k  $\rightarrow$  PASSED

• Shear Wall 6

### Orift - Wind

#### Drift criteria: H/400

Wind Load Cases					
Load Case	Maximum Drift (in)	Allowable Drift (in)	Pass/Fail		
Wind Case 1 X-Direction	0.588931	3.06	PASS		
Wind Case 1 Y-Direction	2.618755	3.06	PASS		
Wind Case 2 X-Direction (+M)	0.680642	3.06	PASS		
Wind Case 2 X-Direction (-M)	0.544755	3.06	PASS		
Wind Case 2 Y-Direction (+M)	2.843785	3.06	PASS		
Wind Case 2 Y-Direction (-M)	1.511819	3.06	PASS		
Wind Case 3	2.142169	3.06	PASS		
Wind Case 4 (+Moments in Same Direction)	3.006926	3.06	PASS		
Wind Case 4 (-Moments in Same Direction)	1.472554	3.06	PASS		
Wind Case 4 (+Moments in Opposite Direction)	2.286839	3.06	PASS		
Wind Case 4 (-Moments in Opposite Direction)	1.594228	3.06	PASS		

### Orift - Seismic

#### Drift criteria:

TABLE 12.12-1 ALLOWABLE STORY DRIFT,  $\Delta_a{}^{a,b}$ 

Occupancy Category		
I or II	III	IV
$0.025h_{sx}^{c}$	0.020h <sub>sx</sub>	0.015h <sub>sx</sub>
0.010h <sub>sx</sub>	$0.010h_{sx}$	0.010h <sub>sx</sub>
$0.007h_{sx}$	$0.007h_{sx}$	$0.007h_{sx}$
$0.020h_{sx}$	$0.015h_{sx}$	$0.010h_{sx}$
	$ \begin{array}{c} \text{I or II} \\ 0.025h_{sx}{}^c \\ \hline 0.010h_{sx} \\ 0.007h_{sx} \end{array} $	I or II         III $0.025h_{sx}{}^c$ $0.020h_{sx}$ $0.010h_{sx}$ $0.010h_{sx}$ $0.007h_{sx}$ $0.007h_{sx}$

#### Loading Conditions Checked

Seismic x-direction + eccentricity
Seismic x-direction - eccentricity
Seismic y-direction + eccentricity
Seismic y-direction - eccentricity

 $\rightarrow$  PASSED

### Overturning Moment

**Controlling Load Combination:** 

0.9D + 1.0E +1.6H

Overturning moment in the x-direction
 > M<sub>resist</sub> = 461,528 k-ft > M<sub>overturn</sub> = 73,764 k-ft → PASSED

Overturning moment in the y-direction

 $> M_{resist} = 1,496,161 \text{ k-ft} > M_{overturn} = 154,774 \text{ k-ft} \rightarrow PASSED$ 

### Conclusion

Lateral system acceptable according to industry standard serviceability and strength considerations.

# **Thank You! Any Questions?**

