




	General Information					
Presentation Outline	General Construction Information	General Electrical Information				
<ul> <li>Introduction         Location, Statistics, General Information     </li> <li>Actual Mechanical Design</li> </ul>	✤Turner Construction Company and STV Inc. will lead as joint General Contractors.	◆Electrical Engineers: WSP Flack + Kurtz				
System, Loads, Utility Costs Alternative Design Mechanical Depth: GSHP	New York Department of Design and Construction will be responsible for overseeing the progression of the project.	♦460/265V 3-Phase High Voltage system stepped down to 120/208 V 3-Phase Low Voltage System General Mechanical Information				
Electrical Breadth: PV Array Construction Breadth: Cost Analysis	General Structural Information Structural Engineers : Robert Silman Associates	♦Mechanical Engineers: WSP Flack + Kurtz				
* The Final Analysis Integration of Depths & Breadths Final Recommendation	<ul> <li>Structural Engineers : Robert Sinnan Associates</li> <li>Steel Super Structure</li> </ul>	♦Centralized Heating and Cooling Plant System				









	Ea	st Car	npus B	uilding	Loads	
Presentation Outline	Station         Latitud           New York, LaGaardia Aprt         40.78N	e Longitude Elevation i 73.88W 30	Heating DB         Cooling DB         Cooling DB         Cooling MCW           (99.5%)         0.4%         0.4%         0.4%           12.6         92.2         74.4	g Evaporation Evaporation MCDB 0.4% 77.2 87.2	Debunid DP 0.4%         Debunid HR 0.4%         Debunid MCDB 0.4%           74.3         185.5         \$1.0	<ul> <li>The East Campus was chosen as the specific building of study.</li> <li>East and West Campus essentially two separate buildings</li> <li>375,405 SF</li> </ul>
Alternative Design     Mechanical Depth: GSHP     Electrical Breadth: PV Array	Cooling Load Heating Load	Tons 1235.5	<b>ft²/ton</b> 303.84	MBh 14826.4 -10,104.2	Btu/hr ft <sup>2</sup> 39.49 -26.92	<ul> <li>TRANE Trace 700 Used</li> <li>Location: LaGuardia Airport (1.6 miles from NYPA)</li> </ul>
Construction Breadth: Cost Analysis     The Final Analysis     Integration of Depths & Breadths			·	·		<ul><li>◆Block Load Analysis</li><li>◆52 Zones</li></ul>
Final Recommendation						
M. Scavelli Mechanical Option Senior Thesis 2010-2011	The Penns	ylvania State U	niversity: Departi	ment of Architectu	iral Engineering	Master/Bachelor of Architectural Engineering Student


Presentation Outline	Source	Electricity Consumption [kWh]	The East Campus was chosen as the specific building of study
	Primary Heating	10,945 (does not include gas consumption)	East and West Campus essentially two separate buildings
Location, Statistics, General Information	Primary Cooling	1,745,320	◆375.405 SF
* Actual Mechanical Design	Auxiliary	103,668	
System, Loads, Utility Costs	Lighting	2,986,304	
* Alternative Design	Receptacle	839,635	
Mechanical Depth: GSHP	Totals	5,685,782	♦ TRANE Trace 700 Used
Electrical Breadth: PV Array Construction Breadth: Cost Analysis	Primary Heating	Natural Gas Consumption[kBtu]	♦Location: LaGuardia Airport (1.6 miles from NYPA)♦Block Load Analysis
* The Final Analysis	Natural Gas Boiler	· · · · · · · · · · · · · · · · · · ·	✤52 Zones
Integration of Depths & Breadths Final Recommendation			


Presentation Outline * Introduction		-	ergy Ut	✤ The East Campus was chosen as the specific building of study	
Location, Statistics, General Information Ener Actual Mechanical Design	rgy Cost	Energy Consumption	Building Size (East Campus Only)	Utility Price/ ft <sup>2</sup> • yr	♦East and West Campus essentially two separate buildings ♦375,405 SF
System, Loads, Utility Costs	11 /kWh	5,634,061 kWh/yr	375,405 ft <sup>2</sup>	\$2.507 / ft <sup>2</sup> • yr	
Alternative Design     Mechanical Depth: GSHP	858/1000 ft <sup>3</sup> NG	5,530,679 kBtu/yr	375,405 ft <sup>2</sup>	\$.1699/ ft <sup>2</sup> • yr	♦TRANE Trace 700 Used
Electrical Breadth: PV Array	Total Utility Cost: \$2.677/ ft <sup>2</sup> • yr				<ul> <li>Location: LaGuardia Airport (1.6 miles from NYPA)</li> <li>Block Load Analysis</li> </ul>
Construction Breadth: Cost Analysis	Annual Cost: \$1,004,921/yr				
* The Final Analysis Integration of Depths & Breadths Final Recommendation					◆52 Zones


















		Energy N	/Iodeling	GSHP Major Discussion Topics	
Presentation Outline		GSHP			<b>◆</b> Justification
* Introduction	Yearly Electricity Consumption [kWh]			• 0 0 1 1	
Location, Statistics, General Information	System	CP	GSHP	Δ	♦ System Schematics
	Primary Heating	10,945*	421,204	-410,259	
* Actual Mechanical Design	Primary Cooling	1,745,320	833,324	911,996	*C 16 U D U C'
System, Loads, Utility Costs	Auxiliary	103,668	96,049	7,619	♦Ground Source Heat Pump Loop Sizing
	Lighting	2,986,304	2,986,304	0	
Alternative Design Mechanical Depth: GSHP	Receptacle Totals	839,635 5,685,782	839,635 5,176,517	0 509,265	✤Energy Modeling
Electrical Breadth: PV Array Construction Breadth: Cost Analysis		Natura	Gas Consumption [kBtu] GSHP System		♦Utility Cost Comparison
	Primary Heating	Central Plant	GSHP System	Δ	
Integration of Depths & Breadths Final Recommendation	Natural Gas Boilers	5,530,679	0	5,530,679	
L. Scavelli Mechanical Option Senior Thesis 2010-2011	The Pennsylvania	State University: Depa	tment of Architectur	al Engineering	Master/Bachelor of Architectural Engineering Student








































	Construction C	ost Construction Discussion Topics
Presentation Outline	Costs	Length Optimization
Introduction Location, Statistics, General Information	Cost of Cooling Towers Cost_ct	3.837.433 \$40,700 1006.000 ♦Construction Cost
Actual Mechanical Design     System, Loads, Utility Costs	Savings on Chillers Saving_chlr Savings on Boilers Saving_blr Saving_blr	5278 208 ⊨170 200 89,325 ◆Life Cycle Cost Analysis
Alternative Design     Mechanical Depth: GSHP     Electrical Breadth: PV Array	Variables	
Construction Breadth: Cost Analysis	Length of GSHP L_gshp 249,047	(ft)
Integration of Depths & Breadths Final Recommendation	Water Circulation         G         22663           GSHP Cooling         Q         1009           CT Supplementary Cooling         203         % of Cooling         83.2%           % of Cooling         00.0%         % of Cooling         100.0%	(galons) [tons] [tons] [%]
4. Scavelli Mechanical Option Senior Thesis 2010-2011	The Pennsylvania State University: Department of Archit	

