

Technical Report One

ASHRAE Standards 62.1 AND 90.1 Analysis

9/23/2011

New Castle Center for Delaware Hospice, Inc.



New Castle, DE

Image By: Skanska

Zachary Klixbull

Penn State University

Architectural Engineering

Advisor: Professor Bahnfleth

Mechanical Option

Table of Contents

Executive Summary	3
Mechanical System Overview	3
ASHREA 62.1	5
Section 5 Compliance	5
Section 6 Procedure	9
ASHREA 90.1	15
Section 5 Building Envelope	15
Section 6 Heating, Ventilating, and Air Conditioning	17
Section 9 Lighting	18
Executive Summary	3
Reference	19
Appendix	20

Executive Summary

The purpose of this report is to see if New Castle Center for Delaware Hospice is compliance with ASHREA Standard 62.1-2007 and Standard 90.1-2007. New Castle Center for Delaware Hospice is a two story building of 65,000 SF medical and administration. Image 1 (page 4) shows the location of the site for Google maps. Throughout the report New Castle Center for Delaware Hospice may show as DE Hospice to shorten the name. The DE Hospice is divided into two buildings connected by a Lobby area. Building A is a one story building with the main entrance and patient area facilities for the DE Hospice. The support services and administration are in the two story building B. Building A has patient rooms open to an outside patio and a courtyard for the inner patient rooms. DE Hospice has aluminum curtain wall systems with manufactured stone for the lower part of the exterior wall for the first floor and manufactured stone for some exterior walls. The manufactured stone is also used chimney on the East side of building B. The building is topped with asphalt shingles on the gable roof and cupolas. Windows are cladwood windows with louvers for shading.

ASHREA Standard 62.1-2007 Analysis has two parts, section 5 systems and equipment and section 6 ventilation rate procedures. In section 5 the buildings is looked at equipment and system issues such as preventing mold growth, re-entry of contaminated air, and particulate filtration. Section 6 the building is determined whether it meets ventilation and exhaust requirements at design conditions.

ASHREA Standard 90.1-2007 is looking at the building's compliance with energy design. Section 5 covers Building Envelope effects of insulation and glazing. Section 6 Heating, Ventilation, and Air Conditioning systems cover the design and efficiency of systems like the air handling unit electric motor efficiency. Section 7 Service Water Heating looking at boiler and hot water storage efficiency. Section 9 Lighting covering the power density of the lights throughout the building.

Mechanical System Overview

The DE Hospice is a geothermal based mechanical cooling and heating system. The geothermal wells are under the east parking lot and in to the mechanical room in the basement. Then it is piped up to the attic where heat pump units and energy recovery units are. The water to water geothermal heat pump exchanges the energy from 20% glycol source to the R410A refrigerant.

September 23,
2011

Zachary Klixbull
Mechanical Option

DE Hospice

Advisor: Professor Bahnfleth

The refrigerant goes to heat pump units throughout the attic and the three ventilation heat pumps. The mechanical system does use two energy recover units that are located in the attic with the heat pumps. There are eight mechanical rooms in the attic. One mechanical room in the attic is not in line with an energy recovery unit or ventilation heat pump unit, it receives outside air directly to a regular heat pump. (see ASHREA Standard 62.1-2007 section 6 and appendix for more information on the mechanical ventilation)




Image 1: A is the location of site, Image by maps.google.com

ASHRAE 62.1

Section 5 Analysis

Section 5.1 Natural Ventilation

Natural ventilation for this building is not possible, because the windows do not open.

Section 5.2 Ventilation Air Distribution

The ventilation air distribution has the ability to be adjusted to achieve balanced air distribution. The ventilation rate schedule (table 1, page 5) shows the air distribution to the different rooms listed in table 1.

Section 5.3 Exhaust Duct Location

Most exhaust ducts end in the attic space, where exhaust fans are negatively pressurizing the space relative to the spaces below and the outside.

Section 5.4 Ventilation Air Distribution

The rooms' ventilation system controls are manually set with heat pump units or heat pump units, energy recovery units or heat pump and VHP having a fixed position for minimum supply airflow.

Section 5.5 Airstream Surfaces

Sheet metal and metal fasteners are used for ducts making it mold growth and erosion resistant. The airstream surfaces of HVAC systems are mold growth and erosion resistant.

Section 5.6 Outdoor Air Intakes

Outdoor air intakes are located a safe distance away from outdoor contaminant sources and exhaust fans in accordance with ASHRAE 62.1-2007 Table 5-1. Select louvers are used to prevent rain and wind penetration.

September 23,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth

Ventilation Rate Schedule

Area Designation	Pressure Relationship to Adjacent Area	Minimum Air Change of Outdoor Air per Hour	Minimum Total Air Changes per Hour	All Air Exhausted Directly to Outdoors	Space Air Recirculate within Room
Resident room	Equal	2	2	Optional	Optional
Resident area corridor	Equal	Optional	4	Optional	Optional
Physical therapy	Negative	2	6	Optional	Optional
Occupational therapy	Negative	2	6	Optional	Optional
Soiled workroom	Negative	2	10	Yes	No
Clean workroom	Negative	2	4	Optional	Optional
Toilet room	Negative	Optional	10	Yes	No
Bathroom	Negative	Optional	10	Yes	No
Janitor's closet	Negative	Optional	10	Yes	No
Sterilizer equip. rm.	Negative	Optional	10	Yes	No
Line chute room	Negative	Optional	10	Yes	No
trash chute room	Negative	Optional	10	Yes	No
Food Preparation	Equal	2	10	Yes	Yes
Warewashing room	Negative	Optional	10	Yes	Yes
Dietary day storage	Equal	Optional	2	Yes	No
Laundry, general	Equal	2	10	Yes	No
Soiled line sorting	Negative	Optional	10	Yes	No
Clean line storage	Positive	Optional	2	Yes	No
Special care room	Negative	2	12	Yes	No
Dining	Equal	2	4	Optional	Optional
Activity room	Equal	4	6	Optional	Optional
Resident gathering	Equal	4	4	Optional	Optional

Table 1: Ventilation Rate Schedule for M001 of drawings

Section 5.8 Combustion Air

All combustion air from boiler, generator and other fuel-burning appliances has sufficient air for combustion and removal of combustion products.

Section 5.9 Particulate Matter Removal

All Air Handling Units and Make-up Air Unit should have disposable panel filters with MERV (ASHRAE 52.2) 7.

Section 5.10 Dehumidification

Building is designed for 50% RH +/- 5% with the building being positively pressurized.

Section 5.11 Drain Pans

The energy recovery units, heat pump units and coiling coils meet minimum requirements for drain pans slope, outlet, seal, and size.

Section 5.12 Finned-Tube Coils and Heat Exchangers

Cooling coils and heat exchangers have at least 18 inches of access space for cleaning.

Section 5.13 Humidifiers and Water-Spray Systems

Humidification is to be handled by return air.

Section 5.14 Access for Inspection, Cleaning, and maintenance

All equipment with access doors has sufficient working space for inspection and routine maintenance.

Section 5.15 Building Envelope and Interior Surfaces

Building envelope has weather barrier on walls and membrane roofing. Pipes and ducts that could reach temperature lower than dew-point are insulated.

Section 5.16 Buildings with Attached Parking Garages

The building has a parking lot, no parking garage.

September 23,
2011

Zachary Klixbull

Mechanical Option

TECHICAL REPORT ONE

DE Hospice

Advisor: Professor Bahnfleth

Section 5.17 Air Classification and Recirculation

The building is mostly Air Class 1, except for kitchen (Air Class 4) and restrooms (Air Class 2), which are exhausted out of space to outdoors.

Section 5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas

The building is medical office and no smoking is allowed within the building.

Section 6 Analysis

Ventilation Rate Procedure

Ventilation Heat Pump Units (VHP-1 thru -3) and Energy Recovery units (ERU-1 and-2) has been taken analysis of for the ventilation rate procedure. In this section the five zones that are identified in DWG-1,-2,-3 and -4 (pages 11-14).

Breathing Zone Outdoor Airflow (Vbz)

$$Vbz = R_p * P_z + R_a * A_z \quad (\text{Eq 6-1})$$

Zone Outdoor Airflow (Voz)

$$Voz = Vbz/Ez \quad (\text{Eq 6-2})$$

Single-Zone System (Vot)

$$Vot = Voz \quad (\text{Eq 6-3})$$

100% Outdoor Air Systems

$$Vot = \sum_{\text{all zones}} Voz \quad (\text{Eq 6-4})$$

Zone Primary Outdoor Air Fraction (Zp)

$$Z_p = Voz/V_{p_z} \quad (\text{Eq 6-5}).$$

Uncorrected Outdoor Air Intake (Vou)

$$Vou = D * \sum_{\text{all zones}} (R_p * P_z) + \sum_{\text{all zones}} (R_a * A_z) \quad (\text{Eq 6-6})$$

$$D = P_s / \sum_{\text{all zones}} P_z \quad (\text{Eq 6-7})$$

Outdoor Air Intake (Vot)

$$Vot = Vou/E_v \quad (\text{Eq 6-8})$$

Where

- Az = zone floor area (SF)
- Pz = zone population (Table 6-1)
- Rp = outdoor airflow rate per person (CFM/Person)
- Ra = outdoor airflow rate per unit area (CFM/SF)
- Ez = zone air distribution effectiveness (Table 6-2)
- Vpz = zone primary airflow
- Ps = system population
- D = occupant diversity
- Ev = system ventilation efficiency based on max Zp (Table 6-3)

In the appendix have further calculations for ventilation rate procedure and values of the define information for calculation above. All information for this calculation came from drawings and specification provide by Skanska.

Section 6 Results

VHP-1 has a ventilation system efficiency of 95% with critical zone being the large conference room. VHP-2 has a ventilation system efficiency of 68% with critical zone being a conference room. VHP-3 has 255% outdoor air as a % of design primary supply air. This shows a low design primary supply fan airflow rate. ERU-1 has 404% outdoor air as a % of design primary supply air. This shows a low design primary supply fan airflow rate. ERU-2 has 510% outdoor air as a % of design primary supply air. This shows a low design primary supply fan airflow rate

September 23,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth



DWG 1: From left to right: ERU-1 (see appendix pages 28-30), VHP-1 (see appendix pages 19-20)


September 23,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth



DWG 2: ERU-2 (see appendix pages 31-33)

September 23,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth



DWG 4: From left to right: VHP-2 (see appendix pages 21-23), VHP-3 (see appendix pages 24-27)

ASHRAE 90.1

Section 5 Analysis- building Envelope

Section 5.1.4 Climate

The site is in New Castle, DE, climate zone 4. See Fig. 5.1.4




Fig. 5.4.1 United State Locations (image by resourcecenter.pnl.gov)

Section 5.5 Prescriptive Building Envelope Option

The building envelope was analyzed by prescriptive building procedure. Table 5.5-4 from ASHRAE Standard 90.1-2007 was used for building envelope requirements for climate zone 4A. Table 2 shows vertical fenestration area being less than 40% of the gross wall area. Table 3

shows minimum insulation value for the building's type of material and also shows minimum glassing insulation value and maximum shading coefficient.

Fenestration Area

Façade	Glass (SF)	Gross Wall (SF)	Glass %	Complies
North	1328	6291	21.1%	Yes
East	1240	6812	18.2%	Yes
South	1563	7139	21.9%	Yes
West	1694	6294	26.9%	Yes

Table 2

Construction	Description	90.1 Zone 4		Building		Complies
		U Max	R Min	U-Factor	R-Value	
Roof	Insulation Entirely above Deck	0.048	20	0.020	49	Yes
Walls	Mass	0.104	9.5	0.067	15	Yes
Floors	Mass	0.087	8.3	0.087	8.3	Yes
Fenestration		U Max	SHGC Max	U-Factor	SHGC	
Metal Framing	Windows	0.55	0.4	0.28	0.40	Yes
Metal Framing	Doors	0.85	0.4	0.28	0.40	Yes

Table 3

September 23,
2011

Zachary Klixbull

DE Hospice

Mechanical Option

Advisor: Professor Bahnfleth

Section 6 Analysis- Heating, Ventilating, and Air Conditioning

The building's gross area exceeds 25,000 SF. Mandatory provisions' zone isolation procedure was used for table 3. Fans are variable volume, so CFM * 0.0015 should be greater than horsepower for that equipment.

Fans	CFM	CFM*0.0015	HP	Comply
EF-1,2	125	3/16	1/4	No
EF-3	175	21/80	1/15	Yes
EF-4	200	3/10	9/79	Yes
EF-5	100	3/20	3/28	Yes
EF-6,7	200	3/10	9/79	Yes
EF-8	1400	2 1/10	1/2	Yes
EF-9	700	1 1/20	1/4	Yes
EF-10	100	3/20	1/4	No
EF-11	150	9/40	1/4	No
EF-12,13	2175	3 21/80	1/4	Yes
EF-14	1750	2 5/8	1/6	Yes
EF-15	2700	4 1/20	1/3	Yes
EF-16	2300	3 9/20	1/4	Yes
EF-17	3000	4 1/2	1/4	Yes
KEF-1	1400	2 1/10	1/2	Yes
VEF-1	250	3/8	1/4	No

Fans	CFM	CFM*0.0015	HP	Comply
HP-1	260	2/5	1/10	No
HP-2	330	1/2	1/10	No
HP-3	430	2/3	1/10	No
HP-4	530	3/4	1/4	No
HP-5	710	1	1/4	No
HP-6	940	1 2/5	1/2	No
HP-7	1150	1 5/7	1/2	No
HP-8	1260	1 8/9	1/2	No
HP-9	1710	2 4/7	3/4	No
VHP-1	1250	1 7/8	1	Yes
VHP-2	2140	3 1/5	2	No
VHP-3	2265	3 2/5	2	No
MAU-1	1120	1 2/3	1/2	No
ERU-1	1555	2 1/3	1 1/2	No
ERU-2	1825	2 3/4	2	No

Table 4

Section 9 Analysis- Lighting

According to Table 9.6.1 of ASHREA Standards 90.1-2007, the building –specific space type of exam/treatment has a limit of 1.5 W/SF. The building has been designed to 1.5 W/SF and therefore it complies with ASHREA Standards 90.1-2007.

ASHREA Standards 90.1 Results

TH DE Hospice does well for ASHREA Standards 90.1 until the supply air fans HP is overall to low for section 6 of analysis (table 4), it doesn't comply. DE Hospice does comply with all other sections of ASHREA Standards 90.1.

Reference

ASHREA, 2007, ANSI/ASHARE, Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc. Atlanta, GA

ASHREA, 2007, ANSI/ASHARE, Standard 90.1-2007, Energy Standard for Buildings Except Low-rise Residential Buildings. American Society of Heating, Refrigerating, and Air Conditioning Engineers, Inc. Atlanta, GA

Building: DE Hospice Building A		System	
System Tag/Name: VHP-1		3363	
Operating Condition Description: Ventilation Heat Pump		103	
Units (select from pull-down list)		1,250	
		0.10	
		5.0	
Inputs for System			
Floor area served by system	Name	Units	
Population of area served by system (including diversity)	AS	SI	
Design primary supply fan airflow rate	Ps	P	
OA req'd per unit area for system (Weighted average)	Vpsd	cfm	100% diversity
OA req'd per person for system area (Weighted average)	Ras	cfm/sf	
	Rps	cfm/ps	
	Er		
Inputs for Potentially Critical Zones			
Zone Name	HP-2	HP-5	HP-2
Zone Tag	1	2	3
Space Use	Libraries	Office space	Corridors
Floor Area of zone	120	120	350
Design population of zone	1.2	0.6	1.0
Design total supply to zone (primary plus local recirculated)	330	710	430
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air as a representative of zone system return air			
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	65.0%
Air distribution type at conditioned analyzed	Dz		
Zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed	Ez		
Results			
Ventilation System Efficiency	Ev		0.96
Outdoor air intake required for system	Vot	cfm	900
Outdoor air per unit floor area	Vol/As	cfm/sf	0.27
Outdoor air per person served by system (including diversity)	Vol/Ps	cfm/ps	8.7
Outdoor air as a % of design primary supply air	Ypd	cfm	72%
Unitized calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= 7870
Uncorrected OA requirement for system	Vou	cfm	= 852
Uncorrected OA req'd as a fraction of primary SA	Xs		= 0.11
Initial Calculations for Individual zones			
OA rate per unit area for zone	Raz	cfm/sf	
OA rate per person	Rpz	cfm/ps	
Total supply air to zone (at condition being analyzed)	Vz	cfm	
Unused OA req'd to breathing zone	vzb	cfm	
Unused OA requirement for zone	vzb/Ez	cfm	
Fraction of zone supply not directly recirc. from zone	Fa		
Fraction of zone supply from fully mixed primary air	Fb		
Fraction of zone OA not directly recirc. from zone	Fc		
Unused OA fraction required in supply air to zone	Zd		
Unused OA fraction required in primary air to zone	Zp		
System Ventilation Efficiency (App. A Method)			
Zone Ventilation Efficiency (App. A Method)	Evz		= (Fa + FbXs - FcZ) / Fa
System area efficiency (App. A Method)	Ev		= min(evz)
Ventilation System Efficiency (Table 6.3 Method)	Ev		= Value from Table 6.3
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	= Vou / Ev
OA intake req'd as a fraction of primary SA	Y		= Vol / Vps
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= 900
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= 882
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= 0.11
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum	Deg F		= -77

VHP-1

Building: DE Hospice Building A																			
System Tag/Name: VHP-1																			
Operating Condition Description: Ventilation Heat Pump																			
Units (select from pull-down list)																			
Inputs for System	<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>AG</td> <td>sf</td> <td>3325</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>103</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>1,250</td> </tr> <tr> <td>Ras</td> <td>ch/sf</td> <td>0.10</td> </tr> <tr> <td>Rps</td> <td>ch/p</td> <td>5.0</td> </tr> </table>	Name	Units	System	AG	sf	3325	Ps	P	103	Vpsd	cfm	1,250	Ras	ch/sf	0.10	Rps	ch/p	5.0
Name	Units	System																	
AG	sf	3325																	
Ps	P	103																	
Vpsd	cfm	1,250																	
Ras	ch/sf	0.10																	
Rps	ch/p	5.0																	
<p>Floor area served by system</p> <p>Population of area served by system (including diversity)</p> <p>Design primary supply fan airflow rate</p> <p>OA req'd per unit area for system (Weighted average)</p> <p>OA req'd per person for system area (Weighted average)</p> <p>Inputs for Potentially Critical zones</p> <p>Zone Name</p> <p>Zone Tag</p> <p>Space type</p> <p>Floor Area of zone</p> <p>Design population of zone</p> <p>Design total supply to zone (primary plus local recirculated)</p> <p>Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?</p> <p>Local recirc. air as a percentage of area system return air</p>	<p>Select from pull-down list</p> <p>Select from pull-down list</p> <p>Select from pull-down list</p> <p>Select from pull-down list or leave blank if N/A</p>																		
Inputs for Operating Condition Analyzed	<table border="1"> <tr> <th>Conference/m</th> <th>Conference/m</th> </tr> <tr> <td>8</td> <td>9</td> </tr> <tr> <td>HP-7</td> <td>HP-7</td> </tr> </table> <p>Zone <i>like turns purple table for critical zones</i></p>	Conference/m	Conference/m	8	9	HP-7	HP-7												
Conference/m	Conference/m																		
8	9																		
HP-7	HP-7																		
Results	<table border="1"> <tr> <td>Ds</td> <td>%</td> <td>830%</td> <td>100%</td> <td>100%</td> </tr> <tr> <td>cz</td> <td></td> <td>CS</td> <td>CS</td> <td>CS</td> </tr> <tr> <td>Ep</td> <td></td> <td>1.00</td> <td>1.00</td> <td>1.00</td> </tr> </table> <p>Ev = 0.95 Vot = 900 Vot/As = 0.27 Vot/Ps = 8.7 Vot/Ps = 72%</p>	Ds	%	830%	100%	100%	cz		CS	CS	CS	Ep		1.00	1.00	1.00			
Ds	%	830%	100%	100%															
cz		CS	CS	CS															
Ep		1.00	1.00	1.00															
General Calculations	<p>Initial Calculations for the System as a whole</p> <p>Primary supply air flow to system at conditioned analyzed = 7870</p> <p>Unrecirculated OA requirement for system = 852</p> <p>Unrecirculated OA req'd as a fraction of primary SA = 0.11</p> <p>Initial Calculations for Individual zones</p> <p>OA rate per unit area for zone</p> <p>Total supply air to zone (at condition being analyzed)</p> <p>Unused OA req'd to treating zone</p> <p>Unused OA requirement for zone</p> <p>Fraction of zone supply not directly recirc. from zone</p> <p>Fraction of zone OA not directly recirc. from zone</p> <p>Unused OA fraction required in supply air to zone</p> <p>Unused OA fraction required in primary air to zone</p> <p>System Ventilation Efficiency</p> <p>Zone Ventilation Efficiency (App A Method) = 0.90</p> <p>System Ventilation Efficiency (App A Method) = 0.99</p> <p>Ventilation System Efficiency (Table 6.3 Method)</p> <p>Minimum outdoor air intake airflow</p> <p>Outdoor Air Intake Flow required to System = 900</p> <p>OA Intake req'd as a fraction of primary SA = 0.11</p> <p>Outdoor Air Intake Flow required to System (Table 6.3 Method) = 862</p> <p>OA Intake req'd as a fraction of primary SA (Table 6.3 Method) = 0.11</p> <p>OA Temp. at which Min OA provides all cooling</p> <p>OAT below which OA intake flow is @ minimum = -77</p>																		

VHP-1

Building: DE Hospice Building B		System	
System Tag/Name: VHP-2		HP-2	
Operating Condition Description: Ventilation Heat Pump		Office space	
Units (select from pull-down list)		HP-3	
		Office space	
		HP-4	
		Office space	
		HP-5	
		Office space	
		HP-6	
		Office space	
		HP-7	
		Office space	
Inputs for System			
Floor area served by system	Name	Units	
Population of area served by system (including diversity)	As	sf	3102
Design primary supply fan airflow rate	P	cfm	54
OA req'd per unit area for system (Weighted average)	Vpsd	cfm	2,140
OA req'd per person for system area (Weighted average)	Ras	cfm/sf	0.10
	Rps	cfm/sf	5.0
Inputs for Potentially Critical Zones			
Zone Name	Zone Tag		
Space type			
Floor Area of zone	AZ	sf	765
Design population of zone	Pz		130
Design total supply to zone (primary plus local recirculated)	P	cfm	3,825
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Vtdz	cfm	1260
Local recirc. rate, % contrib. of air system return air	Er	%	
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	67.7%
Air distribution type at conditioned analyzed	Ds	%	
Zone air circulation effectiveness at conditioned analyzed	Ez		
Primary air fraction of supply air at conditioned analyzed	Ep		
Results			
Ventilation System Efficiency	Ev		0.68
Outdoor air intake required for system	Vot	cfm	1896
Outdoor air per unit floor area	Vot/As	cfm/sf	0.23
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/sf	20.2
Outdoor air as a % of design primary supply air	Ypd	cfm	88%
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= 14490
Uncorrected OA req'd for system	Vou	cfm	= 1260
Uncorrected OA req'd as a fraction of primary SA	Xs		= 0.09
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	cfm/sf	= 0.06
OA rate per person	Rpz	cfm/sf	= 5.00
Total supply air to zone (at condition being analyzed)	Vdz	cfm	= 330
Unused OA req'd to breathing zone	vz	cfm	= 37.2
Unused OA requirement for zone	Voz	cfm	= 65.0
Fraction of zone supply not directly recirc. from zone	Fa		= 85
Fraction of zone supply from fully mixed primary air	Fb		= 1.00
Fraction of zone OA not directly recirc. from zone	Fc		= 1.00
Unused OA fraction required in supply air to zone	Zd		= 0.11
Unused OA fraction required in primary air to zone	Zp		= 0.05
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Ez		= 0.98
System Ventilation Efficiency (App A Method)	Ev		= 0.68
Ventilation System Efficiency (Table 6.3 Method)	Ev		= 0.74
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	= 1896
OA intake req'd as a fraction of primary SA	Y		= 0.13
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= 1740
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= 0.12
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum	Deq F		= -58

VHP-2


Building: DE Hospice Building B		System	
System Tag/Name: VHP-2		VHP-2	
Operating Condition Description: Ventilation Heat Pump		Ventilation Heat Pump	
Units (select from pull-down list)		Units	
Floor area served by system	AS	sf	3195
Population of area served by system (including diversity)	Ps	P	94
Design primary supply fan airflow rate	Vpsd	cfm	2,140
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.10
OA req'd per person for system area (Weighted average)	Rps	cfm/p	5.0
Inputs for Potentially Critical Zones			
Zone Name	HP-2	HP-3	HP-4
Zone Tag	8	9	10
Space type	Office space	Conference/Meeting	Office space
Floor Area of zone	325	425	110
Design population of zone	1625	2125	0.55
Design total supply to zone (primary plus local recirculated)	330	1260	330
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave. system return air			
Zone like turns purple italic for critical zone(s)			
Zone Tag	HP-2	HP-3	HP-4
Space type	Office space	Conference/Meeting	Office space
Floor Area of zone	325	425	110
Design population of zone	1625	2125	0.55
Design total supply to zone (primary plus local recirculated)	330	1260	330
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave. system return air			
Inputs for Potentially Critical Zones			
Zone Name	HP-2	HP-3	HP-4
Zone Tag	8	9	10
Space type	Office space	Conference/Meeting	Office space
Floor Area of zone	325	425	110
Design population of zone	1625	2125	0.55
Design total supply to zone (primary plus local recirculated)	330	1260	330
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave. system return air			
Results			
Percent of total design airflow rate at conditioned analyzed	Ds	%	67%
Air distribution type at conditioned analyzed	Ev	cfm	0.68
Zone air distribution effectiveness at conditioned analyzed	Vot	cfm	1696
Primary air fraction of supply air at conditioned analyzed	Vot/As	cfm/sf	0.23
Ventilation System Efficiency	Vot/Ps	cfm/p	20.2
Outdoor air intake required for system	Ypd	cfm	89%
Outdoor air per unit floor area			
Outdoor air per person served by system (including diversity)			
Outdoor air as a % of design primary supply air			
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	14480
Unrecirculated OA requirement for system	Vou	cfm	1269
Unrecirculated OA req'd as a fraction of primary SA	Xs	=	0.09
Initial Calculations for Individual zones			
OA rate per unit area for zone	Raz	cfm/sf	0.06
OA rate per person	Rpz	cfm/p	5.00
Total supply air to zone (at condition being analyzed)	Vaz	cfm	5.00
Unused OA req'd to breathing zone	Vbz	cfm	1,260
Unused OA requirement for zone	Voz	cfm	131.8
Fraction of zone supply not directly recirc. from zone	Fa	=	28
Fraction of zone supply from fully mixed primary air	Fb	=	Ep + (1-Ep)Er
Fraction of zone OA not directly recirc. from zone	Fc	=	1 - (1-Ez)(1-Ep)(1-Er)
Unused OA fraction required in supply air to zone	Zd	=	Voz / Vaz
Unused OA fraction required in primary air to zone	Zp	=	Voz / Vpz
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz	=	(Fa + Fb)(S - FzZ) / Fa
System Ventilation Efficiency (App A Method)	Ev	=	min(EVz)
Ventilation System Efficiency (Table 6.3 Method)	Ev	=	Value from Table 6.3
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	1696
OA intake req'd as a fraction of primary SA	Y	=	Vot / Vps
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	1740
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y	=	Vot / Vps
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum	Deg F	=	((Tt-dTsf)-(1-Y)Tr)+dTrr
			-58

VHP-2

Building: DE Hospice Building B		System	
System Tag/Name: VHP-2		VHP-2	
Operating Condition Description: Ventilation Heat Pump		Ventilation Heat Pump	
Units (select from pull-down list)		Units	
Floor area served by system	AS	sf	8183
Population of area served by system (including diversity)	Ps	P	94
Design primary supply fan airflow rate	Vpsd	cfm	2,140
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.10
OA req'd per person for system area (Weighted average)	Rps	cfm/ps	5.0
Inputs for Potentially Critical Zones			
Zone Name			
Zone Tag			
Spaces Type			
Floor Area of zone	AZ	sf	Select from pull-down list
Design population of zone	Pz	P	(default value listed, may be overridden)
Design total supply to zone (primary plus local recirculated)	Vztd	cfm	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Er		Select from pull-down list or leave blank (N/A)
Local recirc. air % represent % of ave system return air			
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	67.7%
Air distribution type at conditioned analyzed	Ez		
Zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed			
Results			
Ventilation System Efficiency	Ev		0.68
Outdoor air intake required for system	Vot	cfm	1896
Outdoor air per unit floor area	Vot/As	cfm/sf	0.23
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/ps	20.2
Outdoor air as a % of design primary supply air	Ypd	cfm	89%
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= VpdDs = 14480
Uncorrected OA requirement for system	Vou	cfm	= Rps Ps + Ras As = 1289
Uncorrected OA req'd as a fraction of primary SA	Xs		= Vou / Vps = 0.09
Initial Calculations for Individual Zones			
OA rate per unit area for zone	Raz	cfm/sf	
OA rate per person	Rpz	cfm/ps	
Total supply air to zone (at condition being analyzed)	Vz	cfm	= Rps Pz + Raz Az = 0.06
Unused OA req'd to breathing zone	Vbz	cfm	= Vbz/Ez = 5.00
Unused OA requirement for zone	Voz	cfm	= Vbz/Ez = 5.00
Fraction of zone supply not directly recirc. from zone	Fa		= Ep + (1-Ep)Er = 0.06
Fraction of zone OA not directly recirc. from zone	Fb		= 1-(1-Ez)(1-Ep)(1-Er) = 0.06
Unused OA fraction required in supply air to zone	Zd		= Voz / Vz = 0.06
Unused OA fraction required in primary air to zone	Zp		= Voz / Vpz = 0.06
System Ventilation Efficiency			
Zone Ventilation Efficiency (App. A Method)	Evz		= (Fa + FbXs - Fcz) / Fa = 0.68
System Ventilation Efficiency (App. A Method)	Ev		= min(Esz) = 0.68
Ventilation System Efficiency (Table 6.3 Method)	Ev		= Value from Table 6.3 = 0.74
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	= Vou / Ev = 1896
OA intake req'd as a fraction of primary SA	Y		= Vot / Vps = 0.13
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= Vot / Ev = 1740
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= Vot / Vps = 0.12
OA Temp. at which Min. OA provides all cooling			
OAT below which OA Intake flow is @ minimum	DoatF		= (Tp-d)sh-h1xYWT+dTri = -58

VHP-2

Building: DE Hospice Building B		System	
System Tag/Name: VHP-3		12650	
Operating Condition Description: Ventilation Heat Pump		187	
Units (select from pull-down list)		2,265	
		0.10	
		5.0	
Inputs for System			
Floor area served by system	Name	Units	
Population of area served by system (including diversity)	As	sf	
Design primary supply fan airflow rate	Ps	cfm	
OA req'd per unit area for system (Weighted average)	Vpsd	cfm/sf	100%
OA req'd per person for system (Weighted average)	Ras	cfm/ps	
	Rps	cfm/ps	
Inputs for Potentially Critical Zones			
Zone Name	Zone tags		
Zone Tag	Space type		
Floor Area of zone	Select from pull-down list		
Design population of zone	Az	sf	
Design total supply to zone (primary plus local recirculated)	Pz	cfm	(default value listed, may be overridden)
Induction Terminal Unit, Dual Fan Duct or Transfer Fan?	Vtzd	cfm	
Local recirc. air % representative of area system return air	Er	%	
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	
Air distribution type at conditioned analyzed	Dz		
zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed	Ez		
Results			
Ventilation System Efficiency	Ev		0.39
Outdoor air intake required for system	Vot	cfm	5766
Outdoor air per unit floor area	Vot/As	cfm/sf	0.45
Outdoor air per person served by system (including diversity)	Vot/Ps	cfm/ps	30.8
Outdoor air as a % of design primary supply air	Ypd	cfm	255%
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= VpdDs = 17650
Uncorrected OA requirement for system	Vou	cfm	= Rps Ps + Ras As = 2223
Uncorrected OA req'd as a fraction of primary SA	Xs		= Vou / Vps = 0.13
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	cfm/sf	
OA rate per person	Rpz	cfm/ps	
Total supply air to zone (at condition being analyzed)	Vtz	cfm	
Unused OA req'd to breathing zone	Vbz	cfm	
Unused OA requirement for zone	Voz	cfm	
Fraction of zone supply not directly recirc. from zone	Fa		
Fraction of zone supply from fully mixed primary air	Fb		
Fraction of zone OA not directly recirc. from zone	Fc		
Unused OA fraction required in supply air to zone	Zd		
Unused OA fraction required in primary air to zone	Zp		
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz		
System Ventilation Efficiency (App A Method)	Ev		
Ventilation System Efficiency (Table 6.3 Method)	Ev		
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	
OA intake req'd as a fraction of primary SA	Y		
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum	Deg F		




Building:		DE Hospice Building B	
System Tag/Name:		VHP-3	
Operating Condition Description:		Ventilation Heat Pump	
Units (select from pull-down list)		[P]	
Inputs for System			
Floor area served by system	AS	sf	12880
Population of area served by system (including diversity)	Ps	P	187
Design primary supply fan airflow rate	Vpsd	cfm	2,265
OA req'd per unit area for system (Weighted average)	Ras	cfm/sf	0.10
OA req'd per person for system area (Weighted average)	Rps	cfm/p	5.0
Inputs for Potentially Critical Zones			
Zone Name	HP-3	HP-6	HP-9
Zone Tag	8	9	10
Space type	Corridors	Booking/waiting	Conference/meeting
Floor Area of zone	335	1600	250
Design population of zone	10	80	12.5
Design total supply to zone (primary plus local recirculated)	Vztd	cfm	430
Induction Terminal Unit, Dual Fan/Dual Duct or Transfer Fan?	Er		
Local recirc. air is representative of ave. system return air?			
Inputs for Operating Condition Analyzed			
Percent of total design airflow rate at conditioned analyzed	Ds	%	77.9%
Air distribution type at conditioned analyzed	Dz		
Zone air distribution effectiveness at conditioned analyzed	Ep		
Primary air fraction of supply air at conditioned analyzed	Ev		
Ventilation System Efficiency	Vot	cfm	0.39
Outdoor air intake required for system	Vot/As	cfm/sf	0.45
Outdoor air per unit floor area	Vot/Ps	cfm/p	30.8
Outdoor air per person served by system (including diversity)	Vot/Rps	cfm/p	265%
Outdoor air as a % of design primary supply air			
Results			
Vps	=	Vot/Ds	= 17650
Vou	=	Rps Ps + Ras As	= 2223
Xs	=	Vou/Vps	= 0.13
Raz	=	Vps/Vztd	= 0.06
Rpz	=	Vps/Vztd	= 0.06
Vz	=	Vztd/Vz	= 0.00
Vz	=	Rpz Fz + Raz Az	= 430
Vz	=	Vz/Ez	= 20.1
Fa	=	Vz/Vz	= 20
Fb	=	Ep + (1-Ep)Er	= 1.00
Fc	=	Ep	= 1.00
Fd	=	1-(1-Ez)(1-Ep)(1-Er)	= 1.00
Zd	=	Voz/Vz	= 0.05
Zp	=	Voz/Vz	= 0.05
Ez	=	(Fa + Fb)(1 - Fz) / Fa	= 1.08
Ev	=	min(Evz)	= 0.39
Ev	=	Value from Table 6.3	= n/a
Vot	=	Vou/Ev	= 5766
Y	=	Vot/Vps	= 0.33
Y	=	Vou/Ev	= n/a
Y	=	Vot/Vps	= n/a
Deg F = ((T-T)SP-1)-Y(TT+dtm) = 20			
OAT below which OA Intake flow is @ minimum			



Building: DE Hospice Building B		System: VHP-3		System: VHP-3	
Operating Condition Description: Ventilation Heat Pump		Units		System	
Units (select from pull-down list)		Name	Units		
Inputs for System		Room area served by system	sf	12,500	
Population of area served by system (including diversity)		P	cfm	1,817	
Design primary supply fan airflow rate		Vpsd	cfm	2,263	
OA req'd per unit area for system (Weighted average)		Ras	cfm/sf	0.10	
OA req'd per person for system area (Weighted average)		Rps	cfm/yp	5.0	
Inputs for Potentially Critical Zones		Zone Name			
Zone Tag		Zone Name			
Space Type		Space Type			
Floor Area of zone		Az	sf	Select from pull-down list	
Design population of zone		Pz	cfm	(default value listed; may be overridden)	
Design total supply to zone (primary plus local recirculated)		Vzd	cfm	Select from pull-down list or leave blank (N/A)	
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?		Local recirc. air, representative of area system return air			
Inputs for Operating Condition Analyzed		Local recirc. air, representative of area system return air			
Percent of total design airflow rate at conditioned analyzed		Ds	%	77.9%	
Air distribution type at conditioned analyzed		Ds	%		
Zone air distribution effectiveness at conditioned analyzed		Ez			
Primary air fraction of supply air at conditioned analyzed		Ep			
Results		Ev = 0.39			
Ventilation System Efficiency		Vot = 5766			
Outdoor air intake required for system		Vot/As = 0.45			
Outdoor air per unit floor area		Vot/Ps = 30.8			
Outdoor air per person served by system (including diversity)		Ypd = 265%			
Outdoor air as a % of design primary supply air					
Uncalculated Calculations					
Initial Calculations for the System as a whole		Vps = 17650			
Primary supply air flow to system at conditioned analyzed		Vou	cfm	2223	
Uncorrected OA requirement for system		Xs	cfm	0.13	
Uncorrected OA req'd as a fraction of primary SA					
Initial Calculations for Individual Zones		Raz = 0.06			
OA rate per unit area for zone		Rpz	cfm/yp	0.06	
Total supply air to zone (at condition being analyzed)		Vdz	cfm	5.00	
Unused OA req'd to breathing zone		Vbz	cfm	710	
Unused OA requirement for zone		Voz	cfm	29.8	
Fraction of zone supply not directly recirc. from zone		Fa		77	
Fraction of zone OA not directly recirc. from zone		Fb		30	
Fraction of zone OA not directly recirc. from zone		Fc		1.00	
Unused OA fraction required in supply air to zone		Zd		0.11	
Unused OA fraction required in primary air to zone		Zp		0.04	
System Ventilation Efficiency		Evz = 1.02			
Zone Ventilation Efficiency (App. A Method)		Evs = 1.07			
System Ventilation Efficiency (App. A Method)		Evs = 1.07			
Ventilation System Efficiency (Table 6.3 Method)		Evs = 1.07			
Minimum outdoor air intake airflow		Vot = 5766			
Outdoor Air Intake Flow required to System		Vot/As = 0.33			
OA intake req'd as a fraction of primary SA		Vot/Ps = n/a			
Outdoor Air Intake Flow required to System (Table 6.3 Method)		Y = n/a			
OA intake req'd as a fraction of primary SA (Table 6.3 Method)		Y = n/a			
OA Temp at which Min OA provides all cooling		Deg F = 20			
OAT below which OA intake flow is @ minimum					



Building: DE Hospice Building B		System Tag/Name: VHP-3																			
Operating Condition Description: Ventilation Heat Pump		Units (select from pull-down list)																			
Inputs for System		<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>As</td> <td>sf</td> <td>12880</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>187</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>2,265</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.10</td> </tr> <tr> <td>Rps</td> <td>cfm/tp</td> <td>5.0</td> </tr> </table>		Name	Units	System	As	sf	12880	Ps	P	187	Vpsd	cfm	2,265	Ras	cfm/sf	0.10	Rps	cfm/tp	5.0
Name	Units	System																			
As	sf	12880																			
Ps	P	187																			
Vpsd	cfm	2,265																			
Ras	cfm/sf	0.10																			
Rps	cfm/tp	5.0																			
Inputs for Potentially Critical Zones		<p>Zone Name: <input type="text"/> 100% diversity</p> <p>Zone Tag: <input type="text"/></p> <p>Space type: <input type="text"/></p> <p>Floor Area of zone: <input type="text"/></p> <p>Design population of zone: <input type="text"/></p> <p>Design total supply to zone (primary plus local recirculated): <input type="text"/></p> <p>Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? <input type="text"/></p> <p>Local recirc. air-% representative of ave system return air: <input type="text"/></p> <p>Select from pull-down list</p>																			
Inputs for Operating Condition Analyzed		<p>Percent of total design airflow rate at conditioned analyzed: <input type="text"/> 77.9%</p> <p>Air distribution type at conditioned analyzed: <input type="text"/></p> <p>Zone air distribution effectiveness at conditioned analyzed: <input type="text"/></p> <p>Primary air fraction of supply air at conditioned analyzed: <input type="text"/></p>																			
Results		<p>Ventilation System Efficiency: 0.39</p> <p>Outdoor air intake required for system: 5766</p> <p>Outdoor air per unit floor area: 0.45</p> <p>Outdoor air per person served by system (including diversity): 30.8</p> <p>Outdoor air as a % of design primary supply air: 265%</p>																			
Detailed Calculations for the System as a whole		<p>Primary supply air flow to system at conditioned analyzed: $Vps = VpdDs = 17650$</p> <p>Uncorrected OA requirement for system: $Vou = Rps Ps + Ras As = 2223$</p> <p>Uncorrected OA req'd as a fraction of primary SA: $Xs = Vou / Vps = 0.13$</p> <p>Initial Calculations for individual zones</p> <p>OA rate per unit area for zone: $Raz = Vps / As = 0.06$</p> <p>OA rate per person: $Rpz = Vps / Ps = 0.06$</p> <p>Total supply air to zone (at condition being analyzed): $Vz = Vps + VpdDs = 5.00$</p> <p>Unused OA req'd to breathing zone: $Vbz = Vz - Raz As = 7.10$</p> <p>Unused OA requirement for zone: $Voz = Vbz / Ps = 9.4$</p> <p>Fraction of zone supply not directly recirc. from zone: $Fa = Voz / (Voz + VpdDs) = 9$</p> <p>Fraction of zone supply from fully mixed primary air: $Fb = VpdDs / (VpdDs + Voz) = 1.00$</p> <p>Fraction of zone OA not directly recirc. from zone: $Fc = 1 - (Fa + Fb) = 1.00$</p> <p>Unused OA fraction required in supply air to zone: $Zd = Fc / (1 + Fa) = 0.02$</p> <p>Unused OA fraction required in primary air to zone: $Zp = Zd / Xs = 0.02$</p> <p>System Ventilation Efficiency</p> <p>Zone Ventilation Efficiency (App A Method): $Evz = (Fa + FbXs - Fcz) / Fa = 1.10$</p> <p>System Ventilation Efficiency (App A Method): $Ev = min(Evz) = 1.10$</p> <p>Ventilation System Efficiency (Table 6.3 Method): $Evs = Value from Table 6.3 = 0.39$</p> <p>Minimum outdoor air intake airflow</p> <p>Outdoor Air Intake Flow required to System: $Vot = Vou / Ev = 5766$</p> <p>OA intake req'd as a fraction of primary SA: $Y = Vou / Vps = 0.33$</p> <p>Outdoor Air Intake Flow required to System (Table 6.3 Method): $Yot = Vou / Vps = 0.33$</p> <p>OA intake req'd as a fraction of primary SA (Table 6.3 Method): $Yot = Vou / Vps = 0.33$</p> <p>OA Temp at which Min OA provides all cooling</p> <p>OAT below which OA intake flow is @ minimum: $Deg F = ((Tp-dT) - (1-Y)Tr) + dTr = 20$</p>																			




Building: DE Hospice Building A		System	
System Tag/Name: ERU1		Name	
Operating Condition Description: Energy Recovery		Units	
Units (select from pull-down list)		System	
As	4400	st	
Ps	81	diversity	100%
Vpsd	1.555		
Ras	0.10		
Rps	5.0		
Inputs for System			
Floor area served by system			
Population of area served by system (including diversity)			
Design primary supply fan airflow rate			
OA req'd per unit area for system (Weighted average)			
OA req'd per person for system area (Weighted average)			
Inputs for Potentially Critical zones			
Zone Name			
Zone Tag			
Space type			
Floor Area of zone			
Design population of zone			
Design total supply to zone (primary plus local recirculated)			
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?			
Local recirc. air % representative of ave system return air			
Inputs for Operating Condition Analyzed			
Ds	100%	%	567%
Ez	CS		
Ep	1.00		
Results			
Ev	0.13		
Vot	6285	cfm	
Vot/As	1.43	cfm/sf	
Vot/Ps	77.6	cfm/p	
Ypd	404%	cfm	
Detailed Calculations			
Initial Calculations for the System as a whole			
Vps	=	VpdDs	= 8820
Vou	=	Rps Ps + Ras As	= 845
Xs	=	Vou / Vps	= 0.10
Initial Calculations for individual zones			
Raz	=	OA rate per unit area for zone	0.18
Roz	=	OA rate per person	7.50
Vdz	=	Total supply air to zone (at condition being analyzed)	330
Vbz	=	Unused OA req'd to breathing zone	317.3
Voz	=	Unused OA requirement for zone	317
Fa	=	Fraction of zone supply not directly recirc. from zone	1.00
Fb	=	Fraction of zone supply from fully mixed primary air	1.00
Fc	=	Fraction of zone OA not directly recirc. from zone	1.00
Zd	=	Unused OA fraction required in supply air to zone	0.96
Zp	=	Unused OA fraction required in primary air to zone	0.96
System Ventilation Efficiency			
Evz	=	Zone Ventilation Efficiency (App A Method)	0.13
Ev	=	System Ventilation Efficiency (App A Method)	0.13
Minimum outdoor air intake airflow			
Vot	=	Outdoor Air Intake Flow required to System	6285
Y	=	OA intake req'd as a fraction of primary SA	0.71
Vot	=	Outdoor Air Intake Flow required to System (Table 6.3 Method)	n/a
Y	=	OA intake req'd as a fraction of primary SA (Table 6.3 Method)	n/a
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum		Deg F = $\frac{(T_p - T_s)(h - 1) + Y(T_r + dTr)}{Y}$	
		= 48	

Building:		DE Hospice Building A	
System Tag/Name:		ERU-1	
Operating Condition Description:		Energy Recovery	
Units (select from pull-down list)		IP	
Inputs for System			
Floor area served by system	Name	Units	System
Population of area served by system (including diversity)	As	sf	4400
Design primary supply fan airflow rate	Ps	F	81
OA req'd per unit area for system (Weighted average)	Vpsd	cfm	1.555
OA req'd per person for system area (Weighted average)	Rps	cfm/psf	0.10
	Rps	cfm/psf	5.0
Inputs for Potentially Critical Zones			
Zone Name	HP-3	HP-1	
Zone Tag	15	16	
Space type	Office space	Office space	
Floor Area of zone	Az	sf	120
Design population of zone	Pz	P	0.8
Design total supply to zone (primary plus local recirculated)	Vzsd	cfm	430
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?	Er		
Local recirc. air % representative of ave system return air	Ds	%	56.7%
Percent of total design airflow rate at conditioned analyzed	Ez	%	100%
Air distribution type at conditioned analyzed	Ep		CS
Zone air distribution effectiveness at conditioned analyzed	Ev		1.00
Primary air fraction of supply air at conditioned analyzed	Vot	cfm	0.13
	Vot/As	cfm/psf	6285
Results	Vot/As	cfm/psf	1.43
Ventilation System Efficiency	Vot/As	cfm/psf	77.6
Outdoor air intake required for system	Ypd	cfm	404%
Outdoor air per unit floor area			
Outdoor air per person served by system (including diversity)			
Outdoor air as a % of design primary supply air			
Detailed Calculations			
Initial Calculations for the System as a whole			
Primary supply air flow to system at conditioned analyzed	Vps	cfm	= 8820
Uncorrected OA requirement for system	Vou	cfm	= 845
Uncorrected OA req'd as a fraction of primary SA	Xs		= 0.10
Initial Calculations for individual zones			
OA rate per unit area for zone	Raz	cfm/psf	0.06
OA rate per person	Rpz	cfm/psf	5.00
Total supply air to zone (at condition being analyzed)	Vzsd	cfm	500
Unused OA req'd to breathing zone	Voz	cfm	430
Unused OA requirement for zone	Voz/Ez	cfm	10.2
Fraction of zone supply not directly recirc. from zone	Fa		14
Fraction of zone supply from fully mixed primary air	Fb		1.00
Fraction of zone OA not directly recirc. from zone	Fc		1.00
Unused OA fraction required in supply air to zone	Zd		1.00
Unused OA fraction required in primary air to zone	Zp		0.02
System Ventilation Efficiency			
Zone Ventilation Efficiency (App A Method)	Evz		= (Fa + Fbx - Fcz) / Fa = 1.07
System Ventilation Efficiency (App A Method)	Ev		= min(Evz) = 0.13
Ventilation System Efficiency (Table 6.3 Method)	Ev		= Value from Table 6.3 = n/a
Minimum outdoor air intake airflow			
Outdoor Air Intake Flow required to System	Vot	cfm	= 6285
OA intake req'd as a fraction of primary SA	Y		= 0.71
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Vot	cfm	= n/a
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y		= n/a
OA Temp at which Min OA provides all cooling			
OAT below which OA intake flow is @ minimum	Deq F		= 48

ERU-1

Building: DE Hospice Building A							
System Tag/Name: ERU2							
Operating Condition Description: Energy Recovery							
Units (select from pull-down list)							
Name	Units						
As	sf						
Ps	P						
Vpd	cfm						
Ras	cm/sf						
Rps	cfm/p						
System							
	3195						
	142						
	1,555						
	0.10						
	5.0						
100% diversity Potentially Critical Zones							
Zone Name	HP-5	HP-4	HP-3	HP-3	HP-1	HP-2	HP-4
Zone Tag	8	9	10	11	12	13	14
Space type	Bookings/waiting	Bedroom/liv	Bedroom/liv	Bedroom/liv	Libraries	Laundry rooms, central	Bedroom/liv
Floor Area of zone	360	270	270	270	225	300	270
Design population of zone	18	2.7	2.7	2.7	2.25	3	2.7
Design total supply to zone (primary plus local recirculated)	710	1150	430	430	260	330	530
Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?							
Local recirc. air % representative of ave system return air							
Select from pull-down list (default value listed; may be overridden) Select from pull-down list, or leave blank if N/A							
Zone lbs turns purple italic for critical zone(s)							
Ds	%	100%	100%	100%	100%	100%	100%
Ez	%	CS	CS	CS	CS	CS	CS
Ep	%	1.00	1.00	1.00	1.00	1.00	1.00
Percent of total design airflow rate at conditioned analyzed Air distribution type at conditioned analyzed Zone air distribution effectiveness at conditioned analyzed Primary air fraction of supply air at conditioned analyzed							
Results							
Ev	0.16						
Outdoor air intake required for system	7923						
Outdoor air per unit floor area	1.63						
Outdoor air per person served by system (including diversity)	56.8						
Outdoor air as a % of design primary supply air	610%						
Detailed Calculations							
Initial Calculations for the System as a whole							
Primary supply air flow to system at conditioned analyzed	VpdDs = 10550						
Uncorrected OA requirement for system	Rps Ps + Ras As = 1230						
Uncorrected OA req'd as a fraction of primary SA	Xs = Vou / Vps = 0.12						
Initial Calculations for Individual zones							
OA rate per unit area for zone	Raz cm/sf = 0.06						
OA rate per person	Rpz cm/p = 7.50						
Total supply air to zone (at condition being analyzed)	Vdz cfm = 710						
Unused OA req'd to breathing zone	Vbz cfm = 156.6						
Unused OA requirement for zone	Voz cfm = 30						
Fraction of zone supply not directly recirc. from zone	Fa = 1.00						
Fraction of zone supply from fully mixed primary air	Fp = 1.00						
Fraction of zone OA not directly recirc. from zone	Fc = 1.00						
Unused OA fraction required in supply air to zone	Zd = 0.22						
Unused OA fraction required in primary air to zone	Zp = 0.22						
System Ventilation Efficiency							
Zone Ventilation Efficiency (App A Method)	Evz = (Fa + Fb) / (Fa + Fb + Xs - Fz) / Fa = 0.90						
System Ventilation Efficiency (App A Method)	Ev = min (Evz) = 0.16						
Ventilation System Efficiency (Table 6.3 Method)	Ev = Value from Table 6.3 = n/a						
Minimum outdoor air intake airflow							
Outdoor Air Intake Flow required to System	Vot cfm = 7923						
OA intake req'd as a fraction of primary SA	Y = Vou / Ev = 0.75						
Outdoor Air Intake Flow required to System (Table 6.3 Method)	Yot cfm = n/a						
OA intake req'd as a fraction of primary SA (Table 6.3 Method)	Y = Vou / Vps = n/a						
OA Terms at which Min OA provides all cooling							
OA below which OA intake flow is @ minimum	Deg F = ((Tpd-Ts)(1-Y)) / (Tt-dTr) = 49						



Building: DE Hospice Building A																			
System Tag/Name: ERU2																			
Operating Condition Description: Energy Recovery																			
Units (select from pull-down list)																			
Inputs for System	<table border="1"> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> <tr> <td>As</td> <td>sf</td> <td>5185</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>142</td> </tr> <tr> <td>Vpzd</td> <td>cfm</td> <td>1,555</td> </tr> <tr> <td>Ras</td> <td>cfm/sf</td> <td>0.10</td> </tr> <tr> <td>Rps</td> <td>cfm/p</td> <td>5.0</td> </tr> </table>	Name	Units	System	As	sf	5185	Ps	P	142	Vpzd	cfm	1,555	Ras	cfm/sf	0.10	Rps	cfm/p	5.0
Name	Units	System																	
As	sf	5185																	
Ps	P	142																	
Vpzd	cfm	1,555																	
Ras	cfm/sf	0.10																	
Rps	cfm/p	5.0																	
Inputs for Potentially Critical Zones	<p>Zone Name: HP-5 HP-8</p> <p>Zone Tag: 15 16</p> <p>Space type: Laundry rooms, central</p> <p>Floor Area of Zone: 450 550</p> <p>Design population of zone: 4.3 27.3</p> <p>Design total supply to zone (primary plus local recirculated): 710 1710</p> <p>Induction Terminal Unit, Dual Fan Duct or Transfer Fan? HP-5 HP-8</p> <p>Local recirc. air % representative of ave. system return air: 100% diversity</p> <p><i>Zone title turns purple italic for critical zone(s)</i></p>																		
Inputs for Operating Condition Analyzed	<p>Ds % 100% 100%</p> <p>Ez % CS CS</p> <p>Ep % 1.00 1.00</p> <p>67.8% 100%</p>																		
Results	<p>Ventilation System Efficiency: 0.16</p> <p>Outdoor air intake required for system: 7923</p> <p>Outdoor air per unit floor area: 1.63</p> <p>Outdoor air per person served by system (including diversity): 56.8</p> <p>Outdoor air as a % of design primary supply air: 510%</p>																		
Detailed Calculations	<p>Initial Calculations for the System as a whole</p> <p>Primary supply air flow to system at conditioned analyzed: 10550</p> <p>Uncorrected OA requirement for system: 1230</p> <p>Uncorrected OA req'd as a fraction of primary SA: 0.12</p> <p>Initial Calculations for Individual Zones</p> <p>OA rate per unit area for zone: 0.12</p> <p>OA rate per person: 5.00</p> <p>Total supply air to zone (at condition being analyzed): 710</p> <p>Unused OA req'd to breathing zone: 76.5</p> <p>Unused OA requirement for zone: 77</p> <p>Fraction of zone supply not directly recirc. from zone: 1.00</p> <p>Fraction of zone supply from fully mixed primary air: 1.00</p> <p>Fraction of zone OA not directly recirc. from zone: 1.00</p> <p>Unused OA fraction required in supply air to zone: 0.11</p> <p>Unused OA fraction required in primary air to zone: 0.14</p> <p>System Ventilation Efficiency</p> <p>Zone Ventilation Efficiency (App A Method): 0.16</p> <p>System Ventilation Efficiency (App A Method): n/a</p> <p>Ventilation System Efficiency (Table 6.3 Method): n/a</p> <p>Minimum outdoor air intake airflow</p> <p>Outdoor Air Intake Flow required to System: 7923</p> <p>OA intake req'd as a fraction of primary SA: 0.75</p> <p>Outdoor Air Intake Flow required to System (Table 6.3 Method): n/a</p> <p>OA intake req'd as a fraction of primary SA (Table 6.3 Method): n/a</p> <p>O.A. Terms at which Min. OA provides all cooling</p> <p>OAT below which OA intake flows @ minimum: 49</p>																		

