

victoria interval

MTOB[pennsylvania]

ae senior thesis [**struc**]
advisor [dr. boothby]
april 3,2013

MTOB

final report



contents

contents	I
acknowledgements	IV
abstract.....	V
building introduction	1
executive summary	2
structural overview – existing	3
building materials	4
foundation system	5
framing system.....	6
floor system	7
lateral system.....	8
roof system	9
thesis objectives	10
problem statement	10
proposed solution	11
MAE requirements.....	11
breadth studies	12
structural redesign	14
gravity	14
RAM analysis	16
plastic analysis	18
cost analysis of cellular beams.....	19



vierendeel truss designs	19
foundations consideration.....	21
lateral	23
wind + seismic loads for redesign.....	23
stiffness comparison	24
frame efficiencies comparison.....	25
story drift	26
structural redesign conclusion.....	26
architectural redesign.....	27
breaking the box	27
elevations.....	28
materials used.....	30
envelope comparison.....	31
R-value and temperature gradient	31
potential for condensation	32
architectural conclusion.....	32
mechanical redesign.....	33
mechanical loads.....	33
zoning + duct layout.....	34
VAV boxes	35
mechanical conclusion.....	35
MAE course integration	36
final conclusion	37
appendix A: cellular beams.....	38
A.1 plastic moments	38




A.2 example plastic analysis calculation	41
A.3 spreadsheet for (plastic) symmetrical failure mechanisms	43
A.4 axial force check on cellular beam	45
A.5 deflection check on cellular beam.....	45
A.6 interaction check	46
A.7 web post buckling.....	46
A.8 cellular beam cost analysis	47
appendix B: lateral analysis	48
B.1 existing frame stiffness calculation	48
B.2 proposed frame stiffness calculation	50
B.3 story displacement load cases/combos.....	52
appendix C: foundation loads	55
appendix D: architectural calcs	56
D.1 mullion design	56
D.2 R-value + temp gradients	58
D.3 pressure gradient + RH	60
appendix E: mechanical calcs	61
E.1 HVAC loads for typical floor	61
E.2 ASHRAE 62.1-2007 outdoor air requirements.....	63
E.3 TRACE system checksums	65
E.4 TRACE room checksums.....	69
E.5 IBC tables used	73
appendix F: additional drawings	75



appendix A: cellular beams

A.1 plastic moments



PLASTIC MOMENTS 2/5

MIDDLE WEB, W18x35 (TOP HALF)

$$t_w = 0.30 \text{ in}$$

$$\begin{aligned} M_p &= \frac{bh^2}{4} F_y \quad (\text{RECTANGULAR SECTION}) \\ &= \frac{(0.3)(5.28)^2}{4} F_y \quad 50 \text{ ksi} \\ &= (2.09 \text{ in}^3) (50 \text{ ksi}) \\ &= \boxed{104.5 \text{ k-in}} \end{aligned}$$

MIDDLE WEB, W18x46 (BOTTOM HALF)

$$t_w = 0.36 \text{ in}$$

$$\begin{aligned} M_p &= \frac{(0.36)(5.28)^2}{4} (50 \text{ ksi}) \\ &= (2.5 \text{ in}^3) (50 \text{ ksi}) \\ &= \boxed{125.5 \text{ k-in}} \end{aligned}$$

PLASTIC MOMENTS 3/5

BOTTOM TEE

$$A_f = b_f t_f = (6.06)(0.605) = 3.6663$$

$$A_w = b_w h_w = (0.36)(3.395) = 1.222$$

AREA FL. BELOW PNA:

$$\frac{1}{2}(A_f - A_w) = \frac{1}{2}(3.6663 - 1.222) = 1.222$$

DIST TO PNA

$$\frac{A_{\text{below}}}{b_f} = \frac{1.222}{6.06} = 0.202 \text{ in}$$

MOMENTS ABOUT PNA

- FLANGE ABOVE
 $A = 3.6663 - 1.222 = 2.4443$ $\text{ARM} = \frac{1}{2}(0.605 - 0.202) = 0.2015$

- FLANGE BELOW
 $A = 1.222$ $\text{ARM} = \frac{1}{2}(0.202) = 0.101$

- WEB
 $A = 1.222$ $\text{ARM} = \frac{1}{2}(3.395) = 1.6975$

$$Z_p = (2.4443)(0.2015) + (1.222)(0.101) + (1.222)(1.6975)$$

$$= 2.69 \text{ in}^3$$

$$\sigma' = 50 \text{ ksi}$$


$$M_p = (2.69)(50) = 134.5 \text{ k in}$$

A.2 example plastic analysis calculation

PLASTIC ANALYSIS, UPPERBOUND THM. 1/2


EXAMPLE CALCULATION (SEE SPREADSHEET FOR COMPLETE VERSION)

30 - CELL CELLULAR BM:




ASSUMING COLLAPSE MECHANISMS WILL ALL BE SYMMETRICAL SINCE THE LOAD IS UNIFORM AND THE SECTIONS ARE SYMMETRICAL

POSSIBLE MECHANISM SHAPES



WE WILL FIRST CHECK THIS COLLAPSE MECHANISM :



ALSO, NOTE HINGE FORMATION IN THE WEB MEMBERS.

THIS IS B/C FOR BOTH W18x35, W18x46, WE HAVE :

$$M_{p, \text{WEB}} < M_{p, \text{TEE}}$$

$$M_{p, \text{WEB}, 18x35} = 104.5 \text{ k-in}$$


$$M_{p, \text{WEB}, 18x46} = 125.5 \text{ k-in}$$

PLASTIC ANALYSIS, UPPER BOUND THM β_2

EX CALCULATION

$$\delta W_{\text{EXT}} = \delta W_{\text{INT}}$$

$$\sum P(d; \theta) = \sum M_{p_i}(\theta_i)$$



$$P(2+4+6+\dots+28+30+28+\dots+2)\theta = M_{p_{35}}(2\theta) + 30M_{p_{35}}(\theta)$$

$$+ M_{p_{46}}(2\theta) + 30\theta M_{p_{46}}$$

$$450 P \theta = 32 M_{p_{35}} + 32 M_{p_{46}}$$

$$= 32(104.5) + 32(125.5)$$

$$\Rightarrow P = \frac{7360}{450}$$

$\therefore = 16,355.6 \text{ K PER PANEL}$

$$= \boxed{8.18 \text{ K/FT}}$$



THE EXCEL SPREADSHEET WILL
CALCULATE THIS FOR ALL SYMMETRICAL
COLLAPSE MECHANISMS TO FIND
THE LEAST UPPER BOUND, WHICH
WILL BE THE CORRECT MECHANISM

A.3 spreadsheet for (plastic) symmetrical failure mechanisms

d	# hinges:												
0	2	0	2	0	2	0	2	0	2	0	2	0	2
2	2	2	2	2	2	2	2	2	2	2	2	2	2
4	2	4	2	4	2	4	2	4	2	4	2	4	4
6	2	6	2	6	2	6	2	6	2	6	2	6	6
8	2	8	2	8	2	8	2	8	2	8	2	8	8
10	2	10	2	10	2	10	2	10	2	10	2	10	10
12	2	12	2	12	2	12	2	12	2	12	2	12	12
14	2	14	2	14	2	14	2	14	2	14	2	14	14
16	2	16	2	16	2	16	2	16	2	16	2	16	16
18	2	18	2	18	2	18	2	18	2	18	2	18	16
20	2	20	2	20	2	20	2	20	2	20	2	18	16
22	2	22	2	22	2	22	2	22	2	20	2	18	16
24	2	24	2	24	2	24	2	22	0	20	2	18	16
26	2	26	2	26	2	24	0	22	0	20	2	18	16
28	2	28	2	26	0	24	0	22	0	20	2	18	16
30	2	28	0	26	0	24	0	22	0	20	2	18	16
28	2	28	2	26	0	24	0	22	0	20	2	18	16
26	2	26	2	26	2	24	0	22	0	20	2	18	16
24	2	24	2	24	2	24	2	22	0	20	2	18	16
22	2	22	2	22	2	22	2	22	2	20	2	18	16
20	2	20	2	20	2	20	2	20	2	20	2	18	16
18	2	18	2	18	2	18	2	18	2	18	2	18	16
16	2	16	2	16	2	16	2	16	2	16	2	16	16
14	2	14	2	14	2	14	2	14	2	14	2	14	14
12	2	12	2	12	2	12	2	12	2	12	2	12	12
10	2	10	2	10	2	10	2	10	2	10	2	10	10
8	2	8	2	8	2	8	2	8	2	8	2	8	8
6	2	6	2	6	2	6	2	6	2	6	2	6	6
4	2	4	2	4	2	4	2	4	2	4	2	4	4
2	2	2	2	2	2	2	2	2	2	2	2	2	2
0	2	0	2	0	2	0	2	0	2	0	2	0	0
62		60		56		52		48		44		40	
$\delta_{ext} = P^*\theta^*$	450	$\delta_{ext} = P^*\theta^*$	448	$\delta_{ext} = P^*\theta^*$	442	$\delta_{ext} = P^*\theta^*$	432	$\delta_{ext} = P^*\theta^*$	418	$\delta_{ext} = P^*\theta^*$	400	$\delta_{ext} = P^*\theta^*$	378
$\delta_{ext} = \theta^*$	7360	$\delta_{ext} = \theta^*$	6900	$\delta_{ext} = \theta^*$	6440	$\delta_{ext} = \theta^*$	5980	$\delta_{ext} = \theta^*$	5520	$\delta_{ext} = \theta^*$	5060	$\delta_{ext} = \theta^*$	4600
P=	16.35556	P=	15.40179	P=	14.57014	P=	13.84259	P=	13.20574	P=	12.65	P=	12.16931
w =	8.177778	w =	7.700893	w =	7.285068	w =	6.921296	w =	6.602871	w =	6.325	w =	6.084656
													w = 5.880682

d	# hinges:														
0	0	0	0	0	0	0	0	0	0	0	0	0	0		
2	2	2	2	2	2	2	2	2	2	2	2	2	0		
4	4	4	4	4	4	4	4	4	4	2	2	2	0		
6	6	6	6	6	6	6	4	2	2	2	2	2	0		
8	8	8	8	8	6	6	4	2	2	2	2	2	0		
10	10	10	8	8	6	4	2	2	2	2	2	2	0		
12	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
14	12	10	8	8	6	4	2	2	2	2	2	2	0		
12	12	10	8	8	6	4	2	2	2	2	2	2	0		
10	10	10	8	8	6	4	2	2	2	2	2	2	0		
8	8	8	8	8	6	4	2	2	2	2	2	2	0		
6	6	6	6	6	6	4	2	2	2	2	2	2	0		
4	4	4	4	4	4	4	2	2	2	2	2	2	0		
2	2	2	2	2	2	2	2	2	2	2	2	2	0		
0	0	0	0	0	0	0	0	0	0	0	0	0	0		
32		28		24		20		16		12		8		4	
$\delta_{\text{ext}} = P^* \theta^*$	322	$\delta_{\text{ext}} = P^* \theta^*$	288	$\delta_{\text{ext}} = P^* \theta^*$	250	$\delta_{\text{ext}} = P^* \theta^*$	208	$\delta_{\text{ext}} = P^* \theta^*$	162	$\delta_{\text{ext}} = P^* \theta^*$	112	$\delta_{\text{ext}} = P^* \theta^*$	58	$\delta_{\text{ext}} = P^* \theta^*$	0
$\delta_{\text{ext}} = \theta^*$	3680	$\delta_{\text{ext}} = \theta^*$	3220	$\delta_{\text{ext}} = \theta^*$	2760	$\delta_{\text{ext}} = \theta^*$	2300	$\delta_{\text{ext}} = \theta^*$	1840	$\delta_{\text{ext}} = \theta^*$	1380	$\delta_{\text{ext}} = \theta^*$	920	$\delta_{\text{ext}} = \theta^*$	460
P=	11.42857	P=	11.18056	P=	11.04	P=	11.05769	P=	11.35802	P=	12.32143	P=	15.86207	P=	#DIV/0!
w =	5.714286	w =	5.590278	w =	5.52	w =	5.528846	w =	5.679012	w =	6.160714	w =	7.931034	w =	#DIV/0!
*least upper bound															




A.4 axial force check on cellular beam

$$w_{failure\ mechanism} = 5.52 \frac{k}{ft} \text{ and } F = \frac{M}{d} \frac{\left(5.52 \frac{k}{ft}\right)(60 ft)^2}{\frac{8}{26''}} = 95.5 k$$

top T flange

$$A = (0.425)(6) + (3.575)(0.3) = 3.6225 in^2$$


$$\sigma = \frac{F}{A} = \frac{95.5 k}{3.6225 in^2} = 26.36 ksi \leq 50 ksi$$



Bottom T flange

$$A = (0.605)(6.06) + (3.395)(0.36) = 4.8885 in^2$$

$$\sigma = \frac{F}{A} = \frac{95.5 k}{4.8885 in^2} = 19.54 ksi \leq 50 ksi$$



A.5 deflection check on cellular beam

live load deflection

$$\Delta_{LL,allow} = \frac{L}{360} = \frac{(60') \left(12 \frac{in}{ft}\right)}{360} = 2 in$$

$$\Delta_{LL} \approx \frac{5 \cdot w \cdot L^4}{384 \cdot E \cdot I} = \frac{(5) \left(0.281 \frac{k}{ft}\right) (60 ft)^4 (12^3)}{(384)(29,000 ksi)(1433 in^4)} = 1.97 in \leq 2 in \text{ GOOD}$$

$$I = \frac{bh^3}{12} = \left(\frac{(6.03'')(26'')^3}{12} \right) - 2 \cdot \left(\frac{(2.85'')(24.97'')^3}{12} + (2.85)(24.97)(0.18'')^2 \right) = 1433 in^4$$

total load deflection

$$\Delta_{TL,allow} = \frac{L}{240} = \frac{(60') \left(12 \frac{in}{ft}\right)}{240} = 3 in$$

$$\Delta_{TL} \approx \frac{5 \cdot w \cdot L^4}{384 \cdot E \cdot I} = \frac{(5) \left(0.846 \frac{k}{ft}\right) (60 ft)^4 (12^3)}{(384)(29,000 ksi)(1433 in^4)} = 5.94 in - (3'' camber) = 2.94 in \leq 3 in \text{ GOOD}$$

A.6 interaction check

NOTE: these values are taken from the RAM model

Precomposite:

Beam: $V = 3.69$ kips $M = 196.09$ kip-ft at 22.125 ft

Top Tee:

$$fa = 25.68 \text{ ksi}$$

$$Fa = 29.54 \text{ ksi}$$

$$fb = 3.98 \text{ ksi}$$

$$Fb = 30.00 \text{ ksi}$$

$$H1-1: 0.869 + 0.113 = 0.982$$

$$H1-2: 0.856 + 0.133 = 0.988$$

Beam: $V = 5.79$ kips $M = 174.76$ kip-ft at 17.625 ft

Bot Tee:

$$fa = 16.89 \text{ ksi}$$

$$Ft = 30.00 \text{ ksi}$$

$$fb = 6.58 \text{ ksi}$$

$$Fb = 30.00 \text{ ksi}$$

$$H2-1: 0.563 + 0.219 = 0.782$$

Composite: $V_c = 10.75$ kips

Beam: $V = 21.91$ kips $M = 97.58$ kip-ft at 4.125 ft

Top Tee:

$$fa = 5.63 \text{ ksi}$$

$$Fa = 29.54 \text{ ksi}$$

$$fb = 12.03 \text{ ksi}$$

$$Fb = 30.00 \text{ ksi}$$

$$H1-1: 0.191 + 0.341 = 0.532$$

$$H1-2: 0.188 + 0.401 = 0.589$$

Beam: $V = 0.95$ kips $M = 380.50$ kip-ft at 28.875 ft

Bot Tee:

$$fa = 31.88 \text{ ksi}$$

$$Ft = 33.00 \text{ ksi}$$

$$fb = 0.00 \text{ ksi}$$

$$Fb = 33.00 \text{ ksi}$$

$$H2-1: 0.966 + 0.000 = 0.966$$

A.7 web post buckling

NOTE: these values are taken from the RAM model

Precomposite Max $V_h = 12.21$ kips at 2.88 ft

	Mmax kip-ft	Mallow kip-ft	Mmax/Mallow
Top:	8.24	12.84	0.642
Bot:	8.24	16.37	0.503

Composite Max $V_h = 19.00$ kips at 2.88 ft

	Mmax kip-ft	Mallow kip-ft	Mmax/Mallow
Top:	12.82	12.84	0.999
Bot:	12.82	16.37	0.783

Therefore, web post buckling controls the section of cellular beam selected

A.8 cellular beam cost analysis

30'x30' composite beam and slab system = **\$17.30¹⁹**

Assembly B10102564200

Based on National Average Costs

Floor, composite metal deck, shear connectors, 5.5" slab, 30'x30' bay, 23.5" total depth, 40 PSF superimposed load, 81 PSF total load

Description	Quantity	Unit	Material	Installation	Total
Shores, vertical members, to 10' high, includes erect and strip by hand	0.01500	Ea.	0.00	0.30	0.30
Welded wire fabric, sheets, 6 x 6 - W1.4 x W1.4 (10 x 10) 121 lb. per C.S.F., A185, incl...	0.01000	C.S.F.	0.15	0.36	0.51
Structural concrete, placing, elevated slab, pumped, less than 6" thick, includes strike...	0.33300	C.F.	0.00	0.51	0.51
Structural concrete, ready mix, lightweight, 110 #/C.F., 3000 psi, includes local aggre...	0.33300	C.F.	2.41	0.00	2.41
Concrete finishing, floors, for specified Random Access Floors in ACI Classes 1, 2, 3 an...	1.00000	S.F.	0.00	0.86	0.86
Concrete surface treatment, curing, sprayed membrane compound	0.01000	C.S.F.	0.08	0.09	0.17
Weld shear connector, 3/4" dia x 4-7/8" L	0.12600	Ea.	0.09	0.25	0.35
Structural steel project, apartment, nursing home, etc, 100-ton project, 3 to 6 stories,...	4.45400	Lb.	6.24	1.92	8.15
Metal floor decking, steel, non-cellular, composite, galvanized, 3" D, 22 gauge	1.05000	S.F.	2.08	0.98	3.06
Metal decking, steel edge closure form, galvanized, with 2 bends, 12" wide, 18 gauge	0.03300	L.F.	0.13	0.08	0.21
Sprayed fireproofing, cementitious, normal density, beams, 1 hour rated, 1-3/8" thick...	0.50400	S.F.	0.29	0.50	0.79
Total			\$11.45	\$5.85	\$17.30

Assuming that the only change from this system is the replacement of W-shape with cellular beams, we have:

@ 60' span, expect SmartBEAM (LB27x35/46) to cost \$150/ton more than traditional W-shape²⁰

LB27x35/46 typical beam size, 3 beams per 30'x60' bay

$$\frac{35+46}{2} = 40.5 \text{ PLF (60')} \cdot (3\text{bms}) = 7290\# = 3.65 \text{ tons}$$

Since the bay size is double the typical bay (30'x30'), divide tonnage by two

$$\frac{3.65 \text{ tons}}{2} = \left(\frac{1.82 \text{ tons}}{30' \times 30' \text{ bay}} \right) \times \left(\frac{\$150}{\text{ton}} \right) = \frac{\$273}{30' \times 30' \text{ bay}}$$

$$\frac{\$273}{900 \text{ SF}} = +\$0.30 \text{ per SF} \times (152,000 \text{ SF}) \approx \$46,200 \text{ total additional cost}$$


\$17.30 + \$0.30 = \$17.60 Total Cost per SF

¹⁹ "RSMeansOnline," Reed Construction Data Inc., 2013 <meanscostworks.com> (12 October 2012)

²⁰ Steve Redman, CMC Steel, Personal communication (21 March 2013).

appendix B: lateral analysis

B.1 existing frame stiffness calculation



 Academic license user	Job No	Sheet No	Rev
		2	
Part			
Ref			
By Date 19-Feb-13 Chd			
Client File STIFFNESS - existing fra Date/Time 19-Feb-2013 18:02			

Node Displacements

Node	L/C	X (in)	Y (in)	Z (in)	Resultant (in)	rX (rad)	rY (rad)	rZ (rad)
1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
2	1:LOAD CASE	0.086	-0.000	0.000	0.086	0.000	0.000	-0.000
3	1:LOAD CASE	0.131	-0.000	0.000	0.131	0.000	0.000	-0.000
4	1:LOAD CASE	0.177	-0.000	0.000	0.177	0.000	0.000	-0.000
5	1:LOAD CASE	0.231	-0.000	0.000	0.231	0.000	0.000	-0.000
6	1:LOAD CASE	0.294	-0.000	0.000	0.294	0.000	0.000	-0.000
7	1:LOAD CASE	0.085	0.000	0.000	0.085	0.000	0.000	0.000
8	1:LOAD CASE	0.087	-0.000	0.000	0.087	0.000	0.000	-0.000
9	1:LOAD CASE	0.130	-0.001	0.000	0.130	0.000	0.000	-0.000
10	1:LOAD CASE	0.177	-0.000	0.000	0.177	0.000	0.000	-0.000
11	1:LOAD CASE	0.231	-0.000	0.000	0.231	0.000	0.000	-0.000
12	1:LOAD CASE	0.293	-0.000	0.000	0.293	0.000	0.000	-0.000
13	1:LOAD CASE	0.086	-0.023	0.000	0.089	0.000	0.000	-0.000
14	1:LOAD CASE	0.131	-0.012	0.000	0.131	0.000	0.000	-0.000
15	1:LOAD CASE	0.177	-0.012	0.000	0.178	0.000	0.000	-0.000
16	1:LOAD CASE	0.231	-0.015	0.000	0.232	0.000	0.000	-0.000
17	1:LOAD CASE	0.294	-0.008	0.000	0.294	0.000	0.000	-0.000
18	1:LOAD CASE	0.087	0.000	0.000	0.087	0.000	0.000	0.000
19	1:LOAD CASE	0.130	0.011	0.000	0.131	0.000	0.000	-0.000
20	1:LOAD CASE	0.177	0.012	0.000	0.178	0.000	0.000	-0.000
21	1:LOAD CASE	0.231	0.014	0.000	0.232	0.000	0.000	-0.000
22	1:LOAD CASE	0.293	0.007	0.000	0.293	0.000	0.000	-0.000

Node Displacement Summary

	Node	L/C	X (in)	Y (in)	Z (in)	Resultant (in)	rX (rad)	rY (rad)	rZ (rad)
Max X	6	1:LOAD CASE	0.294	-0.000	0.000	0.294	0.000	0.000	-0.000
Min X	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Max Y	21	1:LOAD CASE	0.231	0.014	0.000	0.232	0.000	0.000	-0.000
Min Y	13	1:LOAD CASE	0.086	-0.023	0.000	0.089	0.000	0.000	-0.000
Max Z	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Min Z	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Max rX	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Min rX	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Max rY	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Min rY	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Max rZ	18	1:LOAD CASE	0.087	0.000	0.000	0.087	0.000	0.000	0.000
Min rZ	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.001
Max Rst	17	1:LOAD CASE	0.294	-0.008	0.000	0.294	0.000	0.000	-0.000

Print Time/Date: 19/02/2013 18:03


STAAD.Pro V8i (SELECTseries 3)/Academic 20.07.08.22

Print Run 2 of 2

Stiffness of original frame

$$K = \frac{P}{\Delta} = \frac{1 k}{0.294 \text{ in}} = 3.34 \text{ ksi} \text{ using STAAD values of displacement}$$

B.2 proposed frame stiffness calculation



Print Time/Date: 19/02/2013 18:02

STAAD.Pro V8i (SELECTseries 3)/Academic 20.07.08.22

Print Run 1 of 2

 Academic license user	Job No	Sheet No	Rev
Job Title		2	
	Part		
	Ref		
	By Date 19-Feb-13 Chd		
Client	File STIFFNESS - new frame	Date/Time 19-Feb-2013 17:58	

Node Displacements

Node	L/C	X (in)	Y (in)	Z (in)	Resultant (in)	rX (rad)	rY (rad)	rZ (rad)
1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
2	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
3	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
4	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
5	1:LOAD CASE	0.001	0.000	0.000	0.001	0.000	0.000	-0.000
6	1:LOAD CASE	0.001	0.000	0.000	0.001	0.000	0.000	-0.000
7	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
8	1:LOAD CASE	0.000	-0.000	0.000	0.000	0.000	0.000	-0.000
9	1:LOAD CASE	0.000	-0.000	0.000	0.000	0.000	0.000	-0.000
10	1:LOAD CASE	0.000	-0.000	0.000	0.000	0.000	0.000	-0.000
11	1:LOAD CASE	0.000	-0.000	0.000	0.001	0.000	0.000	-0.000
12	1:LOAD CASE	0.001	-0.000	0.000	0.001	0.000	0.000	-0.000
13	1:LOAD CASE	0.000	-0.000	0.000	0.000	0.000	0.000	-0.000
14	1:LOAD CASE	0.000	-0.000	0.000	0.000	0.000	0.000	-0.000
15	1:LOAD CASE	0.000	-0.000	0.000	0.000	0.000	0.000	-0.000
16	1:LOAD CASE	0.000	-0.000	0.000	0.000	0.000	0.000	-0.000
17	1:LOAD CASE	0.001	-0.000	0.000	0.001	0.000	0.000	-0.000

Node Displacement Summary

	Node	L/C	X (in)	Y (in)	Z (in)	Resultant (in)	rX (rad)	rY (rad)	rZ (rad)
Max X	6	1:LOAD CASE	0.001	0.000	0.000	0.001	0.000	0.000	-0.000
Min X	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Max Y	6	1:LOAD CASE	0.001	0.000	0.000	0.001	0.000	0.000	-0.000
Min Y	12	1:LOAD CASE	0.001	-0.000	0.000	0.001	0.000	0.000	-0.000
Max Z	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Min Z	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Max rX	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Min rX	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Max rY	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Min rY	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Max rZ	7	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Min rZ	1	1:LOAD CASE	0.000	0.000	0.000	0.000	0.000	0.000	-0.000
Max Rst	6	1:LOAD CASE	0.001	0.000	0.000	0.001	0.000	0.000	-0.000

Print Time/Date: 19/02/2013 18:02

STAAD.Pro V8i (SELECTseries 3)/Academic 20.07.08.22

Print Run 2 of 2

Stiffness of proposed frame

$$K = \frac{P}{\Delta} = \frac{1 k}{0.1 \text{ in}} = 10 \text{ ksi} \text{ using STAAD values of displacement}$$

B.3 story displacement load cases/combos

allowable inter-story drift

$$\frac{H}{400} = \frac{(13 \text{ ft}) \left(12 \frac{\text{in}}{\text{ft}} \right)}{400} = 0.39 \text{ in} \geq 0.23398 \text{ in maximum in RAM model, OK}$$

load case definitions

1	D	DeadLoad	RAMUSER
2	Lp	PosLiveLoad	RAMUSER
3	Sp	PosRoofLiveLoad	RAMUSER
4	E1	Wind	EQ_IBC09_X_+E_F
5	E2	Wind	EQ_IBC09_X_-E_F
6	E3	Wind	EQ_IBC09_Y_+E_F
7	E4	Wind	EQ_IBC09_Y_-E_F
8	E5	Seismic	EQ_IBC09_X_+E_F
9	E6	Seismic	EQ_IBC09_X_-E_F
10	E7	Seismic	EQ_IBC09_Y_+E_F
11	E8	Seismic	EQ_IBC09_Y_-E_F
12	W1	Wind Calc X	W_User
13	W2	Wind Calc Y	W_User

load combinations

1 *	1.000 D
2 *	1.000 D + 1.000 Lp
3 *	1.000 D + 1.000 Sp
4 *	1.000 D + 0.750 Lp + 0.750 Sp
5 *	1.000 D + 1.000 W1
6 *	1.000 D + 1.000 W2
7 *	1.000 D - 1.000 W1
8 *	1.000 D - 1.000 W2
9 *	1.000 D + 0.750 Lp + 0.750 Sp + 0.750 W1
10 *	1.000 D + 0.750 Lp + 0.750 Sp + 0.750 W2
11 *	1.000 D + 0.750 Lp + 0.750 Sp - 0.750 W1
12 *	1.000 D + 0.750 Lp + 0.750 Sp - 0.750 W2
13 *	1.000 D + 0.750 Lp + 0.750 W1
14 *	1.000 D + 0.750 Lp + 0.750 W2
15 *	1.000 D + 0.750 Lp - 0.750 W1
16 *	1.000 D + 0.750 Lp - 0.750 W2
17 *	1.000 D + 0.750 Sp + 0.750 W1
18 *	1.000 D + 0.750 Sp + 0.750 W2
19 *	1.000 D + 0.750 Lp-0.525 E1

20 *	1.000 D + 0.750 Sp - 0.750 W2
21 *	0.600 D + 1.000 W1
22 *	0.600 D + 1.000 W2
23 *	0.600 D - 1.000 W1
24 *	0.600 D - 1.000 W2
25 *	1.012 D + 0.700 E1
26 *	1.012 D + 0.700 E2
27 *	1.012 D + 0.700 E3
28 *	1.012 D + 0.700 E4
29 *	1.012 D + 0.700 E5
30 *	1.012 D + 0.700 E6
31 *	1.012 D + 0.700 E7
32 *	1.012 D + 0.700 E8
33 *	1.012 D - 0.700 E1
34 *	1.012 D - 0.700 E2
35 *	1.012 D - 0.700 E3
36 *	1.012 D - 0.700 E4
37 *	1.012 D - 0.700 E5
38 *	1.012 D - 0.700 E6
39 *	1.012 D - 0.700 E7
40 *	1.012 D - 0.700 E8
41 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E1
42 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E2
43 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E3
44 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E4
45 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E5
46 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E6
47 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E7
48 *	1.009 D + 0.750 Lp + 0.750 Sp + 0.525 E8
49 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E1
50 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E2
51 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E3
52 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E4
53 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E5
54 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E6
55 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E7
56 *	1.009 D + 0.750 Lp + 0.750 Sp - 0.525 E8
57 *	1.009 D + 0.750 Lp + 0.525 E1
58 *	1.009 D + 0.750 Lp + 0.525 E2
59 *	1.009 D + 0.750 Lp + 0.525 E3
60 *	1.009 D + 0.750 Lp + 0.525 E4
61 *	1.009 D + 0.750 Lp + 0.525 E5
62 *	1.009 D + 0.750 Lp + 0.525 E6
63 *	1.009 D + 0.750 Lp + 0.525 E7

64 *	1.009 D + 0.750 Lp + 0.525 E8
65 *	1.009 D + 0.750 Lp - 0.525 E1
66 *	1.009 D + 0.750 Lp - 0.525 E2
67 *	1.009 D + 0.750 Lp - 0.525 E3
68 *	1.009 D + 0.750 Lp - 0.525 E4
69 *	1.009 D + 0.750 Lp - 0.525 E5
70 *	1.009 D + 0.750 Lp - 0.525 E6
71 *	1.009 D + 0.750 Lp - 0.525 E7
72 *	1.009 D + 0.750 Lp - 0.525 E8
73 *	1.009 D + 0.750 Sp + 0.525 E1
74 *	1.009 D + 0.750 Sp + 0.525 E2
75 *	1.009 D + 0.750 Sp + 0.525 E3
76 *	1.009 D + 0.750 Sp + 0.525 E4
77 *	1.009 D + 0.750 Sp + 0.525 E5
78 *	1.009 D + 0.750 Sp + 0.525 E6
79 *	1.009 D + 0.750 Sp + 0.525 E7
80 *	1.009 D + 0.750 Sp + 0.525 E8
81 *	1.009 D + 0.750 Sp - 0.525 E1
82 *	1.009 D + 0.750 Sp - 0.525 E2
83 *	1.009 D + 0.750 Sp - 0.525 E3
84 *	1.009 D + 0.750 Sp - 0.525 E4
85 *	1.009 D + 0.750 Sp - 0.525 E5
86 *	1.009 D + 0.750 Sp - 0.525 E6
87 *	1.009 D + 0.750 Sp - 0.525 E7
88 *	1.009 D + 0.750 Sp - 0.525 E8
89 *	0.588 D + 0.700 E1
90 *	0.588 D + 0.700 E2
91 *	0.588 D + 0.700 E3
92 *	0.588 D + 0.700 E4
93 *	0.588 D + 0.700 E5
94 *	0.588 D + 0.700 E6
95 *	0.588 D + 0.700 E7
96 *	0.588 D + 0.700 E8
97 *	0.588 D - 0.700 E1
98 *	0.588 D - 0.700 E2
99 *	0.588 D - 0.700 E3
100 *	0.588 D - 0.700 E4
101 *	0.588 D - 0.700 E5
102 *	0.588 D - 0.700 E6
103 *	0.588 D - 0.700 E7
104 *	0.588 D - 0.700 E8

appendix C: foundation loads

IMPACT ON FOUNDATIONS @ B2, B9, D2, D9, F2, F9	
<u>EDGE COL (B2, F2, B9, F9)</u>	
existing loads	redesign loads
<p>TOTAL LOAD = 342.4 k</p> $\Rightarrow \frac{443.2}{342.4} = 1.3 = 30\% \text{ increase in load on col/foundation}$	<p>TOTAL LOAD = 443.2 k</p>
<u>MIDDLE COL (D2, D9)</u>	
<p>TOTAL LOAD = 526 k</p> $\Rightarrow \frac{857}{526} = 1.63 = 63\% \text{ increase in load on foundation}$	<p>TOTAL LOAD = 857 k</p>

appendix D: architectural calcs

D.1 mullion design

MULLION DESIGN	$\frac{1}{2}$	
	WIND LOAD:	$22 \text{ PSF} \times 5' = 110 \text{ PLF}$
		$110 \text{ PLF} \times \frac{1\text{FT}}{0.3048 \text{ m}} \times \frac{4.45 \text{ N}}{1\#} = 1.61 \text{ KN/m}$
	ASSUME:	MULLION IS ALUMINUM 6063-T5 EXP JOINTS ARE RIGID
 $13' = 3.96 \text{ m}$	BENDING:	$+M_{max} = d_m \cdot q \cdot L^2$ $= (0.0703)(1.61 \text{ KN/m})(3.96 \text{ m})^2$ $= 1.77 \text{ kN}\cdot\text{m}$ $-M_{max} = d_m \cdot q \cdot L^2$ $= (-0.125)(1.61)(3.96)^2$ $= -3.16 \text{ kN}\cdot\text{m}$ $\therefore -M_{max} = -3.16 \text{ kN}\cdot\text{m} \text{ CONTROLS}$
		$\sigma' = \frac{Mc}{I} = \frac{M}{S} \Rightarrow S = \frac{M}{\sigma}$ $S = \frac{M}{\sigma} = \frac{-3.16 \text{ kN}\cdot\text{m}}{69000 \text{ KN/m}^2} = 4.57 \times 10^{-5} \text{ m}^3$ $= 45,700 \text{ mm}^3$
		$S \leq \frac{I}{y}$ $45700 \text{ mm}^3 \leq \frac{(1)}{12} (101.6 \text{ mm})^4 - \frac{(1)}{12} (101.6 - 2t)^4$ $2,321,560 - 8879603 = -\left(\frac{1}{12}\right)(101.6 - 2t)^4$ $7869616 = (101.6 - 2t)^4$ $94.18 - 101.6 = -2t$ $\Rightarrow t = 3.7 = 4 \text{ mm (too thin to make)}$ $\Rightarrow \text{try } 6.35 \text{ mm } (\approx \frac{1}{4}')$

MULLION DESIGN (cont) 2/2

SHEAR:

$$Q_{max} = d_f q L$$

$$= (0.625)(1.61)(3.96)$$

$$= 3.98 \text{ kN}$$

$$T = \left(\frac{3}{2}\right) \frac{V}{A} \Rightarrow A = \left(\frac{3}{2}\right) \frac{V}{T}$$

$$A = \left(\frac{3}{2}\right) \frac{3980 \text{ N}}{37 \text{ N/mm}^2}$$

$$= 157.7 \text{ mm}^2$$

$$157.7 \leq (101.6)^2 - (101.6 - 2t)^2$$

$$100.82 \leq 101.6 - 2t$$

$0.39 \leq t$ (again, too small \rightarrow stick w/ 6.35mm $\approx \frac{1}{4}$ ")

DEFLECTION

$$f_{max} = \frac{d_f q L^4}{100EI}$$

$$= \frac{(0.521)(1.61)(3.96)^4}{100(70000 \text{ N/mm}^2)\left(\frac{1}{12}\right)(101.6)^4 - \left(\frac{1}{12}\right)(101.6 - (6.35)2)^4}$$


$$= \frac{206.27 \times 10^{12}}{(100)(70000)(8674543)}$$

$$= 8.02 \text{ mm}$$

$$f_{allow} = \frac{\text{SPAN}}{180} = \frac{3960 \text{ mm}}{180} = 22 \neq 20 \rightarrow \text{use } 20 \text{ mm}$$

$8.02 \text{ mm} < 20 \text{ mm}$, \therefore GOOD!

USE $\frac{1}{4}$ " THICK (6.35mm) MULLION



D.2 R-value + temp gradients

existing brick veneer wall system						
layer material	conductivity, k (W/mK)	thickness, l (m)	conductance, C $C = k/l$ (W/m ² K)	resistance, R _{SI} $R_{SI} = 1/C$ m ² K/W	temp change, ΔT $\Delta T = (R_i/\sum R_{ij}) * (T_{int} - T_{ext})$ (°C)	t (°C)
exterior temp (-15 C, 85% RH)						-15
exterior film	-	-	34.00	0.029	0.393	
						-14.607
brick	1.3	0.09	14.44	0.069	0.926	
						-13.681
air gap	-	0.04	-	0.170	2.273	
						-11.408
rigid insulation (EPS 1)	0.039	0.05	0.78	1.282	17.144	
						5.736
Batt Insulation/Stud	-	0.07	-	0.896	11.981	
						17.717
gypsum board	0.16	0.02	8.00	0.125	1.672	
						19.389
interior film	-	-	8.30	0.120	1.611	
interior temp (21 C, 40% RH)						21
				R _{SI} = 2.692		
				R _{value} = 5.678*R _{SI} = 15.286		
				U _{SI} = 0.371		
				U _{value} = 0.065		

redesigned insulated panel [brick skin]						
layer material	conductivity, k (W/mK)	thickness, l (m)	conductance, C $C = k/l$ (W/m ² K)	resistance, R _{SI} $R_{SI} = 1/C$ m ² K/W	temp change, ΔT $\Delta T = (R_i/\sum R_{ij}) * (T_{int} - T_{ext})$ (°C)	t (°C)
exterior temp (-15 C, 85% RH)						-15
exterior film	-	-	34.00	0.029	0.273	
						-14.727
brick	1.3	0.09	14.44	0.069	0.643	
						-14.084
air gap	-	0.04	-	0.170	1.579	
						-12.505
insulation panel	-	0.0508	-	2.466	22.902	
						10.397
3" Batt Insulation/6"Stud	-	0.07	-	0.896	8.322	
						18.720
gypsum board	0.16	0.02	8.00	0.125	1.161	
						19.881
interior film	-	-	8.30	0.120	1.119	
interior temp (21 C, 40% RH)						21
				R _{SI} = 3.876		
				R _{value} = 5.678*R _{SI} = 22.007		
				U _{SI} = 0.258		
				U _{value} = 0.045		

redesigned insulated panel [metal skin]

layer material	conductivity, k (W/mK)	thickness, l (m)	conductance, C $C = k/l$ (W/m ² K)	resistance, R _{SI} $R_{SI} = 1/C$ m ² K/W	temp change, ΔT $\Delta T = (R_i/\sum R_i) * (T_{int} - T_{ext})$ (°C)	t (°C)
exterior temp (-15 C, 85% RH)						-15
exterior film	-	-	34.00	0.029	0.278	
						-14.722
metal panel	80	0.008	10000.00	0.000	0.001	
						-14.721
air gap	-	0.04	-	0.170	1.608	
						-13.113
insulation panel	0.039	0.0508	-	2.466	23.318	
						10.205
3" Batt Insulation/6"Stud	-	0.07	-	0.896	8.474	
						18.678
gypsum board	0.16	0.02	8.00	0.125	1.182	
						19.861
interior film	-	-	8.30	0.120	1.139	
interior temp (21 C, 40% RH)						21
$R_{SI} = \mathbf{3.807}$ $R_{value} = 5.678 * R_{SI} = \mathbf{21.614}$ $U_{SI} = \mathbf{0.263}$ $U_{value} = \mathbf{0.046}$						

D.3 pressure gradient + RH

existing brick veneer wall system							
layer material	permeability, μ $M = \mu/t$ (ng/Pa*s*m)	permeance, M $R_{vj} = 1/M$ (Pa*s*m ² /ng)	R_{vj}	pressure change, ΔP $\Delta P = (R_{vj}/\sum R_{vj}) * (P_{int} - P_{ext})$ (Pa)	P_w @ interface (Pa)	$P_{w,sat}$ $P_{w,sat} = 1000e^{(52.58 - 6790.5/T - 5.028lnT)}$ (Pa)	RH $RH = P_w/P_{w,sat}$ (%)
exterior temp (-15 C, 85% RH)					162.43	191.1	85.0
exterior film	-	75000	0.000013	0.163			
brick	10	111.1111111	0.009000	109.864	162.6	197.4	82.4
air gap		7200	0.000139	1.695	272.5	212.9	128.0
rigid insulation (EPS 1)	2	40	0.025000	305.179	274.2	255.6	107.2
Batt Insulation/Stud	3	42.85714286	0.023333	284.834	579.3	913.5	63.4
gypsum board	2	100	0.010000	122.072	864.2	2012.8	42.9
interior film	-	15000	0.000067	0.814	986.2	2234.3	44.1
interior temp (21 C, 40% RH)					987.1	2467.6	40.0
			0.067552	824.62			

redesigned insulated panel [brick skin]							
layer material	permeability, μ $M = \mu/t$ (ng/Pa*s*m)	permeance, M $R_{vj} = 1/M$ (Pa*s*m ² /ng)	R_{vj}	pressure change, ΔP $\Delta P = (R_{vj}/\sum R_{vj}) * (P_{int} - P_{ext})$ (Pa)	P_w @ interface (Pa)	$P_{w,sat}$ $P_{w,sat} = 1000e^{(52.58 - 6790.5/T - 5.028lnT)}$ (Pa)	RH $RH = P_w/P_{w,sat}$ (%)
exterior temp (-15 C, 85% RH)					162.4310376	191.1	85.0
exterior film	-	75000	0.000013	0.161804	162.592842	195.4	83.2
brick	10	111.1	0.009000	109.217666	271.810507	206.0	131.9
air gap		7200	0.000139	1.685458	273.495965	234.1	116.8
insulation panel	2	39.37	0.025400	308.236524	581.732489	1253.4	46.4
Batt Insulation/Stud	3	42.86	0.023333	283.156911	864.889400	2143.2	40.4
gypsum board	2	100	0.010000	121.352962	986.242362	2303.4	42.8
interior film	-	15000	0.000067	0.809020	987.051	2467.6	40.0
interior temp (21 C, 40% RH)			0.067952	824.62			

redesigned insulated panel [metal skin]							
layer material	permeability, μ $M = \mu/t$ (ng/Pa*s*m)	permeance, M $R_{vj} = 1/M$ (ng/Pa*s*m ²)	R_{vj}	pressure change, ΔP $\Delta P = (R_{vj}/\sum R_{vj}) * (P_{int} - P_{ext})$ (Pa)	P_w @ interface (Pa)	$P_{w,sat}$ $P_{w,sat} = 1000e^{(52.58 - 6790.5/T - 5.028lnT)}$ (Pa)	RH $RH = P_w/P_{w,sat}$ (%)
exterior temp (-15 C, 85% RH)					162.43	191.1	85.0
exterior film	-	75000	0.000013	0.184	162.6	195.5	83.2
metal panel	10	1250	0.000800	11.041	173.7	195.5	88.8
air gap		7200	0.000139	1.917	175.6	222.9	78.8
insulation panel	2	39.37007874	0.025400	350.537	526.1	1237.5	42.5
Batt Insulation/Stud	3	42.85714286	0.023333	322.015	848.1	2137.7	39.7
gypsum board	2	100	0.010000	138.007	986.1	2300.5	42.9
interior film	-	15000	0.000067	0.920	987.1	2467.6	40.0
interior temp (21 C, 40% RH)			0.059752	824.62			

appendix E: mechanical calcs

E.1 HVAC loads for typical floor

HVAC Loads for Typical Floor							
Room Name	Area (sf)	Lighting Load (W/sf)	Misc. Load (W/sf)	Number of People	Total Load (btu)	CFM Required	Adjusted CFM
220 Office	240	1.0	0.83	1	1757	80	75
302 Conference	290	1.0	6.90	10	10366	471	475
304 Copy	130	1.0	0.00	0	444	20	25
306 Office	150	1.0	1.33	1	1450	66	75
308 Office	150	1.0	1.33	1	1450	66	75
310 Office	150	1.0	1.33	1	1450	66	75
312 Office	150	1.0	1.33	1	1450	66	75
320 Conference	430	1.0	6.51	14	14594	663	675
322 Kitchen	330	1.0	4.85	8	8627	392	400
324 Conference	430	1.0	6.51	14	14594	663	675
330 Office	150	1.0	1.33	1	1450	66	75
332 Office	150	1.0	1.33	1	1450	66	75
334 Office	150	1.0	1.33	1	1450	66	75
336 Office	150	1.0	1.33	1	1450	66	75
338 Copy	110	1.0	0.00	0	375	17	25
420 Office	250	1.0	0.80	1	1791	81	75
418 Office	150	1.0	1.33	1	1450	66	75
416 Office	150	1.0	1.33	1	1450	66	75
414 Office	150	1.0	1.33	1	1450	66	75
410 Office	150	1.0	1.33	1	1450	66	75
408 Office	150	1.0	1.33	1	1450	66	75
406 Office	150	1.0	1.33	1	1450	66	75
404 Office	150	1.0	1.33	1	1450	66	75
402 Office	250	1.0	0.80	1	1791	81	75
142 Copy	110	1.0	0.00	0	375	17	25
140 Office	150	1.0	1.33	1	1450	66	75
138 Office	150	1.0	1.33	1	1450	66	75
136 Office	150	1.0	1.33	1	1450	66	75
134 Office	150	1.0	1.33	1	1450	66	75
132 Office	150	1.0	1.33	1	1450	66	75
130 Office	160	1.0	1.25	1	1484	67	75
124 Conference	400	1.0	7.00	14	14492	659	650
122 Conference	260	1.0	6.15	8	8388	381	375
120 Conference	410	1.0	6.83	14	14526	660	650
110 Office	160	1.0	1.25	1	1484	67	75
108 Office	150	1.0	1.33	1	1450	66	75
106 Office	150	1.0	1.33	1	1450	66	75
104 Office	150	1.0	1.33	1	1450	66	75
102 Copy	110	1.0	0.00	0	375	17	25
202 Office	240	1.0	0.83	1	1757	80	75
204 Office	150	1.0	1.33	1	1450	66	75
206 Office	150	1.0	1.33	1	1450	66	75
208 Office	150	1.0	1.33	1	1450	66	75
210 Office	160	1.0	1.25	1	1484	67	75
214 Office	150	1.0	1.33	1	1450	66	75
216 Office	150	1.0	1.33	1	1450	66	75
218 Office	160	1.0	1.25	1	1484	67	75

Room Name	Area (sf)	Lighting Load (W/sf)	Misc. Load (W/sf)	Number of People	Total Load (btu)	CFM Required	Adjusted CFM
Open Office NW	1738	1.0	1.15	10	15308	696	700
309 Office	150	1.0	1.33	1	1450	66	75
311 Office	150	1.0	1.33	1	1450	66	75
510 Office	150	1.0	1.33	1	1450	66	75
512 Office	150	1.0	1.33	1	1450	66	75
700 Training Room	600	1.0	6.67	20	20800	945	950
560 Conference	670	1.0	5.37	18	19164	871	875
800 File Room	600	1.0	0.00	0	2048	93	100
329 Office	150	1.0	1.33	1	1450	66	75
331 Office	150	1.0	1.33	1	1450	66	75
530 Office	150	1.0	1.33	1	1450	66	75
532 Office	150	1.0	1.33	1	1450	66	75
Open Office NE	2442	1.0	1.06	13	20523	933	925
Open Office SW	1800	1.0	1.44	13	18332	833	825
609 Office	150	1.0	1.33	1	1450	66	75
607 Office	150	1.0	1.33	1	1450	66	75
605 Office	150	1.0	1.33	1	1450	66	75
603 Office	160	1.0	1.25	1	1484	67	75
107 ITS Server	570	1.0	0.00	0	1945	88	100
107a Storage	240	1.0	0.00	0	819	37	25
111 Guest Office	80	1.0	2.50	1	1211	55	50
001 Elev Lobby	610	1.0	0.00	0	2082	95	100
100 Reception	600	1.0	2.67	8	9549	434	425
129 Office	100	1.0	2.00	1	1279	58	50
131 Guest Office	100	1.0	2.00	1	1279	58	50
135 Guest Office	100	1.0	2.00	1	1279	58	50
133 Kitchen	380	1.0	6.32	12	12548	570	575
909 Office	150	1.0	1.33	1	1450	66	75
907 Office	150	1.0	1.33	1	1450	66	75
905 Office	150	1.0	1.33	1	1450	66	75
903 Office	150	1.0	1.33	1	1450	66	75
Open Office SE	1437	1.0	1.39	10	14280	649	650
100W Corridor	400	1.0	0.00	0	1365	62	50
500W Corridor	800	1.0	0.00	0	2730	124	125
500 Corridor	500	1.0	0.00	0	1707	78	75
300 Corridor	700	1.0	0.00	0	2389	109	100
700n Corridor	191	1.0	0.00	0	652	30	25
800n Corridor	210	1.0	0.00	0	717	33	25
100e Corridor	315	1.0	0.00	0	1075	49	50

TOTALS	
Square Footage	26423
CFM Required	14800
CFM/SF	0.56
Total Population	100
Population Div.	41.3%

E.2 ASHRAE 62.1-2007 outdoor air requirements

Ventilation for Acceptable Indoor Air Quality (ASHRAE 62.1-2007)										
Program Area (SF)	Room Type	People	Area	Occupant Density, #/1000 sf	Air Class	Zone P _z	Zone Population, V _{bz} , cfm	Zone OA, E _z	Zone OA, V _{oz} , cfm	
		Outdoor Air Rate, Rp	Outdoor Air Rate, Ra							
220 Office	240	Office Space	5	0.06	5	1	1	19.4	1.0	19.4
302 Conference	290	Conference/ meeting	5	0.06	50	1	10	67.4	1.0	67.4
304 Copy	130	Storage Rooms	0	0.12	0	0	0	15.6	1.0	15.6
306 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
308 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
310 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
312 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
320 Conference	430	Conference/ meeting	5	0.06	50	1	14	95.8	1.0	95.8
322 Kitchen	330	Office Space	5	0.06	5	1	8	59.8	1.0	59.8
324 Conference	430	Conference/ meeting	5	0.06	50	1	14	95.8	1.0	95.8
330 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
332 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
334 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
336 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
338 Copy	110	Storage Rooms	0	0.12	0	0	0	13.2	1.0	13.2
420 Office	250	Office Space	5	0.06	5	1	1	20	1.0	20
418 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
416 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
414 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
410 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
408 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
406 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
404 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
402 Office	250	Office Space	5	0.06	5	1	1	20	1.0	20
142 Copy	110	Storage Rooms	0	0.12	0	0	0	13.2	1.0	13.2
140 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
138 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
136 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
134 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
132 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
130 Office	160	Office Space	5	0.06	5	1	1	14.6	1.0	14.6
124 Conference	400	Conference/ meeting	5	0.06	50	1	14	94	1.0	94
122 Conference	260	Conference/ meeting	5	0.06	50	1	8	55.6	1.0	55.6
120 Conference	410	Conference/ meeting	5	0.06	50	1	14	94.6	1.0	94.6
110 Office	160	Office Space	5	0.06	5	1	1	14.6	1.0	14.6
108 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
106 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
104 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
102 Copy	110	Storage Rooms	0	0.12	0	0	0	13.2	1.0	13.2
202 Office	240	Office Space	5	0.06	5	1	1	19.4	1.0	19.4
204 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
206 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
208 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
210 Office	160	Office Space	5	0.06	5	1	1	14.6	1.0	14.6
214 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
216 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
218 Office	160	Office Space	5	0.06	5	1	1	14.6	1.0	14.6

Program Area (SF)	Room Type	People	Area	Occupant Density, #/1000 sf	Air Class	Zone Population, P_z	Breathing			
		Outdoor Air Rate, Rp	Outdoor Air Rate, Ra				Zone OA, $V_{bz, cfm}$	Zone OA, E_z	Zone OA, $V_{oz, cfm}$	
Open Office NW	1738	Office Space	5	0.06	5	1	10	154.28	1.0	154.28
309 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
311 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
510 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
512 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
700 Training Room	600	Conference/ meeting	5	0.06	50	1	20	136	1.0	136
560 Conference	670	Conference/ meeting	5	0.06	50	1	18	130.2	1.0	130.2
800 File Room	600	Storage Rooms	0	0.12	0	0	0	72	1.0	72
329 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
331 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
530 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
532 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
Open Office NE	2442	Office Space	5	0.06	5	1	13	211.52	1.0	211.52
Open Office SW	1800	Office Space	5	0.06	5	1	13	173	1.0	173
609 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
607 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
605 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
603 Office	160	Office Space	5	0.06	5	1	1	14.6	1.0	14.6
107 ITS Server	570	Electrical Equip Rooms	0	0.06	0	0	0	34.2	1.0	34.2
107a Storage	240	Storage Rooms	0	0.12	0	0	0	28.8	1.0	28.8
111 Office	80	Office Space	5	0.06	5	1	1	9.8	1.0	9.8
001 Elev Lobby	610	Reception Areas	5	0.06	5	1	0	36.6	1.0	36.6
100 Reception	600	Reception Areas	5	0.06	5	1	8	76	1.0	76
129 Office	100	Office Space	5	0.06	5	1	1	11	1.0	11
131 Office	100	Office Space	5	0.06	5	1	1	11	1.0	11
135 Office	100	Office Space	5	0.06	5	1	1	11	1.0	11
133 Kitchen	380	Office Space	5	0.06	5	1	12	82.8	1.0	82.8
909 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
907 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
905 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
903 Office	150	Office Space	5	0.06	5	1	1	14	1.0	14
Open Office SE	1437	Office Space	5	0.06	5	1	10	136.22	1.0	136.22
100W Corridor	400	Corridors	0	0.06	0	1	0	24	1.0	24
500W Corridor	800	Corridors	0	0.06	0	1	0	48	1.0	48
500 Corridor	500	Corridors	0	0.06	0	1	0	30	1.0	30
300 Corridor	700	Corridors	0	0.06	0	1	0	42	1.0	42
700n Corridor	191	Corridors	0	0.06	0	1	0	11.46	1.0	11.46
800n Corridor	210	Corridors	0	0.06	0	1	0	12.6	1.0	12.6
100e Corridor	315	Corridors	0	0.06	0	1	0	18.9	1.0	18.9

E.3 TRACE system checksums

System Checksums By ACADEMIC

AHU-01										Packaged Terminal Air Conditioner										
COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES					
Peaked at Time: Outside Air:		Mo/Hr: 7 / 15 OADB/WB/HR: 86 / 71 / 95			Space Sens + Lat. Blu/h		Plenum Sens. + Lat. Blu/h			Space Total Blu/h		Space Sensible Blu/h			Space Peak Space Sens Blu/h		Coil Peak Tot Sens Blu/h		Percent of Total (%)	
Envelope Loads					Sens.	Lat.	Sens.	Lat.		Total	Net	Percent of Total (%)	Sensible Blu/h		Envelope Loads	Sens.	Peak	Percent of Total (%)	SADB Ra Plenum Return RevOA Fn MtrTD Fn BltdT Fn Frct	
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Skylite Solar	0	0	0	53.5 75.0 76.1 78.5 0.0 0.0	
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Skylite Cond	0	0	0	90.8 70.0 54.1 0.0 0.0	
Roof Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Roof Cond	0	0	0	0.0	
Glass Solar	20.115	0	0	0	20.115	17	27.352	37	-219	0	0	0	0	0	Glass Solar	0	0	0	0.0	
Glass/Door Cond	718	0	0	0	718	1	2.658	4	2.658	4	0	0	0	0	Glass/Door Cond	0	0	0	0.0	
Wall Cond	2.648	0	0	0	0	0	0	0	0	0	0	0	0	0	Wall Cond	0	0	0	0.0	
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Partition/Door	0	0	0	0.0	
Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Floor	0	0	0	0.0	
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Adjacent Floor	0	0	0	0.0	
Infiltration	19.816	0	19.816	17	5.346	7	35.137	47	35.137	47	-71.618	-71.618	-54.828	-71.618	Infiltration	0	0	0	0.0	
Sub Total ==>	43.297	0	43.297	37											Sub Total ==>				0.0	
Internal Loads															Internal Loads					
Lights	18.258	4.564	22.822	19	18.258	25	28	25	20.880	29	0	0	0	0	Lights	0	0	0	0.0	
People	34.878	0	34.878	29	0	0	0	0	0	0	0	0	0	0	People	0	0	0	0.0	
Misc	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Misc	0	0	0	0.0	
Sub Total ==>	53.136	4.564	57.700	49	39.138	53	53	53	39.138	53	0	0	0	0	Sub Total ==>	0	0	0	0.0	
Ceiling Load	0	0	0	0	20.017	17	0	0	0	0	0	0	0	0	Ceiling Load	0	0	0	0.0	
Ceiling Load	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Ventilation Load	0	0	0	0.0	
Ventilation Load	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	0.0	
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0	0.0	
Dehumid. Ov Sizing	0	-2.450	-2.450	-2	0	0	0	0	0	0	0	0	0	0	Exhaust Heat	0	0	0	0.0	
Exhaust Heat															OA Preheat Diff.	0	0	0	0.0	
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0	RA Preheat Diff.	0	0	0	0.0	
Duct Heat Pickup	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Additional Reheat	0	0	0	0.0	
Underflr Sup Ht Pickup	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Underflr Sup Ht Pickup	0	0	0	0.0	
Supply Air Leakage															Supply Air Leakage	0	0	0	0.0	
Grand Total ==>	96.433	2.114	118.564	100.00			74.275	100.00							Grand Total ==>	-71.618	-126.354	100.00	0.0	
COOLING COIL SELECTION										AREAS										
Total Capacity ton	Sens Cap MBh	Coil Airflow cfm	Enter DB/WB/HR °F	Leave DB/WB/HR °F	Leave DEW/BH/R gr/lb	Leave DEW/BH/R °F	Gross Total ft ²	Gross ft ²	Areas (%)	Main Htg MBh	Aux Htg MBh	Preheat MBh	Humidif MBh	Opt Vent MBh	Main Htg cfm	Aux Htg cfm	Preheat cfm	Humidif cfm	Opt Vent cfm	
Main Cig	9.9	118.6	80.0	3.233	77.9	64.9	75.6	53.5	52.5	60.0	0.0	0.0	0.0	0.0	126.4	3.23	54.1	90.8	0.0	
Aux Cig	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Total	9.9	118.6														6.079	0	0	0	
																	2.232	670	30	
																		0	0	
																		0	0	
																		0	0	
																		-126.4	85	

Project Name: MTOB 1-1-TRC
Dataset Name: MTOB 1-1-TRC

TRACE® 700 v6.2.9 calculated at 03:31 PM on 02/25/2013
Alternative - 1 System Checksums Report Page 1 of 4

System Checksums

By ACADEMIC

AHU-02

COOLING COIL PEAK			CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES					
Peaked at Time: Outside Air:	Mo/Hr: 7 / 15 OADB/WB/HR: 86 / 71 / 95		Space Sens + Lat. Btu/h	Plenum Sens + Lat Btu/h	Net Total Btu/h	Percent Of Total (%)	Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	Cooling SADB Ra Plenum Return Ret/OA Fn MtrTD Fn BlidTD Fn Frict	Heating Design OADB: 5 Roach Cond Fn Cond Fn Frict	
Envelope Loads														
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Roof Cond	24,662	0	24,662	0	18	30,852	37	0	0	0	0	0	0	0
Glass Solar	-108	0	-108	0	-808	-808	-1	0	0	0	0	0	0	0
Glass/Door Cond	2,491	0	2,491	2	2,486	3	0	0	0	0	0	0	0	0
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Infiltration	25,243	0	25,243	19	6,806	6	0	0	0	0	0	0	0	0
Sub Total ==>	52,288	0	52,288	39	39,346	47	0	0	0	0	0	0	0	0
Internal Loads														
Lights	23,703	5,926	29,629	22	23,703	28	0	0	0	0	0	0	0	0
People	34,110	0	34,110	25	20,203	24	0	0	0	0	0	0	0	0
Misc	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sub Total ==>	57,813	5,926	63,738	47	43,906	53	0	0	0	0	0	0	0	0
Ceiling Load	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Ventilation Load	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Dehumid. On Sizing	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Ov/Undr. Sizing	0	-3,305	-3,305	-2	0	0	0	0	0	0	0	0	0	0
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Underfr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total ==>	110,100	2,621	134,364	100,00	83,251	100,00	0	0	0	0	0	0	0	0
COOLING COIL SELECTION			ENTER DB/WB/HR			LEAVE DB/WB/HR			GROSS TOTAL			AREAS		
Total Capacity ton	Main Cig 11.2	134.4	Total Capacity MBh	Coil Airflow cfm	Entered DB/WB/HR °F	Leave DB/WB/HR °F	Leave DB/WB/HR gr/lb	Gross Total ft ²	Floor Part	Floor Part	Floor Part	MAIN AIRFLOW MBh	Ent Lvg Main Htg	
Aux Cig	0.0	0.0	Sens Cap MBh	3,433	77.9	64.7	74.5	7,892	0	0	0	3,433	53.3	94.4
Opt Vent	0.0	0.0		0	0.0	0.0	0.0	0	0	0	0	0.0	0.0	0.0
Total	11.2	134.4		0	0.0	0.0	0.0	0	0	0	0	0.0	0.0	0.0
HEATING COIL SELECTION			ENTER DB/WB/HR			LEAVE DB/WB/HR			GROSS TOTAL			AREAS		
Total Capacity ton	Main Cig 11.2	134.4	Total Capacity MBh	Coil Airflow cfm	Entered DB/WB/HR °F	Leave DB/WB/HR °F	Leave DB/WB/HR gr/lb	Gross Total ft ²	Floor Part	Floor Part	Floor Part	MAIN AIRFLOW MBh	Ent Lvg Main Htg	
Aux Cig	0.0	0.0	Sens Cap MBh	3,433	74.5	51.3	57.1	7,892	0	0	0	3,433	53.3	94.4
Opt Vent	0.0	0.0		0	0.0	0.0	0.0	0	0	0	0	0.0	0.0	0.0
Total	11.2	134.4		0	0.0	0.0	0.0	0	0	0	0	0.0	0.0	0.0

Project Name: MTOB 1-1 TRC
Dataset Name: MTOB 1-1 TRC

Appendix E: mechanical calcs

TRACE® 700 v6.2.9 calculated at 03:31 PM on 03/25/2013
Alternative - 1 System Checksums Report Page 2 of 4



System Checksums

By ACADEMIC

AHU-03		COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES						
		Peaked at Time: Outside Air:	Mo/Hr: 7 / 15 OADB/WB/HR: 86 / 71 / 95	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Or Total (%)	Sensible Btu/h	Percent Or Total (%)	Envelope Loads	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	Mo/Hr: Heating Design OADB: 5	Cooling SADB Ra Plenum Return Ret/OA Fn MtrTD Fn BlidTD Fn Frict	Heating 70.0 75.0 75.8 77.1 0.0 0.0 0.0				
Envelope Loads				0	0	0	0	0	0	Skyline Solar	0	0	0	84.9						
Skyline Solar				0	0	0	0	0	0	Skyline Cond	0	0	0	70.0						
Skyline Cond				0	0	0	0	0	0	Rooftop Cond	0	0	0	61.6						
Roof Cond				0	0	0	0	0	0	Glass Solar	0	0	0	0.0						
Glass Solar	31,859	0	31,859	30	41,680	54	41.680	0	0	Glass Door Cond	-10,634	10,634	0.0	0.0						
Glass Door Cond	933	0	933	1	44	0	44	0	0	Wall Cond	-6,820	6,820	6.67	4.102						
Wall Cond	4,271	0	4,271	4	4,619	6	0	0	0	Partition/Door	0	0	0	4.102						
Partition/Door	0			0	0	0	0	0	0	Floor	0	0	0	4.102						
Floor	0			0	0	0	0	0	0	Adjacent Floor	0	0	0	4.102						
Adjacent Floor	0			0	0	0	0	0	0	Infiltration	-47,820	-47,820	46.77	0						
Infiltration	18,540	0	18,540	17	4,690	6	50,944	66	66	Sub Total ==>	-65,275	-65,275	63.84	0						
Sub Total ==>	55,603	0	55,603	52						Internal Loads	0	0	0	0						
Internal Loads										Lights	0	0	0	0						
Lights	15,924	3,981	19,905	19	15,924	21	10,634	14	14	People	0	0	0	0						
People	18,321	0	18,321	17	0	0	0	0	0	Misc	0	0	0	0						
Misc	0									Sub Total ==>	34	34	0	0						
Sub Total ==>	34,245	3,981	38,226	36	26,558	34				Ceiling Load	0	0	0	0						
Ceiling Load	0	0	0	14,613	14	0	0	0	0	Air Trans Heat	0	0	0	0						
Ventilation Load	0	0	0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0	0						
Adj Air Trans Heat	0									Exhaust Heat	0	0	0	0						
Dehumid. Or Sizing				0	0	0	0	0	0	RA Preheat Diff.	0	0	0	0						
Ov/Undr Sizing				-1,962	-1,962	-2	-2	0	0	Additional Reheat	0	0	0	0						
Exhaust Heat										Underflr Sup Ht Pkup	0	0	0	0						
Sup. Fan Heat										Supply Air Leakage	0	0	0	0						
Ret. Fan Heat										Grand Total ==>	89,848	2,019	106,481	100,00	77,502	100,00	-65,275	-102,240	100,00	No. People 43
COOLING COIL SELECTION		Total Capacity ton	Sens Cap MBh	Coil Airflow cfm	Enter DB/WB/HR °F	Leave DB/WB/HR °F	Leave DB/WB/HR gr/lb	Gross Total ft ²	Gross Total ft ² (%)	AREAS				HEATING COIL SELECTION						
Main Cig	8.9	106.5	77.4	4,102	76.7	63.3	69.7	57.3	54.5	Floor	5,302	0	0	Main Htg MBh	-102.2	4,102	61.6	84.9		
Aux Cig	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	Part	0	0	0	Aux Htg MBh	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	Int Door	0	0	0	Preheat MBh	0.0	0	0.0	0.0		
Total	8.9	106.5								Ex/Fir Roof	0	0	0	Humidif Opt Vent	0.0	0	0.0	0.0		
										Ext Door Wall	2,320	696	30	Total	-102.2	20.08	-19.28	43		

Project Name: MTOB 1-1-TRC
Dataset Name: MTOB 1-1-TRC

TRACE@700 v6.2.9 calculated at 03:31 PM on 02/25/2013
Alternative - 1 System Checksums Report Page 3 of 4

System Checksums

By ACADEMIC

AHU-04

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Space Sens + Lat. Btu/h	Plenum Sens. Btu/h	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)	Space Peak Btu/h	Percent Tot Sens Btu/h	Coil Peak Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Tot Sens Btu/h	Coil Peak Btu/h	Percent Heating Design		
Envelope Loads														SADB	Cooling
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	Ra Plenum	Heating
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	Return	
Roof Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	Fm MtrTD	
Glass Solar	36,368	0	36,368	26	42,604	45	Envelope Loads	0	0	0	0	0	0	Fm BltdT	
Glass/Door Cond	1,639	0	1,639	1	1,086	1	Skylite Solar	0	0	0	0	0	0	Fm Frct	
Wall Cond	5,187	0	5,187	4	5,536	6	Skylite Cond	0	0	0	0	0	0		
Partition/Door	0	0	0	0	0	0	Glass/Solar	0	0	0	0	0	0		
Floor	0	0	0	0	0	0	Glass/Door Cond	-11,835	0	0	0	0	0		
Adjacent Floor	0	0	0	0	0	0	Wall Cond	-7,590	565	0	0	0	0		
Infiltration	26,094	0	26,094	19	9,037	10	Partition/Door	0	0	0	0	0	0		
Sub Total ==>	69,288	0	69,288	50	58,262	62	Floor	0	0	0	0	0	0		
Internal Loads							Adjacent Floor	0	0	0	0	0	0		
Lights	21,475	5,369	26,843	19	21,475	23	Lighting	0	0	0	0	0	0		
People	25,158	0	25,158	18	14,785	18	People	0	0	0	0	0	0		
Misc	0	0	0	0	0	0	Misc	0	0	0	0	0	0		
Sub Total ==>	46,632	5,369	52,001	37	36,260	38	Sub Total ==>	0	0	0	0	0	0		
Ceiling Load	0	0	0	0	0	0	Ceiling Load	0	0	0	0	0	0		
Ventilation Load	0	0	0	0	20,750	15	Ventilation Load	0	0	0	0	0	0		
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	0	0	0		
Dehumid. Ov Sizing	0	-2,601	-2,601	0	0	0	Ov/Undr Sizing	0	0	0	0	0	0		
Ov/Undr Sizing	0	-2,601	-2,601	-2	0	0	Exhaust Heat	0	0	0	0	0	0		
Exhaust Heat	0	0	0	0	0	0	OA Preheat Diff.	0	0	0	0	0	0		
Ret. Fan Heat	0	0	0	0	0	0	RA Preheat Diff.	0	0	0	0	0	0		
Duct Heat Pkup	0	0	0	0	0	0	Additional Reheat	0	0	0	0	0	0		
Underfl Sup Ht Pkup	0	0	0	0	0	0	Underfl Sup Ht Pkup	0	0	0	0	0	0		
Supply Air Leakage	0	0	0	0	0	0	Supply Air Leakage	0	0	0	0	0	0		
Grand Total ==>	115,920	2,768	139,438	100,00	94,522	100,00	Grand Total ==>	-83,913	-134,438	100,00	-83,913	-134,438	100,00		
COOLING COIL SELECTION				Enter DB/W/BHR				Leave DB/W/BHR				AREAS			
Total Capacity ton	Sens Cap MBh	Coil Airflow cfm	Enter DB/W/BHR °F	Leave DB/W/BHR °F	Leave DEWB/HR gr/lb	Gross Total ft ²	Gross ft ²	Main Htg	Aux Htg	Int Door	Floor Part	Main Htg	Ent Cfm	Lvg °F	
Main Cig	11.6	139.4	100.6	4,718	77.2	64.0	72.0	56.2	54.0	61.4	7,150	0.0	4,718	86.7	
Aux Cig	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0	0.0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0	0.0	0.0	0.0	
Total	11.6	139.4													

Project Name: MTOB 1-1-TRC
Dataset Name:

TRACE® 700 v6.2.9 calculated at 03:31 PM on 02/25/2013
Alternative - 1 System Checksums Report Page 4 of 4

E.4 TRACE room checksums

Room Checksums

By ACADEMIC

220 Office

COOLING COIL PEAK			CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES		
									SADB	Ra Plenum	Heating
									OADB	Return	Design
	Peak at Time: Outside Air:	Mo/Hr: 7 / 17 OADB/MB/HR: 84 / 69 / 90		Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Sensible Btu/h	Percent Of Total (%)	Space Sens Btu/h	Coil Peak Space Sens Btu/h	Percent Of Total (%)
Envelope Loads				0	0	0	0	0	0	0	0.00
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0.00
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0.00
Roof Cond	0	0	0	0	0	0	0	0	0	0	0.00
Glass Solar	2,835	0	2,835	45	3,029	61	Glass Solar	0	0	0	0.00
GlassDoor Cond	262	0	262	4	197	4	GlassDoor Cond	-1,787	-1,787	27.44	87.1
Wall Cond	522	0	522	8	502	10	Wall Cond	-1,146	-1,146	280	70.0
Partition/Door	0	0	0	0	0	0	Partition/Door	0	0	0	0.00
Floor	0	0	0	0	0	0	Floor	0	0	280	65.3
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	0	280	65.3
Infiltration	756	0	756	12	216	4	Infiltration	-2,165	-2,165	280	0.0
Sub Total ==>	4,374	0	4,374	70	3,945	79	Sub Total ==>	-5,098	-5,098	0	0.00
Internal Loads							Internal Loads				
Lights	721	180	901	14	721	15	Lights	0	0	0.00	0.00
People	540	0	540	9	300	6	People	0	0	0.00	0.00
Misc	0	0	0	0	0	0	Misc	0	0	0.00	0.00
Sub Total ==>	1,261	180	1,441	23	1,021	21	Sub Total ==>	0	0	0.00	0.00
Ceiling Load	0	0	0	0	0	0	Ceiling Load	0	0	0.00	0.00
Ventilation Load	0	0	494	8	0	0	Ventilation Load	0	0	0.00	0.00
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0.00	0.00
Dehumid. Or Sizing	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0.00	0.00
Ov/Undr Sizing	0	-30	0	0	0	0	Exhaust Heat	0	0	0.00	0.00
Exhaust Heat	0	0	0	0	0	0	OA Preheat Diff.	0	0	0.00	0.00
Sup. Fan Heat	0	0	0	0	0	0	RA Preheat Diff.	0	0	0.00	0.00
Ret. Fan Heat	0	0	0	0	0	0	Additional Reheat	0	0	0.00	0.00
Duct Heat Pkup	0	0	0	0	0	0	System Plenum Heat	0	0	0.00	0.00
Underflr Sup Ht Pkup	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0	0.00	0.00
Supply Air Leakage	0	0	0	0	0	0	Supply Air Leakage	0	0	0.00	0.00
Grand Total ==>	5,635	150	6,280	100.00	4,965	100.00	Grand Total ==>	-5,098	-5,098	100.00	100.00
COOLING COIL SELECTION			LEAVE DB/WB/HR			AREAS			HEATING COIL SELECTION		
Total Capacity ton	Sens Cap. MBh	Col Airflow cfm	Enter DB/WB/HR °F	Leave DB/WB/HR °F	gr/lb	Gross Total	Glass ft²	(%)	Capacity MBh	Col Airflow cfm	Lvg °F
Main Cig	0.5	6.3	5.3	280	76.2	63.1	58.4	64.3	Main Htg	-6.5	280
Aux Cig	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	Aux Htg	0.0	0.0
Cpt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	Preheat	0.0	0.0
Total	0.5	6.3							Humidif	0.0	0.0
									Opt Vent	0.0	0.0
									Total	-6.5	0.0

Project Name: MTOB 1-1.TRC
Dataset Name:

TRACE® 700 v6.2.9 calculated at 03:31 PM on 02/25/2013
Alternative - 1 System Checksums Report Page 35 of 86

Room Checksums

By ACADEMIC

306 Office

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES				
Peaked at Time: Outside Air:	Mo/Hr: 7 / 8 OADB/MB/HR: 69 / 65 / 88	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Burn	Percent Of Total (%)	Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	SADB Ra Plenum Return Ret/DA Fn MtrTD Fn Bltd Fn Frict	Cooling Ra Plenum Return Ret/DA Fn MtrTD Fn Bltd Fn Frict	Heating 70.0 75.0 75.7 75.0 0.0 0.0 0.0			
Envelope Loads																
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Roof Cond	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Glass Solar	1.906	0	0	0	0	1.906	62	1.906	77	0	0.00	0.00	0.00	0.00	0.00	
GlassDoor Cond	-68	0	0	0	-68	-68	-3	-67.3	-67.3	20.14	20.14	12.92	12.92	12.92		
Wall Cond	131	0	0	0	0	131	4	131	5	-432	-432	0	0.00	0.00	0.00	
Partition/Door	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Floor	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Infiltration	140	0	0	0	0	140	5	-127	-5	-1.353	-1.353	40.48	40.48	0.00	0.00	
<i>Sub Total ==></i>	<i>2,109</i>	<i>0</i>	<i>2,109</i>	<i>69</i>	<i>0</i>	<i>1,842</i>	<i>74</i>	<i>1,842</i>	<i>74</i>	<i>-2,458</i>	<i>-2,458</i>	<i>73.53</i>	<i>73.53</i>	<i>0</i>	<i>0</i>	<i>0</i>
Internal Loads																
Lights	451	113	563	18	451	18	451	18	0	0	0.00	0.00	0.00	0.00	0.00	
People	338	0	338	11	188	8	188	8	0	0	0.00	0.00	0.00	0.00	0.00	
Misc	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
<i>Sub Total ==></i>	<i>788</i>	<i>113</i>	<i>901</i>	<i>29</i>	<i>638</i>	<i>26</i>	<i>638</i>	<i>26</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>	<i>0.00</i>	<i>0.00</i>	<i>0.00</i>	<i>0.00</i>
Ceiling Load																
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Exhaust Sizing	0	-25	0	0	-25	-1	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
<i>Grand Total ==></i>	<i>2,897</i>	<i>88</i>	<i>3,077</i>	<i>100.00</i>	<i>2,480</i>	<i>100.00</i>	<i>2,480</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-2,458</i>	<i>-2,458</i>	<i>-3,342</i>	<i>100.00</i>	<i>0</i>	<i>0</i>	<i>0</i>
COOLING COIL SELECTION																
Total Capacity ton	Sens Cap. MBh	Enter DB/WB/HR cfm	Leave DB/WB/HR °F	Gross Total ft ²	Gross Glass ft ²	Gross Total ft ²	Gross Glass ft ²	Main Htg Aux Htg	Main Htg Aux Htg	Main Htg Aux Htg	Capacity MBh	Coil Airflow cfm	Ent Lvg °F	Total MBh		
Main Cig	0.3	2.5	129	75.0	62.8	56.9	54.7	63.1	0	0	-3.3	129	63.6	87.9		
Aux Cig	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0	0	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0	0	0.0	0	0.0	0.0		
<i>Total</i>	<i>0.3</i>	<i>3.1</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>	<i>0.0</i>	
HEATING COIL SELECTION																

Project Name:
Dataset Name:

MTOB 1-1.TRC

TRACE® 700 v6.2.9 calculated at 03:31 PM on 02/25/2013
Alternative - 1 System Checksums Report Page 39 of 86

Room Checksums

By ACADEMIC

309 Office

COOLING COIL PEAK			CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES		
Peaked at Time: Outside Air:	Moi/Hr: 7 / 15 OA DB/MB/HR: 86 / 71 / 95	OADB: 86	Mo/Hr: 7 / 15 OADB: 86	Sens. + Lat. Space Sens. + Lat.	Plenum Btu/h	Net Total Burnt	Percent Of Total (%)	Sensible Btu/h	Percent Of Total (%)	Space Peak Btu/h	Coil Peak Tot Sens Btu/h
Envelope Loads	0	0	0	0	0	0	0	0	0	0	0
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0
Roof Cond	0	0	0	0	0	0	0	0	0	0	0
Glass Solar	0	0	0	0	0	0	0	0	0	0	0
Glass Door Cond	0	0	0	0	0	0	0	0	0	0	0
Wall Cond	0	0	0	0	0	0	0	0	0	0	0
Partition/Door	0	0	0	0	0	0	0	0	0	0	0
Floor	0	0	0	0	0	0	0	0	0	0	0
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0
Infiltration	575	575	33	575	33	229	229	26	26	-1,353	-1,353
<i>Sub Total ==></i>											
Internal Loads	451	113	563	32	451	52	Lights	0	0	0.00	0.00
People	338	0	338	19	188	22	People	0	0	0.00	0.00
Misc	0	0	0	0	0	0	Misc	0	0	0.00	0.00
<i>Sub Total ==></i>	788	113	901	51	638	74	<i>Sub Total ==></i>	0	0	0.00	0.00
Ceiling Load	0	0	0	0	0	0	Ceiling Load	0	0	0.00	0.00
Ventilation Load	0	0	0	0	0	0	Ventilation Load	0	0	0.00	0.00
Adj Air Trans Heat	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0.00	0.00
Dehumid. Ov Sizing	0	0	0	0	0	0	Ov/Under Sizing	0	0	0.00	0.00
Exhaust Heat	0	-85	0	0	0	0	Exhaust Heat	0	0	0.00	0.00
Sup. Fan Heat	0	0	0	0	0	0	OA Preheat Diff.	0	0	0.00	0.00
Ret. Fan Heat	0	0	0	0	0	0	RA Preheat Diff.	0	0	0.00	0.00
Duct Heat Pkup	0	0	0	0	0	0	Additional Reheat	0	0	0.00	0.00
Underflr Sup Ht Pkup	0	0	0	0	0	0	System Plenum Heat	0	0	0.00	0.00
Supply Air Leakage	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0	0.00	0.00
<i>Grand Total ==></i>	1,363	27	1,766	100.00	867	100.00	<i>Grand Total ==></i>	-1,353	-1,353	-2,237	100.00
COOLING COIL SELECTION			LEAVE DB/WB/HR			AREAS			HEATING COIL SELECTION		
Total Capacity ton	Sens Cap. MBh	Col Airflow cfm	Enter DB/WB/HR °F	Leave DB/WB/HR °F	gr/lb	Gross Total ft ²	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Lvg °F
Main Cig	0.2	1.8	1.0	23	82.2	67.8	83.4	38.8	39.5	37.1	125.0
Aux Cig	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<i>Total</i>	0.2	1.8									
Main Htg	Aux Htg		Floor Part	150					Main Htg	Coil Airflow	Lvg °F
			Int Door	0					0.0	0.0	125.0
			Ex/Fir	0					-0.1	0.0	0.0
			Roof	0					23	34.0	39.8
			Wall	0					0.0	0.0	0.0
			Ext Door	0					0.0	0.0	0.0
									-2.2		
									Total/		

Project Name:
Dataset Name:

MTOB 1-1.TRC

TRACE® 700 v6.2.9 calculated at 03:31 PM on 02/25/2013
Alternative - 1 System Checksums Report Page 41 of 86

Room Checksums

By ACADEMIC

320 Conference

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES				
Peaked at Time: Outside Air:	Moi/Hr: 7 / 15 OADB/MB/HR: 86 / 71 / 95	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Burn	Percent Of Total (%)	Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	SADB Ra Plenum Return Ret/DA Fn MtrTD Fn Bltd Fn Frict	Cooling SADB Ra Plenum Return Ret/DA Fn MtrTD Fn Bltd Fn Frict	Heating SADB Ra Plenum Return Ret/DA Fn MtrTD Fn Bltd Fn Frict			
Envelope Loads																
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Roof Cond	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Glass Solar	1.007	0	1.007	6	4.639	42	-165	-2	-1.638	-1.638	10.36	10.36	10.36	10.36	10.36	
GlassDoor Cond	269	0	269	2	319	3	0	0	-1.051	-1.051	6.64	6.64	6.64	6.64	6.64	
Wall Cond	302	0	302	2	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Partition/Door	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Floor	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Infiltration	1.684	0	1.684	10	-364	-3	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
<i>Sub Total ==></i>	<i>3.261</i>	<i>0</i>	<i>3.261</i>	<i>19</i>	<i>4.429</i>	<i>40</i>	<i>Sub Total ==></i>	<i>-6.567</i>	<i>-6.567</i>	<i>-3.878</i>	<i>-3.878</i>	<i>24.52</i>	<i>24.52</i>	<i>0</i>	<i>0</i>	<i>0</i>
Internal Loads																
Lights	1.291	323	1.614	9	1.291	12	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
People	8.600	0	8.600	50	5.268	48	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Misc	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
<i>Sub Total ==></i>	<i>9.891</i>	<i>323</i>	<i>10.214</i>	<i>59</i>	<i>6.559</i>	<i>60</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0.00</i>	<i>0.00</i>	<i>0.00</i>	<i>0.00</i>	<i>0.00</i>
Ceiling Load																
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Dehumid. Ov Sizing	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
OverUnder Sizing	0	-126	-126	-1	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Sup. Fan Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	
<i>Grand Total ==></i>	<i>13.152</i>	<i>197</i>	<i>17.364</i>	<i>100.00</i>	<i>10.988</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-6.567</i>	<i>-6.567</i>	<i>-15.816</i>	<i>-15.816</i>	<i>100.00</i>	<i>100.00</i>	<i>0</i>	<i>0</i>	<i>0</i>
COOLING COIL SELECTION				LEAVE DB/WB/HR				AREAS				HEATING COIL SELECTION				
Total Capacity ton	Sens Cap. MBh	Enter DB/WB/HR cfm	Leave DB/WB/HR °F °F gr/lb	Total Gross Total ft ²	Gross Glass ft ²	Total Floor Part ft ²	Total Ext Door ft ²	Main Htg MBh	Aux Htg MBh	Preheat -0.6	Humidif 0.0	Opt Vent 0.0	Total Lvg °F	Coil Airflow cfm	Ent °F	Lvg °F
Main Cig	1.5	17.4	10.6	428	78.9 65.4 76.3	51.0 50.9 0.0 0.0	430 0	51.8	75.0	0.0	0.0	0.0	428	49.8	84.4	
Aux Cig	0.0	0.0	0.0	0	0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0	0	0.0	70.0	0.0	0.0	0.0	428	49.8	84.4	
Opt Vent	0.0	0.0	0.0	0	0.0 0.0 0.0 0.0	0.0 0.0 0.0 0.0	0	0.0	70.0	0.0	0.0	0.0	428	49.8	84.4	
<i>Total</i>	<i>1.5</i>	<i>17.4</i>						<i>358</i>	<i>107</i>	<i>30</i>	<i>0</i>	<i>0</i>	<i>40.38</i>	<i>-36.78</i>	<i>51.0</i>	

Project Name:
MTOB 1-1.TRC
Dataset Name:

TRACE® 700 v6.2.9 calculated at 03:31 PM on 02/25/2013
Alternative - 1 System Checksums Report Page 45 of 86

E.5 IBC tables used

SECTION 503 GENERAL BUILDING HEIGHT AND AREA LIMITATIONS

TABLE 503

ALLOWABLE BUILDING HEIGHTS AND AREAS^a

Building height limitations shown in feet above grade plane. Story limitations shown as stories above grade plane.

Building area limitations shown in square feet, as determined by the definition of "Area, building," per story

GROUP		TYPE OF CONSTRUCTION								
		TYPE I		TYPE II		TYPE III		TYPE IV		T
		A	B	A	B	A	B	HT	A	
	HEIGHT (feet)	UL	160	65	55	65	55	65	50	
STORIES(S) AREA (A)										
A-1	S	UL	5	3	2	3	2	3	2	2
	A	UL	UL	15,500	8,500	14,000	8,500	15,000	11,50	
A-2	S	UL	11	3	2	3	2	3	2	2
	A	UL	UL	15,500	9,500	14,000	9,500	15,000	11,50	
A-3	S	UL	11	3	2	3	2	3	2	2
	A	UL	UL	15,500	9,500	14,000	9,500	15,000	11,50	
A-4	S	UL	11	3	2	3	2	3	2	2
	A	UL	UL	15,500	9,500	14,000	9,500	15,000	11,50	
A-5	S	UL	UL	UL	UL	UL	UL	UL	UL	UL
	A	UL	UL	UL	UL	UL	UL	UL	UL	
B	S	UL	11	5	3	5	3	5	3	3
	A	UL	UL	37,500	23,000	28,500	19,000	36,000	18,00	
E	S	UL	5	3	2	3	2	3	1	1
	A	UL	UL	26,500	14,500	23,500	14,500	25,500	18,50	
F-1	S	UL	11	4	2	3	2	4	2	2
	A	UL	UL	25,000	15,500	19,000	12,000	33,500	14,00	
F-2	S	UL	11	5	3	4	3	5	3	3
	A	UL	UL	37,500	23,000	28,500	18,000	50,500	21,00	
H-1	S	1	1	1	1	1	1	1	1	1
	A	21,000	16,500	11,000	7,000	9,500	7,000	10,500	7,500	

TABLE 601
FIRE-RESISTANCE RATING REQUIREMENTS FOR BUILDING ELEMENTS (hours)

BUILDING ELEMENT	TYPE I		TYPE II		TYPE III		TYPE IV	TYPE V	
	A	B	A ^d	B	A ^d	B	HT	A ^d	B
Primary structural frame ^g (see Section 202)	3 ^a	2 ^a	1	0	1	0	HT	1	0
Bearing walls Exterior ^{f, g}	3	2	1	0	2	2	2	1	0
Interior	3 ^a	2 ^a	1	0	1	0	1/HT	1	0
Nonbearing walls and partitions Exterior	See Table 602								
Nonbearing walls and partitions Interior ^e	0	0	0	0	0	0	See Section 602.4.6	0	0
Floor construction and secondary members (see Section 202)	2	2	1	0	1	0	HT	1	0
Roof construction and secondary members (see Section 202)	1 ^b / ₂	1 ^{b,c}	1 ^{b,c}	0 ^c	1 ^{b,c}	0	HT	1 ^{b,c}	0

For SI: 1 foot = 304.8 mm.

- a. Roof supports: Fire-resistance ratings of primary structural frame and bearing walls are permitted to be reduced by 1 hour where supporting a roof only.
- b. Except in Group F-1, H, M and S-1 occupancies, fire protection of structural members shall not be required, including protection of roof framing and decking where every part of the roof construction is 20 feet or more above any floor immediately below. Fire-retardant-treated wood members shall be allowed to be used for such unprotected members.
- c. In all occupancies, heavy timber shall be allowed where a 1-hour or less fire-resistance rating is required.
- d. An approved automatic sprinkler system in accordance with Section [903.3.1.1](#) shall be allowed to be substituted for 1-hour fire-resistance-rated construction, provided such system is not otherwise required by other provisions of the code or used for an allowable area increase in accordance with Section [506.3](#) or an allowable height increase in accordance with Section [504.2](#). The 1-hour substitution for the fire resistance of exterior walls shall not be permitted.
- e. Not less than the fire-resistance rating required by other sections of this code.
- f. Not less than the fire-resistance rating based on fire separation distance (see Table 602).
- g. Not less than the fire-resistance rating as referenced in Section [704.10](#)

appendix F: additional drawings

