
ONE CHRISTINA CRESCENT

125 S. West Street Wilmington, Delaware



Electrical Systems Existing Conditions and Building Load Summary Report

November 2, 2007

Kevin DannaLighting/Electrical
Primary Consultant: Ted Dannerth

TABLE OF CONTENTS

Executive Summary
Summary Description of Distribution Systems
Service Entrance
Voltage Systems
Transformers4
Emergency Power Systems5
Over-current Devices5
Locations of Switchgear5
Power Factor Correction5
Design Issues5
Lighting Loads5
Mechanical and Other Loads6
Service Entrance Size6
Utility Company Information6
Communication Systems9
Appendix A10
Appendix B15
Appendix C17
Appendix D

One Christina Crescent Wilmington, DE November 6, 2007

Executive Summary

This report is a survey of the existing electrical system conditions for One Christina Crescent. A brief description of the electrical distribution system is presented, followed by a more detailed review of the various components and details of the system. This report addresses the service entrance, voltage systems, transformers, emergency power systems, over-current devices, switchgear, power factor correction, design issues, lighting loads, mechanical loads, service entrance size, utility company information, and communication systems.

I. POWER DISTRIBUTION SYSTEMS

Summary Description of Distribution System

The electrical power distribution system for One Christina Crescent is a simple radial system. There is a single primary feeder servicing the building with 12KV 3-phase power and one primary transformer which steps the voltage down from 12KV to 480Y/277V 3-phase, 4 wire for utilization. Power is also stepped down from 480Y/277V to 208Y/120V 3-phase, 4 wire for lighting and receptacle loads. The Uninterruptible Power System (UPS) for the building's data center is connected to 480V 3-phase.

Service Entrance

The power utility company's service and responsibility ends at their switchgear and the owner's service and responsibility begins at the point of connection of the primary service feeder to the power company's switchgear. The power company provides the switchgear and the electrical contractor provides the 500 KCMIL, copper 15KV primary service feeder.

Voltage Systems

- 480Y/277V 3-phase, 4 wire
 - o Connected Loads: Mechanical
- <u>208Y/120V 3-phase</u>, 4 wire
 - o Connected Loads: Lighting and Receptacles
- 480V 3 wire
 - o Connected Loads: Uninterruptible Power System (UPS)

Transformers

INDIVIDUAL TRANSFORMER SCHEDULE

Τ.	DDIMADY	CECONDARY	CIZ		TEMP	TAD		
TA G	PRIMARY VOLTAGE	SECONDARY VOLTAGE	SIZ E	TYPE	TEMP. RISE	TAP S	MOUNTING	REMARKS
N/ A	12000V,3PH,3W	480Y/277V,3PH,4W	375 0	DRY TYPE	N/A	N/A	PAD MOUNTED ON FLOOR	
T-1	480V,3PH,3W	208Y/120V,3PH,4W	45	DRY TYPE	80° C	6	FLOOR MOUNTED	K-4 RATED
T-2	480V,3PH,3W	208Y/120V,3PH,4W	45	DRY TYPE	80° C	6	FLOOR MOUNTED	K-4 RATED
T-3	480V,3PH,3W	208Y/120V,3PH,4W	45	DRY TYPE	80° C	6	FLOOR MOUNTED	K-4 RATED
T-4	480V,3PH,3W	208Y/120V,3PH,4W	45	DRY TYPE	80° C	6	FLOOR MOUNTED	K-4 RATED
T-5	480V,3PH,3W	208Y/120V,3PH,4W	75	DRY TYPE	80° C	6	FLOOR MOUNTED	K-4 RATED
T-6	480V,3PH,3W	208Y/120V,3PH,4W	45	DRY TYPE	80° C	6	FLOOR MOUNTED	K-4 RATED
T-7	480V,3PH,3W	208Y/120V,3PH,4W	45	DRY TYPE DRY	80° C	6	FLOOR MOUNTED	K-4 RATED
T-8	480V,3PH,3W	208Y/120V,3PH,4W	45	TYPE DRY	80° C	6	FLOOR MOUNTED	K-4 RATED
T-9	480V,3PH,3W	208Y/120V,3PH,4W	45	TYPE	80° C	6	FLOOR MOUNTED	K-4 RATED
T- 10	480V,3PH,3W	208Y/120V,3PH,4W	45	DRY TYPE	80° C	6	PAD MOUNTED ON FLOOR	
T- 11	480V,3PH,3W	208Y/120V,3PH,4W	30	DRY TYPE	80° C	6	FLOOR MOUNTED	
T- 12	480V,3PH,3W	208Y/120V,3PH,4W	30	DRY TYPE	80° C	6	FLOOR MOUNTED	
T- 13	480V,3PH,3W	208Y/120V,3PH,4W	15	DRY TYPE	80° C	6	PAD MOUNTED ON FLOOR	
T- 14	480V,3PH,3W	208Y/120V,3PH,4W	30	DRY TYPE	80° C	6	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	150	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	150	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	150	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	150	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	150	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	30	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	75	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	225	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	112. 5	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	208Y/120V,3PH,4W	112. 5	DRY TYPE	150° C	N/A	FLOOR MOUNTED	
N/ A	480V, 3PH	480V, 3PH	225				FLOOR MOUNTED	ISOLATION TRANSFORMER
N/ A	480V, 3PH	480V, 3PH	112. 5				FLOOR MOUNTED	ISOLATION TRANSFORMER
N/	480V, 3PH	480V, 3PH	112.				FLOOR MOUNTED	ISOLATION

Kevin Danna			One	Christina Crescent
Lighting/Electrical				Wilmington, DE
Ted Dannerth				November 6, 2007
A	5			TRANSFORMER

Emergency Power Systems

There are (2) natural gas driven emergency generators rated at 500KW/625KVA, 277/480V, 3 PH., 4W. One generator is connected to a combination fire pump controller with automatic transfer switch. Subdistribution panel SDB is connected to this first generator by means of an 800 amp automatic 4 pole transfer switch. The second generator is connected to panel WS, which serves the IT stations, by way of a 400 amp 4 pole automatic transfer switch. This second generator is also connected the computer room equipment panel CPB through an 800 amp 4 pole automatic transfer switch. A UPS system is installed to provide uninterrupted power to the data center. The system consists of a 225 KVA UPS and (2) 100 KVA UPS. Three Power Distribution Units are connected to the three respective panels that receive power from the UPS systems. One PDU is rated for 225 KVA and the other two are 75 KVA. The UPS system is on the 480Y/277V 3 PH., 4W voltage.

Over-current Devices

Circuit breakers and class "R" fuses are used.

- 1) Service Entrance Switchgear: 600A Fuses 15KV 200E
- 2) Distribution Panel Boards: Circuit breakers; 3 amp fuses for meters in sub-distribution panel "SDR"
- 3) Motor Control Center: Circuit Breakers
- 4) Local Lighting and Appliance Panelboards: Circuit Breakers

Locations of Switchgear

Tables listing all of the major switchgear equipment and panel boards with their respective locations can be found in Appendix A.

Power Factor Correction

It appears that capacitors are used on the individual circuits fed from the motor control center. Please note that it is only assumed that the symbols on these circuits represent capacitors as no tag is provided. Also, no information on capacitors or power factor correction equipment could be found in the buildings specifications.

Design Issues

There is a large data center on the fourth floor which must be on continuously and therefore needs to be on a UPS system. The building is occupied and in use 24/7. Voltage drops may be an issue considering that the building spans a long distance.

One Christina Crescent Wilmington, DE November 6, 2007

Lighting Loads

A schedule of all luminaires used in One Christina Crescent can be found in Appendix B.

Mechanical and other Loads

Schedules of all major mechanical equipment used in One Christina Crescent can be found in Appendix C.

Service Entrance Size

Complete calculation spreadsheets for the service entrance size during various stages of project development can be found in Appendix D. Below is a summary table from the three calculation methods used for this report. The table lists the actual design equipment sizes for the main breaker and transformer. While the actual design equipment is appropriate for the loads during preliminary calculations, it is undersized according to the actual load calculations performed in this report. This discrepancy may be due to the fact that the drawings used were incomplete from an electrical design standpoint. In this case, portions of the distribution system may have been altered or the main equipment resized at a later point in actual design of the building. Discrepancy could have also occurred because of incomplete load information taken from the drawings.

Service Entrance Size Summary									
Phase	Total Load (VA)	Total Load (A)							
Conceptual	2397014	2883							
Design Development	4044962	4865							
Construction	5344230	6428							
Design Equipment	Transformer	Switchgear							
	3750000	5000							

Utility Company Information

Delmarva Power P.O. Box 17000 Wilmington, DE 19886 www.delmarva.com

The rate schedule that applies to One Christina Crescent is as follows.



Rate Changes to Delaware Commercial/Industrial Customer Bills

Effective June 1, 2007, Delmarva Power's supply rates have changed based on a schedule approved by the Delaware Public Service Commission (DEPSC).

For more information, visit www.delmarva.com and click on the "Choices and Rates" tab.

* Phase-In Credit - Customers who have an Electric Delivery Phase-In Summary section on their bill elected to have their rates phased-in over time, without interest. The Phase-In Credit/Charge line item in the Electric Supply Section only applies to those customers. Between June 1, 2007 and December 31, 2007, you may have a credit or no charge at all depending on your tariff and the season. Please note that as of January 1, 2008, you will begin to pay back the amount you deferred and the line item will become a phase-in "charge."

Rate Schedule	Previo	Rates effective 6/1/07			
	Summer (JunSept.)	Winter (OctMay)	Summer (JunSept.)	Winter (OctMay)	
Small General Service Secondary Non-Demand -	SGS-ND				
Delivery Charges					
Customer Charges	\$8.36/Month	\$8.36/Month	\$8.36/Month	\$8.36/Month	
Distribution Energy kWh	\$0.035310/kWh	\$0.035310/kWh	\$0.035310/kWh	\$0.035310/kWh	
Supply Charges					
Transmission Energy	\$0.003140/kWh	\$0.003140/kWh	\$1.139000/kW	\$1.139000/kW	
Standard Offer Service Energy kWh	\$0.104576/kWh	\$0.101666/kWh	\$0.106350/kWh	\$0.101315/kWh	
Phase In Credit Charge kWh*	\$(0.002881)/kWh	\$(0.011251)/kWh	\$0.000000/kWh	\$(0.002708)/kWh	
General Service Water Heating - GSW					
Delivery Charges					
Distribution Energy kWh	\$0.014975/kWh	\$0.014975/kWh	\$0.014975/kWh	\$0.014975/kWh	
Supply Charges					
Transmission Energy	\$0.001929/kWh	\$0.001929/kWh	\$1.139000/kW	\$1.139000/kW	
Standard Offer Service Energy kWh	\$0.085315/kWh	\$0.100817/kWh	\$0.087025/kWh	\$0.100481/kWh	
Phase In Credit Charge kWh*	\$(0.013791)/kWh	\$(0.025728)/kWh	\$(0.002275)/kWh	\$(0.012519)/kWh	
General Service Space Heating - GSH					
Delivery Charges					
Distribution Energy kWh	\$0.014975/kWh	\$0.014975/kWh	\$0.014975/kWh	\$0.014975/kWh	
Supply Charges	40102177012172		40102101011111		
Transmission Energy	\$0.002574/kWh	\$0.002574/kWh	\$1.139000/kW	\$1.139000/kW	
Standard Offer Service Energy kWh	\$0.123228/kWh	\$0.100817/kWh	\$0.125066/kWh	\$0.100481/kWh	
Phase In Credit Charge kWh	\$(0.021007)/kWh	\$(0.025200)/kWh	\$(0.005064)/kWh	\$(0.011740)/kWh	
Minimum Charge	\$4.99/Month	\$4.99/Month	\$4.99/Month	\$4.99/Month	
Medium General Service - Secondary - MGS-S					
Delivery Charges	\$25.42/Month	\$25.42/Month	\$25.42/Month	\$25.42/Month	
Distribution Demand kW	\$3.654078/kW	\$3.654078/kW	\$3.654078/kW	\$3.654078/kW	
Distribution Energy kWh	\$0.002905/kWh	\$0.002905/kWh	\$0.002905/kWh	\$0.002905/kWh	
Supply Charges					
Transmission Demand kW	\$0.748676/kW	\$0.748676/kW	\$1.139000/kW	\$1.139000/kW	
Standard Offer Service Demand kW	\$18.355448/kW	\$10.403852/kW	\$15.028459/kW	\$9.543857/kW	
Standard Offer Service Energy kWh	\$0.059687/kWh	\$0.066687/kWh	\$0.050345/kWh	\$0.062505/kWh	
Off-Peak Service Meter Chrg	\$8.99/Month	\$8.99/Month	\$8.99/Month	\$8.99/Month	
General Service - Secondary - LGS-S					
Delivery Charges					
Customer Charge	\$159.62/Month	\$159.62/Month	\$159.62/Month	\$159.62/Month	
Distribution Demand kW	\$2.407000/kW	\$2.407000/kW	\$2.407000/kW	\$2.407000/kW	
Distribution On-Peak kWh	\$0.002393/kWh	\$0.002393/kWh	\$0.002393/kWh	\$0.002393/kWh	
Distribution Off-Peak kWh	\$0.002393/kWh	\$0.002393/kWh	\$0.002393/kWh	\$0.002393/kWh	
Power Factor Charge/Credit	\$0.030000/kW	\$0.030000/kW	\$0.030000/kW	\$0.030000/kW	
Supply Charges Transmission Demand kW	@n 022472/LW/	¢n 922472/1-w/	@1 120000/LW/	¢1 1 20000/Law	
Standard Offer Service Demand kW	\$0.823472/kW \$22.898184/kW	\$0.823472/kW	\$1.139000/kW	\$1.139000/kW \$12.433537/kW	
Standard Offer Service Demand RW Standard Offer Service On-Peak kWh	\$22.898184/KW \$0.087509/kWh	\$14.554370/kW \$0.093382/kWh	\$18.635390/kW \$0.056295/kWh	\$12.433337/KW \$0.064793/kWh	
Standard Offer Service Off-Peak kWh	\$0.087309/kWh	\$0.095582/kWh	\$0.036293/kWh	\$0.064793/kWh	
Standard Offer Service Off-Feak KWII	φυ.υσ1307/KWN	φυ.υσυσυυ/KWI	φυ.υээ1э3/KW N	.⊅0.04 ±06.5/K W N	

Rate Schedule	Previo	us Rates	Rates effective 6/1/07		
nate schedule	Summer (JunSept.)	Winter (OctMay)	Summer (JunSept.)	Winter (OctMay)Large	
General Service - Primary - GS-P					
Delivery Charges					
Customer Charge	\$235.42/Month	\$235.42/Month	\$235.42/Month	\$235.42/Month	
Alternate Customer Charge	\$92.89/Month	\$92.89/Month	\$92.89/Month	\$92.89/Month	
Distribution Demand kW	\$2.624797//kW	\$2.624797//kW	\$2.624797//kW	\$2.624797//kW	
Distribution On-Peak kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	
Off-Peak kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	
Power Factor Charge/Credit	\$0.030000/kW	\$0.030000/kW	\$0.030000/kW	\$0.030000/kW	
RARM (eligible HPS Customers Only)					
Capacity PLC < 600 kW		\$150 per m	onth plus \$0.045988 per	kW of Capacity PLC	
Capacity PLC >= 600 kW			\$601.19 per month		
Supply Charges	************				
Transmission Demand kW	\$0.835292/kW	\$0.835292/kW	\$1.139000/kW	\$1.139000/kW	
Standard Offer Service	000 440 (524 34)	0424250554394	047 440403/1399	@40.0005454.W	
Demand kW	\$22.148673/kW	\$13.125055/kW	\$17.660193/kW	\$10.988547/kW	
On-Peak kWh	\$0.091929/kWh	\$0.089905/kWh	\$0.075051/kWh	\$0.076963/kWh	
Off-Peak kWh	\$0.073367/kWh	\$0.071759/kWh	\$0.060250/kWh	\$0.061770/kWh	
OR Hourly Priced Service	See Rider HPS**	See Rider HPS**	See Rider HPS**	See Rider HPS**	
General Service - Transmission - GS-T					
Delivery Charges					
Customer Charge	\$2732.30Month	\$2732.30Month	\$2732.30Month	\$2732.30Month	
Distribution Demand kW	\$0.102055kW	\$0.102055kW	\$0.102055kW	\$0.102055kW	
Distribution On-Peak kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	
Distribution Off-Peak kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	\$0.000273/kWh	
Power Factor Charge/Credit	\$0.030000/kW	\$0.030000/kW	\$0.030000/kW	\$0.030000/kW	
Supply Charges	n 6 1100ee	11 6 1111000	13. 5. 1.1304.4	11 1 1110000	
Transmission Demand kW	Refer to HPS**	Refer to HPS**	Refer to HPS**	Refer to HPS**	
Standard Offer Service Demand kW	Refer to HPS**	Refer to HPS**	Refer to HPS**	Refer to HPS**	
Standard Offer Service On-Peak kWh Standard Offer Service Off-Peak kWh	Refer to HPS** Refer to HPS**				
Outdoor Recreational Lighting - ORL					
Delivery Charges					
Customer Charge	\$8.36/Month	\$8.36/Month	\$8.36/Month	\$8.36/Month	
Distribution Energy kWh	\$0.024250/kWh	\$0.024250/kWh	\$0.024250/kWh	\$0.024250/kWh	
Supply Charges	\$0.02 125 0/K W II	\$0.02 12507KWII	\$0.02 125 0/K W II	90.02 1250/K WII	
Transmission Energy	\$0.000663/kWh	\$0.000663/kWh	\$1.139000/kW	\$1.139000/kW	
Supply Energy kWh	\$0.117758/kWh	\$0.139258/kWh	\$0.119578/kWh	\$0.138242/kWh	
Phase In Credit Charge kWh*	\$(0.017092)/kWh	\$(0.032918)/kWh	\$(0.000423)/kWh	\$(0.013554)/kWh	
Outdoor Unitains Bass Of					
Outdoor Lighting-Rate OL Delivery Charges					
Distribution Charges: Based on type of lighting					
Open Bottom Luminaire with bracket					
Mercury					
8,600 Lumen (175W)	\$4.91	\$4.91	\$4.91	\$4.91	
High Pressure Sodium					
9,500 Lumen (100W)	\$5.05	\$5.05	\$5.05	\$5.05	
Enclosed Luminaire with bracket					
Mercury					
4,200 Lumen (100W)	\$4.48	\$4.48	\$4.48	\$4.48	
8,600 Lumen (175W)	\$5.73	\$5.73	\$5.73	\$5.73	
High Pressure Sodium					
5,800 Lumen (70W)	\$5.64	\$5.64	\$5.64	\$5.64	
9,500 Lumen (100W)	\$5.95	\$5.95	\$5.95	\$5.95	
50,000 Lumen (400W)	\$12.05	\$12.05	\$12.05	\$12.05	
Supply Charges	****	*****	****		
Night-time OL	\$0.066791/kWh	\$0.066791/kWh	\$0.067213/kWh	\$0.067213/kWh	
Traffic-light OL	\$0.066791/kWh	\$0.066791/kWh	\$0.067213/kWh	\$0.067213/kWh	
Phase In Credit Charge kWh*	\$(0.012242)/kWh	\$(0.012242)/kWh	\$(0.001838)/kWh	\$(0.001838)/kWh	

^{**}Hourly Priced Service (HPS) Rider is available in the tariff section of our website at www.delmarva.com.

One Christina Crescent Wilmington, DE November 6, 2007

II. COMMUNICATION SYSTEMS

FIRE ALARM

The intelligent reporting, microprocessor controlled fire detection and signaling system provides manual and automatic alarm initiation, automatic signaling via voice evacuation speakers and ADA/UL1971 strobes, firefighter's one-way paging system and two-way telephone intercommunications, auto-manual smoke pressurization system operations, sprinkler system monitoring, elevator recall and power shutdown operations and fire department notification. The fire alarm control panel is a Notifier model AFP-1010 which contains a microprocessor based Central Processing Unit (CPU). The system also consists of a display interface assembly, lead acid battery secondary power source, addressable monitor module, addressable output module, fault isolator module, manual stations, analog thermal sensors, duct mounted smoke detectors, analog photoelectric sensors, apartment unit smoke detectors, audio/visual signaling appliance (speaker/strobe), audio signaling appliance (speaker), visual signaling appliance, synchronization module, sprinkler bell, firefighters telephone warden station, and remote annunciator panel.

TELEPHONE AND DATA COMMUNICATIONS

A system of conduits, terminal boxes, outlet boxes, junction boxes and other necessary accessories for telephone outlets was installed and left complete and ready for Barclays, who installed their own wire and equipment.

RESCUE ASSISTANCE TWO-WAY COMMUNICATION

The rescue assistance two-way communication system provides audio and visual two-way communications for the handicapped in accordance with "The Americans with Disabilities Act" and complies with design specifications for areas of rescue assistance as published by the Federal Register/Volume 56, No. 144 Section 4.3.11.4. The system consists of a Cornell Model A4208 master station, intercommunications amplifier, and Cornell model 4201 remote stations.

One Christina Crescent Wilmington, DE November 6, 2007

Appendix A

Locations of Switchgear

Error! Not a valid link.

Appendix B

Lighting Loads

					LUMINAIRE SCH	IEDULE					
FIXTUR	DESCRIPTION	VOLTAGE	TOTAL FIXTURE WATTAG	MANUFACTU RE	CATALOG	LAMPS	BALLAST/ XFMR TYPE	BALLAS T FACTO	CURREN T @ STARTIN	POWER FACTOR @ STARTING	GENERAL LOCATION

ı cu	Dannerui		1	ı		-	ı	r		1101	ember (5, 2007
						NO.	TYPE				& OPERATIN G	
LT-15	SURFACE MOUNTED FLOOD LIGHT	277	1100	GE LIGHTING SYSTEMS	ULGC-01-MH-4-A-X-CO- HDO-P	1	METAL HALIDE	N/A	N/A	N/A	N/A	FIFTH FLOOR ROOF
LT-101	RECESSED LENSED DOWNLIGHT	277	70	KIRLIN	HRR-04050-43	1	CDM70/T6/83 0	N/A	N/A	N/A	N/A	OUTSIDE LOWER SOFFIT
LT-102	RECESSED LENSED DOWNLIGHT RECESSED	277	150	KIRLIN	HRR-06052-15	1	CDM150/T6/8 30	N/A	N/A	N/A	N/A	OUTSIDE UPPER SOFFIT
LT-104	LENSED ADJUSTABLE ACCENT SURFACE OR PENDANT	277	150	KIRLIN	HRR-06056	1	CDM150/T6/8 30	N/A	N/A	N/A	N/A	TRIPOD
LT-106	HUNG FLUORESCENT FIXUTRE RECESSED CEILING 2'X4'	277	70	SIMKAR	IE232-B11-277	2	32W 4' T8	N/A	N/A	N/A	N/A	VARIOUS
LT-107	LAY-IN FLUORESCENT FIXTURE SURFACE MOUNTED 4'	277	135	SIMKAR	TY244-432-B11-4L-UNV	4	32W 4' T8	N/A	N/A	N/A	N/A	VARIOUS
LT-108	FLUORESCENT FIXTURE SURFACE MOUNTED 3'	277	75	SIMKAR	FCO-232-B11	2	32W 4' T8	N/A	N/A	N/A	N/A	STAIRWEL LS FIRST FLOOR
LT-109	FLUORESCENT FIXTURE RECESSED PERIMETER	277	60	SIMKAR	FCO-225-B11	2	25W 3' T8	N/A	N/A	N/A	N/A	TOILET ROOMS
LT-110	COVE FLUORESCENT FIXTURE WALL- MOUNTED	277	VARIES	LIGHTOLIER	PTS 7-2L-E82	VARIE S	32W 4' T8	N/A	N/A	N/A	N/A	CORE TOILET ROOMS
LT-111	WALL-PAK WITH POLYCARBONA TE LENS SURFACE CEILING OR	277	175	HUBBELL	PVL-150P-128-LP	1	150W METAL HALIDE CLEAR MOGUL	N/A	N/A	N/A	N/A	VARIOUS
EX	WALL MOUNTED LED EXIT SIGN SURFACE WALL MOUNTED	277	3	EMERGI-LITE	ECL-R-277		LED	N/A	N/A	N/A	N/A	VARIOUS
EM	EMERGENCY LIGHT FIXTURE SURFACE CEILING OR	277	36	EMERGI-LITE	ECX-2-6V	2	9W HEADS	N/A	N/A	N/A	N/A	VARIOUS
EMX	WALL MOUNTED COMBINATION EMERGENCY/E XIT SIGN SURFACE WALL MOUNTED REMOTE EMERGENCY HEAD -	277	36	EMERGI-LITE	ECX-2-LIR	2	9W HEADS + LED SIGN	N/A	N/A	N/A	N/A	VARIOUS
R	WEATHER RESISTANCE 2X4 RECESSED FLOURESCENT	6	9	EMERGI-LITE	EF-11	1	9W	N/A	N/A	N/A	N/A	VARIOUS
Α	INDIRECT FIXTURE 2X2 RECESSED FLOURESCENT	277	58	FOCAL POINT	FBX24B2T8E277GPSL835W H	2	32W T8	ELECTRON IC	N/A	N/A	N/A	
A2	INDIRECT FIXTURE 9" DIA. RESCESSED	277	65	FOCAL POINT	FBX22B2BX40E277GPSL83 5WH	2	40W BIAX	ELECTRON IC ELECTRON	N/A	N/A	N/A	
В	FLUORESCENT DOWNLIGHT	277	35	WILA	10812277WHDFSHDIM	1	26W QUAD TUBE	IC DIMMING	N/A	N/A	N/A	
С	RECESSED FLUORESCENT DOWNLIGHT	277	33.5	EDISON PRICE	LL/8-277COL	2	13W 2-PIN COMPACT FLOURESCE NT	ELECTRON IC	N/A	N/A	N/A	
D	RECESSED FLUORESCENT DOWNLIGHT	277		PORTFOLIO	C6226E6250LI	2	26W 2-PIN COMPACT FLUORESCE NT	ELECTRON IC	N/A	N/A	N/A	
E	2X4 RECESSED FLUORESCENT FIXTURE PENDANT	277		METALUX	2GR8-332A1252772EB8	3	32W T8	ELECTRON IC	N/A	N/A	N/A	
F	MOUNTED FLUORESCENT DIRECT FIXTURE 6" DIA.			ILLUMINATIN G EXPERIENCE S	LINEAR-1-S125	1	54W T5 HO	ELECTRON IC	N/A	N/A	N/A	
G	RECESSED FLUORESCENT DOWNLIGHT	277		LITON	LFH6132E- 27/C260/LR660WC	1	32W TRIPLE TUBE	ELECTRON IC	N/A	N/A	N/A	

One Christina Crescent Wilmington, DE November 6, 2007

I cu I	Jannerui								INOV	cilibei (J, 2007
	LOW VOLTAGE PENDANT FIXTURE MOUNTED ON A FREEJACK SYSTEM		TECHLIGHTIN			50W HALOGEN BI-	ELECTRON				
Н	CANOPY WHITE LED		G	700FJFIRFHS24 (FIXTURE)	1	PIN	IC XFMR	N/A	N/A	N/A	
К	ENCAPSULATE D LAMPS	120	BRUCK	13501 (ORION BELT		LED		N/A	N/A	N/A	
				D-300WDC (LED DRIVER)				N/A	N/A	N/A	
				, , , , , , , , , , , , , , , , , , , ,				N/A	N/A	N/A	
	10" DIA. RECESSED FLUORESCENT			70424 (100W XFMR)		32W COMPACT FLUORESCE	ELECTRON	N/A	N/A	N/A	
L	DOWNLIGHT	277	INFINITY	PH10-232T-2DIM-CG	2	NT NT	IC DIMMING	N/A	N/A	N/A	
М	7.5" DIA. INCANDESCEN T DOWNLIGHT FLUORESCENT	277	INFINITY	R75120-277-CG	1	120W PAR38	MAGNETIC 2 WIRE STEPDOW N XFMR ELECTRON	N/A	N/A	N/A	
N	PENDANT	120	DELTALIGHT	271-64-21/JETI-LUSTER	2	54W T5	IC	N/A	N/A	N/A	
Т	6" DIA. METAL HALIDE	277	KIRLIN	HRR-04050T-43-277	1	50W METAL HALIDE LOWER WATTAGE PULSE 25W COMPACT	ELECTRON IC	N/A	N/A	N/A	
U	PENDANT FIXTURE	120	DELTALIGHT	271-61-21/JETI-S	1	FLUORESCE NT	ELECTRON IC	N/A	N/A	N/A	
w	4' INDUSTRIAL FLUORESCENT STRIP 1X4 FLUORESCENT	277	COLUMBIA	CSR4232EB8277-CSRWG4- CSHC	2	32W T8	ELECTRON IC	N/A	N/A	N/A	UPS ROOM
×	VIRGIN ACRYLIC FIXTURE	277	LIGHTOLIER	SPS1GFSVA232277HI	2	32W T8	ELECTRON IC	N/A	N/A	N/A	DATA CENTER
z	DECORATIVE PENDANT	277	2 THOUSAND DEGREES	700TDEMPFS-CF	1	18W T4	ELECTRON IC	N/A	N/A	N/A	
R	7.5" DIA. FLUORESCENT SHOWER LIGHT	277	INFINITY	PVSL68-113Q277EB	1	13W TWIN TUBE	ELECTRON IC	N/A	N/A	N/A	
s	9" FLUORESCENT DOWNLIGHT	MULTI- VOLT	PRESCOLITE	CFTD970HEB	2	70W DOUBLE QUAD TUBE	ELECTRON IC	N/A	N/A	N/A	

Appendix C

Mechanical Loads

MECHANICAL		
EQUIPMENT SCHEDULE		

EQUIPMENT	DESCRIPTION	LOAD	VOLTAGE
TAG			& PHASE
HRU-1	HEAT RECOVERY UNIT	46 HP	460V/3- PHASE
			460V/3-
HRU-2	HEAT RECOVERY UNIT	46 HP	PHASE 480V/3-
C-1	WATER CHILLER	257.1 KW	PHASE
C-2	WATER CHILLER	257.1 KW	480V/3- PHASE
C-3	WATER CHILLER	67.26 KW	480V/3- PHASE
	WATER OFFICER		480V/3-
B-1	HEATING BOILER	74 HP	PHASE 480V/3-
B-2	HEATING BOILER	74 HP	PHASE
CT-1	COOLING TOWER	76 HP	480V/3- PHASE
			480V/3-
CT-2	COOLING TOWER	76 HP	PHASE 460V/3-
AHU-2-01	AIR HANDLING UNIT	40 HP	PHASE
AHU-2-02	AIR HANDLING UNIT	40 HP	460V/3- PHASE
AHU-3-01	AIR HANDLING UNIT	40 HP	460V/3- PHASE
	AIR HANDLING ONLY		460V/3-
AHU-3-02	AIR HANDLING UNIT	40 HP	PHASE 460V/3-
AHU-4-01	AIR HANDLING UNIT	50 HP	PHASE
AHU-4-02	AIR HANDLING UNIT	40 HP	460V/3- PHASE
		40 HP	460V/3-
AHU-5-01	AIR HANDLING UNIT	40 HP	PHASE 460V/3-
AHU-5-02	AIR HANDLING UNIT	25 HP	PHASE 460V/3-
AHU-6-01	AIR HANDLING UNIT	40 HP	PHASE
AHU-6-02	AIR HANDLING UNIT	40 HP	460V/3- PHASE
			480V/3-
EF-1	EXHAUST FAN	2 HP	PHASE 480V/3-
EF-2	EXHAUST FAN	2 HP	PHASE 120V/1-
EF-3	EXHAUST FAN	1/6 HP	PHASE
CAF-1	COMBUSTION AIR FOR BOILER	1/3 HP	120V/1- PHASE
			120V/1-
CAF-2	COMBUSTION AIR FOR BOILER	1/3 HP	PHASE 480V/3-
EF-4	EXHAUST FAN	1.5 HP	PHASE
EF-5	EXHAUST FAN	1.5 HP	480V/3- PHASE
			480V/3-
P-1	COOLING TOWER PUMP	40 HP	PHASE 480V/3-
P-2	COOLING TOWER PUMP	40 HP	PHASE 480V/3-
P-3	COOLING TOWER PUMP	40 HP	PHASE
P-4	CHILLER PUMP	30 HP	480V/3- PHASE
			480V/3-
D-5	CHILLER PUMP	30 HP	PHASE

1 eu Daimein		1101	ember 0, 2007
P-6	CHILLER PUMP	30 HP	480V/3- PHASE
		00115	480V/3-
P-7	SYSTEM CHILLED WATER PUMP	60 HP	PHASE 480V/3-
P-8	SYSTEM CHILLED WATER PUMP	60 HP	PHASE
			480V/3-
P-9	RETAIL CHILLED WATER PUMP	7.5 HP	PHASE 480V/3-
P-10	RETAIL CHILLED WATER PUMP	7.5 HP	PHASE
P-11	HEATING HOT WATER PUMP	7.5 HP	480V/3- PHASE
			480V/3-
P-12	HEATING HOT WATER PUMP	7.5 HP	PHASE 480V/3-
P-13	HEATING HOT WATER PUMP	7.5 HP	PHASE
P-14	SYSTEM HEATING HOT WATER PUMP	25 HP	480V/3- PHASE
D.45		05.110	480V/3-
P-15	SYSTEM HEATING HOT WATER PUMP	25 HP	PHASE 120V/1-
UH-1	UNIT HEATER	1/6 HP	PHASE
UH-2	UNIT HEATER	1/6 HP	120V/1- PHASE
			120V/1-
UH-3	UNIT HEATER	1/6 HP	PHASE 120V/1-
UH-4	UNIT HEATER	1/6 HP	PHASE
UH-5	UNIT HEATER	1/50 HP	120V/1- PHASE
011-0	ONTHEATER	1/30 111	120V/1-
UH-6	UNIT HEATER	1/6 HP	PHASE 120V/1-
UH-7	UNIT HEATER	1/2 HP	PHASE
UH-8	UNIT HEATER	1/6 HP	120V/1- PHASE
PF-1	STAIR & ELEVATOR FAN	5 HP	480V/3- PHASE
PF-2	STAIR & ELEVATOR FAN	5 HP	480V/3- PHASE
		-	480V/3-
PF-3	STAIR & ELEVATOR FAN	5 HP	PHASE 480V/3-
PF-4	STAIR & ELEVATOR FAN	5 HP	PHASE
PF-5	STAIR & ELEVATOR FAN	5 HP	480V/3- PHASE
-	OTAIR & EEE VITORTIAN	0111	120V/1-
E	TOILET ROOMS W/ 1 TOILET CEILING EXHAUST FAN	1.4 AMPS	PHASE
E-1	CENTRAL CORE COMMON TOILET ROOMS CEILING EXHAUST FAN	2.5 AMPS	120V/1- PHASE
	EALI COLL		480V/3-
FC-111	FAN COIL	5 HP	PHASE 480V/3-
FC-113	FAN COIL	1.5 HP	PHASE
FC-115	FAN COIL	1.5 HP	480V/3- PHASE
		4.5.110	480V/3-
FC-117	FAN COIL	1.5 HP	PHASE 480V/3-
FC-119	FAN COIL	5 HP	PHASE
FC-129	FAN COIL	2 HP	480V/3- PHASE
FC-131	FAN COIL	3/4 HP	480V/3- PHASE
			480V/3-
FC-133	FAN COIL	1 HP	PHASE

One Christina Crescent Wilmington, DE November 6, 2007

rea Dannerin		11	0 veinber 0, 2007
			480V/3-
FC-135	FAN COIL	1.5 HP	PHASE
			480V/3-
ELEV. #1	ELEVATOR	40 HP	PHASE
			480V/3-
ELEV. #2	ELEVATOR	40 HP	PHASE
			480V/3-
ELEV. #3	ELEVATOR	40 HP	PHASE
			480V/3-
ELEV. #4	ELEVATOR	40 HP	PHASE
			480V/3-
ELEV. #5	ELEVATOR	40 HP	PHASE
			480V/3-
ELEV. #6	ELEVATOR	40 HP	PHASE
			480V/3-
ELEV. #7	ELEVATOR	40 HP	PHASE

Appendix D

Service Entrance Sizing

	Service Entrance Sizing	ı - Schematic & Cond	eptual		
Building Usage	Demand Power Density		Area	Load	Load
Type	(VA/SF)	Floor	(SF)	(VA)	(Amps)

100 200000000				1,0,01	
Office Building	8	First	27433	219464	264
		Second	44243	353944	426
		Third	51915	415320	500
		Fourth	52192	417536	502
		Fifth	53471	427768	515
		Sixth	43134	345072	415
		Total	272388	2179104	2621
		Total w/ Growth (10%)		2397014	2883

Service Entrance Sizing - Design Development						
Load Category	Demand Power Density (VA/SF)	Floor	Area (SF)	Load (VA)	Load (Amps)	
Lighting	3.5	First	27433	96016		
		Second	44243	154851		
		Third	51915	181703		
		Fourth	52192	182672		
		Fifth	53471	187149		
		Sixth	43134	150969		
		Total		953358	1147	
Receptacle s	1	First	27433	27433		
		Second	44243	44243		
		Third	51915	51915		
		Fourth	52192	52192		
		Fifth	53471	53471		
		Sixth	43134	43134		
		Total		272388		
			1st 10KVA @ 100%	10000		
			Remainder @ 50%	131194		
			Total	141194	170	
Fans/Pump	2	First	27433	54866		
		Second	44243	88486		
		Third	51915	103830		
		Fourth	52192	104384		
		Fifth	53471	106942		
		Sixth	43134	86268		
		Total		544776	655	

HVAC/Othe r	7	First	27433	192031	
		Second	44243	309701	
		Third	51915	363405	
		Fourth	52192	365344	
		Fifth	53471	374297	
		Sixth	43134	301938	
		Total		1906716	2293
			Total	3677238	4265
			Total w/ 10% Growth	4044962	4865

	Service I	Entrance Sizing - Co	onstruction
Equipment/Panel	Connected Load (VA)	Demand Load (VA)	Demand Factor Assumptions
Chiller 1	498831	399065	0.8
Chiller 2	498831	399065	0.8
Chiller 3	103923	83138	0.8
Panel RPA	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPB	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPC	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPD	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPE	103923	97492	Assume 78% is lighting and 22% is receptacle
Panel RPF	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPG	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPH	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPJ	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel RPK	49883	49396	Assume 78% is lighting and 22% is receptacle
Pump P-1	29828	23862	0.8
Pump P-2	29828	23862	0.8
Pump P-3	29828	23862	0.8
Pump P-4	22371	17897	0.8
Pump P-5	22371	17897	0.8
Pump P-6	22371	17897	0.8
Pump P-9	5593	4474	0.8
Pump P-10	5593	4474	0.8

Keviii Dailila			One Christina Crescent
Lighting/Electrical			Wilmington, DE
Ted Dannerth		1	November 6, 2007
Pump P-11	5593	4474	0.8
Pump P-12	5593	4474	0.8
Pump P-13	5593	4474	0.8
Pump P-14	18643	14914	0.8
Pump P-15	18643	14914	0.8
Pump P-7	44742	35794	0.8
Pump P-8	44742	35794	0.8
CT-1	22371	17897	0.8
CT-2	22371	17897	0.8
PBS-1	5593	4474	0.8
Compactor	11186	8948	0.8
Heating Boiler #1	1491	1193	0.8
Heating Boiler #2	1491	1193	0.8
AHU-2-01	29828	23862	0.8
AHU-2-02	29828	23862	0.8
AHU-3-01	29828	23862	0.8
AHU-3-02	29828	23862	0.8
AHU-4-01	29828	23862	0.8
AHU-4-02	29828	23862	0.8
AHU-5-01	29828	23862	0.8
AHU-5-02	29828	23862	0.8
AHU-6-01	29828	23862	0.8
AHU-6-02	29828	23862	0.8
HRU-1	83138	66511	0.8
HRU-2	83138	66511	0.8
			Assume 78% is lighting and 22% is
Panel PE	83138	78993	receptacle
Elevator #1	29828	25354	0.85
Elevator #2	29828	25354	0.85
Elevator #3	29828	25354	0.85
Elevator #4	29828	25354	0.85
Elevator #5	29828	25354	0.85
Elevator #6	29828	25354	0.85
Elevator #7	29828	25354	0.85
PF-1	3729	2983	0.8
PF-2	3729	2983	0.8
PF-3	3729	2983	0.8
PF-4	3729	2983	0.8
PF-5	3729	2983	0.8
Panel EMA	83138	78993	Assume 78% is lighting and 22% is receptacle
Panel EMB	66511	64195	Assume 78% is lighting and 22% is receptacle
Panel SDG	1662769	1484864	Assume 78% is lighting and 22% is receptacle
Panel SDH	831384	744932	Assume 78% is lighting and 22% is receptacle

One Christina Crescent

Kevin Danna

Total Demand Load	4858391	
Total Demand Load w/ 10% Growth	5344230	
Total Current	5844	
Total Current w/ 10% Growth	6428	

Service Entrance Size Summary					
Phase Total Load (VA) Total Load (
Conceptual	2397014	2883			
Design Development	4044962	4865			
Construction	5344230	6428			
Actual Equipment	Transformer	Switchgear			
	3750000	5000			