

CARL R. DARNALL ARMY MEDICAL CENTER

MARISSA CALDWELL
MECHANICAL OPTION



CARL R. DARNALL ARMY MEDICAL CENTER

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON

STRUCTURAL BREADTH

CONSTRUCTION BREADTH

CONCLUSION



BUILDING OVERVIEW

CARL R. DARNALL
ARMY MEDICAL
CENTER
FORT HOOD, TX

BUILDING OVERVIEW

- THESIS GOALS
- DEPTH
 - DEDICATED OUTDOOR AIR SYSTEM
 - VARIABLE REFRIGERANT FLOW
 - WATER SOURCE HEAT PUMP
 - AIR QUALITY ANALYSIS
 - ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

OWNER: ARMY CORPS OF ENGINEERS

DEPARTMENT OF DEFENSE – UFC STANDARD 4-510

LOCATED ON FORT HOOD BASE, OUTSIDE OF KILLEEN, TX

FLOOR AREA: 900,000 SQ FT

REPLACING THE CURRENT CARL R. DARNALL ARMY MEDICAL CENTER ACROSS STREET



CARL R. DARNALL

ARMY MEDICAL

CENTER

FORT HOOD, TX

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS


ENERGY COMPARISON

STRUCTURAL BREADTH

CONSTRUCTION BREADTH


CONCLUSION

BUILDING OVERVIEW



LEVEL 5

MEDICAL SUPPORT



LEVEL 6

LIBRARY

CARL R. DARNALL

ARMY MEDICAL

CENTER

FORT HOOD, TX

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS


ENERGY COMPARISON

STRUCTURAL BREADTH


CONSTRUCTION BREADTH

CONCLUSION

BUILDING OVERVIEW



LEVEL 5



LEVEL 6

CARL R. DARNALL

ARMY MEDICAL

FORT HOOD, TX

CENTER

BUILDING OVERVIEW

- THESIS GOALS
- DEPTH
 - DEDICATED OUTDOOR AIR SYSTEM
 - VARIABLE REFRIGERANT FLOW
 - WATER SOURCE HEAT PUMP
 - AIR QUALITY ANALYSIS
 - ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

MECHANICAL SYSTEM

COOLING SYSTEM



- (4) 1,300 TON CENTRIFUGAL CHILLERS
- (4) 18,000 MBH COOLING TOWERS
- (1) 200 TON HEAT RECOVERY CHILLER
 - DOMESTIC HOT WATER & CHILLED WATER
- PROVIDES 44°F TO AHUS

HEATING SYSTEM



- (4) 11,700 MBH STEAM BOILERS
 - LOW NOX BURNER & BOILER STACK ECONOMIZER
- (3) STEAM TO WATER HEAT EXCHANGER
- STEAM FOR HUMIDIFICATION & STERILE EQUIPMENT
- PROVIDES 140°F TO AHUS AND CAVS

CARL R. DARNALL

ARMY MEDICAL

CENTER

FORT HOOD, TX

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON

STRUCTURAL BREADTH

CONSTRUCTION BREADTH


CONCLUSION

MECHANICAL SYSTEM

AIRSIDE SYSTEM



ENTHALPY WHEEL TO PRECONDITION OUTDOOR AIR
(2) 45,000 CFM AIR HANDLER PROVIDING 55°F AIR
CONSTANT AIR VOLUME TERMINAL UNITS WITH REHEAT



CARL R. DARNALL

ARMY MEDICAL

BUILDING OVERVIEW
THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM
VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON

STRUCTURAL BREADTH

CONSTRUCTION BREADTH

CONCLUSION

CENTER

FORT HOOD, TX

REDUCE ENERGY



SAFE COMMUNITY



ECONOMICALLY FEASIBLE



STRUCTURALLY STABLE



CARL R. DARNALL

ARMY MEDICAL

CENTER

FORT HOOD, TX

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS


ENERGY COMPARISON

STRUCTURAL BREADTH


CONSTRUCTION BREADTH

CONCLUSION

VARIABLE REFRIGERANT FLOW



WATER SOURCE HEAT PUMP



CARL R. DARNALL

ARMY MEDICAL

CENTER


FORT HOOD, TX

BUILDING OVERVIEW
 THESIS GOALS
 DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW
 WATER SOURCE HEAT PUMP
 AIR QUALITY ANALYSIS
 ENERGY COMPARISON
 STRUCTURAL BREADTH
 CONSTRUCTION BREADTH
 CONCLUSION


DEDICATED OUTDOOR AIR SYSTEM



DOAS DELIVERS AIR DIRECTLY TO THE SPACE IN VRF SYSTEM
 ENTHALPHY WHEEL WITH GENERAL EXHAUST
 WSHP REDUCES BY 32%, VRF REDUCES BY 60%



DOAS Unit	Baseline Design	DOAS Unit	DX Cooling Coil	Natural Gas Coil
	Supply OA (cfm)	OA Supply (cfm)	Total Capacity (MBH)	Total Capacity (MBH)
L5 AHU	26,090	7,380	360	80
L6 AHU	37,075	10,366	300	60



CARL R. DARNALL

ARMY MEDICAL

CENTER

FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW**
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

VARIABLE REFRIGERANT FLOW


VARIABLE REFRIGERANT FLOW WITH R-410A

INDOOR VRF UNITS HAVE THE ABILITY TO OPERATE AS A CONDENSER AND A EVAPORATOR

CONSISTS OF 3 PIPES: LOW PRESSURE, HIGH PRESSURE & VAPOR SUCTION LINE

HEAT RECOVERY VS. HEAT PUMP

DEFROST OPERATION



CARL R. DARNALL

ARMY MEDICAL

CENTER


FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

ASHRAE 15 COMPLIANCE



LEVEL 5



LEVEL 6

INSTITUTIONAL OCCUPANCY & INDIRECT CLOSED SYSTEM
 CONCENTRATION MAY NOT EXCEED 50% LISTED IN TABLE 4-1
 MULTI-V REFRIGERANT CHARGE CALCULATOR
 SMALL ROOMS USE IN-DUCT VRF INDOOR UNITS

ASHRAE 15 REFRIGERANT CHARGE LIMIT

	OEL (ppm/v/v)	Safety Group	RCL		Highly Toxic or Toxic Under Code Classification	
			ppm v/v	lb/Mcf		g/m ³
R-410A	1,000	A1	140,000	13	420	Neither

REFRIGERANT CHARGE CALCULATIONS

Zone Configuration	Zone	Outdoor Unit		Capacity (tons)	# Indoor Units	RCL (lb/Mcf)	Comply with ASHRAE 15?
		Cooling	Heating				
Zoning 1	L5 South Exterior	264,000	297,000	22	23	22.14	NO
Zoning 2	L5 South East Ext	144,000	162,000	12	12	19.50	NO
	L5 South West Ext	120,000	135,000	10	11	19.76	NO
Zoning 3	L5 South West Ext	96,000	108,000	8	11	12.17	YES
	L5 S Exterior Zone	96,000	108,000	8	10	12.15	YES
	L5 SE Exterior Zone	96,000	108,000	8	10	11.82	YES
	L5 SE Corner Zone	96,000	108,000	8	10	11.68	YES

CARL R. DARNALL


ARMY MEDICAL

CENTER

FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW**
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

ASHRAE 15 COMPLIANCE



INSTITUTIONAL OCCUPANCY & INDIRECT CLOSED SYSTEM
 CONCENTRATION MAY NOT EXCEED 50% LISTED IN TABLE 4-1
 MULTI-V REFRIGERANT CHARGE CALCULATOR
 SMALL ROOMS USE IN-DUCT VRF INDOOR UNITS

ASHRAE 15 REFRIGERANT CHARGE LIMIT

	OEL (ppm/v/v)	Safety Group	RCL			Highly Toxic or Toxic Under Code Classification
			ppm v/v	lb/Mcf	g/m ³	
R-410A	1,000	A1	140,000	13	420	Neither

REFRIGERANT CHARGE CALCULATIONS

Zone Configuration	Zone	Outdoor Unit		Capacity (tons)	# Indoor Units	RCL (lb/Mcf)	Comply with ASHRAE 15?
		Cooling	Heating				
Zoning 1	L5 South Exterior	264,000	297,000	22	23	22.14	NO
Zoning 2	L5 South East Ext	144,000	162,000	12	12	19.50	NO
	L5 South West Ext	120,000	135,000	10	11	19.76	NO
Zoning 3	L5 South West Ext	96,000	108,000	8	11	12.17	YES
	L5 S Exterior Zone	96,000	108,000	8	10	12.15	YES
	L5 SE Exterior Zone	96,000	108,000	8	10	11.82	YES
	L5 SE Corner Zone	96,000	108,000	8	10	11.68	YES

CARL R. DARNALL

ARMY MEDICAL

CENTER

FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

ZONING



LEVEL 5



LEVEL 6

INTERIOR & EXTERIOR ROOMS PLACED ON SAME SYSTEM
 ZONES BASED ON THE S EXTERIOR ZONE'S OUTDOOR UNIT'S CAPACITY
 FOUR WAY CASSETTES FOR PATIENT ROOMS, IN-DUCT FOR OFFICES

Zone Configuration	Zone	Outdoor Unit		Capacity (tons)	# Indoor Units	RCL (lb/Mcf)	Comply with ASHRAE 15?
		Cooling	Heating				
Zoning 1	L5 South Exterior	264,000	297,000	22	23	22.14	NO
Zoning 2	L5 South East Ext	144,000	162,000	12	12	19.50	NO
	L5 South West Ext	120,000	135,000	10	11	19.76	NO
Zoning 3	L5 South West Ext	96,000	108,000	8	11	12.17	YES
	L5 S Exterior Zone	96,000	108,000	8	10	12.15	YES
	L5 SE Exterior Zone	96,000	108,000	8	10	11.82	YES
	L5 SE Corner Zone	96,000	108,000	8	10	11.68	YES

SIZING

CARL R. DARNALL
ARMY MEDICAL
CENTER
FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
 - DEDICATED OUTDOOR AIR SYSTEM
 - VARIABLE REFRIGERANT FLOW
 - WATER SOURCE HEAT PUMP
 - AIR QUALITY ANALYSIS
 - ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

Zone	Critical Load		Outdoor Unit			Number of Units	Max Number
	Load	MBH	Cooling	Heating	Derated Heating		
L5 NW Exterior Zone	Cooling	66,238	72,000	81,000	68,850	11	13
L5 W Interior Zone	Cooling	55,708	72,000	81,000	68,850	13	13
L5 SW Exterior Zone	Cooling	76,585	96,000	108,000	91,800	10	16
L5 S Exterior Zone	Cooling	78,562	96,000	108,000	91,800	13	16
L5 SE Corner Zone	Cooling	87,183	96,000	108,000	91,800	13	13
L5 SE Exterior Zone	Cooling	77,507	96,000	108,000	91,800	10	16
L5 NE Exterior Zone	Cooling	51,079	72,000	81,000	68,850	13	13
L5 NE Interior Zone	Heating	37,148	72,000	81,000	68,850	16	16
L6 NW Interior Zone	Cooling	51,814	72,000	81,000	68,850	13	13
L6 Interior Zone	Cooling	52,251	72,000	81,000	68,850	12	13
L6 E Interior Zone	Cooling	68,708	72,000	81,000	68,850	12	13
L6 SW Exterior Zone	Cooling	68,374	72,000	81,000	68,850	13	13
L6 S Exterior Zone	Cooling	45,069	72,000	81,000	68,850	13	13
L6 SE Exterior Zone	Cooling	55,377	72,000	81,000	68,850	13	13
L6 NE Exterior Zone	Cooling	82,378	96,000	108,000	91,800	14	16
L6 NW Exterior Zone	Cooling	59,672	72,000	81,000	68,850	9	13



OVERALL 16 OUTDOOR CONDENSING UNITS
 DERATED HEATING CAPACITY BASED ON 25°F WINTER CONDITIONS
 MAX NUMBER OF INDOOR UNITS FOR OUTDOOR UNIT DEPENDS ON LG MULTI-V

CARL R. DARNALL



ARMY MEDICAL

FORT HOOD, TX

SIZING

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
 - DEDICATED OUTDOOR AIR SYSTEM
 - VARIABLE REFRIGERANT FLOW
 - WATER SOURCE HEAT PUMP
 - AIR QUALITY ANALYSIS
 - ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

Room Name	Sensible from AHU (btu/h)	Room Load (btu/h)	Adjusted (btu/h)	Heating (btu/h)	VRF Indoor Unit		WSHP Unit	
					Cooling	Heating	Cooling	Heating
Medical Bed	3,169	10,528	7,359	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	3,169	10,528	7,359	7,270	9,600	10,900	9,700	12,000
Pediatric Equipment	1,036	2,649	1,613	39	7,500	8,500	8,000	9,800
Soiled Utility	216	135	135	0				
Nurse Team Center	1,192	2,570	1,378	40	7,500	8,500	8,000	9,800
Remote Monitor Station	755	2,649	1,894	39				
Lab/SAT Poct	265	2,649	2,384	39				



CARL R. DARNALL


ARMY MEDICAL

CENTER

FORT HOOD, TX


- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW**
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

ENERGY CONSUMPTION




RECEPTACLE & LIGHTING DOMINATE ENERGY
 SPACE COOLING INCLUDES BOTH COOLING & HEATING MODE
 HEAT REJECTION ENERGY OF THE CONDENSING UNIT
 VRF CONSUMES 753,443 KWH FEWER THAN BASELINE

VRF: ELECTRICAL ENERGY CONSUMPTION



BASELINE: ELECTRICAL ENERGY CONSUMPTION



CARL R. DARNALL

ARMY MEDICAL


CENTER

FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

WATER SOURCE HEAT PUMP

- WATER LOOP REMAINS BETWEEN 60°F & 95°F
- USES BOILER & COOLING TOWER WHEN IT CANNOT STAY IN THE TEMPERATURE RANGE
- CONNECTS TO EXISTING HOT WATER SYSTEM FOR 140°F MINIMUM FLOW
- ALL UNITS ON SAME LOOP, SHARE BETWEEN OFFICES & PATIENT ROOMS



CARL R. DARNALL

ARMY MEDICAL

FORT HOOD, TX

CENTER

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON

STRUCTURAL BREADTH

CONSTRUCTION BREADTH

CONCLUSION

BOILER

Equipment Tag	Type	Capacity (Btu/h)	Boiler Horse Power (BHP)	Fluid Flow (gpm)	Primary Fuel	NO _x Emissions (ppm)
Boiler - 01	Gas Fired	511,011	20.0	621.0	Natural Gas	40



GAS FIRED HOT WATER BOILER

MEETS PEAK HEATING LOAD DURING WINTER OPERATION

PRIMARY FUEL IS NATURAL GAS, SECONDARY FUEL IS FUEL OIL

ALL NEW EQUIPMENT WILL BE LOCATED IN CENTRAL UTILITY PLANT

COOLING TOWER

CARL R. DARNALL

ARMY MEDICAL


FORT HOOD, TX

CENTER

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
 - DEDICATED OUTDOOR AIR SYSTEM
 - VARIABLE REFRIGERANT FLOW
 - WATER SOURCE HEAT PUMP**
 - AIR QUALITY ANALYSIS
 - ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

Equipment Tag	Design Nominal Tonnage	Motor Hp	Fluid Flow (gpm)	Design Ambient WB (°F)	Design EWT (°F)	Design LWT (°F)
Cooling Tower - 01	228.0	7.5	636	78	95	85

MARLEY SOFTWARE USED FOR COOLING TOWER
DESIGN FOR PEAK COOLING LOAD DURING SUMMER
DESIGN ENTERING WATER TEMPERATURE OF 95°F WB



CARL R. DARNALL

ARMY MEDICAL

FORT HOOD, TX

CENTER

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON


STRUCTURAL BREADTH

CONSTRUCTION BREADTH

CONCLUSION

WATER SOURCE HEAT PUMP

Room Name	Sensible from AHU (btu/h)	Room Load (btu/h)	Adjusted (btu/h)	Heating (btu/h)	VRF Indoor Unit		WSHP Unit	
					Cooling	Heating	Cooling	Heating
Medical Bed	3,169	10,528	7,359	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	2,868	10,528	7,659	7,270	9,600	10,900	9,700	12,000
Medical Bed	3,169	10,528	7,359	7,270	9,600	10,900	9,700	12,000
Pediatric Equipment	1,036	2,649	1,613	39	7,500	8,500	8,000	9,800
Soiled Utility	216	135	135	0	7,500	8,500	8,000	9,800
Nurse Team Center	1,192	2,570	1,378	40				
Remote Monitor Station	755	2,649	1,894	39				
Lab/SAT Poct	265	2,649	2,384	39				



CARL R. DARNALL


ARMY MEDICAL

CENTER

FORT HOOD, TX


- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

ENERGY CONSUMPTION




RECEPTACLE & FANS DOMINATE ENERGY CONSUMED
 SPACE COOLING INCLUDES BOTH COOLING & HEATING MODE
 HEAT REJECTION ENERGY OF THE COOLING TOWER
 WSHP SAVES OVER 531,242 kWh THAN BASELINE

WSHP: ELECTRICAL ENERGY CONSUMPTION



BASELINE: ELECTRICAL ENERGY CONSUMPTION



CARL R. DARNALL



ARMY MEDICAL

FORT HOOD, TX

CENTER

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS**
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

AIR QUALITY ANALYSIS



BASELINE CO₂ CONCENTRATION OF 652 PPM
PROPOSED CO₂ CONCENTRATION OF 912 PPM
OSHA OEL OF 5,000 PPM

CARL R. DARNALL


ARMY MEDICAL

CENTER


FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS**
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

AIR QUALITY ANALYSIS



ASHRAE 15 OEL OF 1,000 PPM
PASSES THE OEL OF R410A WITHIN THE FIRST HOUR



REFRIGERANT LEAK BASED ON ASHRAE 15 APPENDIX B: TESTING
LEAK AT RATE OF 2% BY MASS OF THE STARTING CHARGE PER HOUR

CARL R. DARNALL

ARMY MEDICAL

FORT HOOD, TX

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON

STRUCTURAL BREADTH


CONSTRUCTION BREADTH

CONCLUSION

CENTER

PAYBACK PERIOD

Initial Cost	VRF	WSHP
Expenses / Savings	Additional Costs	Initial Costs
Cooling Tower	-\$29,868	\$0
Boiler - 765 MBH	-\$17,800	\$0
Outdoor Condensing Unit	\$528,000	\$0
Chiller 270 ton	-\$190,500	-\$190,500
Terminal Units	\$170,825	\$285,600
Piping	\$74,176	\$426,920
DOAS Unit	-\$361,000	-\$361,000
Costs	\$173,833	\$161,020
Maitnenance Costs		
16 Air Cooled Condensers	\$138,480	\$0
Cooling Tower	-\$8,872	\$0
Chiller - 270 ton	-\$104,744	-\$104,744
Boiler - 765 MBH	-\$5,835	\$0
Maitnenance Costs	\$19,030	-\$104,744
Expenses	\$245,596	\$56,276
Annual Energy Costs	\$71,763	\$69,108
Simple Payback Period	3.42	0.81
Discounted Payback Period	8.72	2.96
Life Cycle Cost	\$2,025,861.00	\$2,631,110.00
Savings	\$784,351.66	\$179,102.66



LONGER PAYBACK PERIOD FOR VRF SYSTEM THAN WSHP

SIMILAR INITIAL COSTS FOR BOTH

VARY WITHIN THE MAINTENANCE COSTS OF LARGER EQUIPMENT

20 YEAR LIFE CYCLE

CARL R. DARNALL


ARMY MEDICAL

CENTER

FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

ENERGY & EMISSIONS COMPARISON




LOW NOX BURNER FOR BOILERS – 30 PPM, 40 PPM FOR PROPOSED


VRF ONLY USES NATURAL GAS FOR DOAS UNIT

WSHP SAVES 51% ON NATURAL GAS, VRF SAVES 72%

ELECTRICITY CONSUMPTION



NATURAL GAS CONSUMPTION



CARL R. DARNALL

ARMY MEDICAL

FORT HOOD, TX

CENTER

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON

STRUCTURAL BREADTH

CONSTRUCTION BREADTH

CONCLUSION

STRUCTURAL BREADTH

	Rebar Size	lb/ft	Number	Weight (lb)	Cost	Total	Savings
Baseline Design	#6	1.50	24	1,219.9	\$1,205	\$7,542	\$4,248
	#11	5.28	47	8,443.7	\$6,337		
Proposed Design	#6	1.50	44	2,236.5	\$2,209	\$3,294	
	#8	2.66	16	1,445.8	\$1,085		


Design	Column Strip		Middle Strip	
	Neg. Moment	Pos. Moment	Neg. Moment	Pos. Moment
Baseline	11 (#11)	18 (#11)	24 (#6)	18 (#11)
Reduced Load	16 (#7)	18 (#6)	12 (#6)	14 (#6)

COST SAVINGS OF \$4,248 FOR REDUCING LOAD

ORIGINAL AHUS HAD 22,000 LB OPERATING WEIGHT

DOWNSIZED STRUCTURAL SYSTEM BY ELIMINATING ANTI-FORCE PROTECTION & PROGRESS COLLAPSE RESISTANCE LOADS

ANALYSIS COMPLIES WITH ACI 318 & DIRECT DESIGN METHOD



Equipment	Cooling Capacity (Btu/h)	Number	Operating Weight (lb)
Outdoor Condensing Unit	72,000	11	4,972
	96,000	5	2,865
L5 DOAS Unit	360,000	1	4,284
L6 DOAS Unit	300,000	1	4,282

CARL R. DARNALL

ARMY MEDICAL

FORT HOOD, TX

CENTER

BUILDING OVERVIEW

THESIS GOALS

DEPTH

DEDICATED OUTDOOR AIR SYSTEM

VARIABLE REFRIGERANT FLOW

WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS

ENERGY COMPARISON

STRUCTURAL BREADTH

CONSTRUCTION BREADTH

CONCLUSION

CONSTRUCTION BREADTH

Removal of IBS Floor							
Material	Unit	Amount	Crew	Daily Output	Labor-Hours	Total Incl. O&P	Total
W6x20	ft	4,148	8	600	0.093	43	\$178,364
Floor Decking (3" deep, 18 ga)	sq-ft	39,304	5	2850	0.011	4.29	\$168,614
Polypropylene Fiber Rebar Mat	ft ³	6,550	4	9500	0.004	1.07	\$7,009
LW Concrete, 2-1/2"	sq-ft	39,304	8	2585	0.022	3.3	\$129,703
						Total	\$483,690
						Entire Building	\$6,046,125

REMOVING IBS FLOORS GAINED 18 DAYS

AVERAGE INSTALLATION RATE OF TERMINAL UNITS IN A INTERSTITIAL FLOOR IS 30 MINUTES QUICKER

PIPING INSTALLATION DOES NOT TAKE INTERSTITIAL FLOOR INTO ACCOUNT

Task	Duration - Man Days					
	Baseline		VRF		WSHP	
	Man - Days	Total Days	Man - Days	Total Days	Man - Days	Total Days
FR&P Interstitial Floors	79.96	10	0.00	0	0.00	0
Install Interstitial Floor Deck	65.36	8	0.00	0	0.00	0
Install terminal units	51.00	26	76.98	38	76.98	38
Piping	66.29	4	16.82	17	12.83	13
Sheetmetal	32.00	11	21.33	11	21.33	11
Total		58	Total	66	Total	62
				Difference in Duration	-8	-4

CARL R. DARNALL

ARMY MEDICAL

CENTER


FORT HOOD, TX

- BUILDING OVERVIEW
- THESIS GOALS
- DEPTH
- DEDICATED OUTDOOR AIR SYSTEM
- VARIABLE REFRIGERANT FLOW
- WATER SOURCE HEAT PUMP
- AIR QUALITY ANALYSIS
- ENERGY COMPARISON
- STRUCTURAL BREADTH
- CONSTRUCTION BREADTH
- CONCLUSION

RECOMMENDATIONS


VARIABLE REFRIGERANT FLOW

- SAVES **60%** IN ELECTRICAL ENERGY CONSUMPTION
- CONSUMES **72%** LESS NATURAL GAS
- PAYBACK PERIOD OF **8.72** YEARS
- TAKES **16%** LONGER INSTALLATION TIME



WATER SOURCE HEAT PUMP

- SAVES **31%** IN ELECTRICAL ENERGY CONSUMPTION
- CONSUMES **51%** LESS NATURAL GAS
- PAYBACK PERIOD OF **2.96** YEARS
- TAKES **8%** LONGER INSTALLATION TIME



ACKNOWLEDGEMENTS

CARL R. DARNALL

ARMY MEDICAL

BUILDING OVERVIEW
THESIS GOALS
DEPTH

DEDICATED OUTDOOR AIR SYSTEM
VARIABLE REFRIGERANT FLOW
WATER SOURCE HEAT PUMP

AIR QUALITY ANALYSIS
ENERGY COMPARISON

STRUCTURAL BREADTH
CONSTRUCTION BREADTH

CONCLUSION

CENTER

FORT HOOD, TX

MICHAEL MORDER

MECHANICAL DESIGN ENGINEER,
SOUTHLAND INDUSTRIES

ASHLEY HAYES

PROJECT MANAGER,
SOUTHLAND INDUSTRIES

SHAWN MANLEY

SENIOR MECHANICAL ENGINEER,
SOUTHLAND INDUSTRIES

DR. W. BAHNFLETH

THESIS ADVISOR,
PROFESSOR AT PENN STATE

PHOTOS COURTESY OF HKS INC. AND WINGLER &
SHARP ARCHITECTS, INC.



PENN STATE ARCHITECTURAL ENGINEERING FACULTY

AE CLASS OF 2015

AE POWERPLAYERS



QUESTIONS?

CARL R. DARNALL ARMY MEDICAL CENTER REPLACEMENT

