



### The Palestra Building London, England

## **APPENDIX D: Trace Output**





### The Palestra Building London, England

## **Existing Systems Energy Simulation**

By ae

Alternative: 1 Palestra Building

						N	lonthly Co	onsumptio	n					
Equipment	t - Utilitv	Jan	Feb	Mar	Apr	Mav	June	Julv	Auq	Sept	Oct	Nov	Dec	Total
Lights														
	Electric (kWh) Peak (kW)	135,459.5 439.7	122,510.0 439.7	145,343.4 439.7	129,495.7 439.7	140,401.4 439.7	139,379.6 439.7	130,517.6 439.7	145,343.4 439.7	129,495.7 439.7	140,401.4 439.7	134,437.6 439.7	130,517.6 439.7	1,623,302.8 439.7
MISC LD	Electric (kWh) Peak (kW)	234,034.4 816.2	211,696.4 816.2	253,279.4 816.2	223,381.2 816.2	243,657.1 816.2	242,625.8 816.2	224,412.1 816.2	253,279.4 816.2	223,381.3 816.2	243,657.1 816.2	233,003.5 816.2	224,412.1 816.2	2,810,820.0 816.2

#### AHU 1

Eq4371 - Fan coil supply fan (Main Clg Fan) Electric (kWh) 266,006.9 254,985.8 306,652.6 263,462.2 336,715.3 345,809.9 404,881.2 433,306.1 344,123.8 313,433.8 266,362.5 251,983.3 3,787,723.3 Peak (kW) 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,500.0 1,500.0 1,500.0 1,425.0 1,425.0 1,425.0 1,425.0 1,500.0

#### AHU 2

Eq4371 - Fan coil supply fan (Main Clg Fan) Electric (kWh) 251,393.2 229,756.5 278,262.3 243,554.5 272,396.3 273,698.9 263,497.0 294,199.0 251,853.8 286,334.8 252,604.0 240,197.4 3,137,747.8 Peak (kW) 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0

#### AHU 3

Eq4372 - Unit vent supply f	fan (Ma	in Clg Fai	ר)										
Electric (kWh)	5,364.1	3,898.3	4,612.9	3,854.4	2,920.2	2,904.0	2,902.6	3,037.7	2,695.7	3,074.8	4,348.7	4,114.1	43,727.5
Peak (kW)	55.0	55.0	55.0	55.0	38.5	38.5	40.2	38.5	38.5	38.5	55.0	55.0	55.0

#### AHU 4

Eq4372 - Unit vent supply f	fan (Ma	in Clg Fa	n)										
Electric (kWh)	6,044.0	4,274.3	4,922.9	3,904.2	2,929.2	2,912.6	3,419.0	3,066.5	2,727.9	3,182.5	4,816.4	4,466.5	46,666.0
Peak (kW)	55.0	55.0	55.0	55.0	38.5	38.5	55.0	38.5	38.5	38.5	55.0	55.0	55.0

AHU 7

						M	lonthly Co	onsumptio	n					
Eauipmen	nt - Utilit∨	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
AHU 7														
Eq4371 -	Fan coil supply fa Electric (kWh) Peak (kW)	in (Maii 76,020.0 400.0	n Clg Fan) 68,780.0 400.0	) 83,260.0 400.0	72,400.0 400.0	79,640.0 400.0	79,640.0 400.0	72,400.0 400.0	83,260.0 400.0	72,400.0 400.0	79,640.0 400.0	76,020.0 400.0	72,400.0 400.0	915,860.0 400.0
Cpl 1: CH	ILLERS													
Chiller 2	(Cooling Equipr Electric (kWh) Peak (kW)	nent) 225.8 30.5	170.5 30.4	223.3 30.3	414.3 41.3	1,479.8 41.3	2,236.1 41.3	17,037.9 148.6	5,798.3 118.7	2,895.4 84.1	1,269.4 41.3	266.1 34.2	250.4 41.3	32,267.2 148.6
Eq5221 -	Condenser fan Electric (kWh) Peak (kW)	829.9 17.2	747.5 17.2	944.4 17.2	941.5 17.2	2,252.7 17.2	2,138.4 17.2	4,785.9 17.2	4,138.8 17.2	2,750.6 17.2	1,381.3 17.2	852.9 17.2	796.1 17.2	22,559.8 17.2
Eq5001 -	Cnst vol chill wate Electric (kWh) Peak (kW)	er pump 11.0 0.9	(Misc Ac 5.5 0.9	7.3 0.9	Equipmer 14.7 0.9	it) 132.1 0.9	181.6 0.9	238.4 0.9	232.0 0.9	167.8 0.9	134.8 0.9	11.0 0.9	8.3 0.9	1,144.4 0.9
Eq5011 -	Cnst vol cnd wate	er pump	(Misc Ac	cessory E	Equipmen	t)								
	Electric (kWh) Peak (kW)	96.8 8.1	48.4 8.1	64.6 8.1	129.1 8.1	1,161.9 8.1	1,597.6 8.1	2,097.8 8.1	2,041.3 8.1	1,476.5 8.1	1,186.1 8.1	96.8 8.1	72.6 8.1	10,069.4 8.1
Eq5302 -	Cntl panel & inter	locks (l	Misc Acce	ssory Eq	uipment)									
	Electric (kWh) Peak (kW)	1.2 0.1	0.6 0.1	0.8 0.1	1.6 0.1	14.4 0.1	19.8 0.1	26.0 0.1	25.3 0.1	18.3 0.1	14.7 0.1	1.2 0.1	0.9 0.1	124.8 0.1
Chiller 3	(Cooling Equipr	nent)												
	Electric (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	5,856.1 148.6	0.0 118.7	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	5,856.1 148.6
Eq5221 -	Condenser fan													
	Electric (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	673.1 16.1	0.0 13.7	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	673.1 16.1
Eq5001 -	Cnst vol chill wate	er pump	(Misc Ac	cessory l	Equipmen	it)								
	Electric (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	55.0 0.9	0.0 0.9	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	55.0 0.9

					N	Ionthly Co	onsumptio	n					
Equipment - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Auq	Sept	Oct	Nov	Dec	Total
Cpl 1: CHILLERS													
Eq5012 - Cnst vol cnd w	ater pump	(Misc A	ccessory l	Equipmer	nt)								
Electric (kW Peak (kV	,	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	581.3 9.7	0.0 9.7	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	581.3 9.7
Eq5302 - Cntl panel & ir	terlocks	(Misc Acce	essory Eq	uipment)									
Electric (kW Peak (kV	h) 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	6.0 0.1	0.0 0.1	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	6.0 0.1
Chiller 4 (Cooling Equ	ipment)												
Electric Peak (k)		0.0	0.0	0.0	0.0	0.0	148.5	0.0	0.0	0.0	0.0	0.0	148.5
Eq5221 - Condenser far	n												
Electric Peak (kV	,	0.0	0.0	0.0	0.0	0.0	16.1	0.0	0.0	0.0	0.0	0.0	16.1
Eq5001 - Cnst vol chill v			ccessory	• •	,								
Electric Peak (kV	,	0.0	0.0	0.0	0.0	0.0	0.9	0.0	0.0	0.0	0.0	0.0	0.9
Eq5011 - Cnst vol cnd w		•	ccessory l		,								
Electric Peak (kW	,	0.0	0.0	0.0	0.0	0.0	8.1	0.0	0.0	0.0	0.0	0.0	8.1
Eq5302 - Cntl panel & in		(Misc Acce		• •									
Electric Peak (kV	,	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1
Chiller 5 (Cooling Equ	• •												
Electric Peak (kV	,	0.0	0.0	0.0	0.0	0.0	148.5	0.0	0.0	0.0	0.0	0.0	148.5
Eq5221 - Condenser far													
Electric Peak (kV	,	0.0	0.0	0.0	0.0	0.0	16.1	0.0	0.0	0.0	0.0	0.0	16.1
Eq5001 - Cnst vol chill v	• •	•	ccessory	• •	,								
Electric Peak (kV	,	0.0	0.0	0.0	0.0	0.0	0.9	0.0	0.0	0.0	0.0	0.0	0.9
Eq5011 - Cnst vol cnd w	• •	•	ccessory l	• •	,								
Electric Peak (k)	,	0.0	0.0	0.0	0.0	0.0	8.1	0.0	0.0	0.0	0.0	0.0	8.1
Eq5302 - Cntl panel & in		(Misc Acce		• •	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0.0	
Electric Peak (k)	,	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1
Chiller 6 (Cooling Equ		0.0	0.0	0.0	0.0	0.0	140 E	0.0	0.0	0.0	0.0	0.0	140 5
Electric Peak (kV	,	0.0	0.0	0.0	0.0	0.0	148.5	0.0	0.0	0.0	0.0	0.0	148.5
Eq5221 - Condenser far		0.0	0.0	0.0	0.0	0.0	16.4	0.0	0.0	0.0	0.0	0.0	46.4
Electric Peak (k)	V) 0.0	0.0	0.0	0.0	0.0	0.0	16.1	0.0	0.0	0.0	0.0	0.0	16.1
ect Name: set Name: P:\becca's trace\	Palestra.TRC							Alt				d at 08:02 PM nsumption re	

#### Alternative: 1 Palestra Building

						M	onthly Co	onsumptio	n					
Equipment - Utilit	V	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Cpl 1: CHILLERS	5													
Eq5001 - Cnst vo	l chill wate	roumo	(Misc Ac	cessory E	 auinmen	t)								
•	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.9	0.0	0.0	0.0	0.0	0.0	0.9
Eq5302 - Cntl par	· ,		Misc Acce											
• •	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1
Chiller 7 (Cooli	ng Equipm	ent)												
	Peak (kW)	ý 0.0	0.0	0.0	0.0	0.0	0.0	134.9	0.0	0.0	0.0	0.0	0.0	134.9
Eq5221 - Conder	nser fan													
•	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	14.8	0.0	0.0	0.0	0.0	0.0	14.8
Eq5001 - Cnst vo	l chill wate	r pump	(Misc Ac	cessory E	Equipmen	t)								
Electric	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.9	0.0	0.0	0.0	0.0	0.0	0.9
Eq5302 - Cntl par	nel & interl	ocks (	Misc Acce	ssory Equ	uipment)									
Electric	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1
Chiller 1 (Cooli	ng Equipm	ient)												
Electric	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	135.0	0.0	0.0	0.0	0.0	0.0	135.0
Eq5221 - Conder	nser fan													
Electric	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	14.8	0.0	0.0	0.0	0.0	0.0	14.8
Eq5001 - Cnst vo	l chill wate	r pump	(Misc Ac	cessory E	Equipmen	t)								
Electric	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.9	0.0	0.0	0.0	0.0	0.0	0.9
Eq5302 - Cntl par	nel & interl	ocks (	Misc Acce	ssory Equ	uipment)									
Electric	Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1
Hpl 1: BOILERS														
Boiler 1 (Heatin	ng Equipm	ent)												
	Gas (kWh) Peak (kW)	287,220.4 975.6	281,241.8 975.6	338,255.3 975.6	240,878.6 975.6	167,499.1 975.6	165,143.7 975.6	51,019.5 975.6	98,907.3 975.6	102,842.2 975.6	162,823.1 975.6	262,783.5 975.6	234,140.6 975.6	2,392,755.3 975.6
Eq5020 - Heating	water circ	pump	(Misc Ac	cessory E	quipment	)								
Ele	•	294,450.0 975.0		-		, 196,950.0 975.0	193,050.0 975.0	63,375.0 975.0	123,825.0 975.0	122,850.0 975.0	214,500.0 975.0	286,650.0 975.0	273,000.0 975.0	2,630,550.0 975.0

Alternative: 1 Palestra Building

						N	lonthly Co	onsumptio	n					
Eauipmei	nt - Utilitv	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Hpl 1: BC	DILERS													
Eq5240 -	Boiler forced draf	ft fan (N	lisc Acces	sory Equ	ipment)									
	Electric (kWh) Peak (kW)	824.6 2.7	750.9 2.7	952.9 2.7	709.9 2.7	551.5 2.7	540.6 2.7	177.5 2.7	346.8 2.7	344.0 2.7	600.7 2.7	802.7 2.7	764.5 2.7	7,366.6 2.7
Eq5307 -	Boiler cntl panel	& inter	(Misc Acc	essory Ec	luipment)									
	Electric (kWh) Peak (kW)	151.0 0.5	137.5 0.5	174.5 0.5	130.0 0.5	101.0 0.5	99.0 0.5	32.5 0.5	63.5 0.5	63.0 0.5	110.0 0.5	147.0 0.5	140.0 0.5	1,349.0 0.5
Boiler 2	(Heating Equipn	nent)												
	Gas (kWh) Peak (kW)	278,048.9 975.6	265,365.8 975.6	321,951.3 975.6	232,376.6 975.6	139,441.6 975.6	113,490.8 975.6	34,944.8 975.6	74,469.3 975.6	76,375.6 975.6	138,526.9 975.6	237,073.3 975.6	220,487.8 975.6	2,132,552.8 975.6
Eq5020 -	Heating water cir	• •	•	cessory E										
	Electric (kWh) Peak (kW)	249,600.0 975.0	222,300.0 975.0	246,675.0 975.0	175,500.0 975.0	128,700.0 975.0	111,150.0 975.0	43,875.0 975.0	93,600.0 975.0	86,775.0 975.0	128,700.0 975.0	216,450.0 975.0	200,850.0 975.0	1,904,175. 975.0
Eq5240 -	Boiler forced draf	ft fan (N	lisc Acces	sory Equ	ipment)									
	Electric (kWh) Peak (kW)	699.0 2.7	622.5 2.7	690.8 2.7	491.5 2.7	360.4 2.7	311.3 2.7	122.9 2.7	262.1 2.7	243.0 2.7	360.4 2.7	606.2 2.7	562.5 2.7	5,332.5 2.7
Eq5307 -	Boiler cntl panel	& inter	(Misc Acc	essory Ec	uipment)									
	Electric (kWh) Peak (kW)	128.0 0.5	114.0 0.5	126.5 0.5	90.0 0.5	66.0 0.5	57.0 0.5	22.5 0.5	48.0 0.5	44.5 0.5	66.0 0.5	111.0 0.5	103.0 0.5	976.5 0.5
Boiler 3	(Heating Equipn	nent)												
	Gas (kWh) Peak (kW)	268,825.0 975.6	256,255.0 975.6	291,909.8 975.6	218,536.6 975.6	116,359.2 975.6	111,219.5 975.6	19,512.2 975.6	35,386.3 975.6	60,698.7 975.6	115,316.5 975.6	237,073.3 975.6	220,487.8 975.6	1,951,579.8 975.6
Eq5020 -	Heating water cir	c pump	(Misc Ac	cessory E	quipment	)								
	Electric (kWh) Peak (kW)	249,600.0 975.0	222,300.0 975.0	228,150.0 975.0	159,900.0 975.0	111,150.0 975.0	111,150.0 975.0	19,500.0 975.0	48,750.0 975.0	67,275.0 975.0	128,700.0 975.0	216,450.0 975.0	200,850.0 975.0	1,763,775.0 975.0
Eq5240 -	Boiler forced draf	ft fan (N	lisc Acces	sory Equ	ipment)									
	Electric (kWh) Peak (kW)	699.0 2.7	622.5 2.7	638.9 2.7	447.8 2.7	311.3 2.7	311.3 2.7	54.6 2.7	136.5 2.7	188.4 2.7	360.4 2.7	606.2 2.7	562.5 2.7	4,939.3 2.7
Eq5307 -	Boiler cntl panel	& inter	(Misc Acc	essory Ec	luipment)									
	Electric (kWh) Peak (kW)	128.0 0.5	114.0 0.5	117.0 0.5	82.0 0.5	57.0 0.5	57.0 0.5	10.0 0.5	25.0 0.5	34.5 0.5	66.0 0.5	111.0 0.5	103.0 0.5	904.5 0.5
a at Niawaa.												4		

Project Name:

Dataset Name: P:\becca's trace\Palestra.TRC

 $\label{eq:transform} \begin{array}{c} {\sf TRACE} \$ \ 700 \ v4.1 \ calculated \ at \ 08:02 \ PM \ on \ 03/28/2006 \\ {\sf Alternative - 1} \quad {\sf Equipment \ Energy \ Consumption \ report \ page \ 5 \ of \ 6} \end{array}$ 

					M	lonthly Co	nsumptio	n					
Equipment - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Hpl 1: BOILERS													
Boiler 4 (Heating Equipm	nent)												
Gas (kWh) Peak (kW)	257,550.5 975.6	235,986.4 975.6	280,975.7 975.6	218,452.8 975.6	111,945.3 975.6	98,637.2 975.6	19,512.2 975.6	5,717.9 975.6	36,875.7 975.6	100,372.3 975.6	232,103.8 975.6	213,651.8 975.6	1,811,781.6 975.6
Eq5020 - Heating water circ	c pump	(Misc Ac	cessory E	quipment	)								
Electric (kWh) Peak (kW)	233,025.0 975.0	206,700.0 975.0	209,625.0 975.0	159,900.0 975.0	111,150.0 975.0	111,150.0 975.0	19,500.0 975.0	7,800.0 975.0	41,925.0 975.0	112,125.0 975.0	216,450.0 975.0	200,850.0 975.0	1,630,200.0 975.0
Eq5240 - Boiler forced draft	t fan (N	lisc Acces	ssory Equ	ipment)									
Electric (kWh) Peak (kW)	652.6 2.7	578.8 2.7	587.0 2.7	447.8 2.7	311.3 2.7	311.3 2.7	54.6 2.7	21.8 2.7	117.4 2.7	314.0 2.7	606.2 2.7	562.5 2.7	4,565.2 2.7
Eq5307 - Boiler cntl panel &	& inter	(Misc Acc	essory Ec	juipment)									
Electric (kWh) Peak (kW)	119.5 0.5	106.0 0.5	107.5 0.5	82.0 0.5	57.0 0.5	57.0 0.5	10.0 0.5	4.0 0.5	21.5 0.5	57.5 0.5	111.0 0.5	103.0 0.5	836.0 0.5

### MONTHLY ENERGY CONSUMPTION

By ae

Alternative: 1 Palestra Building

\_\_\_\_

						Month	nlv Enera	/ Consum	ption					
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	;													
	On-Pk Cons. (kWh)	2,005,564	1,819,345	2,105,694	1,692,834	1,633,466	1,621,389	1,280,122	1,502,611	1,353,867	1,659,670	1,911,922	1,807,670	20,394,152
	On-Pk Demand (kW)	7,543	7,687	7,687	7,456	7,352	7,316	7,321	7,349	7,306	7,317	7,454	7,694	7,694
Gas														
	On-Pk Cons. (kWh)	1,091,644	1,038,849	1,233,092	910,244	535,245	488,491	124,989	214,481	276,792	517,039	969,033	888,768	8,288,669
	On-Pk Demand (kW)	3,902	3,902	3,902	3,902	3,902	3,902	3,902	3,902	3,902	3,902	3,902	3,902	3,902
Building	g Energy Consumpt	ion =		3,332	MJ/(m2·	-year)								

		0,002	
S	ource Energy Consumption =	8,123	MJ/(m2-year)
F	loor Area =	30,992	m2

## **ENERGY CONSUMPTION SUMMARY**

By ae

	Elect Cons. (kWh)	Gas Cons. (kwh)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Primary heating				
Primary heating	26,269.6	8,288,669.0	29.0 %	8,803,731.0
Primary cooling				
Cooling Compressor Tower/Cond Fans Condenser Pump Other CLG Accessories Cooling Subtotal	38,123.2 23,232.9 10,650.8 130.8 72,137.7		0.1 % 0.1 % 0.0 % 0.0 % 0.3 %	114,381.1 69,705.7 31,955.5 392.4 216,434.7
Auxiliary				
Supply Fans Circ Pumps Base Utilities	7,931,724.5 7,929,899.5		27.7 % 27.7 % 0.0 %	23,797,552.0 23,792,076.0 0.0
Aux Subtotal	15,861,624.0		55.3 %	47,589,628.0
Lighting				
Lighting	1,623,302.6		5.7 %	4,870,394.5
Receptacle				
Receptacles	2,810,820.3		9.8 %	8,433,304.0
Heating plant load				
Base Utilities			0.0 %	0.0
Cogeneration				
Cogeneration			0.0 %	0.0
Totals				
Totals**	20,394,154.0	8,288,669.0	100.0 %	69,913,488.0

\* Note: Resource Utilization factors are included in the Total Source Energy value. \*\* Note: This report can display a maximum of 6 utilities. If additional utilities are used, they will be included in the total.

## MONTHLY UTILITY COSTS

By ae

Alternative: 1

Feb 150,480 101	Mar 174,149 101	Apr 140,023 101	May 135,116 101	June 134,118 101	July 105,910 101	Aug 124,300 101	Sept 112,006 101	Oct 137,282	Nov 158,132	Dec	Total
,	, -	,	,	,		,	,	'	,	,	
,	, -	,	,	,		,	,	'	,	,	
					101	101	101	101	101	101	1,207
150,581	174,249	140,124	135,217	134,219	106,011	124,401	112,106	137,383	158,233	149,616	1,688,113
3,299	3,916	2,890	1,700	1,551	397	681	879	1,642	3,077	2,822	26,320
3	,299	,299 3,916	,299 3,916 2,890	2,299 3,916 2,890 1,700	,299 3,916 2,890 1,700 1,551	,299 3,916 2,890 1,700 1,551 397	,299 3,916 2,890 1,700 1,551 397 681	,299 3,916 2,890 1,700 1,551 397 681 879	2,299 3,916 2,890 1,700 1,551 397 681 879 1,642	2,299 3,916 2,890 1,700 1,551 397 681 879 1,642 3,077	2,299 3,916 2,890 1,700 1,551 397 681 879 1,642 3,077 2,822

Monthly Total (\$): 169,440	153,880	178,165	143,014	136,917	135,770	106,408	125,082	112,985	139,025	161,310	152,438	1,714,433
-----------------------------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	-----------

### **ELECTRICAL PEAK CHECKSUMS**

By ae

#### Alternative: 1 Palestra Building Yearly Time of Peak: 14(Hr) 7(Month)

Equipment Description		Electrical Demand (kw)	Percent of Total (%)
Cooling Equipment			
Chiller 2		0.74	0.01
	Sub total	0.74	0.01
Heating Equipment			
Boiler 1		978.23	12.72
	Sub total	978.23	12.72
Fan Equipment			
SUMMATION OF FAN ELECTRICAL DEMAND		1,350.00	17.56
SUMMATION OF FAN ELECTRICAL DEMAND		1,350.00	17.56
SUMMATION OF FAN ELECTRICAL DEMAND		40.00	0.52
SUMMATION OF FAN ELECTRICAL DEMAND		55.00	0.72
SUMMATION OF FAN ELECTRICAL DEMAND		55.00	0.72
	Sub total	2,850.00	37.08
Miscellaneous			
Lights		329.39	4.28
Base Utilities		0.00	0.00
Misc Equipment		601.41	7.82
	Sub total	930.80	12.10
	Total	4,759.77	62

### YEARLY CASH FLOW

By ae

Alternative:1Life Cycle Cost:31,868,440.64

Year	Utility Cost (\$)	Maint. Cost (\$)	Interest Cost (\$)	Principal Cost (\$)	Property Taxes (\$)	Insurance Cost (\$)	Revenue Penalty (\$)	Replace. Expenses (\$)	Deprec. Tax (\$)	Cash Flow Effect (\$)	Present Value (\$)
0	0	0	0	17,826,732	0	0	0	0	0	17,826,732	17,826,732
1	1,714,433	306,000	0	0	0	0	0	0	891,337	1,438,079	1,250,504
2	1,714,433	367,200	0	0	0	0	0	0	891,337	1,487,039	1,124,415
3	1,714,433	440,640	0	0	0	0	0	0	891,337	1,545,791	1,016,383
4	1,714,433	528,768	0	0	0	0	0	0	891,337	1,616,294	924,121
5	1,714,433	634,522	0	0	0	0	0	0	891,337	1,700,897	845,646
6	1,714,433	761,426	0	0	0	0	0	0	891,337	1,802,420	779,236
7	1,714,433	913,711	0	0	0	0	0	0	891,337	1,924,248	723,396
8	1,714,433	1,096,453	0	0	0	0	0	0	891,337	2,070,442	676,831
9	1,714,433	1,315,744	0	0	0	0	0	0	891,337	2,245,875	638,418
10	1,714,433	1,578,893	0	0	0	0	0	0	891,337	2,456,394	607,183
11	1,714,433	1,894,671	0	0	0	0	0	0	891,337	2,709,016	582,285
12	1,714,433	2,273,605	0	0	0	0	0	0	891,337	3,012,164	562,995
13	1,714,433	2,728,326	0	0	0	0	0	0	891,337	3,375,941	548,685
14	1,714,433	3,273,992	0	0	0	0	0	0	891,337	3,812,473	538,812
15	1,714,433	3,928,790	0	0	0	0	0	0	891,337	4,336,311	532,909
16	1,714,433	4,714,548	0	0	0	0	0	0	891,337	4,964,918	530,575
17	1,714,433	5,657,457	0	0	0	0	0	0	891,337	5,719,245	531,466
18	1,714,433	6,788,949	0	0	0	0	0	0	891,337	6,624,439	535,289
19	1,714,433	8,146,739	0	0	0	0	0	0	891,337	7,710,670	541,793
20	1,714,433	9,776,086	0	0	0	0	0	0	891,337	9,014,148	550,767

## **TRACE® 700 Economic Summary**

Alternative 1 - - Palestra Building

By ae

#### **Project Information**


Weather file	Heathrow, England
Project Name Location	London, England
Building Owner User	Balckfriars Investment
Company	Penn State University
Comments	-

**Economic Summary** 

Alternative	Installed	First Year	Final Year	First Year	Final Year	Life Cycle
Number	Cost	Util.Cost	Util. Cost	Maint. Cost	Maint. Cost	Cost
1	17,826,732.00	1,714,433.42	1,714,433.42	306,000.00	9,776,086.14	31,868,440.64

## Monthly Utility Costs per Utility

(1 alternative)



### Equipment Energy Consumption by Alternative

	Elect Cons. (kWh)	Gas Cons. (kwh)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Alternative: 1 - Palestra Bui	lding			
Primary heating	26,269.6	8,288,669.0	29.0%	8,803,731.0
Cooling Compressor	38,123.2		0.1%	114,381.1
Tower/Cond Fans	23,232.9		0.1%	69,705.7
Condenser Pump	10,650.8		0.0%	31,955.5
Other CLG Accessories	130.8		0.0%	392.4
Supply Fans	7,931,724.5		27.7%	23,797,552.0
Circ Pumps	7,929,899.5		27.7%	23,792,076.0
Lighting	1,623,302.6		5.7%	4,870,394.5
Totals	20,394,154.0	8,288,669.0	100.0%	69,913,488.0

\* Note: Resource Utilization factors are included in the Total Source Energy value.





### The Palestra Building London, England

## Natural Gas Engine Driven Chiller Plant Energy Simulation

#### Alternative: 1 Palestra Building

						N	Ionthly Co	onsumptio	n					
Equipment	- Utilitv	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Lights														
	Electric (kWh) Peak (kW)	171,215.5 640.1	154,884.0 640.1	185,958.4 640.1	163,314.5 640.1	178,587.0 640.1	178,057.5 640.1	163,844.0 640.1	185,958.4 640.1	163,314.5 640.1	178,587.0 640.1	170,686.0 640.1	163,844.0 640.1	2,058,250.8 640.1
MISC LD		0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011	0.011
	Electric (kWh) Peak (kW)	234,034.4 816.2	211,696.4 816.2	253,279.4 816.2	223,381.2 816.2	243,657.1 816.2	242,625.8 816.2	224,412.1 816.2	253,279.4 816.2	223,381.3 816.2	243,657.1 816.2	233,003.5 816.2	224,412.1 816.2	2,810,820.0 816.2
AHU 1														
Eq4371 - Fa	an coil supply fa	an (Maii	n Clg Fan	)										
	Electric (kWh) Peak (kW)	1,773.4 9.5	1,699.9 9.5	2,044.4 9.5	1,756.4 9.5	2,244.8 9.5	2,305.4 10.0	2,699.2 10.0	2,888.7 10.0	2,294.2 9.5	2,089.6 9.5	1,775.8 9.5	1,679.9 9.5	25,251.5 10.0
AHU 2														
Eq4371 - Fa	an coil supply fa		n Clg Fan	,										
	Electric (kWh) Peak (kW)	1,676.0 9.5	1,531.7 9.5	1,855.1 9.5	1,623.7 9.5	1,816.0 9.5	1,824.7 9.5	1,756.7 9.5	1,961.3 9.5	1,679.0 9.5	1,908.9 9.5	1,684.0 9.5	1,601.3 9.5	20,918.3 9.5
AHU 3														
	nit vent supply	fan (Ma	in Clg Fa	n)										
	Electric (kWh) Peak (kW)	350.5 4.9	289.4 5.1	, 368.2 4.9	355.0 3.9	436.5 3.9	364.5 3.9	554.6 3.9	473.5 3.9	372.2 3.9	377.4 3.9	314.1 5.1	344.8 5.0	4,600.6 5.1
AHU 4														
Eq4372 - U	nit vent supply	fan (Ma	in Clg Fai	n)										
	Electric (kWh) Peak (kW)	350.3 5.5	338.7 5.5	418.4 5.5	345.5 5.3	524.5 5.4	515.4 4.7	832.2 5.5	792.6 5.0	563.3 4.7	400.8 4.9	360.3 5.5	331.1 5.5	5,773.0 5.5

AHU 7

Alternative: 1 Palestra Building

					M	onthly Co	onsumptio	n					
Equipment - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
AHU 7													
Eq4371 - Fan coil supply fa	an (Mai	n Clg Fan)											
Electric (kWh) Peak (kW)	1,900.5 10.0	1,719.5 10.0	2,081.5 10.0	1,810.0 10.0	1,991.0 10.0	1,991.0 10.0	1,810.0 10.0	2,081.5 10.0	1,810.0 10.0	1,991.0 10.0	1,900.5 10.0	1,810.0 10.0	22,896.5 10.0
Cpl 1: IC Engine Chiller Pla	ant												
IC Chiller 1 (Cooling Equ	uipment)												
Gas (kWh) Peak (kW)	622.7 80.3	467.9 80.2	621.4 80.1	1,056.5 94.5	5,550.6 94.5	8,379.2 94.5	32,928.5 393.7	16,273.2 193.9	9,352.1 141.8	4,416.9 94.5	710.3 85.6	662.4 94.5	81,041.5 393.7
Eq5100 - Cooling tower													
Electric (kWh) Peak (kW)	2,260.9 13.6	2,026.9 13.9	2,450.6 14.2	2,311.0 16.8	4,401.3 21.5	4,531.9 21.5	6,880.6 21.5	6,962.3 21.5	4,951.1 21.5	4,005.2 18.1	2,342.0 14.1	2,252.0 15.1	45,375.5 21.5
Eq5100 - Cooling tower													
Make Up Water (kL) Peak (kL/Hr)	124.3 3.6	112.1 3.8	143.0 4.1	145.9 4.8	392.4 5.5	364.8 6.0	1,294.6 11.3	708.0 8.0	456.7 6.5	216.4 4.8	128.3 3.7	119.0 3.7	4,205.4 11.3
Eq5001 - Cnst vol chill wate	er pump	(Misc Ac	cessory	Equipmen	t)								
Electric (kWh) Peak (kW)	14.6 1.8	10.9 1.8	14.6 1.8	29.2 1.8	262.7 1.8	361.2 1.8	474.3 1.8	461.5 1.8	328.3 1.8	268.2 1.8	21.9 1.8	16.4 1.8	2,263.7 1.8
Eq5010 - Cnst vol cnd wate	er pump	(Misc Ac	cessory I	Equipmen	t)								
Electric (kWh) Peak (kW)	25.1 3.1	18.8 3.1	25.1 3.1	50.1 3.1	451.1 3.1	620.2 3.1	814.4 3.1	792.5 3.1	563.8 3.1	460.5 3.1	37.6 3.1	28.2 3.1	3,887.3 3.1
Eq5300 - Cntl panel & inter	rlocks (	Misc Acce	ssory Eq	uipment)									
Electric (kWh) Peak (kW)	8.0 1.0	6.0 1.0	8.0 1.0	16.0 1.0	144.0 1.0	198.0 1.0	260.0 1.0	253.0 1.0	180.0 1.0	147.0 1.0	12.0 1.0	9.0 1.0	1,241.0 1.0
EDC Heater (Misc Acces	ssory Equ	ipment)											
Electric (kWh) Peak (kW)	110.4 0.2	99.9 0.2	110.4 0.2	105.6 0.2	90.0 0.2	78.3 0.2	72.6 0.2	73.7 0.2	81.0 0.2	89.6 0.2	106.2 0.2	110.3 0.2	1,127.9 0.2
IC CHiller 2 (Cooling Equ	uipment)												
Gas (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	7,500.0 393.7	0.0 193.9	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	7,500.0 393.7

Project Name:

 $\label{eq:transform} \begin{array}{c} {\sf TRACE} \$ \ 700 \ v4.1 \ calculated \ at \ 08:12 \ PM \ on \ 03/28/2006 \\ {\sf Alternative - 1} \quad {\sf Equipment \ Energy \ Consumption \ report \ page \ 2 \ of \ 6} \end{array}$ 

					N	Ionthly Co	onsumptio	n					
Equipment - Utilitv	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Tota
Cpl 1: IC Engine Chiller Plar	nt												
Eq5100 - Cooling tower													
Electric (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	965.3 21.5	0.0 21.5	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	965.3 21.5
Eq5100 - Cooling tower													
Make Up Water (kL) Peak (kL/Hr)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	79.3 3.3	0.0 2.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	79.3 3.3
Eq5001 - Cnst vol chill wate	r pump	(Misc Ad	ccessory	Equipmen	nt)								
Electric (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	82.1 1.8	0.0 1.8	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	82.1 1.8
Eq5010 - Cnst vol cnd water	pump	(Misc Ac	ccessory I	Equipmen	t)								
Electric (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	141.0 3.1	0.0 3.1	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	141.0 3.1
Eq5300 - Cntl panel & interlo	ocks (	Misc Acce	essory Eq	uipment)									
Electric (kWh) Peak (kW)	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	45.0 1.0	0.0 1.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	45.0 1.0
EDC Heater (Misc Access	sory Equ	uipment)											
Electric (kWh) Peak (kW)	111.6 0.2	100.8 0.2	111.6 0.2	108.0 0.2	111.6 0.2	108.0 0.2	104.9 0.2	111.6 0.2	108.0 0.2	111.6 0.2	108.0 0.2	111.6 0.2	1,307. 0.2
IC Chiller 3 (Cooling Equi	pment)												
Gas Peak (kW) Eq5100 - Cooling tower	0.0	0.0	0.0	0.0	0.0	0.0	393.7	0.0	0.0	0.0	0.0	0.0	393.7
Electric Peak (kW) Eq5100 - Cooling tower	0.0	0.0	0.0	0.0	0.0	0.0	21.5	0.0	0.0	0.0	0.0	0.0	21.5
Make Up Water Peak (kL/Hr)	0.0	0.0	0.0	0.0	0.0	0.0	3.3	0.0	0.0	0.0	0.0	0.0	3.3
Eq5001 - Cnst vol chill water			ccessory			0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Electric Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	1.8	0.0	0.0	0.0	0.0	0.0	1.8
Eq5010 - Cnst vol cnd water	pump	(Misc Ad	ccessory I	Equipmen	t)								
Electric Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	3.1	0.0	0.0	0.0	0.0	0.0	3.1
		Mise Acce		uipment)									
Eq5300 - Cntl panel & interlo Electric Peak (kW)	ocks (		ssory Ly	aipmont)									

Feb	Mar	Apr	May								
quipment)			iviay	June	Julv	Aua	Sept	Oct	Nov	Dec	Tota
quipment)											
gaipinont)											
6 100.8 0.2	111.6 0.2	108.0 0.2	111.6 0.2	108.0 0.2	111.6 0.2	111.6 0.2	108.0 0.2	111.6 0.2	108.0 0.2	111.6 0.2	1,314.0 0.2
it)											
0.0	0.0	0.0	0.0	0.0	393.7	0.0	0.0	0.0	0.0	0.0	393.7
0.0	0.0	0.0	0.0	0.0	21.5	0.0	0.0	0.0	0.0	0.0	21.5
0.0	0.0	0.0	0.0	0.0	3.3	0.0	0.0	0.0	0.0	0.0	3.3
p (Misc A	ccessory l	Equipmen	it)								
0.0	0.0	0.0	0.0	0.0	1.8	0.0	0.0	0.0	0.0	0.0	1.8
p (Misc A	ccessory E	Equipmen	t)								
0.0	0.0	0.0	0.0	0.0	3.1	0.0	0.0	0.0	0.0	0.0	3.1
(Misc Acc	essory Eq	uipment)									
0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	1.0
quipment)											
6 100.8	111.6	108.0	111.6	108.0	111.6	111.6	108.0	111.6	108.0	111.6	1,314.
0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
t)											
0.0	0.0	0.0	0.0	0.0	393.7	0.0	0.0	0.0	0.0	0.0	393.7
0.0	0.0	0.0	0.0	0.0	21.5	0.0	0.0	0.0	0.0	0.0	21.5
0.0	0.0	0.0	0.0	0.0	3.3	0.0	0.0	0.0	0.0	0.0	3.3
• •	ccessory l										
0.0	0.0	0.0	0.0	0.0	1.8	0.0	0.0	0.0	0.0	0.0	1.8
	ccessory E	• •	,								
0.0	0.0	0.0	0.0	0.0	3.1	0.0	0.0	0.0	0.0	0.0	3.1
•		• /									
0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	0.0	0.0	1.0
		(Misc Accessory Eq 0.0 0.0	(Misc Accessory Equipment) 0.0 0.0 0.0	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0 0.0	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0 0.0 1.0	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0 0.0 1.0 0.0	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0 0.0 1.0 0.0 0.0 TRAC	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0 0.0 1.0 0.0 0.0 0.0 TRACE® 700 v4.	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0 0.0 1.0 0.0 0.0 0.0 0.0 TRACE® 700 v4.1 calculated	(Misc Accessory Equipment) 0.0 0.0 0.0 0.0 0.0 1.0 0.0 0.0 0.0 0.0

						N	lonthly Co	nsumptio	n					
Equipment - Ut	ilitv	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Cpl 1: IC Engin	e Chiller Pla	ant												
	(Misc Acces Electric (kWh) Peak (kW)	ssory Equ 111.6 0.2	ipment) 100.8 0.2	111.6 0.2	108.0 0.2	111.6 0.2	108.0 0.2	111.6 0.2	111.6 0.2	108.0 0.2	111.6 0.2	108.0 0.2	111.6 0.2	1,314.0 0.2
Hpl 1: BOILER	S													
Boiler 1 (Hea	ating Equipn Gas (kWh) Peak (kW)		279,779.7 975.6	337,934.0 975.6	244,647.7 975.6	171,879.6 975.6	159,275.1 975.6	51,019.5 975.6	101,100.0 975.6	100,938.4 975.6	163,548.8 975.6	256,205.4 975.6	232,689.0 975.6	2,386,237.8 975.6
Eq5020 - Heati E	ng water cir Electric (kWh) Peak (kW)		(Misc Ac 265,200.0 975.0	cessory E 321,750.0 975.0		,	210,600.0 975.0	63,375.0 975.0	142,350.0 975.0	158,925.0 975.0	193,050.0 975.0	286,650.0 975.0	273,000.0 975.0	2,698,800.0 975.0
Eq5240 - Boile E	r forced draf Electric (kWh) Peak (kW)	t fan (N 824.6 2.7	lisc Acces 742.7 2.7	sory Equ 901.0 2.7	ipment) 709.9 2.7	660.8 2.7	589.8 2.7	177.5 2.7	398.6 2.7	445.1 2.7	540.6 2.7	802.7 2.7	764.5 2.7	7,557.8 2.7
Eq5307 - Boile E	r cntl panel a Electric (kWh) Peak (kW)	& inter 151.0 0.5	(Misc Acc 136.0 0.5	essory Eq 165.0 0.5	uipment) 130.0 0.5	121.0 0.5	108.0 0.5	32.5 0.5	73.0 0.5	81.5 0.5	99.0 0.5	147.0 0.5	140.0 0.5	1,384.0 0.5
Boiler 2 (Hea	ating Equipn Gas (kWh) Peak (kW)		255,915.5 975.6	304,971.0 975.6	228,864.8 975.6	131,597.7 975.6	114,175.3 975.6	33,527.9 975.6	74,469.3 975.6	76,375.6 975.6	131,404.7 975.6	235,156.8 975.6	220,487.8 975.6	2,071,681.4 975.6
Eq5020 - Heati E	ng water cir Electric (kWh) Peak (kW)	c pump 233,025.0 975.0	•	cessory E 273,000.0 975.0		:) 132,600.0 975.0	115,050.0 975.0	43,875.0 975.0	93,600.0 975.0	86,775.0 975.0	128,700.0 975.0	179,400.0 975.0	164,775.0 975.0	1,851,525.0 975.0
Eq5240 - Boile E	r forced draf Electric (kWh) Peak (kW)	t fan (N 652.6 2.7	lisc Acces 630.7 2.7	sory Equ 764.5 2.7	ipment) 491.5 2.7	371.3 2.7	322.2 2.7	122.9 2.7	262.1 2.7	243.0 2.7	360.4 2.7	502.4 2.7	461.4 2.7	5,185.0 2.7
Eq5307 - Boile E	r cntl panel a Electric (kWh) Peak (kW)	& inter 119.5 0.5	(Misc Acc 115.5 0.5	essory Eq 140.0 0.5	uipment) 90.0 0.5	68.0 0.5	59.0 0.5	22.5 0.5	48.0 0.5	44.5 0.5	66.0 0.5	92.0 0.5	84.5 0.5	949.5 0.5

Alternative: 1 Palestra Building

\_

					M	onthly Co	nsumptio	n					
Equipment - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Hpl 1: BOILERS													
Boiler 3 (Heating Equipn	nent)												
Gas (kWh) Peak (kW)	257,561.1 975.6	242,992.9 975.6	280,975.7 975.6	218,536.6 975.6	115,121.9 975.6	111,219.5 975.6	19,512.2 975.6	34,470.0 975.6	60,869.8 975.6	112,195.1 975.6	227,055.0 975.6	218,329.6 975.6	1,898,839.4 975.6
Eq5020 - Heating water cir	c pump	(Misc Ac	cessory E	quipment	)								
Electric (kWh) Peak (kW)	216,450.0 975.0	209,625.0 975.0	235,950.0 975.0	175,500.0 975.0	115,050.0 975.0	111,150.0 975.0	19,500.0 975.0	48,750.0 975.0	67,275.0 975.0	112,125.0 975.0	175,500.0 975.0	164,775.0 975.0	1,651,650.0 975.0
Eq5240 - Boiler forced draf	ft fan (N	lisc Acces	ssory Equ	ipment)									
Electric (kWh) Peak (kW)	606.2 2.7	587.0 2.7	660.8 2.7	491.5 2.7	322.2 2.7	311.3 2.7	54.6 2.7	136.5 2.7	188.4 2.7	314.0 2.7	491.5 2.7	461.4 2.7	4,625.3 2.7
Eq5307 - Boiler cntl panel	& inter	(Misc Acc	essory Ec	uipment)									
Electric (kWh) Peak (kW)	111.0 0.5	107.5 0.5	121.0 0.5	90.0 0.5	59.0 0.5	57.0 0.5	10.0 0.5	25.0 0.5	34.5 0.5	57.5 0.5	90.0 0.5	84.5 0.5	847.0 0.5
Boiler 4 (Heating Equipn	nent)												
Gas (kWh) Peak (kW)	247,156.2 975.6	231,219.4 975.6	280,975.7 975.6	208,181.2 975.6	113,339.2 975.6	97,531.8 975.6	19,512.2 975.6	6,035.5 975.6	35,733.9 975.6	90,007.1 975.6	216,585.4 975.6	191,049.7 975.6	1,737,327.1 975.6
Eq5020 - Heating water cir	c pump	(Misc Ac	cessory E	quipment	)								
Electric (kWh) Peak (kW)	216,450.0 975.0	194,025.0 975.0	235,950.0 975.0	175,500.0 975.0	115,050.0 975.0	111,150.0 975.0	19,500.0 975.0	7,800.0 975.0	41,925.0 975.0	112,125.0 975.0	175,500.0 975.0	161,850.0 975.0	1,566,825.0 975.0
Eq5240 - Boiler forced draf	ft fan (N	lisc Acces	ssory Equ	ipment)									
Electric (kWh) Peak (kW)	606.2 2.7	543.4 2.7	660.8 2.7	491.5 2.7	322.2 2.7	311.3 2.7	54.6 2.7	21.8 2.7	117.4 2.7	314.0 2.7	491.5 2.7	453.3 2.7	4,387.8 2.7
Eq5307 - Boiler cntl panel	& inter	(Misc Acc	essory Ec	uipment)									
Electric (kWh) Peak (kW)	111.0 0.5	99.5 0.5	121.0 0.5	90.0 0.5	59.0 0.5	57.0 0.5	10.0 0.5	4.0 0.5	21.5 0.5	57.5 0.5	90.0 0.5	83.0 0.5	803.5 0.5

### MONTHLY ENERGY CONSUMPTION

By ae

Monthly Energy Consumption														
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	C													
	On-Pk Cons. (kWh)	1,377,723	1,271,762	1,519,245	1,178,114	1,035,685	983,671	552,818	749,894	756,026	982,237	1,232,433	1,163,818	12,803,427
	On-Pk Demand (kW)	5,395	5,396	5,397	5,397	5,404	5,407	5,222	5,352	5,346	5,409	5,396	5,399	5,409
Gas														
Cuo	On-Pk Cons. (kWh)	1,057,295	1,010,376	1,205,477	901,287	537,489	490,581	164,000	232,348	283,270	501,573	935,713	863,219	8,182,627
	On-Pk Demand (kW)	3,983	3,983	3,982	3,997	3,997	3,997	3,997	3,997	3,997	3,997	3,988	3,997	3,997
Mater														
Water		404	110	4.40	4.40	202	205	4 074	700	457	04.0	400	110	4 005
	Cons. (kL)	124	112	143	146	392	365	1,374	708	457	216	128	119	4,285
Buildin	g Energy Consumpt	ion =		2,438	MJ/(m2-	-vear)								
Source	Energy Consumption			5,464	MJ/(m2-									
Floor A	\rea =			30,992	m2									

## **ENERGY CONSUMPTION SUMMARY**

By ae

	Elect Cons. (kWh)	Gas Cons. (kwh)	Water Cons. (kL)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Primary heating					
Primary heating	25,739.8	8,094,085.5		38.7 %	8,597,317.0
Primary cooling					
Cooling Compressor Tower/Cond Fans Condenser Pump Other CLG Accessories Cooling Subtotal	46,340.8 4,028.2 7,663.1 58,032.1	88,541.5 88,541.5	4,284.7 4,284.7	0.4 % 0.2 % 0.0 % 0.0 % 0.7 %	93,201.6 139,036.2 12,085.9 22,991.6 267,315.3
Auxiliary					
Supply Fans Circ Pumps Base Utilities	79,439.9 7,771,146.0			0.4 % 37.0 % 0.0 %	238,343.6 23,315,768.0 0.0
Aux Subtotal	7,850,586.0			37.4 %	23,554,112.0
Lighting					
Lighting	2,058,250.8			9.8 %	6,175,369.5
Receptacle					
Receptacles	2,810,820.3			13.4 %	8,433,304.0
Heating plant load					
Base Utilities				0.0 %	0.0
Cogeneration					
Cogeneration				0.0 %	0.0
Totals					
Totals**	12,803,429.0	8,182,627.0	4,284.7	100.0 %	47,027,416.0

\* Note: Resource Utilization factors are included in the Total Source Energy value. \*\* Note: This report can display a maximum of 6 utilities. If additional utilities are used, they will be included in the total.

## MONTHLY UTILITY COSTS

By ae

Alternative: 1

					N	Monthly U	tility Costs	s					
Jtility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Tota
Electric													
On-Pk Cons.(\$) Off-Pk Cons.(\$)	113,978 101	105,219 101	125,675 101	97,479 101	85,706 101	81,407 101	45,794 101	62,084 101	62,591 101	81,288 101	101,969 101	96,297 101	1,059,487 1,207
Total (\$):	114,078	105,320	125,776	97,579	85,807	81,507	45,895	62,184	62,691	81,389	102,069	96,398	1,060,694
Gas													
On-Pk Cons. (\$)	3,357	3,208	3,828	2,862	1,707	1,558	521	738	900	1,593	2,971	2,741	25,984

Monthly Total (\$):	117,436	108,528	129,604	100,441	87,514	83,065	46,416	62,922	63,591	82,982	105,040	99,139	1,086,678
---------------------	---------	---------	---------	---------	--------	--------	--------	--------	--------	--------	---------	--------	-----------

### **ELECTRICAL PEAK CHECKSUMS**

By ae

#### Alternative: 1 Palestra Building Yearly Time of Peak: 17(Hr) 7(Month)

Equipment Description		Electrical Demand (kw)	Percent of Total (%)
Cooling Equipment			
IC Chiller 1		15.36	0.28
IC CHiller 2		0.15	0.00
IC Chiller 3		0.15	0.00
IC CHiller 4		0.15	0.00
IC Chiller 5		0.15	0.00
	Sub total	15.96	0.28
Heating Equipment			
Boiler 1		978.23	18.13
	Sub total	978.23	18.13
Fan Equipment			
SUMMATION OF FAN ELECTRICAL DEMAND		2.04	0.04
SUMMATION OF FAN ELECTRICAL DEMAND		0.47	0.01
SUMMATION OF FAN ELECTRICAL DEMAND		10.00	0.19
SUMMATION OF FAN ELECTRICAL DEMAND		2.45	0.05
SUMMATION OF FAN ELECTRICAL DEMAND	_	0.85	0.02
	Sub total	15.81	0.31
Miscellaneous			
Lights		640.05	11.86
Base Utilities		0.00	0.00
Misc Equipment		816.20	15.12
	Sub total	1,456.25	26.98
	Total	2,466.25	46

### YEARLY CASH FLOW

By ae

Alternative:1Life Cycle Cost:28,724,974.84

Year	Utility Cost (\$)	Maint. Cost (\$)	Interest Cost (\$)	Principal Cost (\$)	Property Taxes (\$)	Insurance Cost (\$)	Revenue Penalty (\$)	Replace. Expenses (\$)	Deprec. Tax (\$)	Cash Flow Effect (\$)	Present Value (\$)
0	0	0	0	17,826,732	0	0	0	0	0	17,826,732	17,826,732
1	1,086,678	306,000	0	0	0	0	0	0	891,337	935,875	813,804
2	1,086,678	367,200	0	0	0	0	0	0	891,337	984,835	744,677
3	1,086,678	440,640	0	0	0	0	0	0	891,337	1,043,587	686,175
4	1,086,678	528,768	0	0	0	0	0	0	891,337	1,114,089	636,984
5	1,086,678	634,522	0	0	0	0	0	0	891,337	1,198,692	595,962
6	1,086,678	761,426	0	0	0	0	0	0	891,337	1,300,215	562,119
7	1,086,678	913,711	0	0	0	0	0	0	891,337	1,422,044	534,599
8	1,086,678	1,096,453	0	0	0	0	0	0	891,337	1,568,237	512,660
9	1,086,678	1,315,744	0	0	0	0	0	0	891,337	1,743,670	495,660
10	1,086,678	1,578,893	0	0	0	0	0	0	891,337	1,954,189	483,046
11	1,086,678	1,894,671	0	0	0	0	0	0	891,337	2,206,812	474,339
12	1,086,678	2,273,605	0	0	0	0	0	0	891,337	2,509,959	469,129
13	1,086,678	2,728,326	0	0	0	0	0	0	891,337	2,873,736	467,062
14	1,086,678	3,273,992	0	0	0	0	0	0	891,337	3,310,268	467,836
15	1,086,678	3,928,790	0	0	0	0	0	0	891,337	3,834,107	471,191
16	1,086,678	4,714,548	0	0	0	0	0	0	891,337	4,462,713	476,907
17	1,086,678	5,657,457	0	0	0	0	0	0	891,337	5,217,041	484,798
18	1,086,678	6,788,949	0	0	0	0	0	0	891,337	6,122,234	494,708
19	1,086,678	8,146,739	0	0	0	0	0	0	891,337	7,208,466	506,505
20	1,086,678	9,776,086	0	0	0	0	0	0	891,337	8,511,944	520,082

## **TRACE® 700 Economic Summary**

Alternative 1 - - Palestra Building

By ae


#### **Project Information**

Weather file	Heathrow, England
Project Name Location	London, England
Building Owner User	Balckfriars Investment
Company	Penn State University
Comments	-

**Economic Summary** 

Alternative	Installed	First Year	Final Year	First Year	Final Year	Life Cycle
Number	Cost	Util.Cost	Util. Cost	Maint. Cost	Maint. Cost	Cost
1	18,112,724.00	1,107,063.98	1,107,063.98	306,000.00	9,776,086.14	29,095,149.96

## Monthly Utility Costs per Utility



### Equipment Energy Consumption by Alternative

	Elect Cons. (kWh)	Gas Cons. (kwh)	Water Cons. (liters)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Alternative: 1 - Palestra Buil	ding				
Primary heating	25,739.8	8,094,085.5		38.7%	8,597,317.0
Cooling Compressor		88,541.5		0.4%	93,201.6
Tower/Cond Fans	46,340.8		4,284.7	0.2%	139,036.2
Condenser Pump	4,028.2			0.0%	12,085.9
Other CLG Accessories	7,663.1			0.0%	22,991.6
Supply Fans	79,439.9			0.4%	238,343.6
Circ Pumps	7,771,146.0			37.0%	23,315,768.0
Lighting	2,058,250.8			9.8%	6,175,369.5
Totals	12,803,429.0	8,182,627.0	4,284.7	100.0%	47,027,416.0

\* Note: Resource Utilization factors are included in the Total Source Energy value.





### The Palestra Building London, England

## **Dedicated Outdoor Air System Energy Simulation**

By ae

Alternative: 1 Palestra Building

					M	lonthly Co	onsumptio	n					
Equipment - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Auq	Sept	Oct	Nov	Dec	Total
Lights													
Electric (kWh) Peak (kW)	26,869.5 97.7	24,305.9 97.7	29,140.7 97.7	25,636.5 97.7	28,005.2 97.7	27,907.7 97.7	25,733.9 97.7	29,140.7 97.7	25,636.5 97.7	28,005.1 97.7	26,772.1 97.7	25,733.9 97.7	322,887.8 97.7
MISC LD													
Electric (kWh) Peak (kW)	42,556.8 148.4	38,494.9 148.4	46,056.4 148.4	40,619.6 148.4	44,306.7 148.4	44,119.2 148.4	40,807.1 148.4	46,056.4 148.4	40,619.7 148.4	44,306.7 148.4	42,369.4 148.4	40,807.1 148.4	511,119.9 148.4
AHU 3 DOAS													
Eq4372 - Unit vent supply f	an (Ma	in Clg Far	ר)										
Electric (kWh) Peak (kW)	9,933.0 55.0	9,244.8 55.0	10,208.7 55.0	6,768.3 55.0	3,557.9 55.0	3,255.1 55.0	5,253.7 54.9	3,083.8 51.4	3,823.7 55.0	7,507.6 55.0	10,277.8 55.0	9,804.8 55.0	82,719.2 55.0

AHU 4 DOAS

(Main Clg Fan) Eq4372 - Unit vent supply fan Electric (kWh) 9,933.0 9,358.5 3,224.1 81,560.2 10,454.2 6,422.3 3,255.6 3,075.7 5,880.5 3,071.8 7,064.3 10,282.4 9,537.8 Peak (kW) 55.0 55.0 55.0 55.0 55.0 55.0 43.6 55.0 55.0 55.0 53.4 55.0 55.0

#### AHU DOAS 1

Eq4371 - Fan coil supply fan (Main Clg Fan) Electric (kWh) 285,833.6 258,752.1 316,639.5 288,376.0 353,275.5 366,008.5 354,184.3 403,746.6 333,903.9 332,078.9 289,910.3 276,110.4 3,858,819.8 Peak (kW) 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0 1,425.0

#### AHU DOAS 2

Eq4371 - Fan coil supply fan (Main Clg Fan) Electric (kWh) 285,021.1 257,552.2 311,965.2 281,604.2 327,899.3 332,123.8 349,410.6 385,116.4 313,078.7 316,818.9 280,214.3 272,554.4 3,713,359.0 Peak (kW) 1,425.0 1,425

AHU DOAS 7

Alternative: 1 Palestra Building

					N	lonthly Co	onsumptio	n					
Equipment - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
AHU DOAS 7													
Eq4371 - Fan coil supply f Electric (kWh) Peak (kW)	an (Mai 76,020.0 400.0	n Clg Fan 68,780.0 400.0	) 83,260.0 400.0	72,400.0 400.0	79,640.0 400.0	79,640.0 400.0	72,400.0 400.0	83,260.0 400.0	72,400.0 400.0	79,640.0 400.0	76,020.0 400.0	72,400.0 400.0	915,860.0 400.0
Cpl 1: CHILLERS													
Chiller 2 (Cooling Equip Electric (kWh) Peak (kW)	ment) 74,462.7 104.1	67,254.1 104.1	74,462.5 104.1	72,071.4 104.6	74,708.3 121.0	72,858.9 128.2	75,280.6 133.3	77,756.5 133.2	73,316.3 137.9	74,553.4 122.0	72,061.5 104.2	74,462.0 104.4	883,248.2 137.9
Eq5221 - Condenser fan Electric (kWh) Peak (kW)	9,929.7 17.2	9,017.1 17.2	10,065.8 17.2	9,674.0 17.2	10,207.6 17.2	9,876.1 17.2	9,503.0 17.2	10,756.8 17.2	10,166.6 17.2	10,119.5 17.2	9,705.8 17.2	9,963.0 17.2	118,984.9 17.2
Eq5001 - Cnst vol chill wa Electric (kWh) Peak (kW)	ter pump 682.2 0.9	(Misc Ad 616.2 0.9	ccessory   682.2 0.9	Equipmen 660.2 0.9	t) 682.2 0.9	660.2 0.9	682.2 0.9	682.2 0.9	660.2 0.9	682.2 0.9	660.2 0.9	682.2 0.9	8,032.8 0.9
Eq5011 - Cnst vol cnd wat	ter pump	(Misc Ad	ccessory E	Equipmen	t)								
Electric (kWh) Peak (kW)	6,002.9 8.1	5,422.0 8.1	6,002.9 8.1	5,809.3 8.1	6,002.9 8.1	5,809.3 8.1	6,002.9 8.1	6,002.9 8.1	5,809.3 8.1	6,002.9 8.1	5,809.3 8.1	6,002.9 8.1	70,679.6 8.1
Eq5302 - Cntl panel & inte	erlocks (	Misc Acce	essory Eq	uipment)									
Electric (kWh) Peak (kW)	74.4 0.1	67.2 0.1	74.4 0.1	72.0 0.1	74.4 0.1	72.0 0.1	74.4 0.1	74.4 0.1	72.0 0.1	74.4 0.1	72.0 0.1	74.4 0.1	876.0 0.1
Chiller 3 (Cooling Equip	ment)												
Electric (kWh) Peak (kW)	416.4 104.1	312.3 104.1	416.3 104.1	418.3 104.6	419.5 104.9	420.2 105.1	18,143.0 131.8	1,959.1 118.2	315.2 105.1	523.8 104.8	416.8 104.2	313.3 104.4	24,074.2 131.8
Eq5221 - Condenser fan Electric (kWh) Peak (kW)	51.8 12.9	38.8 12.9	51.7 12.9	52.0 13.0	52.2 13.0	52.3 13.1	2,141.0 14.8	245.5 13.6	39.2 13.1	65.1 13.0	51.8 13.0	38.9 13.0	2,880.2 14.8
Eq5001 - Cnst vol chill wa	ter pump	(Misc Ad	ccessory l	Equipmen	it)								
Electric (kWh) Peak (kW)	3.7 0.9	2.8 0.9	3.7 0.9	3.7 0.9	3.7 0.9	3.7 0.9	183.4 0.9	21.1 0.9	2.8 0.9	4.6 0.9	3.7 0.9	2.8 0.9	239.3 0.9

Project Name:

#### Alternative: 1 Palestra Building

-----

				N	Ionthly Co	onsumptio	n					
Equipment - Utility Ja	n Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Cpl 1: CHILLERS												
Eq5012 - Cnst vol cnd water pun	np (Misc A	ccessory	Equipmen	t)								
Electric (kWh) 38 Peak (kW) 9.		38.8 9.7	38.8 9.7	38.8 9.7	38.8 9.7	1,937.8 9.7	222.9 9.7	29.1 9.7	48.4 9.7	38.8 9.7	29.1 9.7	2,528.8 9.7
Eq5302 - Cntl panel & interlocks	(Misc Acc	essory Eq	uipment)									
Electric (kWh) 0. Peak (kW) 0.		0.4 0.1	0.4 0.1	0.4 0.1	0.4 0.1	20.0 0.1	2.3 0.1	0.3 0.1	0.5 0.1	0.4 0.1	0.3 0.1	26.1 0.1
Chiller 4 (Cooling Equipment)												
Electric (kWh) 416 Peak (kW) 104	-	416.1 104.0	418.1 104.5	419.2 104.8	420.0 105.0	2,480.4 131.7	421.5 105.4	315.0 105.0	523.5 104.7	416.6 104.2	313.1 104.4	6,871.8 131.7
Eq5221 - Condenser fan												
Electric (kWh) 51 Peak (kW) 12		51.7 12.9	52.0 13.0	52.1 13.0	52.2 13.1	290.4 14.5	52.4 13.1	39.2 13.1	65.1 13.0	51.8 13.0	38.9 13.0	836.5 14.5
Eq5001 - Cnst vol chill water pur	np (Misc A	ccessory	Equipmen	it)								
Electric (kWh) 3. Peak (kW) 0.		3.7 0.9	3.7 0.9	3.7 0.9	3.7 0.9	22.9 0.9	3.7 0.9	2.8 0.9	4.6 0.9	3.7 0.9	2.8 0.9	61.4 0.9
Eq5011 - Cnst vol cnd water pun	np (Misc A	ccessory	Equipmen	t)								
Electric (kWh) 32 Peak (kW) 8.	-	32.3 8.1	32.3 8.1	32.3 8.1	32.3 8.1	201.7 8.1	32.3 8.1	24.2 8.1	40.3 8.1	32.3 8.1	24.2 8.1	540.6 8.1
Eq5302 - Cntl panel & interlocks	(Misc Acc	essory Eq	uipment)									
Electric (kWh) 0. Peak (kW) 0.		0.4 0.1	0.4 0.1	0.4 0.1	0.4 0.1	2.5 0.1	0.4 0.1	0.3 0.1	0.5 0.1	0.4 0.1	0.3 0.1	6.7 0.1
Chiller 5 (Cooling Equipment)												
Electric Peak (kW) 0.	0.0	0.0	0.0	0.0	0.0	113.9	0.0	0.0	0.0	0.0	0.0	113.9
Eq5221 - Condenser fan												
Electric Peak (kW) 0.		0.0	0.0	0.0	0.0	12.4	0.0	0.0	0.0	0.0	0.0	12.4
Eq5001 - Cnst vol chill water pur	• •	•	Equipmen	•	0.0			0.0	0.0	0.0	0.0	
Electric Peak (kW) 0. Eq5011 - Cnst vol cnd water pun		0.0	0.0 Equipmen	0.0 t)	0.0	0.9	0.0	0.0	0.0	0.0	0.0	0.9
Electric Peak (kW) 0.	• •	0.0	0.0	0.0	0.0	8.1	0.0	0.0	0.0	0.0	0.0	8.1

Alternative: 1 Palestra Building

					N								
Equipment - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Auq	Sept	Oct	Nov	Dec	Total
Cpl 1: CHILLERS													
Eq5302 - Cntl panel & inter	rlocks (	Misc Acce	essory Equ	uipment)									
Electric Peak (kW)	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.1
Hpl 1: BOILERS													
Boiler 1 (Heating Equip	nent)												
Gas (kWh) Peak (kW)	150,923.0 975.6	139,198.3 975.6	163,219.6 975.6	93,904.9 975.6	39,733.7 938.9	38,581.3 963.1	10,992.3 340.0	19,381.0 491.4	26,485.3 912.1	78,093.5 969.4	126,214.7 975.6	130,800.2 975.6	1,017,527.9 975.6
Eq5020 - Heating water cir	rc pump	(Misc Ac	cessory E	quipment	t)								
Electric (kWh) Peak (kW)	307,125.0 975.0	280,800.0 975.0	358,800.0 975.0	202,800.0 975.0	187,200.0 975.0	208,650.0 975.0	53,625.0 975.0	97,500.0 975.0	109,200.0 975.0	245,700.0 975.0	307,125.0 975.0	275,925.0 975.0	2,634,450.0 975.0
Eq5240 - Boiler forced drat	ft fan (N	lisc Acces	ssory Equ	ipment)									
Electric (kWh) Peak (kW)	860.1 2.7	786.4 2.7	1,004.8 2.7	567.9 2.7	524.2 2.7	584.3 2.7	150.2 2.7	273.0 2.7	305.8 2.7	688.1 2.7	860.1 2.7	772.7 2.7	7,377.5 2.7
Eq5307 - Boiler cntl panel	& inter	(Misc Acc	essory Eq	uipment)									
Electric (kWh) Peak (kW)	157.5 0.5	144.0 0.5	184.0 0.5	104.0 0.5	96.0 0.5	107.0 0.5	27.5 0.5	50.0 0.5	56.0 0.5	126.0 0.5	157.5 0.5	141.5 0.5	1,351.0 0.5
Boiler 2 (Heating Equipr	nent)												
Gas (kWh) Peak (kW)	34,884.7 975.6	33,547.3 975.6	36,369.7 975.6	7,086.8 356.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	32,597.3 975.6	24,106.5 975.6	168,592.4 975.6
Eq5020 - Heating water cir	rc pump	(Misc Ac	cessory E	quipment	t)								
Electric (kWh) Peak (kW)	48,750.0 975.0	42,900.0 975.0	52,650.0 975.0	23,400.0 975.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	48,750.0 975.0	28,275.0 975.0	244,725.0 975.0
Eq5240 - Boiler forced drat	ft fan (N	lisc Acces	ssory Equ	ipment)									
Electric (kWh) Peak (kW)	136.5 2.7	120.1 2.7	147.4 2.7	65.5 2.7	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	136.5 2.7	79.2 2.7	685.3 2.7
Eq5307 - Boiler cntl panel	& inter	(Misc Acc	essory Eq	(uipment)									
Electric (kWh) Peak (kW)	25.0 0.5	22.0 0.5	27.0 0.5	12.0 0.5	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	25.0 0.5	14.5 0.5	125.5 0.5

#### Alternative: 1 Palestra Building

			Monthly Consumption											
Equipme	ent - Utility	Jan	Feb	Mar	Apr	Mav	June	Julv	Aua	Sept	Oct	Nov	Dec	Total
Hpl 1: BC	OILERS													
Boiler 3	(Heating Equipm	nent)												
	Gas (kWh) Peak (kW)	14,936.6 975.6	14,530.4 975.6	13,203.2 502.7	0.0 0.0	4,037.2 975.6	4,234.1 586.3	50,941.6 975.6						
Eq5020 - Heating water circ pump (Misc Accessory Equipment)														
	Electric (kWh) Peak (kW)	24,375.0 975.0	21,450.0 975.0	26,325.0 975.0	0.0 0.0	7,800.0 975.0	22,425.0 975.0	102,375.0 975.0						
Eq5240 ·	- Boiler forced draf	tfan (N	lisc Acces	sory Equi	pment)									
	Electric (kWh) Peak (kW)	68.3 2.7	60.1 2.7	73.7 2.7	0.0 0.0	21.8 2.7	62.8 2.7	286.7 2.7						
Eq5307 -	' - Boiler cntl panel & inter (Misc Accessory Equipment)													
	Electric (kWh) Peak (kW)	12.5 0.5	11.0 0.5	13.5 0.5	0.0 0.0	4.0 0.5	11.5 0.5	52.5 0.5						
Boiler 4	(Heating Equipm	nent)												
	Gas (kWh) Peak (kW)	3,902.4 975.6	219.3 73.1	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	950.5 237.6	0.0 0.0	5,072.2 975.6
Eq5020 -	- Heating water cir	c pump	(Misc Ac	cessory E	quipment	t)								
	Electric (kWh) Peak (kW)	3,900.0 975.0	2,925.0 975.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	3,900.0 975.0	0.0 0.0	10,725.0 975.0
Eq5240 ·	- Boiler forced draf	tfan (N	lisc Acces	sory Equi	pment)									
	Electric (kWh) Peak (kW)	10.9 2.7	8.2 2.7	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	10.9 2.7	0.0 0.0	30.0 2.7
Eq5307 -	- Boiler cntl panel a	& inter	(Misc Acc	essory Eq	uipment)									
	Electric (kWh) Peak (kW)	2.0 0.5	1.5 0.5	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	0.0 0.0	2.0 0.5	0.0 0.0	5.5 0.5

### MONTHLY ENERGY CONSUMPTION

By ae

Alternative: 1 Palestra Building

		Monthly Energy Consumption												
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electri	с													
	On-Pk Cons. (kWh)	1,213,757	1,098,855	1,339,253	1,038,082	1,120,458	1,155,772	1,024,439	1,149,685	992,888	1,154,644	1,193,964	1,126,604	13,608,401
	On-Pk Demand (kW)	7,331	6,632	5,594	4,463	4,046	4,046	3,697	4,022	4,046	4,046	6,839	5,658	7,331
Gas														
	On-Pk Cons. (kWh)	204,647	187,495	212,792	100,992	39,734	38,581	10,992	19,381	26,485	78,093	163,800	159,141	1,242,134
	On-Pk Demand (kW)	3,902	3,000	2,454	1,332	939	963	340	491	912	969	3,164	2,537	3,902
Source	Building Energy Consumption =4,792Source Energy Consumption =13,597Source Energy Consumption =14,450													

11,158 m2

Floor Area =

# **ENERGY CONSUMPTION SUMMARY**

By ae

	Elect Cons. (kWh)	Gas Cons. (kwh)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Primary heating				
Primary heating	9,914.1	1,242,134.0	8.4 %	1,337,254.8
Primary cooling				
Cooling Compressor Tower/Cond Fans Condenser Pump Other CLG Accessories Cooling Subtotal	914,194.2 122,701.5 73,749.0 908.8 1,111,553.4		6.2 % 0.8 % 0.5 % 0.0 % 7.5 %	2,742,856.8 368,141.3 221,269.0 2,726.7 3,334,993.5
Auxiliary				
Supply Fans Circ Pumps Base Utilities	8,652,317.0 3,000,608.5		58.3 % 20.2 % 0.0 %	25,959,544.0 9,002,725.0 0.0
Aux Subtotal	11,652,926.0		78.5 %	34,962,272.0
Lighting				
Lighting	322,887.8		2.2 %	968,760.1
Receptacle				
Receptacles	511,120.0		3.4 %	1,533,513.1
Heating plant load Base Utilities			0.0 %	0.0
Cogeneration Cogeneration			0.0 %	0.0
Totals				
Totals**	13,608,400.0	1,242,134.0	100.0 %	42,136,788.0

\* Note: Resource Utilization factors are included in the Total Source Energy value. \*\* Note: This report can display a maximum of 6 utilities. If additional utilities are used, they will be included in the total.

### MONTHLY UTILITY COSTS

By ae

Alternative: 1

Monthly Utility Costs													
Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (\$) Off-Pk Cons. (\$)	100,425 101	90,928 101	110,798 101	85,904 101	92,713 101	95,632 101	84,777 101	95,129 101	82,169 101	95,539 101	98,789 101	93,221 101	1,126,023 1,207
Total (\$):	100,525	91,028	110,898	86,005	92,814	95,733	84,877	95,230	82,269	95,639	98,889	93,322	1,127,230
Gas													
On-Pk Cons. (\$)	650	595	676	321	126	123	35	62	84	248	520	505	3,944
Monthly Total (\$):	101,175	91,623	111,574	86,326	92,940	95,855	84,912	95,291	82,353	95,887	99,410	93,827	1,131,174

### **ELECTRICAL PEAK CHECKSUMS**

By ae

#### Alternative: 1 Palestra Building Yearly Time of Peak: 9(Hr) 1(Month)

Equipment Description		Electrical Demand (kw)	Percent of Total (%)
Cooling Equipment			
Chiller 2		123.28	2.34
	Sub total	123.28	2.34
Heating Equipment			
Boiler 1		978.23	18.56
Boiler 2		978.23	18.56
Boiler 3		978.23	18.56
Boiler 4		978.23	18.56
	Sub total	3,912.92	74.24
Fan Equipment			
SUMMATION OF FAN ELECTRICAL DEMAND		1,225.63	23.25
SUMMATION OF FAN ELECTRICAL DEMAND		1,325.00	25.14
SUMMATION OF FAN ELECTRICAL DEMAND		400.00	7.59
SUMMATION OF FAN ELECTRICAL DEMAND		55.00	1.04
SUMMATION OF FAN ELECTRICAL DEMAND		55.00	1.04
	Sub total	3,060.63	58.06
Miscellaneous			
Lights		93.63	1.78
Base Utilities		0.00	0.00
Misc Equipment		140.61	2.67
	Sub total	234.24	4.45
	Total	7,331.07	139

### YEARLY CASH FLOW

By ae

Alternative:1Life Cycle Cost:28,947,790.94

Year	Utility Cost (\$)	Maint. Cost (\$)	Interest Cost (\$)	Principal Cost (\$)	Property Taxes (\$)	Insurance Cost (\$)	Revenue Penalty (\$)	Replace. Expenses (\$)	Deprec. Tax (\$)	Cash Flow Effect (\$)	Present Value (\$)
0	0	0	0	17,826,732	0	0	0	0	0	17,826,732	17,826,732
1	1,131,174	306,000	0	0	0	0	0	0	891,337	971,472	844,758
2	1,131,174	367,200	0	0	0	0	0	0	891,337	1,020,432	771,593
3	1,131,174	440,640	0	0	0	0	0	0	891,337	1,079,184	709,581
4	1,131,174	528,768	0	0	0	0	0	0	891,337	1,149,687	657,337
5	1,131,174	634,522	0	0	0	0	0	0	891,337	1,234,289	613,660
6	1,131,174	761,426	0	0	0	0	0	0	891,337	1,335,813	577,509
7	1,131,174	913,711	0	0	0	0	0	0	891,337	1,457,641	547,981
8	1,131,174	1,096,453	0	0	0	0	0	0	891,337	1,603,835	524,296
9	1,131,174	1,315,744	0	0	0	0	0	0	891,337	1,779,267	505,779
10	1,131,174	1,578,893	0	0	0	0	0	0	891,337	1,989,786	491,845
11	1,131,174	1,894,671	0	0	0	0	0	0	891,337	2,242,409	481,991
12	1,131,174	2,273,605	0	0	0	0	0	0	891,337	2,545,556	475,783
13	1,131,174	2,728,326	0	0	0	0	0	0	891,337	2,909,333	472,848
14	1,131,174	3,273,992	0	0	0	0	0	0	891,337	3,345,866	472,867
15	1,131,174	3,928,790	0	0	0	0	0	0	891,337	3,869,704	475,565
16	1,131,174	4,714,548	0	0	0	0	0	0	891,337	4,498,311	480,711
17	1,131,174	5,657,457	0	0	0	0	0	0	891,337	5,252,638	488,106
18	1,131,174	6,788,949	0	0	0	0	0	0	891,337	6,157,831	497,584
19	1,131,174	8,146,739	0	0	0	0	0	0	891,337	7,244,063	509,006
20	1,131,174	9,776,086	0	0	0	0	0	0	891,337	8,547,541	522,257

# **TRACE® 700 Economic Summary**

Alternative 1 - - Palestra Building

By ae

#### **Project Information**


Weather file	Heathrow, England
Project Name Location	London, England
Building Owner User	Balckfriars Investment
Company	Penn State University
Comments	

**Economic Summary** 

Alternative	Installed	First Year	Final Year	First Year	Final Year	Life Cycle
Number	Cost	Util.Cost	Util. Cost	Maint. Cost	Maint. Cost	Cost
1	17,436,428.00	1,131,174.34	1,131,174.34	306,000.00	9,776,086.14	28,581,917.36

# Monthly Utility Costs per Utility

(1 alternative)



#### Equipment Energy Consumption by Alternative

	Elect Cons. (kWh)	Gas Cons. (kwh)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Alternative: 1 - Palestra Buil	ding			
Primary heating	9,914.1	1,242,134.0	8.4%	1,337,254.8
Cooling Compressor	914,194.2		6.2%	2,742,856.8
Tower/Cond Fans	122,701.5		0.8%	368,141.3
Condenser Pump	73,749.0		0.5%	221,269.0
Other CLG Accessories	908.8		0.0%	2,726.7
Supply Fans	8,652,317.0		58.3%	25,959,544.0
Circ Pumps	3,000,608.5		20.2%	9,002,725.0
Lighting	322,887.8		2.2%	968,760.1
Totals	13,608,400.0	1,242,134.0	100.0%	42,136,788.0

\* Note: Resource Utilization factors are included in the Total Source Energy value.





#### The Palestra Building London, England

# **DOAS and Gas Engine Driven Chiller Plant Energy Simulation**

#### MONTHLY ENERGY CONSUMPTION

By ae

Alternative: 1 Palestra Building

\_\_\_\_

Monthly Energy Consumption														
Utility		Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric	c													
	On-Pk Cons. (kWh)	1,134,612	1,027,392	1,259,927	961,879	1,043,115	1,080,925	928,984	1,070,529	918,740	1,077,373	1,117,477	1,048,064	12,669,017
	On-Pk Demand (kW)	7,225	6,526	5,250	4,360	3,943	3,943	3,592	3,923	3,946	3,943	6,734	5,553	7,225
Caa														
Gas		000 070	000 400	007.045	000 070	405 075	404 407	477.000	450.000	4 4 9 9 9 9	000 775	004.054	000 704	0 770 055
	On-Pk Cons. (kWh)	329,670	300,139	337,815	222,079	165,275	161,187	177,088	156,263	148,989	203,775	284,854	283,721	2,770,855
	On-Pk Demand (kW)	4,068	3,166	2,998	1,675	1,114	1,143	752	671	1,092	1,522	3,330	2,705	4,068
Water														
	Cons. (kL)	1,508	1,367	1,537	1,486	1,610	1,564	2,003	1,792	1,614	1,585	1,478	1,516	19,061
	g Energy Consumpt			4,982										
	Energy Consumption	on =		13,207	MJ/(m2	-year)								
Floor A	vrea =			11,158	m2									

# **ENERGY CONSUMPTION SUMMARY**

By ae

	Elect Cons. (kWh)	Gas Cons. (kwh)	Water Cons. (kL)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Primary heating					
Primary heating	9,914.1	1,242,134.0		8.1 %	1,337,254.8
Primary cooling					
Cooling Compressor Tower/Cond Fans Condenser Pump Other CLG Accessories Cooling Subtotal	122,329.8 27,837.3 14,124.0 164,291.1	1,528,721.5 1,528,721.5	19,060.7 19,060.7	9.9 % 0.8 % 0.2 % 0.1 % 11.0 %	1,609,180.4 367,026.2 83,520.2 42,376.1 2,102,103.0
Auxiliary					
Supply Fans Circ Pumps Base Utilities Aux Subtotal	8,652,317.0 3,008,486.0 11,660,803.0			56.0 % 19.5 % 0.0 % 75.5 %	25,959,544.0 9,026,360.0 0.0 34,985,904.0
Lighting					
Lighting	322,887.8			2.1 %	968,760.1
Receptacle					
Receptacles	511,120.0			3.3 %	1,533,513.1
Heating plant load					
Base Utilities				0.0 %	0.0
Cogeneration Cogeneration				0.0 %	0.0
Totals					
Totals**	12,669,016.0	2,770,855.5	19,060.7	100.0 %	40,927,536.0

\* Note: Resource Utilization factors are included in the Total Source Energy value.
\*\* Note: This report can display a maximum of 6 utilities. If additional utilities are used, they will be included in the total.

#### MONTHLY UTILITY COSTS

By ae

Alternative: 1

					N	Nonthly U	tility Costs	s					
Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
Electric													
On-Pk Cons. (\$) Off-Pk Cons. (\$)	93,883 101	85,021 101	104,241 101	79,606 101	86,320 101	89,446 101	76,887 101	88,586 101	76,040 101	89,152 101	92,467 101	86,729 101	1,048,377 1,207
Total (\$):	93,984	85,121	104,342	79,706	86,421	89,546	76,987	88,687	76,141	89,252	92,567	86,830	1,049,584
Gas													
On-Pk Cons. (\$)	1,047	953	1,073	705	525	512	562	496	473	647	905	901	8,799
Water													
On-Pk Cons. (\$)	2,185	2,126	2,197	2,176	2,228	2,209	2,394	2,305	2,230	2,218	2,172	2,189	26,630
Monthly Total (#);													
Monthly Total (\$):	97,216	88,200	107,612	82,588	89,174	92,267	79,944	91,488	78,844	92,117	95,644	89,920	1,085,013

#### **ELECTRICAL PEAK CHECKSUMS**

By ae

#### Alternative: 1 Palestra Building Yearly Time of Peak: 9(Hr) 1(Month)

Equipment Description		Electrical Demand (kw)	Percent of Total (%)
Cooling Equipment			
IC Chiller 1		16.83	0.33
IC Chiller 2		0.15	0.00
IC Chiller 3		0.15	0.00
IC Chiller 4		0.15	0.00
IC Chiller 5		0.15	0.00
	Sub total	17.43	0.33
Heating Equipment			
Boiler 1		978.23	18.93
Boiler 2		978.23	18.93
Boiler 4		978.23	18.93
Boiler 3		978.23	18.93
	Sub total	3,912.92	75.72
Fan Equipment			
SUMMATION OF FAN ELECTRICAL DEMAND		1,225.63	23.72
SUMMATION OF FAN ELECTRICAL DEMAND		1,325.00	25.64
SUMMATION OF FAN ELECTRICAL DEMAND		400.00	7.74
SUMMATION OF FAN ELECTRICAL DEMAND		55.00	1.06
SUMMATION OF FAN ELECTRICAL DEMAND		55.00	1.06
	Sub total	3,060.63	59.22
Miscellaneous			
Lights		93.63	1.81
Base Utilities		0.00	0.00
Misc Equipment		140.61	2.72
	Sub total	234.24	4.53

# **ELECTRICAL PEAK CHECKSUMS**

By ae

Alternative: 1 Palestra Building Yearly Time of Peak: 9(Hr) 1(Month)

Equipment Description		Electrical Demand (kw)	Percent of Total (%)
	Total	7,225.22	140

### YEARLY CASH FLOW

By ae

Alternative:1Life Cycle Cost:28,716,638.12

Year	Utility Cost (\$)	Maint. Cost (\$)	Interest Cost (\$)	Principal Cost (\$)	Property Taxes (\$)	Insurance Cost (\$)	Revenue Penalty (\$)	Replace. Expenses (\$)	Deprec. Tax (\$)	Cash Flow Effect (\$)	Present Value (\$)
0	0	0	0	17,826,732	0	0	0	0	0	17,826,732	17,826,732
1	1,085,013	306,000	0	0	0	0	0	0	891,337	934,543	812,646
2	1,085,013	367,200	0	0	0	0	0	0	891,337	983,503	743,669
3	1,085,013	440,640	0	0	0	0	0	0	891,337	1,042,255	685,300
4	1,085,013	528,768	0	0	0	0	0	0	891,337	1,112,757	636,223
5	1,085,013	634,522	0	0	0	0	0	0	891,337	1,197,360	595,300
6	1,085,013	761,426	0	0	0	0	0	0	891,337	1,298,884	561,543
7	1,085,013	913,711	0	0	0	0	0	0	891,337	1,420,712	534,098
8	1,085,013	1,096,453	0	0	0	0	0	0	891,337	1,566,905	512,224
9	1,085,013	1,315,744	0	0	0	0	0	0	891,337	1,742,338	495,281
10	1,085,013	1,578,893	0	0	0	0	0	0	891,337	1,952,857	482,716
11	1,085,013	1,894,671	0	0	0	0	0	0	891,337	2,205,480	474,053
12	1,085,013	2,273,605	0	0	0	0	0	0	891,337	2,508,627	468,880
13	1,085,013	2,728,326	0	0	0	0	0	0	891,337	2,872,404	466,846
14	1,085,013	3,273,992	0	0	0	0	0	0	891,337	3,308,936	467,648
15	1,085,013	3,928,790	0	0	0	0	0	0	891,337	3,832,775	471,027
16	1,085,013	4,714,548	0	0	0	0	0	0	891,337	4,461,381	476,765
17	1,085,013	5,657,457	0	0	0	0	0	0	891,337	5,215,709	484,674
18	1,085,013	6,788,949	0	0	0	0	0	0	891,337	6,120,902	494,600
19	1,085,013	8,146,739	0	0	0	0	0	0	891,337	7,207,134	506,412
20	1,085,013	9,776,086	0	0	0	0	0	0	891,337	8,510,612	520,001

# **TRACE® 700 Economic Summary**

Alternative 1 - - Palestra Building

By ae

#### **Project Information**


Weather file	Heathrow, England				
Project Name Location	London, England				
<b>Building Owner</b>	Balckfriars Investment				
User Company	Penn State University				
Comments					

**Economic Summary** 

Alternative	Installed	First Year	Final Year	First Year	Final Year	Life Cycle
Number	Cost	Util.Cost	Util. Cost	Maint. Cost	Maint. Cost	Cost
1	17,722,422.00	1,085,012.70	1,085,012.70	306,000.00	9,776,086.14	28,618,857.23

# Monthly Utility Costs per Utility





#### Equipment Energy Consumption by Alternative

	Elect Cons. (kWh)	Gas Cons. (kwh)	Water Cons. (liters)	Percent of Total Energy	Total Source Energy* (kWh/yr)
Alternative: 1 - Palestra Buil	ding				
Primary heating	9,914.1	1,242,134.0		8.1%	1,337,254.8
Cooling Compressor		1,528,721.5		9.9%	1,609,180.4
Tower/Cond Fans	122,329.8		19,060.7	0.8%	367,026.2
Condenser Pump	27,837.3			0.2%	83,520.2
Other CLG Accessories	14,124.0			0.1%	42,376.1
Supply Fans	8,652,317.0			56.0%	25,959,544.0
Circ Pumps	3,008,486.0			19.5%	9,026,360.0
Lighting	322,887.8			2.1%	968,760.1
Totals	12,669,016.0	2,770,855.5	19,060.7	100.0%	40,927,536.0

\* Note: Resource Utilization factors are included in the Total Source Energy value.