Lutron Comments
December 13, 2007
Maryland Transportation Authority
Police Training Facility
Hawkins Point, Baltimore, MD

Leah C. Clark Lighting / Electrical Faculty Consultants: R. Mistrick T. Dannerth

## Luke Tigue

- slide headers create less space for material
- don't show second floor plan "just to complete the building"
- instead of zoning use "scenes" you want to create
- in classroom, fixtures that run across your view cut the ceiling
- also think about projector in classroom
- uplight on range?
- Precise good bullet information

## Charles Stone

- range criteria separate into interior/exterior
- rethink exterior illuminance criteria
- front façade rendering everything is in a fog
- classroom A more descriptive criteria
- show more "spark" on classroom zone slide
- classroom A rendering unclear no light on floor...
- range area plan where are fluorescents?
- Be consistent in notes if tells fixtures and lamps, tell it for all
- Really take risks in range area, you're chance to show-off