

Haack, Charles. Technical Assignment Three: Mechanical Systems Existing Conditions. November 21, 2008.

KTA Group, Inc. Mechanical Construction Documents. KTA Group, Herndon, VA. 2008.

Marley Update Cooling Tower Selection Software. [www.marleyct.com](http://www.marleyct.com). Visited March 2009.

Noritake Associates. Architectural Construction Documents. Noritake Associates, Alexandria, VA. 2008.

RS Means Online Cost Estimate Software. [www.rsmeans.com](http://www.rsmeans.com). Visited March 2009.

## Appendices

### Appendix A – Breakdown of Monthly Energy Consumption & Costs

**Table 32 – New Energy Consumption by Month**

Energy Analysis						
Electric	Jan	Feb	Mar	Apr	May	Jun
On Peak Consumption (kWh)	222,030	206,577	231,893	212,386	241,873	192,257
Off Peak Consumption (kWh)	66,069	59,819	64,721	59,351	62,752	116,103
Natural Gas						
On Peak Consumption (Therms)	636	469	1,864	2,930	7,647	7,478
Off Peak Consumption (Therms)	228	175	25	41	646	2705


Energy Analysis							
Electric	Jul	Aug	Sep	Oct	Nov	Dec	Total
On Peak Consumption (kWh)	187,542	199,534	177,926	226,827	216,030	212,822	2,527,697
Off Peak Consumption (kWh)	117,413	119,598	108,422	61,485	59,258	66,874	961,864
Natural Gas							
On Peak Consumption (Therms)	7,877	7,951	5,828	3,824	2,879	482	49,866
Off Peak Consumption (Therms)	3065	2947	2017	4	16	164	12,032



**Tables 33 – New Energy Cost by Month**

Monthly Energy Costs							
	Jan	Feb	Mar	Apr	May	Jun	Total
Natural Gas	\$946.68	\$705.63	\$1,857.45	\$2,921.38	\$8,154.51	\$10,245.12	\$59,114.42
Electricity	\$21,970.23	\$21,335.30	\$22,525.52	\$21,915.96	\$24,118.48	\$25,236.26	\$277,181.20
	Jul	Aug	Sep	Oct	Nov	Dec	<b>\$336,295.62</b>
Natural Gas	\$10,402.56	\$9,349.39	\$7,539.83	\$3,470.85	\$2,840.00	\$681.01	
Electricity	\$25,101.89	\$25,526.54	\$23,977.90	\$22,441.52	\$21,547.72	\$21,483.88	

**Appendix B – Building Usage Schedules**

All schedules reflect a typical Monday to Friday schedule for the respective system. During weekends, the building is assumed to be unoccupied.





**Appendix C – Cooling Tower Design Sheets**

**UPDATE™ Version 4.12.2**  
Product Data: 3/16/2009 (Current)

© 2009 SPX Cooling Technologies, Inc.  
3/18/2009 10:20:03 AM

**Job Information**

**Selected By**

Penn State  
104 Engineering Unit A  
University Park, PA  
wpb5@psu.edu

PSUAE  
Tel 814-863-2076

**SPX Cooling Technologies Contact**

H & H Associates, Inc.  
4510 Westport Drive  
Mechanicsburg, PA 17055  
frank@hassociates.com

Tel 717-796-2401  
Fax 717-796-9717

**Cooling Tower Definition**

Manufacturer	Marley	Fan Motor Speed	1800 rpm
Product	NC Class	Fan Motor Capacity per cell	7.500 BHp
Model	NC8401MAN1	Fan Motor Output per cell	7.376 BHp
Cells	1	Fan Motor Output total	7.376 BHp
CTI Certified	Yes	Air Flow per cell	55280 cfm
Fan	6.000 ft, 5 Blades	Air Flow total	55280 cfm
Fan Speed	370 rpm, 6974.3 fpm	Static Lift	10.425 ft
Fans per cell	1	Distribution Head Loss	0.000 ft
		ASHRAE 90.1 Performance	78.4 gpm/Hp

Model Group Standard Low Sound (A)  
Sound Pressure Level 73 dBA (Single Cell), 5.000 ft from Air Inlet Face. See sound report for details.

**Conditions**

Tower Water Flow	441.9 gpm	Air Density In	0.07094 lb/ft³
Hot Water Temperature	95.00 °F	Air Density Out	0.07141 lb/ft³
Range	10.00 °F	Humidity Ratio In	0.01712
Cold Water Temperature	85.00 °F	Humidity Ratio Out	0.02795
Approach	7.00 °F	Wet-Bulb Temp. Out	86.69 °F
Wet-Bulb Temperature	78.00 °F	Estimated Evaporation	5.0 gpm
Relative Humidity	50 %	Total Heat Rejection	2202000 Btu/h

- This selection satisfies your design conditions.

**Weights & Dimensions**

	Per Cell	Total
Shipping Weight	4275 lb	4275 lb
Heaviest Section	4057 lb	
Max Operating Weight	8678 lb	8678 lb
Width	12.833 ft	12.833 ft
Length	6.521 ft	6.521 ft
Height	10.250 ft	

**Minimum Enclosure Clearance**

Clearance required on air inlet sides of tower without altering performance. Assumes no air from below tower.

Solid Wall	3.757 ft
50 % Open Wall	3.000 ft

Weights and dimensions do not include options; refer to sales drawings.

**Cold Weather Operation**

**Heater Sizing** (to prevent freezing in the collection basin during periods of shutdown)

Heater kW/Cell	9.0	7.5	6.0	4.5	3.0
Ambient Temperature °F	-26.64	-14.92	-3.20	8.52	20.23

**UPDATE™ Version 4.12.2**  
 Product Data: 3/16/2009 (Current)

© 2009 SPX Cooling Technologies, Inc.  
 3/18/2009 10:22:12 AM


**Job Information**

**Selected by**

Penn State PSUAE  
 104 Engineering Unit A Tel 814-863-2076  
 University Park, PA Fax  
 wpb5@psu.edu

**Cooling Tower Definition**

Manufacturer Marley  
 Product NC Class  
 Model NC8401MAN1  
 Cells 1  
 Fan 6,000 ft, 5 Blades  
 Fans per cell 1  
 Fan Motor Capacity per cell 7.500 BHp



**Design Conditions**

Tower Water Flow 441.9 gpm  
 Hot Water Temperature 95.00 °F  
 Cold Water Temperature 85.00 °F  
 Wet-Bulb Temperature 78.00 °F

**Curve Conditions**

Tower Water Flow (100.0 %) 441.9 gpm  
 Fan Speed (100.0 %) 370 rpm  
 Fan Motor Speed (100.0 %) 1800 rpm  
 Fan Motor Output per cell 7.376 BHp  
 Fan Motor Output total 7.376 BHp

**Legend**

- ① 8 °F Range
- ② 10 °F Range
- ③ 12 °F Range
- X Design Point


**Appendix D – Rainwater Tank Sizing Calculations**

Rainfall Storage Tank Calculation				
Region 2 - Mid Atlantic region				
Event	mm		11.53	Values Taken from NOAA
Mean	mm/hr		2.6235	
Mean duration	hr		4.4	
Mean interval	hr		70	
Area of roof	m <sup>2</sup>	A	3902	42001 ft <sup>2</sup>
Runoff Coefficient		$\phi$	1	
Avg # of rainfall events	#	$\theta$	86.96	
Depth Parameter	1/mm	$\zeta$	0.086730269	
Duration Parameter	1/hr	$\lambda$	0.227272727	
Time Parameter	1/hr	$\psi$	0.014285714	
Designed first flush depth	mm	$v_{ff}$	0	
Annual total water collected	L	$R_a$	3912336	1033529.7 gallons
Reliability of supply of water		$R_e$	0.3	
Max reliability of supply of water		$R_{emax}$	0.35088	
Annual discharge time	hr	$T_d$	6087.2	
Maximum use per reliability $R_e$	L/day	$G_{max}$	1499.67	396.17055 gallons
Actual Water use	L/day	G	1189	314.10057 gallons
Required Storage Volume	L	B	60811	16064.675 gallons
Probability of Spillage	%	G(0)	0.3509	
Estimated Spill Volume	L	S	15786.18	4170.2687 gallons


### Appendix E – Structural Calculations

The following appendix is a compilation of PCA Slab outputs and is divided into both the width and length column line calculations for a typical new air handling unit and a new cooling tower. Shear, Moment, and Deflection diagrams are shown along with a graphics showing the placement and size of the reinforcing steel for each of the cases.

### Width Graphical Outputs



**Figure XX - Isometric Displaying Tributary Areas for Width Calculation**



**Figure 25 – Shear and Moment Diagrams for Typical AHU Width**






Figure 26 –Deflection Diagrams for Typical AHU Width



Figure 27 –Reinforcement for Typical AHU Width




Figure 28 – Shear and Moment Diagrams for Typical Cooling Tower Width




Figure 29 – Deflection Diagrams for Typical Cooling Tower Width



Figure 30 –Reinforcement for Typical Cooling Tower Width

Length Graphical Outputs




Figure 31 - Isometric Displaying Tributary Areas for Length Calculation