

# AE SENIOR THESIS

Final Paper

April 7, 2009

**Meghan Graber**

Construction Management

Dr. Riley

**Integrated Science Center**


College of William & Mary

Williamsburg, Virginia

# INTEGRATED SCIENCE CENTER | COLLEGE OF WILLIAM & MARY WILLIAMSBURG, VIRGINIA

## BUILDING STATISTICS

- Building Occupant: Biology, chemistry, and psychology departments
- Size: Expansion - 120,000 GSF  
Renovation - 41,000 GSF
- Number of Stories: 3 stories plus a mechanical penthouse story above grade and one story vivarium below grade
- CM: Gilbane Building Company
- Design Team: Moseley Architects, Payette Architects, SST Planners
- Dates of Construction: January 2006 - March 2009
- Project Cost: \$42 million
- Project Delivery Method: Design-Bid-Build for a CM at risk



## ARCHITECTURE

- 2 phase project: the addition of the 120,000 s.f. ISC building to existing Roger's Hall followed by the renovation of Roger's Hall
- Both buildings contain classrooms, teaching and research laboratories, and faculty offices
- Vivarium located on ground floor of ISC includes animal holding and testing rooms
- Auditorium at East end of Roger's Hall
- ISC building's appearance and façade designed to match the brick style and color seen throughout campus
- Brick veneer/metal stud exterior walls
- Stimulated slate roofing

## STRUCTURAL

- Steel structure provides long spans and column free spaces
- 14" thick concrete perimeter wall continuous around perimeter
- Various sized footings from 4'-0" x 4'-0" to 8'-0" x 8'-0"
- 6" concrete slab-on-grade
- Supported floor system consists of a 5" lightweight concrete slab on 1-1/2" 22 gauge composite deck
- W18x35 and W12x16 are the most typical transfer beams
- Columns vary from W10x33 to W12x65

## MEP SYSTEMS

- 4th floor penthouse of the ISC building contains 5 AHUs with up to 40,700 max cfm
- Roger's mechanical room holds 2 AHUs with a max of 29,900 cfm
- Two 480V boilers located in boiler room along with an expansion tank and various heat pump
- Specialized laboratory features including a lab waste neutralization system and lab/acid waste piping
- Different sized fluorescent and HID lamps for various lighting fixtures
- 2000 kVa transformer is located on the ground floor of the ISC building

# 1 | Table of Contents

<b>1. Abstract .....</b>	<b>1</b>
<b>2. Acknowledgements.....</b>	<b>4</b>
<b>3. Executive Summary.....</b>	<b>5</b>
<b>4. Project Introduction.....</b>	<b>6</b>
<b>5. Project Team Overview .....</b>	<b>6</b>
1. Client Information .....	6
2. Project Delivery Method .....	8
3. Project Staffing Plan .....	10
<b>6. Existing Conditions.....</b>	<b>12</b>
1. Design Overview.....	12
2. Building Systems Summary .....	13
3. Local Conditions .....	16
4. Site Plan of Existing Conditions .....	18
5. Site Layout Planning .....	18
<b>7. Project Logistics Details.....</b>	<b>20</b>
1. Project Schedule Summary.....	20
2. Detailed Project Schedule .....	20
3. Project Cost Evaluation .....	22
4. General Conditions Estimate.....	27
<b>8. Introduction to Thesis Analyses .....</b>	<b>29</b>
1. Labs for the 21 <sup>st</sup> Century .....	29
<b>9. Energy Conservation through Retrofitting.....</b>	<b>20</b>
1. Introduction.....	30
2. Problem Statement .....	30
3. Goal .....	30
4. Methodology .....	30
5. Tools and Resources.....	31
6. Expectations .....	31

7. Research on Building Retrofits .....	31
8. Apply Retrofits to Rogers Hall .....	32
9. Energy Comparison .....	36
10. Energy Cost Comparison .....	37
11. Construction Cost and Schedule Considerations .....	37
12. Conclusions and Recommendations .....	39
<b>10. Implementation of Daylighting .....</b>	<b>41</b>
1. Introduction.....	41
2. Problem Statement .....	41
3. Goal .....	41
4. Methodology .....	42
5. Tools and Resources .....	42
6. Expectations .....	42
7. Research on Daylighting.....	42
8. Light Level and Occupancy Sensors.....	43
9. Choosing a Light Level Sensor .....	44
10. Daylighting Technical Write-up and Calculations.....	45
11. Construction Cost and Schedule Considerations .....	48
12. Conclusions and Recommendations .....	48
<b>11. Solar Heat Gain and Cooling Load Reduction.....</b>	<b>50</b>
1. Introduction.....	50
2. Problem Statement .....	50
3. Goal .....	50
4. Methodology .....	51
5. Tools and Resources .....	51
6. Expectations .....	51
7. Research on Solar Heat Gain and Cooling Loads.....	52
8. Shading Devices.....	55
9. Cooling Load Technical Write-up and Calculations .....	56
10. Cooling Load Comparison.....	60
11. Construction Cost and Schedule Considerations .....	61

12. Conclusions and Recommendations .....61

**12. Appendix..... 64**

A. Site Plans ..... 64

B. Schedules.....65

C. Estimates ..... 66

D. General Conditions Estimate .....67

E. Product Data Sheets – Lamps and Ballasts.....68

F. AGi32 Analysis ..... 69

G. Product Data Sheets – Light Level Sensor.....70

H. CLTD/SCL/CLF Method .....71

## 2 | Acknowledgements

The last five years have been both a challenging and rewarding experience for me. I have learned a lot since my freshman year and I feel a great sense of accomplishment as I wrap up my final year at Penn State and present my final senior thesis project. I could not have made it to this point without the help and support of the following people:

### **Penn State AE Faculty**

- Dr. David Riley
- Dr. Michael Horman
- Professor Robert Holland
- Professor Kevin Parfitt
- Professor Moses Ling

### **Gilbane Building Company**

- Daniel Hamilla
- Nicholas Ivey
- Gregory Dunkle
- Howard Dunn
- Shawn Hughes

### **College of William & Mary**

- Wayne Boy
- Randy Strickland
- Ronald Russell

### **Industry members from PACE who inspired my research topic**

### **All my family and friends for their love and encouragement especially**

- Mom and Dad
- My sisters Kristen and Kaitlyn
- My best friend and roommate of 3 years Samantha D'Agostino

### **My fellow AE Students**

I cannot thank you all enough!

### 3 | Executive Summary

At the PACE Roundtable event last fall, one of the topics discussed was the current energy and economic impacts on construction. There has been increasing interest in incorporating the principles of sustainable design and energy efficiency into building projects. These practices would lead to lower-than-industry-standard operational costs, occupant productivity gain, and they are environmentally beneficial. The following analyses are intended to not only offer reduced operating costs through energy saving opportunities but also to provide a high quality working environment for students and faculty.

The first study focuses on energy conservation through retrofitting. William and Mary's Rogers Hall will be undergoing a major renovation to upgrade its research facilities. This is an ideal opportunity to apply retrofitting techniques that would result in reduced energy consumption. In this analysis, the existing lamps were compared to the installation of more energy efficient ones. Initially, the College of William and Mary would have to invest \$34,567.30 for the new bulbs and ballasts plus an additional \$21,044.13 for their installation. However, changing the bulbs to T8s would conserve 28,245 watts of electricity a year and result in the college saving over \$9,000 a year, an annual savings of 34.2% compared to the existing lamps. The new system would not add time to the construction schedule and would pay for itself after 6.15 years.

The second study analyzes the current lighting layout and proposes an alternative design to implement daylighting techniques and reduce electrical costs. Natural light can result in energy and cost savings only if the lights are shut off or dimmed when sufficient illuminance levels are met. Installing light level sensors in the lab spaces would result in lower energy consumptions and costs as well as reduced maintenance (shorter burn hours). When lights are remained on during daylight hours (no sensors) 326,700 W of energy are consumed in the laboratories. If daylight sensors are used, only 245,025 W of electricity is used, a savings of 81,675 W. This is a 25% energy reduction for the lab spaces. After a few assumptions were made, natural light could reduce the annual electricity costs by approximately \$1,247.82.

The final analysis investigates the feasibility of reducing cooling loads through the use of window overhangs on the south façade of Rogers Hall. During the daytime, solar radiation through the large windows causes significant heat gains in the smaller office spaces and results in increased cooling loads. By installing a window shading devices, solar heat gains decrease and results in lower cooling loads and increased energy cost savings. The overhang reduced the daily total cooling load by 2249.13 Btu. This is a 9.6% reduction. The overhang also resulted in lowering the peak cooling load. The peak cooling load required dropped from 2308.8 Btu/hr for an office containing a window without a shading device to 1750.4 Btu/hr with a shaded window, a difference of 558.4 Btu/hr.

## 4 | Project Introduction

The College of William and Mary is interested in upgrading its out-of-date chemistry, biology, and psychology departments by replacing buildings over 30 years old with top-of-the-line facilities. This joint project includes the addition of a new, high tech laboratory building as well as the renovation of the existing Rogers and Millington Halls. The entire addition/renovation project is broken into five phases. Phases I and II were bid on together and awarded to Gilbane Construction Company. The remaining three phases (Phases III-V) are still in the schematic design stage.

Phase I includes the addition of the 3 story, 116,500 SF Integrated Science Center. This building has a mechanical penthouse located on the 4th floor and an animal holding area in the basement. Once the new addition is complete, Gilbane will work with the college to transition people and equipment out of the existing building into their new home. Once vacant, the existing buildings will be gutted and renovated. Phase II includes the renovation of the exiting, 2 story, 42,500 SF Rogers Hall only. Careful attention is required to move expensive equipment and hazardous materials, and meet certain academic dates. This \$42 million project was started in May 2006 and is targeted to be completed in April 2009.




Figure 4.1 – Phase Designations

## 5 | Project Team Overview

### 5.1 Client Information

College of William and Mary is a public university located in Williamsburg, Virginia. It is the United States second oldest institution of higher education and is one of the eight Public Ivies. To keep its reputation as being a cutting-edge research university, the college has decided to upgrade the outdated departments of Chemistry, Biology, and Psychology. Replacing facilities that are over 30 years old, the addition of the Integrated Science Center and the newly renovated Rogers Hall will include up to date mechanical systems, improved technological capacity and capability, upgraded electrical capacity, and modernization of laboratory spaces and equipment. William and Mary's intent is to become a national leader in research and teaching facilities in these departments.





During the construction process, the owner was represented by the College of William and Mary's Facilities Management Committee. This group, consisting of four members, made most of the decisions regarding the construction of the building and they all attended meetings to deal directly with the construction manager. After talking to Wayne Boy, director of Facilities Planning Design & Construction, the following are concerns or expectations for the Integrated Science Center project.

*Owner Expectations and Keys to Success:*

- **Cost** – Some of the funding for this project is provided by the Virginia College Building Authority and the rest is paid for by sponsors and the college. The College of William and Mary Board of Trustees sincerely desires to keep the project on budget without sacrificing the end product.

*Keys to Success:* No one likes to pay more than they expect. Both the contractor and owner benefit if construction costs are within budget. It is the contractors' responsibility to keep up with the expenditures and budget. This should be updated regularly and the owner should be informed if unexpected changes affect project costs.

- **Quality** – The owner demands a high quality product. By aesthetically appealing and efficient facilities, the college will be able to attract the best faculty and students in these departments.

*Keys to Success:* Quality work must be emphasized at all levels of the project staff. It is necessary to stress the importance of quality to workers when they first get on the project. If poor workmanship is allowed, workers may cut corners and quality could be sacrificed. Gilbane checks daily to make sure the work performed meets the project specifications.

- **Schedule** – The college has requested certain deadlines to be met so as to not interrupt their academic schedule.

*Keys to Success:* The academic calendar was taken into consideration when developing the project schedule. To keep the owner satisfied, it is critical to meet as many benchmarks as possible. Gilbane has developed 2-week look-ahead schedules for its contractors so they are fully aware of their expectations.

- **Safety** – Preventing workplace injuries is not only important for the project workers, it is simply good business. Accidents are costly, in both human and financial terms. Furthermore, it is crucial for W&M to keep their students and faculty unharmed.

*Keys to Success:* It is inevitable that construction will take place during the school year. Gilbane intends to keep everyone injury and accident free by providing overhead protection where necessary, additional lighting and signs, full and easy access around the site, and fencing for security.

## 5.2 Project Delivery Method


Gilbane Building Company was selected by the College of William and Mary to provide pre-construction and construction management services for their Chemistry/Biology/Psychology project on their campus. Gilbane serves as the construction manager at risk for this project. This assignment was chosen by the owner to enable the construction manager to get involved on the project early and to help alleviate some of the responsibilities and decisions from the W&M project staff. A guaranteed maximum price (GMP) contract was offered by Gilbane, which is a typical contract type for them. The proposal was agreed to by the college. Under this arrangement, the construction manager will be acting in the owner's interest. The contract between the College of William and Mary and Gilbane was a GMP of nearly \$42 million and a project schedule duration of 3.5 years.

The lump sum contracts that Gilbane holds with the subcontractors were developed for the individual parties. These contracts specified the list of contract documents, scope of work, work inclusions and exclusions, bid breakdown, unit rates, construction milestones, termination conditions, change order process, bonds and insurance, payment conditions, etc.

Gilbane was awarded this job through a design-bid-build process and was chosen over a select number of other qualified firms. Although this was the first project for Gilbane at the College of William and Mary campus, the original project manager for the job had a prior relationship with one of the W&M team members.

The builder's risk insurance was held by the owner. Gilbane carried general liability, automobile, and worker's compensation insurance. Each subcontractor was to provide general and excess liability insurances, automobile insurance, and worker's compensation insurance. Gilbane also required each subcontractor to have a performance and payment bond.

Figure 5.2.1 - Project Organizational Chart



### 5.3 Project Staffing Plan

Gilbane Building Company was initially hired onto the project early on to act as a consultant to the owner in the development and design phases.


Gilbane's preconstruction department provided estimating, purchasing, and budget control services. The preconstruction team consisted of the Richmond district manager, the accountant, and the project executive.



Once the project reached the construction phase, the project executive was head of the construction team. The ISC project executive oversees the construction progress primarily from the Richmond office and reports to the site once every two weeks. The project manager is in charge of the daily activities onsite. He is mainly responsible for the cost reports, owner correspondence, and schedule updating. The project executive and project manager work together with an accountant (in the Richmond office) for cost reporting. There was no assistant project manager assigned to this job so the project engineer stepped up to help the project manager in his responsibilities. The project engineer is also involved with any resource and engineering related activities relating to the project. There were two superintendents who shared duties in the field. They supervise the subcontractor's workers, inspect construction, oversee the MEP coordination, and enforce safety. The full time Integrated Science Center employees included the project manager, project engineer, and the two superintendents.

Gilbane has gone through numerous staffing changes on this project but the organization has remained the same. None of the original Gilbane team members remain on the William & Mary project, but despite the obvious challenges, the company has managed to keep the project under control.

Figure 5.3.1 - Gilbane Organizational Chart



## 6 | Existing Conditions

### 6.1 Design Overview

#### *Architecture:*

This project includes the construction of a new, high-tech laboratory building as well as the renovation of existing spaces. The addition contains research and teaching laboratories, lecture halls, classrooms, instrument rooms, and office spaces. William and Mary's intent is to upgrade the outdated departments of chemistry, biology, and psychology, replacing facilities over 30 years old. The college aims to become a national leader in research and teaching facilities in these departments.



Figure 6.1.1 - Integrated Science Center North Facade

Founded in 1693, the College of William and Mary is the second oldest institution of higher learning. In order to preserve the historic atmosphere, the college has developed a "vision plan" as guidelines for the insertion of new structures. This stresses the importance of preserving the architectural configuration and character of the Old Campus. Therefore, the ISC building's appearance and facade was designed to match the brick style and color seen throughout the campus.

#### *Building Envelope:*

The brick exterior wall system is comprised of 6" batt insulation that lines the space between two 5/8" gypsum board. The continuous air and vapor barrier is followed by 2" R-10 rigid insulation. A cavity drainage material is located between the insulation and the flemish bond face brick. Masonry ties fasten the brick to the facade, and continuous flashing with weeps extends 1/8" beyond the face of the brick for proper drainage.

The roof system consists of a metal roof deck followed by 5" of nailable vented R-20 insulation. An ice and water protection underlayment was placed before the stimulated slate roofing.



Figure 6.1.2 - Stimulated Slate Roofing

## 6.2 Building Systems Summary

The following table and written information summarizes the main building systems in the Integrated Science Center and Rogers Hall buildings. The information describes the key design and construction aspects of the project.

Yes	No	Work Scope
X		Demolition
X		Structural Steel Frame
X		Cast-In-Place Concrete
	X	Precast Concrete
X		Mechanical System
X		Electrical System
X		Masonry
	X	Curtain Wall
X		Support of Excavation

Table 6.2.1 – Building Systems Summary Table

### Demolition:

The demolition of interior partitions, ceiling assemblies, casework, and flooring materials in the existing Roger's Hall (except in the auditorium area) is required without jeopardizing the structural integrity of the building. Coordination between demolition work and the new work is necessary for the structural, plumbing, mechanical, and electrical systems. Asbestos was detected in samples of vinyl floor tile, black duct mastic, panels of a laboratory fume hood, white pipe mastic, and corrugated cementitious panels from the rooftop HVAC cooling tower therefore abatement was required before commencing work.



Figure 6.2.1 - Demolition

### Structural Steel Frame:

The structural system for the Integrated Science Center consists of structural steel. This steel structure provides the building with long spans and column free spaces. W18x35s and W12x16s are the most typical transfer beams. Column sizes vary from W10x33s to W12x65s. The supported floor system consists of a 5" lightweight concrete slab on a 1-1/2" 22 gauge composite deck. Braced frames and moment resisting connections resist lateral forces on the building.



Figure 6.2.2 - Steel Framing

### *Cast-In-Place Concrete*

Cast in place concrete was used for building footings, foundation walls, slabs-on-grade, suspended slabs, and concrete toppings. All the previously mentioned structures utilized normal weight concrete except for the suspended slabs in which used structural lightweight concrete was poured. The formwork (all horizontal for this project) was fabricated on site using typical wood framing. Undamaged formwork was reuseable once they were cleaned and their surfaces repaired. A concrete pump truck was used for all major pours.

### *Mechanical System:*

A mechanical penthouse is located on the fourth floor of the ISC addition. It contains five (5) AHUs with a max of 40,700 cfm. The existing Roger's Hall has its own mechanical room located on the 1st floor of the east end of the building. The original room was gutted, reconstructed, and new equipment was installed. It contains two (2) AHUs with a max of 29,900 cfm. The constant volume AHUs distribute through galvanized sheet metal duct and supplied to rooms through registers and grilles. Two 480 V boilers are located in the boiler room (ground floor of ISC building) along with an expansion tank and various heat pumps. This specialized laboratory building features a lab waste neutralization system, compressed air system, vacuum piping system and lab/acid waste piping.

### *Electrical System:*

A 2000 kVA transformer (35KV/480V/277V) is located on the ground floor of the ISC building. There are ten (10) dry type transformers (25kVA-300kVA) throughout the building and they are NEMA TP-1 rated. These three phase transformers are 60 Hz with a 480 V delta primary and 208Y/120 V secondary. There is one switchboard rated to withstand fault current of 100,000 amperes. Redundancy is provided by emergency power generation. Emergency/standby power will be supplied by a 1250 kW diesel engine generator. The demand load estimate for this project is 4,253.9 kVA.

Different sized fluorescent, incandescent, and HID lamps are used for various types of lighting fixtures. The majority of the labs, classrooms and offices are illuminated by recessed, ceiling grid mounted, fluorescent lights. Suspended mounted fluorescent lights are used in the bathrooms. The corridors contain wall mounted fixtures and recessed incandescent lighting is located in the lobbies.

### *Masonry:*

This building has brick veneer/metal stud exterior walls. Galvanized steel shelf angles transfers the weight of the masonry back to the structural frame. Masonry ties at 1'-4" O.C. secure the brick veneer to the backup system.



Figure 6.2.3 - Exterior Brick



The brick for the Phase I addition is a Flemish Bond pattern to match the adjacent dorm construction. The brick for the Phase II renovation is also a Flemish Bond pattern to match the existing Roger's Hall. The ISC's ground floor vivarium contains 6" CMU interior partitions.



Figure 6.2.4 - CMU Partitions

*Support of Excavation:*

Permanent steel sheet piles and tie-back anchors were installed at the interface with the existing structures to facilitate the required excavation of the new addition. This system would potentially eliminate any surcharge loads from the existing building foundations on the basement walls of the new structure. Although the basement elevations are above the current ground levels, it is likely that some soils may transport water during wet seasonal conditions. The basement walls were waterproofed and a geocomposite drainage medium was applied to the outside of the walls. The wall drainage material is connected to a storm sewer system.

*Fire Protection:*

ISC and Rogers Hall will be equipped with a fire alarm and sprinkler system. Standard Orifice quick response sprinklers will be installed throughout the entire building. This is a wet sprinkler system. Basket guards will be provided on all exposed on all exposed sprinklers in equipment rooms, electrical rooms, and telecom rooms. Wall mounted pull boxes, audible alarms, and strobe lights are located in the corridors and easy to see spaces.

*Transportation:*

There are two hydraulic passenger elevators in the ISC building. The one located at the north end of the ISC is a 4,500 lb capacity, 4 stop elevator which services the ground through third floors. The south end one is a 3,500 lb capacity, 5 stop elevator which services the ground through fourth floors. The fourth floor is where the penthouse is located. Both cars have a 150 fpm speed capability.

*Telecommunication:*

There are data/communication outlets located in all the laboratories and classrooms. They are located on the floor, in the casework, or wall mounted. Faculty offices contain wall telephone outlets. Wireless LAN antennas and junction boxes are located in the ceiling for internet connection throughout the building.

## 6.3 Local Conditions

### *Williamsburg, Virginia*

The project is located on the campus of the College of William and Mary in Williamsburg, Virginia. The following provides information regarding the city of Williamsburg and its surrounding area.

- **Location** – Williamsburg is located on the I-64 corridor on the Virginia Peninsula, 45 miles southeast of Richmond and 37 miles northwest of Norfolk.
- **Williamsburg's Claim to Fame** – The city is well-known for Colonial Williamsburg, the restored Historic Area of the city, and for the adjacent College of William and Mary. Williamsburg is also part of the Historic Triangle of Virginia, along with Jamestown and Yorktown, which is one of the most popular tourist destinations in the world.
- **Preferred Methods of Construction** – To match the Colonial and Historic Williamsburg areas, most structures are masonry, cast-in-place concrete and light steel.
- **Construction Recycling** – Services are available locally for most materials.
- **Tipping Fee** – In 2008, the tipping fee was \$49.95/ton but is expected to rise to \$53.95 in 2009 (Solid Waste Management Program Overview)
- **Regional Soil Types** – The regional geology is very complex and generally consists of interbedded layers of varying mixtures of sands, silts, and clays.




Figure 6.3.1<sup>1</sup> – Road Map of Williamsburg

### *Project Site*

The subsurface exploration program and geotechnical engineering analyses for this project were performed by Froehling & Robertson Inc. The subsurface exploration program consisted of the installation of one 20-foot deep piezometer and 13 Standard Penetration Test borings that were performed January 31, 2005 through February 3, 2005. The following information regards the existing site conditions.

<sup>1</sup> Maps from mapquest - mapquest.com

Figure 6.3.2<sup>2</sup> – Site Map of RoadsFigure 6.3.3<sup>2</sup> – Aerial view of Existing Site

- **General Boundaries** - The site is generally bounded by Landrum Drive to the north, Jamestown Road to the south, Rogers Hall to the east and Millington Hall to the west.
- **Surface Conditions** – The project site was sparsely wooded and contains pedestrian walkways. An existing ravine is present along the north side of the site.
- **Site Soil Types** – The borings showed layers of varying mixtures of sands, silts, and clays.
- **Subsurface Conditions** – Groundwater level was below the bottom of the piezometer at the time of the study. This level was therefore evaluated by visually judging the moisture content of the spilt-spoon samples and determined to be at a depth of 14 feet to 23 feet below existing ground surface. The contractor was prepared to possibly encounter subsurface water if construction extended below the planned basement subgrade elevation.
- **Construction Parking** – Parking near the site was rather limited. Landrum Drive was restricted to W&M students and staff parking only. It was agreed on to close a portion of Landrum road (see figure above) for convenient parking. This closed the current Landrum Drive loop but did not prevent access to any part of campus.

<sup>2</sup> Maps searched for on google earth - <http://earth.google.com/>

## 6.4 Site Plan of Existing Conditions

The site plan on the following page depicts the general conditions and site layout for this project. The ISC addition is bound to the east and west by existing buildings and to the north by Landrum Road. The larger staging areas were located at the north end of the building; therefore, most deliveries were made from Landrum Road. The site was occasionally accessed from the south but was limited in order to preserve the conditions of the nearby soccer field. Landrum Road is a through street but was blocked for contractor trailers and parking. Two mobile cranes were used on this project and their locations are displayed on the site plan. Existing underground utilities are also shown.

## 6.5 Site Layout Planning

Site plans for the following phases were developed to better visualize the changes in the site as construction progressed. Please refer to **Appendix A** for the excavation, superstructure, and closeout site plans for the College of William and Mary's Integrated Science Center.

### *Excavation Phase*

The excavation plan depicts the site set up during the earliest construction phase of the new building. Excavation moved from the South end of the building to the North end (Area B to Area A). Once necessary, ramps were constructed at both ends. This provided more flexible access around the site in such a limited area. Most of the soil was removed by trucks at the both ends of the proposed building but a small soil storage area was located in the southwest corner.



Figure 6.5.1- Preparation for Excavation



Figure 6.5.2 – Excavation Hole

### ***Superstructure Phase***

The site plan for the superstructure phase of the building shows the location of the crawler cranes, concrete pumps and pump trucks, material staging areas, and a material hoist. The site where the ISC addition is located was rather constricted. The structure is adjoining the existing Rogers Hall to the East and is in close proximity to Millington Hall to the West. Therefore, two crawler cranes were necessary to cover both ends of the building. Floors one through four were erected on in Area B followed by floors one through four in Area A. Steel layout areas were located on both the North and South ends of the building. Delivery and pump trucks had the same site access as the excavation site plan.



Figure 6.5.3- Steel Erection Started

### ***Closeout Phase I and Startup Phase II***

The final site plan, the Closeout of Phase I and Startup of Phase II, was set up much differently than the two previous phases. The fences were relocated to surround Rogers Hall, which is now the new focus of construction. The Integrated Science Center was partially opened for the 2008 summer school session. All temporary roads and walkways were removed and replaced with new sod. Construction deliveries are now made only from Landrum Rd to the northeast. A small part of the North wall was demolished so equipment had easier access and materials could be removed. Dumpsters were then conveniently located near the opening.

Safety is the number one priority for Gilbane. Each of the above site plans were designed with the intent to keep workers and pedestrians unharmed. During both the excavation and superstructure phases, a large number of deliveries were made to the site. A flag person was provided to help direct construction and pedestrian traffic. Overhead protection was provided near Millington Hall during the superstructure phase to protect individuals from any falling debris. Fences and signage were used in all phases of the project to keep people out of the site.

## 7 | Project Logistics Details

### 7.1 Project Schedule Summary

**Appendix B** depicts a summary schedule for Phases I and II of the Integrated Science Center project. It includes the design phase and procurement of construction services. Major phases of construction and milestone dates are illustrated.

### 7.2 Detailed Project Schedule

**Appendix B** also contains a detailed schedule of the construction process and key milestones for the Integrated Science Center project. Due to the limit on the number of items, this report focuses solely on the Phase I addition, enabling a greater detail of each trade sequence. Phase II is smaller and less complex than Phase I. A general schedule for Phase II is provided following the detailed schedule.

#### *Key Element Sequences*

##### **Foundation**

The ISC addition is supported by a shallow foundation system (spread footings) in conjunction with ground reinforcement measures. The Geopier Intermediate Foundations System is used to reinforce the foundation soils on this site. This process first involves drilling a cavity. Layers of aggregate are then placed into the drilled cavity in thin lifts of one-foot compacted thickness. A patented beveled tamper rams each layer of aggregate using vertical impact ramming energy. The tamper forces aggregate laterally into the cavity sidewalls resulting in exceptional union with surrounding soils. Following installation, this system can support the designed spread footings. The figure shown above depicts this process. The Geopier elements provide bearing support, settlement control, significantly higher resistance to sliding and uplift.

The construction of the foundation system started in the basement from the south end of the building to the north end. The basement walls are reinforced cast-in-place concrete.




Figure 7.1.1<sup>3</sup> – Geopier Foundation System

<sup>3</sup> Geopier foundation information - <http://www.geopier.com/index.asp?id=71>

### **Structural**

For the steel erection of the Integrated Science Center, the building was broken into two areas. The north end of the building is considered Area A and the south end is considered Area B. Floors one through four were erected in Area B, followed by floors one through four in Area A. Construction again moved from south to north foundation just as the foundation system had.




Figure 7.1.2 – ISC Area Designations

### **Finishes**

Team meetings were held weekly to help with MEP coordination. Once all the major systems were in, the finishes began. The finishes are sequenced by floor in the same south to north fashion as the foundation system. Installation will occur in the following order:

- Metal Studs
- MEP Rough-In
- Gypsum Board
- Ceiling Grid and Tiles
- Floor Finishes (Carpet, VCT, Ceramic Tile, Epoxy, and Terrazzo)
- Painting
- Lighting Fixtures
- Furniture

### **Phase II**

After the new addition is complete, Gilbane will work with the college to transition people and equipment out of the existing building into their new home. Once vacant, the existing building will be gutted and renovated. The abatement of asbestos was required before demolition could resume in full swing. While construction on the first floor focused on underground utilities, ductwork and piping were started on the second floor. In most cases, trades started on the second floor and moved down to the first. The contractors will complete their trades in the same order listed above.

## 7.3 Project Cost Evaluation

### Actual Cost

The following is a cost breakdown of the major building systems for Phase I and II of the Integrated Science Center job. This information was provided by Gilbane from their September 2005 Design Development Estimate on this project.

### Major Building System Costs

SYSTEMS COST	SITWORK	PHASE I	COST/ 116,426 SF	PHASE II	COST/ 42,340 SF	TOTAL
Foundations	\$0	\$807,917	\$6.94	\$4,464	\$0.11	\$812,381
Slab-On-Grade	\$0	\$209,454	\$1.80	\$9,924	\$0.23	\$219,378
Structural Frame	\$0	\$1,590,469	\$13.66	\$40,292	\$0.95	\$1,630,761
Supported Floor	\$0	\$975,186	\$8.38	\$37,058	\$0.88	\$1,012,244
Roof Structure	\$0	\$189,270	\$1.63	\$99,916	\$2.36	\$289,186
Roof Coverings	\$0	\$529,957	\$4.55	\$56,332	\$1.33	\$586,289
Stairs	\$0	\$139,457	\$1.20	\$18,756	\$0.44	\$158,213
Conveying Systems	\$0	\$261,026	\$2.24	\$0	\$0.00	\$261,026
Exterior Walls	\$0	\$2,607,681	\$22.40	\$40,672	\$0.96	\$2,648,353
Interior Walls	\$0	\$1,496,407	\$12.85	\$509,149	\$12.03	\$2,005,556
Interior Finishes	\$0	\$1,226,871	\$10.54	\$496,170	\$11.72	\$1,723,041
Doors & Hardware	\$0	\$483,607	\$4.15	\$151,334	\$3.57	\$634,941
Windows & Glazed Walls	\$0	\$666,800	\$5.73	\$122,053	\$2.88	\$788,853
Specialties	\$0	\$167,331	\$1.44	\$56,023	\$1.32	\$223,354
Plumbing	\$0	\$2,366,361	\$20.33	\$538,495	\$12.72	\$2,904,856
HVAC System	\$0	\$8,092,726	\$69.51	\$2,379,154	\$56.19	\$10,471,880
Fire Protection	\$0	\$430,364	\$3.70	\$150,776	\$3.56	\$581,140
Power	\$0	\$2,245,369	\$19.29	\$621,904	\$14.69	\$2,867,273
Lighting	\$0	\$928,037	\$7.97	\$364,333	\$8.60	\$1,292,370
Special Electrical	\$0	\$333,594	\$2.87	\$130,995	\$3.09	\$464,589
Special Systems	\$0	\$491,951	\$4.23	\$165,157	\$3.90	\$657,108
Interior Demolition	\$0	\$135,756	\$1.17	\$262,910	\$6.21	\$398,666
Area Lighting	\$30,461	\$0	\$0.00	\$0	\$0.00	\$30,461
Exterior Mechanical Distribution	\$11,184	\$0	\$0.00	\$0	\$0.00	\$11,184
Water Distribution System	\$64,831	\$0	\$0.00	\$0	\$0.00	\$64,831
Sanitary Sewer	\$142,388	\$0	\$0.00	\$0	\$0.00	\$142,388
Storm Drainage	\$150,596	\$0	\$0.00	\$0	\$0.00	\$150,596
Roads	\$42,084	\$0	\$0.00	\$0	\$0.00	\$42,084
Earthwork	\$538,851	\$0	\$0.00	\$0	\$0.00	\$538,851
Landscaping	\$98,782	\$0	\$0.00	\$0	\$0.00	\$98,782
Site Improvements	\$122,031	\$0	\$0.00	\$0	\$0.00	\$122,031
Fencing	\$11,400	\$0	\$0.00	\$0	\$0.00	\$11,400
Special Building Foundations	\$0	\$572,300	\$4.92	\$0	\$0.00	\$572,300
Site Demolition	\$69,790	\$0	\$0.00	\$0	\$0.00	\$69,790
<b>TOTAL</b>	<b>\$1,282,398</b>	<b>\$26,947,891</b>	<b>\$231.46</b>	<b>\$6,255,867</b>	<b>\$147.75</b>	<b>\$34,486,156</b>

Table 7.3.1 – Major Building Systems Costs



### Construction Cost

Table 7.3.2 below shows the actual construction costs and construction costs per square foot. This estimate does not include land costs, sitework, or permitting. The total construction cost for Phases I and II of the Integrated Science Center is **\$33,203,758**.

Building	Cost per SF (CC/SF)	Size (SF)	Total Cost (CC)
Phase I	\$231.46	116,426	\$26,947,891
Phase II	\$147.75	42,340	\$6,255,867
		<b>TOTAL</b>	<b>\$33,203,758</b>

Table 7.3.2 – Building Construction Costs and Construction Costs per SF

### Total Project Cost

The following table illustrates the total project cost and total cost per square foot. The Total project cost includes the building costs for Phases I and II as well as the site work.

Building	Cost per SF (TC/SF)	Size (SF)	Total Cost (TC)
Phase I & II CC	\$209.14	158,766	\$33,203,758
Sitework	\$8.08	158,766	\$1,282,398
<b>TOTAL</b>	<b>\$217.24</b>	<b>158,766</b>	<b>\$34,486,156</b>

Table 7.3.3 – Total Project Cost and Total Cost per SF

The actual cost estimate above does not include jobsite overhead, contingency, or contractor fees. If these were factored in, the total project cost is almost **\$42 million**.

### RS Means 2008 Cost Estimate

The following RS Means estimate was performed using the information for a Commercial/Residential/Institutional college laboratory. The reference page from RS Means 2008 can be found in **Appendix C**. If the square footage of the Integrated Science Center and Rogers Hall were combined, the floor area would go beyond the RS Means chart. Therefore, the estimate was split into Phase I, the ISC building, and Phase II, Rogers Hall. The exterior wall system was assumed to be face brick with concrete block back-up. The common wall where the two buildings are connected was excluded from the building perimeters. Common additives were included for a more accurate estimate.

#### ISC Building – Phase I

- Floor area = 71,970 SF
- Perimeter = 695 feet
- Story Height = 11 feet

#### Rogers Hall – Phase II

- Floor Area = 40,520 SF
- Perimeter = 905 feet
- Story Height = 11 feet

The next two pages show the calculations and additions used to develop a square foot estimate.

**SQUARE FOOTAGE ESTIMATE – Phase I**

RS Means Source Year 2008 Model # M.150  
 Pages(s) 108-109 Ext. Wall Type Face Brick with Concrete Brick Back-up  
 Area 71,970 SF Frame Steel Frame

The Area falls between: 68,000 SF and 80,000 SF  
 \*Base cost per Square Foot is: 152.41

Cost Adjustment Type: (11-12) x 0.733\* Per SF Adjustment -0.733  
 (Story Height)  
 Cost Adjustment Type: (695-1151.15\*)/100 x 1.6\* Per SF Adjustment -7.30  
 (Perimeter)  
 Adjusted Base Cost per Square Foot: 144.38

Base Building Cost 144.38 x 71,9870 = 10,391,028.60  
 Basement Cost 28.60 x 23,320 = 666,952.00  
 Total Cost 11,057,980.60

RS Means Additions:

Addition: (1) 3,500 lb hydraulic elevator at 150 fpm Amount: 59,975.00  
 Addition: (1) 4,500 lb hydraulic elevator at 150 fpm Amount: 63,100.00  
 Addition: (121) Fume Hood, included ductwork Amount: 595,925.00  
 Addition: (21) Safety Equipment, eye wash, hand held Amount: 9,345.00  
 Addition: (10) Deluge Showers Amount: 8,050.00

Multiplier Type Location Value: 0.87  
 Multiplier Type Time Value: -

Total SF Estimate for Building \$10,261,107.00

**\* After interpolation**

**SQUARE FOOTAGE ESTIMATE – Phase II**

RS Means Source Year 2008 Model # M.150  
 Pages(s) 108-109 Ext. Wall Type Face Brick with Concrete Brick Back-up  
 Area 40,520 SF Frame Steel Frame

The Area falls between: 37,000 SF and 45,000 SF  
 \*Base cost per Square Foot is: 168.99

Cost Adjustment Type: (11-12) x 0.928\* Per SF Adjustment -0.928  
 (Story Height)

Cost Adjustment Type: (905-840.08\*)/100 x 2.858\* Per SF Adjustment -3.86  
 (Perimeter)  
 Adjusted Base Cost per Square Foot: 164.20

Base Building Cost 164.20 x 40,520 = 6,653,465.04  
 Basement Cost \_\_\_\_\_ x \_\_\_\_\_ = \_\_\_\_\_  
 Total Cost 11,057,980.60

RS Means Additions:

Addition: (9) Fume Hood, included ductwork Amount: 44,325.00  
 Addition: (4) Safety Equipment, eye wash, hand held Amount: 1,780.00  
 Addition: (2) Deluge Showers Amount: 1,610.00

Multiplier Type Location Value: 0.87  
 Multiplier Type Time Value: -

Total SF Estimate for Building \$9,661,956.00

\* After interpolation

#### D4 Cost 2002 Estimate

Due to the fact that the ISC building and Rogers Hall are different in terms of size and number of floors, the building was again broken into the two construction phases to estimate the cost of this project. For Phase I, the Integrated Science Center, the following four buildings were selected to use in the D4Cost2002 averaging analysis. The D4Cost estimate can be found in **Appendix C**.

Project Name	Size (SF)	Use	Floors	Cost
College Science Center	127,700	Educational	4	\$27,133,551
Ezra Taft Benson Science Building	191,310	Educational	4	\$24,388,293
Engineering Building VA State University	108,288	Educational	4	\$11,769,200
Science & Technology Hall	73,406	Educational	3	\$10,640,503

Table 7.3.4 – Projects Chosen for Phase I D4 Cost Analysis

For Phase II, Rogers Hall, the following two buildings were selected for the averaging estimate.

Project Name	Size (SF)	Use	Floors	Cost
Biopsychological Sciences Building Addition	30,000	Educational	2	\$7,660,300
Science Lecture/Lab Building	25,563	Educational	2	\$2,746,552

Table 7.3.5 – Projects Chosen for Phase II D4 Cost Analysis

These were relatively easy to pick out from the rest because they are all higher education buildings and fell within about the same square footage and number of floors as the ISC and Rogers Hall buildings. These were also chosen based on the building descriptions. I looked for facilities that contained office, class, and laboratory spaces as well as ones that used structural steel and brick masonry.

For each phase, the True Averaging function was used to compare the selected buildings with a target information date (project start date) of June 2006. D4 produced an estimate of **\$25,088,412** for Phase I and **\$10,589,177** for Phase II.

#### Cost Comparison

	Phase I		Phase II		Total Cost (Phase I+II)
	Cost	Cost/SF	Cost	Cost/SF	
<b>Actual Cost</b>	\$26,947,891	\$231.46	\$6,255,867	\$141.75	<b>\$34,486,156</b>
<b>RS Means 2008</b>	\$10,261,107	\$144.38	\$9,661,956	\$168.99	<b>\$19,923,063</b>
<b>D4Cost2002</b>	\$25,088,412	\$215.49	\$10,589,177	\$250.10	<b>\$35,677,589</b>

Table 7.3.6 – Cost and Cost per Square Foot Comparison of Estimates

The RS Means estimate turned out extremely low compared to the actual project cost. This is because the 4<sup>th</sup> floor penthouse and the general conditions were excluded. The ground floor of the ISC is much more sophisticated than just a basement. This could have also contributed to such a low estimate. The additives helped bring the estimate closer, but not significantly. Cabinets, hardware, and countertops were excluded from the estimate because they were not part of the actual cost. These were paid for and installed separately by the owner. The square foot estimate was higher than the actual cost for Phase II. This is because RS Means does not take into consideration that Roger's Hall is a renovation project, not a new building.

The D4 estimate was surprisingly close to the actual cost, just slightly higher. Despite the fact that the software has a limited database, I was able to find a few buildings of similar area, purpose, and structure. Again the Phase II cost was higher than the actual because the program treated Rogers Hall as a newly constructed building as opposed to a renovation.

## 7.4 General Conditions Estimate

Please refer to **Appendix D** for the detailed general conditions estimate.

### Assumptions:

- Location factor for Newport News = 0.87
- Project duration = 46.5 months or 200 weeks (May 15, 2005 – March 31, 2009)
- All Gilbane employees were on the job from the start - the team on this project was rather small to begin with so they took on various positions and shared responsibilities to cover all the start-up tasks
- Maximum commissioning – laboratories have more systems and controls than normal higher education buildings
- Minimum or average unit costs were selected for all other items

The unit costs for the general conditions estimate were taken from the first division of R.S. Means 2008. The general conditions for the Integrated Science Center came out to be around **\$3,351,000**. Contingency, as well as overhead and profit, were not included in this figure. Table 7.4.1 on the following page summarizes the breakdown of the general conditions for this project.

Item	Cost	% of GC
Staff	\$1,109,250	0.331
Temporary Utilities	\$127,287	0.038
Site Office & Expenses	\$52,228	0.016
Site Security & Protection	\$42,533	0.013
Fee, Insurance, Permits and Bonds	\$1,419,394	0.423
Commissioning	\$277,225	0.083
Miscellaneous	\$323,044	0.096
<b>Total</b>	<b>\$3,350,961</b>	<b>1.000</b>

Table 7.4.1 – General Conditions Estimate Breakdown

	General Conditions Estimate
Actual Budget	\$4,286,057
RS Means	\$3,350,961
<b>Difference</b>	<b>-\$935,096</b>

Table 7.4.2 – General Conditions Estimate Comparison

As seen in Table 7.4.2, the estimate varied quite a bit from the actual general conditions budget. This could be contributed to the low project staff estimate for this project. The cost for employees can be difficult to estimate because it depends on the company. All the unit costs for the estimate were taken from R.S. Means rather than from Gilbane's data. The general conditions make up **9%** of the total project cost.

## 8 | Introduction to Thesis Analyses

The College of William and Mary decided to spend millions of dollars on the addition of the Integrated Science Center and the renovation of Rogers Hall with the intent of becoming a national leader in research and teaching facilities in the departments of biology, chemistry, and psychology. With this in mind, this thesis focuses on incorporating the most recent concepts and technology to provide an even more higher performance facility than originally designed.

### 8.1 Labs for the 21<sup>st</sup> Century

#### *Designing Energy Efficient Research Labs*

Labs for the 21<sup>st</sup> century (Labs21) is a voluntary partnership program dedicated to improving the environmental performance of U.S. laboratories. Co-sponsored by the U.S. Environmental Protection Agency (EPA) and U.S. Department of Energy (DOE), Labs21 offers professionals worldwide an opportunity for continuous learning and to exchange information through interactive programs.

The objective of Labs 21 is to pursue sustainable, high performance, and low-energy laboratories that will:

- Minimize overall environmental impacts.
- Protect occupant safety.
- Optimize whole building efficiency on a life-cycle basis.
- Establish goals, track performance, and share results for continuous improvement<sup>4</sup>.

This group focuses on laboratories and high performance facilities because they represent a continuous opportunity for advanced, environmentally preferred, building technologies. The Labs21 approach to improving the energy efficiency and environmental performance of these facilities is to examine the entire building from a “whole building” perspective. This approach allows owners to pursue integrated energy and water conservation measures with significantly higher efficiencies and cost savings than the traditional approach of addressing components individually. This encourages laboratory owners and designers to make capital investment decisions based on the life cycle cost savings, pursue energy-efficient HVAC technologies, design systems that recover and exchange waste heat and other forms of free energy, and incorporate renewable energy systems.

The Labs21 approach was the driving inspiration for the topics selected in this thesis. Each analysis incorporates an energy-saving technique applied to the Integrated Science Center project.

<sup>4</sup> Labs for the 21<sup>st</sup> Century - <http://www.labs21century.gov/about/approach.htm>

## 9 | Energy Conservation through Retrofitting

*AE Construction Management Critical Industry Research Issue*

### 9.1 Introduction

The PACE roundtable event covered a number of current issues facing the construction industry. One of the technical topics discussed was the recent energy and economic impacts on construction. Today's economic situation has made retrofitting existing buildings more appealing to some owners than new construction. The concept of retrofitting can be applied to Phase II of the Integrated Science Center project. While Rogers Hall undergoes interior renovations, updating old or outdated assemblies could lead to reduced operating costs for the owner.

### 9.2 Problem Statement

The College of William and Mary is interested in upgrading its chemistry, biology, and psychology department's image by replacing buildings over 30 years old with state-of-the-art facilities. This renovation project includes the addition of a new, high tech laboratory building as well as improvements to the existing Rogers Hall. During these times of economic uncertainty though, cost is one of the owner's top concerns. Retrofitting MEP features could lead to significant savings.

### 9.3 Goal

The purpose of this analysis is to identify MEP system upgrades or improvements to the existing Rogers Hall that would provide energy savings and reduced operating costs. One feature of building retrofit is that it pays off slowly and modestly. Owners are often hesitant to consider these options because it is difficult for them to pay more upfront even though it will almost certainly pay itself back in the long run. It is imperative to provide annual saving figures and an estimated payoff time in order to prove the value of my retrofit options.

### 9.4 Methodology

1. In order to identify areas of energy savings, extensive study on possible retrofit ideas is needed by researching literature focused on this topic.
2. Examine previously retrofitted laboratories or buildings similar to Rogers Hall by consulting related articles. Gilbane's building database may be a valuable research tool.
3. Study the existing Rogers Hall plans, the newly proposed plans, and determine possible retrofit considerations.
4. Determine the most feasible options and apply them to Rogers Hall.



5. Calculate the initial costs.
6. Calculate the annual cost and energy savings.
7. Determine the pay off duration.
8. Based on the research and calculations, draw conclusions and make recommendations regarding the proposed retrofit ideas.

## 9.5 Tools and Resources

1. College of William and Mary's owner representative
2. Gilbane Building Company
3. Penn State AE faculty
4. Internet and online resources
5. Magazine articles

## 9.6 Expectations

I expect to find ways in which the 35 year old Rogers Hall that could be improved or upgraded. When considering possible energy and cost saving possibilities, the electrical system tends to be overshadowed by the mechanical system. However, significant operating costs can be saved by addressing the electrical system as well. I expect to focus on electrical retrofitting because the majority of the mechanical and plumbing upgrades have been previously addressed or are included in the proposed renovation.

## 9.7 Research on Building Retrofits

Building retrofitting involves substituting older equipment with new or modernized parts or systems that was not existing or available at the time of the original construction. With today's technology, we know how to retrofit existing buildings to reduce their energy consumption by well over 50%, in some cases even 90-95%. An investment in retrofit has three basic features:

1. *It is cost intensive up front.* Energy saving materials and techniques usually cost more at the start than building with cheaper, more common materials and methods. Retrofitting buildings is also labor intensive, labor being a cost that most construction managers seek to reduce.
2. *It pays off slowly and moderately.* It takes time for the extra money invested into retrofits to pay off. Only in the long term do these investments offer a significant dividend.
3. *Its benefits are certain.* Money spent reducing the energy consumption costs of a building will almost undoubtedly pay for itself, given proper maintenance and a reasonable duration of time.

Upgrades and improvements can be applied to any of the building systems to provide various benefits to the owner. Seismic retrofitting involves modifications to existing structures to make them more resistant to ground motion or soil failure due to earthquakes. The incorporation of today's fire protection technology into existing structures helps reduce the loss of property and life due to a fire. Mechanical, electrical, and plumbing retrofits integrate more efficient components into a facility to provide energy and operation cost savings. Due to the recent rise in energy costs, this analysis will focus on MEP enhancements that could reduce energy consumption and therefore decrease operation costs. Building retrofit projects include some of the following elements:

Mechanical and plumbing systems can be upgraded by:

- Replacing inefficient boilers and cooling systems with high efficiency units
- Installing variable speed motors and drives on pumps and fans that consume less energy than their constant speed counterpart
- Converting air and water distribution systems to variable volume (this reduces energy consumption compared to a constant volume arrangement)
- Installing renewable energy technologies
- Installing low-flow and flow-control devices to reduce the use of water
- Installing modern digital control systems to more accurately monitor the operation of all systems

Electrical system improvements can include:

- Converting lighting systems to high-efficiency technology
- Installing motion sensors to ensure equipment is only used when required
- Installing digital lighting control systems
- Converting electric heating to natural gas or solar power
- Installing power factor correction capacitors to reduce utility charges

## 9.8 Applying Retrofits to Rogers Hall

Rogers Hall is currently undergoing interior renovations. New partition walls are being constructed; worn flooring and aged furnishings are being replaced by new tiles and the latest laboratory casework; and original plumbing fixtures are being replaced with low-flow devices. This renovation period is the perfect time to consider and apply retrofit components.

After extensive research and reference to the construction drawings, possible electrical retrofit options became apparent. Converting to high-efficiency lighting components would be the most feasible option which could save a considerable amount of energy and lead to cost savings in the future. An analysis of the existing lighting system versus a high-efficiency alternative is provided below. Other alternatives include installing lighting control systems or motion sensors. These two

options will be evaluated and discussed later in my electrical breadth section. This analysis focuses on the significant energy and operation cost savings in just one retrofit element.

34WF34T12 fluorescent lamps are the most common lamps used in the existing Rogers Hall. This analysis proposes replacing the current F34T12 lamps with 32WF32T8 lamps because they are significantly more efficient in light output and energy consumption. The T8 lamp and high-frequency electronic ballast combination provides a rich source of lighting that delivers a high lumen package, a high color rendering index rating and exceptional energy efficiency.

#### *Existing T12 lamps and T8 Lamp Retrofits*

For years, commercial lighting has been dominated by the common T12 (1.5-inch diameter) cool-white fluorescent lamps and transformer-type magnetic ballasts. Unfortunately, time and experience revealed that technical problems between this lamp-ballast combination resulted in reduced lamp life, poor color rendering, and low light output. High efficiency T8 (1 inch) lamps teamed up with electronic ballasts are now setting new standards for low power consumption, low life-cycle cost and illumination that more closely resembles natural light.

The combination of the 32WT8 lamp with the high-frequency electronic ballast produces a fluorescent lamp that is energy efficient, offers a high lumen and color rendering index package, and has very attractive economics. The following T8 features and operating characteristics show the reasons for the lamp's superior performance.

- Energy savings** (up to 40% less energy)  
 The 32-watt T8 lamps produce similar levels of light as the older 40-watt T12 bulbs. The slim profile of the T8 lamps enables its gases and rare-earth phosphors to function more efficiently. The energy efficiency also improves because the eye can see easily with these "tri-phosphors," so less light is required to accomplish a given task than is needed with other types of lamps. The smaller diameter provides the opportunity for more light to be delivered from the fixture than is possible from a T12 lamp.



Figure 9.8.1 – T5, T8, T12 Diameter Image

- **Better color rendering**

The light from T8 lamps has a higher color rendering index (CRI) than standard T12s. The higher CRI makes objects and surfaces in a room appear more like they would under natural light.

- **More output and longer length of life**

Fluorescent T8 electronic fixtures give 40% more light output than T12 magnetic. After 10,000 hours, T8 lamps are still running at 95% light output, unlike T12s, which are at only 85%. T8s also last up to 24,000 hours versus 20,000 hours for T12s.

- **Cooler operation**

Electronic ballasts consume fewer watts than magnetic ballasts. Lighting systems generate less heat, which reduces cooling loads.

- **Quieter operation**

T8 electric ballasts are 13% quieter than traditional fluorescents.

- **Lightweight design**

Electronic ballasts are less than half the weight of magnetic ballasts. A retrofit of electronic ballasts could eliminate nearly six pounds from a typical four-lamp fixture<sup>5</sup>.

- **No flicker during start-up or operation**

Fluorescent T8 fixtures do not flicker for less eyestrain, better relaxation and concentration.

Straight T8 lamps have the same medium bi-pin bases as T12 lamps, so they can fit the same sockets. However, T8 lamps require an electronic ballast specifically designed to operate lamps at a lower current than T12 lamps. Whenever T12 lamps are replaced with T8 lamps, the ballast must also be replaced.

### *Magnetic Ballasts versus Electric Ballasts*

Rogers Hall's lighting design currently uses standard magnetic ballasts with a 0.88 ballast factor. Newer, more energy-efficient electronic ballasts should be considered. Electronic ballasts use high frequency, solid-state circuitry instead of heavy copper windings to provide the right voltage and current. As a result, electronic ballasts produce more light for each watt, run cooler, and last longer. The ballast is flicker free and produces virtually no sound.

<sup>5</sup> Lightweight Design - <http://www.mge.com/business/saving/detail/t8.htm>

After electronic ballasts were chosen, the next choice is between rapid and instant start. Instant start ballasts were selected in this analysis because they are more economical. Instant start ballasts can be 5 to 10 percent less expensive than the rapid start ballasts which can become a significant difference with the number of ballasts required to operate an entire laboratory facility. The instant start ballasts do not require constant current to maintain lamp operation as is with rapid start ballasts. This provides greater energy savings of about two watts per lamp. Two watts per lamp multiplied by thousands of lamps can have a significant impact on energy use.

#### QUICKTRONIC® High Efficiency Type CC & Lamp Striation Control (LSC) Models



Figure 9.8.2<sup>6</sup> – Ballast Image

#### SYLVANIA QUICKTRONIC® High Efficiency energy saving electronic T8 ballasts offer several advantages:

- 30-60% energy savings when compared to F34T12 magnetically ballasted systems
- SUPERSAVINGS
- Multiple ballast factor options: Low, Normal & High
- Available in:
  - Instant Start and PROStart® (Programmed Rapid Start)
  - Bi-level QUICKSTEP® and POWERSENSE® Dimming models
- Save energy (less power) thus more beneficial to the environment by helping to reduce pollution and greenhouse gas emissions
- Excellent for the most stringent energy codes & sustainability projects

Figure 9.8.3<sup>6</sup> – QUICKTRONIC Advantages

<sup>6</sup> Figures 9.8.2 and 9.8.3 taken from Sylvania's Ballast Technology Applications & Specification Guide <http://content.sylvania.com/app/display.aspx?docid=003699308>

## 9.9 Energy Comparison

A comparison of energy usage for the existing F34T12 and F32T8 is shown in the chart below. By replacing the T12 lamp-magnetic ballast combination with T8s and electronic ballasts, not only does the amount of energy being used decrease but the number of effective lumens actually increases. The 94.3 lumens per watt ratio for the T8 lamps is significantly greater than the T12 lamp's 63.0 lumens per watt. As we will see later, the decrease in energy usage will result in considerable electrical savings. Information regarding the lamps and ballasts of each were taken from the Sylvania product catalog. Please refer to **Appendix E** for the product data sheets used.

	Existing <b>34WF34T12</b> W/ Magnetic Ballast (0.88 Ballast Factor)	Proposed <b>32WF32T8</b> W/ Electronic Ballast (0.88 Ballast Factor)
Rated Lamp Wattage	34 W	<b>32 W</b>
Actual Energy Use	37 W	<b>28 W</b>
Effective Lumens*	2,332	<b>2,640</b>
Lumens per Watt	63.0 L/W	<b>94.3 L/W</b>
Rated Life	20,000 hrs.	<b>24,000 hrs.</b>

Table 9.9.1 – T8 and T12 Energy Comparison

\*Effective lumens are determined by multiplying the rated lumens of a lamp by the ballast factor.

The 34WF34T12 lamp has an initial rating of about 2,650 lumens. The magnetic core and coil energy-efficient ballast operating this lamp has a ballast factor of 0.88:

$$0.88 * 2,650 \text{ lumens} = 2,332 \text{ lumens.}$$

This equation tells the designer that the lamp-ballast combination will produce about 2,332 lumens. Rule of thumb indicates that only about 50 percent of this light will reach the work surface.

The 32WF32T8 lamp has an initial rating of about 3,000 lumens. The electronic ballast has a ballast factor of 88 percent:

$$0.88 * 3,000 \text{ lumens} = 2,640 \text{ lumens.}$$

### 9.10 Energy Cost Comparison

Fixture Type	Number of Fixtures	Watts/Fixture	Operation Hours/Day	Electric Rate (cents/kWh)	Energy Cost (\$/year)
4' 2 Lamp 34WF34T12 w/magnetic ballast (0.88 ballast factor)	284	82	12	7.31	\$7,456.31
4' 2 Lamp F32T8 w/electric ballast (0.88 ballast factor)	284	55	12	7.31	\$5,001.18
					<b>\$2,455.13</b>
4' 4 Lamp 34WF34T12 w/magnetic ballast (0.88 ballast factor)	361	164	12	7.31	\$18,955.82
4' 4 Lamp F32T8 w/electric ballast (0.88 ballast factor)	361	107	12	7.31	\$12,367.52
					<b>\$6,588.30</b>
<b>Savings Per Year</b>					<b>\$9,043.43</b>

Table 9.10.1 – T8 and T12 Energy Cost Comparison

Rogers Hall contains 284 4' 2 lamp fixtures and 361 4' 4 lamp fixtures. Converting from F32T12 lamps to F32T8s would conserve **28,245 watts** of electricity a year, assuming these lights are used 12 hours a day and 365 days a year. Using Virginia's 2008 average retail price of electricity of 7.31 cents per kilowatt-hour, the College of William and Mary would save over **\$9,000** a year. This results in a **34.2%** annual savings. A breakdown of the data used is shown above.

### 9.11 Construction Cost and Schedule Considerations

#### Cost

There is no doubt that retrofitting would save energy and therefore reduce the electrical operating costs for the owner. However, the savings would initially be offset by the first cost for purchasing and installing the new devices. The question is how long will it take before the system pays for itself in energy savings.

Lamps	Quantity	Case Size	Cases Needed	Cost/Case	Cost
F032T8/800XP	2012	30	74*	\$240.60	\$17,804.00
<b>Ballasts</b>					
QHE 2X32T8/UNV ISN-SC	284	10	29	\$191.70	\$5,559.30
QHE 4X32T8/UNV ISN-SC	361	10	37	\$302.80	\$11,203.60
<b>Total Cost</b>					<b>\$34,567.30</b>


Table 9.11.1 – Construction Cost Comparison

\*Specifications call for an additional 10% of lamps for storage.

The chart on the previous page shows the initial cost breakdown for the new lamps and ballasts. Sylvania's 32 watt 4' T8 800 Series Extended Performance fluorescent light bulbs come in cases of 30 at \$240.60 per case. 74 cases would be needed to supply Rogers Hall with all new lamps and have an additional 10% left for storage. The 2 and 4 lamp QHE Instant Start ballasts come in packs of 10 and cost \$191.70 and \$302.80 per pack respectively. This would come to a total initial cost of **\$34,567.30** for the new materials.

Unlike lamp replacement, which may be done by a custodian, ballast replacement usually requires use of a licensed electrician to avoid problems and liabilities. RS Means 2009 was referenced to determine the labor cost of replacing the ballasts. Using the unit labor cost of \$32.63 (location factor included), the cost of installing 645 ballasts would be **\$21,044.13**.

Based on the figures above, the new lighting devices and installation would cost a total of **\$55,612**. With energy savings of \$9,043 a year, it would take **6.15** years to pay itself off. Not only would the new lamps produce annual operation savings, they cost less to maintain and are replaced less frequently.



The figure to the left shows the F32T8 fluorescent lamp cost distribution based on a 2 lamp fixture operating at 12 hours per day. Even though the percent allocation between initial installation cost, maintenance cost, and energy cost may vary depending on operating conditions, the initial cost of the system is small compared to its lifetime operating cost.

Chart 9.11.1<sup>7</sup> – T8 Lamp Cost Allocation

### Schedule

Although the installation of the new lamps and ballasts would take some time, it would have very little, if any, impact on the construction schedule. RS Means 2009 was used to determine the labor hours required to replace the ballasts. One electrician can change 10 indoor fluorescent ballasts in one, eight hour work day. It would take **13 work days** for a **crew of five** labors to replace the 645 ballasts in Rogers Hall. The reference page from RS Means can be found in **Appendix C**. Most, if not all, this work could be done simultaneously while other construction processes and building finishes are taking place.

<sup>7</sup> Chart 9.11.1 found at [http://www.heco.com/vcmcontent/Energy%20Services/Powerlines/pl\\_2006\\_summer.pdf](http://www.heco.com/vcmcontent/Energy%20Services/Powerlines/pl_2006_summer.pdf)



## 9.12 Conclusions and Recommendations

While conducting research for this analysis, every source concurred that proper retrofitting results in significant savings overtime. When the lighting system upgrade was applied to Rogers Hall, the resulting cost studies verified just that. Even only one retrofit would result in considerable energy and operation cost savings. Based on this analysis, I would strongly recommend replacing the F34T12 lamps with F32T8s saving money for the owner.

Initially, the College of William and Mary would have to invest **\$34,567.30** for the new bulbs and ballasts plus an additional **\$21,044.13** for their installation. However, changing the bulbs to T8s would conserve **28,245 watts** of electricity a year and result in the college saving over **\$9,000** a year, an annual savings of **34.2%** compared to the existing lamps. The new system would pay for itself after **6.15 years**.

Not only would these new lamps result in future savings for the owner, they would be more consistent with the lamps used in the new ISC addition. These lamps also provide better quality characteristics, such as improved color, which would benefit the facility occupants.

	Existing <b>34WF34T12</b> W/ Magnetic Ballast (0.88 Ballast Factor)	Proposed <b>32WF32T8</b> W/ Electronic Ballast (0.88 Ballast Factor)
Initial Material Cost and Installation	<b>\$0</b>	\$55,612
Actual Energy Use	37 W	<b>28 W</b>
Annual Energy Costs	\$26,412.13	<b>\$17,368.70</b>
Effective Lumens	2,332	<b>2,640</b>
Rated Life	20,000 hrs.	<b>24,000 hrs.</b>

Table 9.12.1 – Lamp Cost and Energy Comparison

The owner representative at the College of William may be hesitant to pay the extra amount upfront because of additional funding that would be needed. In order to help persuade the owner, the following is a list of benefits that the lighting retrofit would offer the Rogers Hall building owner and occupants:

- **Energy savings**

As seen previously, by upgrading lighting components to more efficient and advanced technologies energy consumption is reduced and result in lower energy bills.

- **Improved quality**

New technologies provide better quality characteristics, such as improved color, and add increased reliability to the systems so fewer short term quality issues arise.

- **Reduced maintenance and labor costs**

Improvements in lighting technologies have led to increased lifetimes for components that will result in fewer failures and lengthen the time between maintenance activities.

- **Building Consistency**

Rogers Hall's addition, the Integrated Science Center, is currently designed to install T8 lamps. Changing the bulbs in Rogers Hall to T8s would provide more consistent lighting characteristics and better flow between buildings.

- **Pollution reduction**

By consuming less electricity, the facility will help reduce the demand and associated harmful emissions, such as CO<sub>2</sub> and other greenhouse gases, from off-site power generation.

- **Green Power systems**

Using more efficient lighting will require less power to be generated, stored, and used to accomplish the same tasks, making alternative power systems more economically and technically feasible.

## 10| Implementation of Daylighting

*AE Lighting & Electrical Breadth*

### 10.1 Introduction

Through the addition of the Integrated Science Center and the renovation of Rogers Hall, the trustees of the College of William and Mary hope the university becomes a national leader in research and teaching facilities in the departments of Chemistry, Biology, and Psychology. Therefore, these buildings should include features that promote a better learning environment such as introducing natural light inside. Studies conducted in schools show that daylighting helps to increase productivity and enhance performance. According to the Laboratories for the 21st Century (Labs 21), “Daylighting helps to provide an interior work environment that stimulates creativity and discovery.” And discovery is what research laboratories are all about.

The Integrated Science Center is designed with three large windows in every laboratory of the building that will provide a sufficient amount of natural light to satisfy daylighting practices. However, this natural light will not result in any energy savings as long as the lights are still turned on. By adding daylighting photosensors that trigger some of the lights to shut off in the labs, the penetrating natural light could provide increased benefits to the occupants as well as reduced energy consumption.

### 10.2 Problem Statement

The current lighting system assumes that lights are on continuously throughout the school day. This is costly and reduces the benefits that natural light is capable of providing. The electric lighting also decreases the quality and benefits of penetrating natural light. Because students’ performance improves in areas of higher levels of natural light, daylighting practices should be implemented in the laboratories.

### 10.3 Goal

The purpose of this study is to coordinate the daylighting design with the electric lighting design so they work together as one system. This requires an analysis of the current laboratory layout, lighting configuration, and amount of daylight present. If the current design does not utilize daylighting efficiently, alternative techniques and designs will be implemented and reassessed. This analysis complements the previous retrofit study and will include the possible energy and cost savings as well as the construction impacts.

## 10.4 Methodology

1. Explore possible daylighting designs and techniques for laboratories.
2. Research the benefits of natural light to building occupants
3. Inquire industry members or meet with AE faculty to obtain advice and guidance.
4. Use computer programs to run daylighting calculations on current room design.
5. Redesign the room configuration and lighting layout based on the program analysis.
6. Run daylight calculations for new room layout.
7. Compare results from lighting tests and determine if the amount of daylighting is sufficient to be beneficial to building occupants.
8. Determine any energy savings provided by using daylighting features.
9. Determine the cost and schedule impacts of implementing new techniques.
10. Come to a conclusion and make recommendation whether the installation of daylighting features is a worthwhile investment.

## 10.5 Tools and Resources

1. Integrated Science Center construction documents
2. Penn State AE faculty and 5th year lighting students
3. Internet articles and online sources on daylighting practices and benefits
4. AutoCAD 2008
5. AGI32 Lighting and Electrical computer software
6. USGBC's LEED for New Construction v2.2

## 10.6 Expectations

Current laboratory configurations are assumed to provide an inadequate amount of daylighting features which means that in the benefits of natural light are not being enjoyed. By incorporating natural light enhancing techniques, such as occupancy or light level sensors, energy consumption will be greatly reduced and it will produce a better environment for the success of the building occupants. After improved coordination between the daylighting design and the electric lighting design is achieved, it will be a worthwhile investment for the owner.

## 10.7 Research on Daylighting

Daylighting is the controlled entry of natural light into a building. The use of daylighting allows photosensors to dim or turn off a building's electric lights to save energy. Daylighting not only saves energy, it increases productivity and generally improves occupant satisfaction and comfort. Science can improve our lives dramatically; therefore, it important to provide scientists and researchers with laboratories that foster innovation and enhance performance.

Providing a pleasant work environment, such as access to natural light and exterior views in labs is a good way to recruit and retain top scientists, technicians, and other key research personnel. Since the goal of the College of William and Mary is to attract the best professors and students in the departments of chemistry, biology, and psychology, incorporating daylighting techniques into the Integrated Science Center addition could be of interest to the owner. In addition, the owner will reap the energy cost savings each month from the reduced electrical load. Daylighting saves energy only when the lights are dimmed or shut off; therefore, photosensor controls are needed to ensure this.

## 10.8 Light Level and Occupancy Sensors

Energy demands and heating loads are reduced when lights are turned off or dimmed. Therefore, it would be best to have controls that trigger the lights to dim or turn off based on a predetermined illuminance. There are two major control systems that can be used to complement daylighting: light level and occupancy sensors.

### *Light Level Sensors*

Light level sensors are installed to trigger certain lamps to dim or turn off when a programmed illuminance level is met within a space. These sensors are equipped photoelectric “eye” that measures the illumination. To prevent the lights from turning off when there is a momentary cloud cover, the sensors contain preset delay timers. Fluorescent lamps, such as the ones found in the Integrated Science Center, are the most common lamps used for daylighting practices. In order to approximate the operational cost savings of implementing light level sensors, sensors that switch lights off, rather than dimmed, are used. Switching lights off is also more economical because dimming requires special dimming ballasts which cost more than the on-off ballasts already installed in the labs.

### *Occupancy Sensors*

Occupancy sensors use infrared technology to detect when a space is occupied. The lights are signaled to stay on by an individual’s heat or movement. Lights will automatically be turned off once a preset amount time passes without detection of any motion. These sensor controls are practical for college campuses. Even during the day, not all the classrooms in a building are being used and typically the lights are left on. This has the potential to build up electrical costs especially with the number of buildings on a college campus. An analysis of the amount of energy occupancy sensors would save would be difficult for the Integrated Science Center because the room usage is unknown.

## 10.9 Choosing a Light Level Sensor

Wattstopper.com was used to select the daylight controlling device for the Integrated Science Center. The following decisions were necessary to determine the proper controlling mechanism:

- *Standalone or system control*

The standalone system was chosen because it controls a single group of lights. For the ISC facility, the lights closest to the windows are the one single group to be controlled. The standalone system is also easy to install and low in cost.

- *Single or multiple control zones*

A single control zone was selected because only one zone is being controlled per sensor. This is also the most common for standalone systems.

- *Open or closed loop technology*

The closed loop technology was selected because it provides on-off switching and measures both daylight and electric levels in the room. The closed loop allows for manual override incase extra lighting is needed.

- *Room location*

Sensors would be placed on the ceiling near the window and pointed toward workspace areas.

Based on the above process, the Light Saver LS-101 Daylighting Controller was selected for the ISC laboratories. Please refer to **Appendix F** for data information on the Light Saver LS-101.

→ Daylighting Sensors & Controls → Stand-alone/Single Channel

### LightSaver® LS-101 Daylighting Controller



Watt Stopper/Legrand's LS-101 Daylighting Controller is a single zone, ON/OFF device that turns lighting off automatically when sufficient natural daylight is present.

Figure 10.9.1<sup>8</sup> – LightSaver LS-101 Daylighting Controller

<sup>8</sup> Figure 10.9.1 taken from Wattstopper.com's product brochure at <http://wattstopper.com/products/details.html?id=180&category=29&type=Commercial>

## 10.10 Daylighting Technical Write-up and Calculations

In order to perform a daylighting study on the designed and proposed lighting layouts, AutoCAD 2009 was used to create a basic three dimensional model of a typical laboratory space found in the Integrated Science Center. The model was then imported into AGi32, a lighting design software, to determine the illuminance levels from the natural light.

Below is a description of room and lighting details found in each laboratory space according to the construction documents and specifications.

- **Room Size:**

Each laboratory space is 31'-0" x 29'-0"

- **Ceiling Height:**

The first 8'-6" closest to the windows has a ceiling height of 11'-0". The rest of the room has a ceiling height of 10'-0". The difference in height is due to the fact that space near the windows was not needed for electrical and mechanical equipment so the added floor-to-ceiling height provides an opportunity for taller windows. The higher daylight can enter a space, the farther back it can reach.

- **Windows:**

Three (3) 7'-0" x 4'-0" double-pane windows are located in each room. A transparency of 0.8 is used in AGi32.

- **Light Fixtures:**

A laboratory contains 15 cable-mounted light fixtures each requiring two (2) T8 lamps. There are two switches per room. One switch turns on one lamp in the 12 fixtures furthest from the windows. The other turns on all the lamps for the 3 fixtures closest to the window plus the remaining 12 lamps in the 12 fixtures furthest from the windows. See Figure 10.10.1 for the typical lighting plan.




Figure 10.10.1 – Typical Lab Lighting Plan





Figure 10.10.2 – 3D Model of Typ. Lab Space

The way the space's lighting fixtures are laid out and wired, using a light level sensor would provide no benefit to the owner. The lights closest to the windows cannot be shut off without turning off lamps in the further fixtures. This design does not take advantage of natural lighting which would result in energy and cost savings. To incorporate energy savings through daylighting, the following lighting arrangement is proposed.



As seen in the figure to the left, the number of fixtures and lamps used remains the same as the designed plan. The proposed layout uses three switches instead of the original two. The row of lights closest to the window would automatically turn off when sufficient levels of illuminance are met. As light penetrates further into the space, the second row of fixtures would turn off and so on. For a room this size, two lighting sensors would be needed per lab.

10.10.3 – Proposed Lab Lighting Plan

To estimate the electrical cost savings provided by the implementation of light level sensors, AGi32 was used to determine the illuminance levels on a 3'-0" work plane. Analyses were run on the east façade windows every hour from 7 AM to 6 PM (when daylight is present). No lights were on so natural was the only consideration.

The following assumptions were made for the AGi32 calculations.

- Reflectance:
  - Ceilings: 0.8
  - Walls: 0.5
  - Floor: 0.2
- Lab station height (work plane): 3'-0"
- Goal illuminance: 80 footcandles for a laboratory (specifications)
- Sky type: cloudy (conservative model)
- Date: September 22, 2009 – The autumnal equinox was used as an average amount of daylight per day over the course of a year.





Figure 10.10.4 to the left is an example of the AGi32 results for September 22,2009 at 1 PM. The area circled in red meets the 80 footcandle illuminance requirements for a laboratory space. The light level sensors would detect this and automatically turn off the first row of fixtures closest to the window. The areas in blue do not meet the illuminance requirements so the lights will remain on. Please refer to **Appendix G** for all other times on September 22, 2009. The results from AGi32 are in the table below.

Figure 10.10.4 – AGi32 Illuminance Levels at 1 PM on September 22, 2009

	Number of Fixtures On Proposed - Sensors	Number of Fixtures On Designed – No Sensors	Difference
<b>7 AM</b>	15	15	0
<b>8 AM</b>	10	15	-5
<b>9 AM</b>	5	15	-10
<b>10 AM</b>	5	15	-10
<b>11 AM</b>	10	15	-5
<b>12 PM</b>	10	15	-5
<b>1PM</b>	10	15	-5
<b>2 PM</b>	10	15	-5
<b>3 PM</b>	15	15	0
<b>4 PM</b>	15	15	0
<b>5 PM</b>	15	15	0
<b>6 PM</b>	15	15	0

Table 10.10.1 – Number of Fixtures On by Hour for September 22, 2009 for Designed and Proposed Layouts

Each fixture contains two 32WF32T8 lamps and one instant-start, electronic ballast. The actual energy use per fixture is 55W. Please refer to **Appendix E** for the product data sheets of these items.

## 10.11 Construction Cost and Schedule Considerations

### Cost

The proposed lighting layout did not change the number or type of lighting fixtures. Therefore, the only additional cost to the owner would be the light level sensors. A sensor could cost between \$100 and \$200. The rooms are also rather long so two sensors would be needed per room. A total of 66 light level sensors would be needed to effectively equip the Integrated Science Center. This would be at least an additional \$6,600 plus installation costs. The sensors would pay back themselves in 5.3 years.

### Schedule

The photosensors would not cause any delay or extra time in the schedule. They are readily available through a manufacturer and therefore not a long lead item. The design phase would be heavily impacted by daylighting techniques. If incorporating daylighting is of interest to the owner, it should be addressed in the initial schematic phase of the facility. Architects and lighting designers need to work together to create a system that works both aesthetically and electrically.

## 10.12 Conclusion and Recommendations

Assuming each fixture remains on the full hour and that the light level sensors are not manually overdriven, the electricity savings provided by use of daylighting can be estimated. The following table compares the energy consumption and operation costs between a laboratory with light level sensors and a lab without sensors.

	<b>Proposed: sensors</b>	<b>Designed: no sensors</b>	<b>Difference</b>
Number of Fixtures On/day	135	180	<b>-45</b>
Actual Energy Use/Fixture	55 W	55 W	-
Total Wattage/Room	7,425 W	9,900 W	<b>-2,475 W</b>
Cents /Kw	7.31 <sup>9</sup>	7.31 <sup>9</sup>	-
Energy Cost/Room	\$0.54	\$0.72	<b>-\$0.18</b>
Number of Rooms	33	33	-
Electric Cost/day	\$17.91	\$23.88	<b>-\$5.97</b>
Average Number of Partly Cloudy or Nicer Days/year	209 <sup>10</sup>	209 <sup>10</sup>	-
<b>Estimated Annual Electricity Costs</b>	<b>\$3,743.47</b>	<b>\$4,991.29</b>	<b>-\$1,247.82</b>

Table 10.10.2 – Designed and Proposed Layout Energy and Cost Comparison

<sup>9</sup>Electricity costs for Virginia -[http://www.eia.doe.gov/cneaf/electricity/epm/table5\\_6\\_a.html](http://www.eia.doe.gov/cneaf/electricity/epm/table5_6_a.html)

<sup>10</sup>Williamsburg's weather (annual average) -

<http://www.weather.com/weather/wxclimatology/monthly/graph/23185>

Using the illumination data from AGi32, the amount of fixtures that would automatically turn off due to daylighting can be found for each hour natural light is present. This was multiplied by the actual energy use per fixture and the number of laboratory spaces in the ISC to get the daily energy savings. When lights are remained on during daylight hours (no sensors) 326,700 W of energy are consumed in the laboratories. If daylight sensors are used, only 245,025 W of electricity is used, a **savings of 81,675 W**. This is a **25% energy reduction** for the lab spaces.

When running the AGi32 analysis, cloudy skies were assumed to provide a conservative model. According to weather.com, the average number of partly cloudy days (or nicer) in Williamsburg, Virginia is 209 days per year. This was used to make an approximate estimate of annual electrical savings. The incorporation of daylighting to the lighting system through the use of light level sensors would reduce the annual electricity costs by approximately **\$1,247.82**.

Based on the above analysis, I would advise the owner to consider the installation of light level sensors to encourage “green” construction on the College of William and Mary campus. The designed windows are large enough to implement this daylight technique and would result in significant electrical cost savings. The estimated annual savings calculated above was based off a few assumptions so I would not be surprised if actual savings would be greater than \$1,250 a year. For additional savings, dimming ballasts or occupancy sensors could also be considered.

# 11 | Solar Heat Gain and Cooling Load Reduction

*AE Mechanical Breadth*

## 11.1 Introduction

The previous analysis described the many benefits of using natural lighting in indoor spaces. In addition to energy savings, daylit spaces have been associated with positive worker benefits such as increased productivity, reduced levels of stress, and better worker attitude. The large windows used in the Integrated Science Center facility provide improved daylighting to the spacious laboratories. In Rogers Hall however, these windows are not lighting large laboratory areas but small office spaces. During the daytime, solar radiation through the windows causes significant heat gains in these smaller spaces resulting in increased cooling loads. By installing window shading devices, solar heat gains are mitigated while enough daylight is transmitted to reduce the need for artificial lighting and its resulting cooling loads.

Exterior overhangs serve as shading devices, preventing solar gain from entering the building which results in reduced cooling loads. A properly sized window overhang on the south-facing windows can reduce energy use by 6%<sup>11</sup>. They also block the majority of direct sunlight, providing shade underneath the window and provide a better view.

## 11.2 Problem Statement

The small offices facing the south each contain one large window which results in significant heat gain and glare caused by sunlight streaming into the building. Solar energy passes through the glass, is absorbed by materials within the room, and then transformed into heat that must be removed by the air conditioner. Keeping unwanted heat out is not only a comfort issue but also an economic one. When heat from the sun is effectively eliminated or controlled through the use of shading strategies, the cooling load on the mechanical system is reduced.

## 11.3 Goal

The purpose of this study is to provide a shading strategy on the south facing windows to reduce the direct solar radiation into the offices and thus decreasing the cooling loads for the building. This requires an analysis of the current solar penetration through the windows as well as the solar penetration after a shading device is applied. Cooling loads for both options will be calculated using the CLTD/SCL/CLF method as described in the 1997 ASHRAE Handbook of Fundamentals. All other cooling factors, other than solar load, will remain constant. This analysis complements the previous studies and will include the possible energy and cost savings as well as the construction impacts.

<sup>11</sup> Overhangs - <http://greenbuildings.santa-monica.org/Content/envelope/envshading.html>

## 11.4 Methodology

1. Explore possible techniques to reduce cooling loads
2. Research the benefits of reducing the amount of direct sunlight and its effect on cooling loads
3. Talk to faculty and industry members for advice and guidance on the subject
4. Calculate solar angles for Williamsburg, Virginia
5. Use computer programs to calculate the amount of daylight into the room with and without a shading device
6. Compare the effects of shading devices on the amount of solar penetration through the windows
7. Calculate the differences in cooling loads
8. Determine any energy savings provided by using shading features
9. Determine cost and schedule impacts of implementing the new design.
10. Come to a conclusion and make recommendation about whether the shading device would be a reasonable investment

## 11.5 Tools and Resources

1. Rogers Hall existing construction documents
2. Penn State AE faculty and 5th year mechanical students
3. Internet articles and online sources on exterior window overhangs, solar reflectance, space heat gain and cooling loads
4. AutoCAD 2008
5. AGI32 Lighting and Electrical computer software
6. 1997 and 2001 ASHRAE Handbook of Fundamentals

## 11.6 Expectations

The designed window configuration results in large amounts of direct sunlight to enter small rooms resulting in considerable heat gain, especially during the summer months. By incorporating shading techniques to the south facade, solar gain and glare will be greatly reduced, substantially lowering the building's energy needs. This would result in operational cost savings as well as possibly reducing equipment costs (due to smaller size equipment being needed). Shading would also provide an improved environment for the building occupants by reducing glare and increasing comfort. Although the cooling loads would be reduced, I do not believe they will be significant enough to be considered by the owner. The new shading devices would not fit in with the standard W&M architecture of the adjacent buildings, a factor in design.

## 11.7 Research on Solar Heat Gain and Cooling Loads

### Heat Gain

Heat gain is the rate at which energy is transferred to or is generated within a space. It usually occurs in the following forms:

1. Solar radiation through openings
2. Heat conduction through exterior walls, roofs, internal partitions, ceilings, and floors
3. Heat generated within the space by occupants, lights, appliances, and equipment
4. Ventilation (outside air) and infiltration air

This analysis will focus on the transmission of solar radiation through fenestration. The total heat admission through glass is

$$\text{Total heat gain} = \text{Solar heat gain} + \text{Conduction heat gain}^{12}$$




Figure 11.7.1<sup>10</sup> – Solar Radiation through Fenestration

<sup>12</sup> Solar radiation through fenestration - [http://www.ninfee.net/UserFiles/File/ZHENQIAN\\_Space%20Heat%20Load%20and%20Cooling%20Load.pdf](http://www.ninfee.net/UserFiles/File/ZHENQIAN_Space%20Heat%20Load%20and%20Cooling%20Load.pdf)

## Cooling Loads

Cooling load is a rate at which energy must be removed from a space to maintain the temperature and humidity at the design values. The total building cooling load consists of heat transferred through the building envelope (windows, walls, roof, doors etc.) and heat generated by occupants, equipment, and lights.




Figure 11.7.1<sup>13</sup> - Sources of Cooling Loads

The cooling load will generally differ from the heat gain because most of the radiation heat is first absorbed by internal surfaces. Due to the thermal capacity of the roof, floor, walls, etc. their temperature increases slowly due to the absorption of radiant heat. This produces a time lag and the effect of radiation will be felt even when the source of radiation (the sun) is removed.

### The CLTD/SCL/CLF Method

(Cooling Load Temperature Difference/Solar Cooling Load/Cooling Load Factor Method)

As mentioned before, the heat gain to the building is not converted to cooling load instantaneously. The CLTD/SCL/CLF method is a simplified way to calculate cooling loads manually. The CLTD accounts for the lag in heat transfer through the wall or roof. SCL accounts for the variation of the solar heat gain with time, the massiveness of the structure, and the geographical location. The CLF accounts for the thermal response of the space to various internal gains.

<sup>13</sup> Sources of Cooling Loads -

<http://me.lsu.edu/~meniki/me4643/downloads/COOLING%20LOAD%20%20%20LECTURE%20OUTLINE.pdf>

<sup>14</sup> Solar heat gain factors -

[http://books.google.com/books?id=OpD226SXKisC&pg=PT1373&lpg=PT1373&dq=solar+heat+gain+factor+for+shaded+window&source=bl&ots=lavdV37qYq&sig=e0GO8hu\\_D0UVReFmfjWKenJl-A&hl=en&ei=OIDYSZDeMKDUIQfi7NzVDA&sa=X&oi=book\\_result&ct=result&resnum=2#PPT1373,M1](http://books.google.com/books?id=OpD226SXKisC&pg=PT1373&lpg=PT1373&dq=solar+heat+gain+factor+for+shaded+window&source=bl&ots=lavdV37qYq&sig=e0GO8hu_D0UVReFmfjWKenJl-A&hl=en&ei=OIDYSZDeMKDUIQfi7NzVDA&sa=X&oi=book_result&ct=result&resnum=2#PPT1373,M1)

Focusing on the solar heat gain portion, the window cooling load has two components: conductive and solar.

$$\text{Conductive: } q_{\text{win (con)}} = U \cdot A \cdot \text{CLTD}_{\text{win c}}^{15}$$

$$\text{Solar: } q_{\text{win (sol)}} = A \cdot (\text{SC}) \cdot (\text{SCL})^{15}$$

Conductive:

- Step 1) Determine U value  
 2) Select  $\text{CLTD}_{\text{win}}$  from ASHRAE Table 34  
 3) Corrections

$$\text{CLTD}_{\text{win c}} = [\text{CLTD}_{\text{win}} + (78 - T_R) + (T_M - 85)]$$

$(78 - T_R)$  = indoor design temperature correction

$(T_M - 85)$  = outdoor design temperature correction

Mean Outdoor Temp ( $T_m$ ) =  $T_{\text{MAX}} - (\text{Daily range}) / 2$

$T_{\text{MAX}}$  = Maximum outdoor temperature

- 4) Determine area from architectural plans  
 5)  $q_{\text{win (con)}} = U \cdot A \cdot \text{CLTD}_{\text{win c}}$

Solar:

- Step 1) Determine shading coefficient (SC) from ASHRAE Tables 15-21 Chapter 29  
 2) Determine zone type from ASHRAE Tables 35B  
 3) Determine solar cooling load (SCL) from ASHRAE Table 36  
 4) Determine area from architectural plans  
 5)  $q_{\text{win (sol)}} = A \cdot (\text{SC}) \cdot (\text{SCL})$

Non-uniform exterior shading, caused by roof overhangs or side fins, must be handled differently. Separate calculations for the externally shaded and unshaded areas are required. The SCL for the north orientation is a close approximation for the shaded glass area at latitudes greater than 24°. Williamsburg falls into this category; therefore, the northern SCL will be used for the shaded areas. The cooling load equations for a window with an overhang are as follows.

$$q = q_{\text{unsh}} + q_{\text{sh}}$$

$$q = (A_s \times \text{SHGF} \times \text{SC}) + (A_{\text{sh}} \times \text{SHGF}_{\text{sh}} \times \text{SC})^{14}$$

$A_s, A_{\text{sh}}$  = sunlit and shaded areas of glass ( $\text{ft}^2$ )

<sup>15</sup> Conductive and solar cooling load equations - <http://me.lsu.edu/~meniki/me4643/downloads/COOLING%20LOAD%20%20%20LECTURE%20OUTLINE.pdf>



## 11.8 Shading Devices

There are two types of shading strategies: indoor shading devices and outdoor shading devices. Commonly used internal shading techniques include blinds, roller shades, and drapes. External shading devices incorporate the installing overhangs, side fins, louvers, and patten grilles to the roof or façade. All strategies reduce the sunlit area of the window glass effectively and therefore decrease the solar heat gain. By preventing excess solar heat gain, cooling loads are reduced cutting air conditioning bills. For this study, overhangs were selected as the means of window shading.

A well designed overhang can shade south facing windows from the high summer sun while still allowing the low winter sun to shine in and provide welcome solar heating. Overhangs are not effective on east or west facing windows because the sun is too low in the morning and afternoon for an overhang to provide any effective shade. They usually only affect the amount of direct solar radiation that strikes a surface; reflected radiation gains are not directly affected.

There are various overhang options available. They may be solid, louvered, or vegetation-supporting. Overhangs may also be fixed, operable, or removable. This study assumes a solid, fixed overhang located directly above the window. The solstices and equinoxes for Williamsburg, Virginia were calculated and the shadow lines were applied to window/wall section of a typical office space. Please see figures below. The summer solstice shadow line was located at the bottom of the sill to determine a minimum overhang length of 1' 5-1/2".




Figure 11.8.1 – Sun Angles through Typical Office Space in Rogers Hall

### Sun Angle Equations

$$\text{Angle of sun away from vertical} = 90^\circ - \text{sun angle (above horizon)}^{16}$$

Solar noon zenith angle = latitude – solar declination<sup>16</sup>

- Latitude (Williamsburg, Virginia) = 37.3
- Solar declinations
  - Summer solstice = 23.5
  - Winter solstice = -23.5
  - Equinoxes = 0

## 11.9 Cooling Load Technical Write-up and Calculations

The following are the steps and sample calculations used to determine the cooling loads for a sunlit window throughout a 24 hour day. The cooling loads for the same window but with an external shade will also be calculated. The maximum cooling loads for each situation will then be compared to determine an approximate amount of energy saved through the reduction of solar radiation through the window. This study focuses exclusively on the heat gain through fenestration. All other factors that go into the total cooling load (such as heat generated by equipment occupants, etc.) will be assumed to constant because they are not affected by the installation of an overhang and will be the same in both scenarios.

**\*\*NOTE:** The solar cooling load (SCL) is required to calculate the solar cooling load. The SCL for a particular zone is dependent on latitude, direction and internal zone parameters, which affect the absorption and release of radiant heat. *The Cooling and Heating Load Calculation Manual Second Edition* (1992) by Faye McQuiston and Jeffery Spitler contained SCL tables for three latitudes; 24, 36, and 48° north; and one month, July. According to this source, supplementary tabular data would have to be generated for other months. I was unable to find any information regarding a means to produce these tables other than using a computer software called SHADE. This affected my original goal of calculating the annual cooling load and cost savings provided by shading the south facing windows. A footnote below the SCL table says that the “data will suffice for about 2 weeks from the 21<sup>st</sup> day of the given month.”<sup>17</sup> To get a general idea of the savings provided by external shading, I will calculate the savings over this two week period.

<sup>16</sup> Sun Angle Calculations - <http://scienceworld.wolfram.com/astronomy/topics/Sun.html>

<sup>17</sup> Faye McQuiston and Jeffery Spitler's *Heating Load Calculation Manual Second Edition* (1992)

The following are weather and design conditions for Williamsburg, Virginia necessary for cooling calculations. Please refer to **Appendix H** for tables from *Heating Load Calculation Manual Second Edition* (1992) used in the CLTD/SCL/CLF Method.

<b>Weather Data and Design Conditions<sup>17</sup></b>	
City:	Williamsburg
State:	Virginia
Latitude:	37.3° N <sup>18</sup>
Longitude:	76.7° W <sup>18</sup>
Maximum Temperature:	99° F
Mean Daily Range:	20

Table 11.9.1 – Weather Data and Existing Design Conditions for Williamsburg, Virginia

### **Cooling Load for Sunlit Window (existing)**

Conductive:  $q_{win (con)} = U \cdot A \cdot CLTD_{win c}$

$U = 0.4$  for existing double pane window

$A = 30 \text{ ft}^2$  exposed glass area

$$CLTD_{win c} = [CLTD_{win} + (78 - T_R) + (T_M - 85)]$$

$CLTD_{win} = 9^\circ\text{F}$  at 12 PM (noon)

$T_R = 70^\circ\text{F}$  \*Assume room temperature of 70°F

$T_M = 99^\circ\text{F}$

$$CLTD_{win c} = [9 + (78 - 70) + (99 - 85)]$$

$$CLTD_{win c} = 31^\circ\text{F}$$

$$q_{win (con)} = (0.4) (30) (31)$$

$$q_{win (con)} = \mathbf{372 \text{ Btu/h}}$$

Solar:  $q_{win (sol)} = A \cdot (SC) \cdot (SCL)$

$A = 30 \text{ ft}^2$  exposed glass area

$SC = 0.88$  (Table 8.10<sup>17</sup>)

$SCL = 71$  (Table 8.9B<sup>17</sup>)

$$q_{win (sol)} = (30) (0.88) (71)$$

$$q_{win (sol)} = \mathbf{1874.4 \text{ Btu/h}}$$

<sup>18</sup> Latitude and longitude of Williamsburg -

<http://www.terraserver.com/view.asp?cx=347811.315165605&cy=4126237.26883864&proj=32618&mpp=0.75&pic=-1&prov=-1&stac=-1&styp=AD>

SC = 0.88 (Table 8.10<sup>17</sup>)

- Double insulating glass
- Nominal thickness of each light = 1/8
- Transmittance = 0.71

Solar Glass Zone Type = B (Table 8.8C<sup>17</sup>)

- 4 walls
- Carpet flooring
- 2.5 in. concrete floors
- With ceiling
- Gypsum partitions
- No inside shade

SCL = 71 (Table 8.9B<sup>17</sup>)

- Zone Type B
- Glass facing south
- 36 ° North Latitude
- July 21<sup>st</sup>
- 12 PM (noon)

Total heat gain = Solar heat gain + Conduction heat gain

$$q_{\text{total}} = 1874.4 + 372$$

$$q_{\text{total}} = \mathbf{2246.4 \text{ Btu/h}} \text{ * at 12 PM (noon)}$$

### ***Cooling Load for Sunlit Window with External Shade (existing)***

Conductive:  $q_{\text{win (con)}} = U \cdot A \cdot \text{CLTD}_{\text{win c}}$

U = 0.4 for existing double pane window

A = 30 ft<sup>2</sup> exposed glass area

$$\text{CLTD}_{\text{win c}} = [\text{CLTD}_{\text{win}} + (78 - T_R) + (T_M - 85)]$$

CLTD<sub>win</sub> = 9°F at 12 PM (noon)

T<sub>R</sub> = 70 °F \*Assume room temperature of 70°F

T<sub>M</sub> = 99° F

$$\text{CLTD}_{\text{win c}} = [9 + (78 - 70) + (99 - 85)]$$

$$\text{CLTD}_{\text{win c}} = 31^\circ\text{F}$$

$$q_{\text{win (con)}} = (0.4) (30) (31)$$

$$q_{\text{win (con)}} = \mathbf{372 \text{ Btu/h}}$$




Figure 9.11.1 - Sun Angle on July 21

Solar:  $q_{sol\ total} = q_{sh} + q_{unsh}$

$$q_{unsh} = A_{unsh} \cdot (SC) \cdot (SCL)_{unsh}$$

$$A_{unsh} = 12.92\text{ ft}^2\text{ exposed glass area}$$

$$SC = 0.88\text{ (Table 8.10}^{17}\text{)}$$

$$SCL = 71\text{ (Table 8.9B}^{17}\text{)} \quad \text{*south SCL}$$

$$q_{unsh} = (12.92) (0.88) (71)$$

$$q_{unsh} = \mathbf{807.2\ Btu/h}$$

$$q_{sh} = A_{sh} \cdot (SC) \cdot (SCL)_{sh}$$

$$A_{sh} = 17.08\text{ ft}^2\text{ exposed glass area}$$

$$SC = 0.88\text{ (Table 8.10}^{17}\text{)}$$

$$SCL = 38\text{ (Table 8.9B}^{17}\text{)} \quad \text{*north SCL}$$

$$q_{sh} = (17.08) (0.88) (38)$$

$$q_{sh} = \mathbf{571.2\ Btu/h}$$

$$q_{sol\ total} = q_{unsh} + q_{sh}$$

$$q_{sol\ total} = 807.2 + 571.2$$

$$q_{sol\ total} = \mathbf{1378.4\ Btu/h} \quad \text{* at 12 PM (noon)}$$

$$q_{total} = q_{sol} + q_{con}$$

$$q_{total} = 1378.4 + 372$$

$$q_{total} = \mathbf{1750.4\ Btu/h} \quad \text{* at 12 PM (noon)}$$

	$q_{conductive}$ (Btu/h)	$q_{unshaded}$ (Btu/h)	$q_{shaded}$ (Btu/h)	$q_{total}$ (Btu/h)
<b>Proposed</b> – Window with Shade Device	372.0	807.2	571.2	1750.4
<b>Designed</b> – Window without Shade Device	372.0	1874.4	0	2246.4
<b>Difference</b>	<b>0</b>	<b>-1067.2</b>	<b>571.2</b>	<b>-496.0</b>

Table 9.11.2 – Cooling Loads for July 21<sup>st</sup> at 12 PM

Table 9.11.2 compares the conductive, solar, and total cooling loads for a room with a window shading device and a room without on July 21<sup>st</sup> at 12 PM. Even though the data applies only one hour of one day, energy savings can be seen. As seen above, only the solar cooling load is affected by shading.

<sup>19</sup> Sun angle determination - [http://www.geocities.com/senol\\_gulgonul/sun/](http://www.geocities.com/senol_gulgonul/sun/)

<sup>20</sup> National Propane Gas Association's energy costs - <http://www.npga.org/i4a/pages/index.cfm?pageid=914>

## 11.10 Cooling Load Comparison

Using the same calculations as the previous section, the total cooling load for the designed and proposed systems were calculated for each hour on July 21, 2009.

	$q_{\text{total}}$ (Btu/hr) Proposed – Window with Shade Device	$q_{\text{total}}$ (Btu/hr) Designed – Window without Shade Device	Difference (Btu/hr)
1 AM	328.80	328.80	0
2 AM	316.80	316.80	0
3 AM	278.40	278.40	0
4 AM	266.40	266.40	0
5 AM	266.40	266.40	0
6 AM	424.80	424.80	0
7 AM	621.70	609.60	12.10
8 AM	828.67	818.40	10.27
9 AM	1097.97	1106.40	-8.43
10 AM	1462.97	1552.80	-89.83
11 AM	1715.48	1958.40	-242.92
12 PM	<b>1750.40</b>	2246.40	-496.10
1 PM	1598.20	<b>2308.80</b>	-710.60
2 PM	1645.95	2136.00	-490.05
3 PM	1602.22	1804.80	-202.59
4 PM	1443.45	1514.40	-70.95
5 PM	1147.20	1147.20	0
6 PM	1077.90	1041.60	36.3
7 PM	730.50	727.20	3.30
8 PM	597.97	597.60	0
9 PM	520.80	520.80	0
10 PM	444.00	444.00	0
11 PM	405.60	405.60	0
12 AM	367.20	367.20	0
Daily Total	<b>21083.67 Btu</b>	<b>23332.80 Btu</b>	<b>-2249.13 Btu</b>

Table 11.10.1 – Cooling Load Comparison for July 21, 2009

Table 11.10.1 shows the total cooling load due to fenestrations for two similar office spaces, one containing a window with a shading device and one without. As seen above, the peak cooling load for the room originally designed window without an overhang is **2308.8 Btu/hr**. For the same room but containing a window with an overhang, the peak cooling load is only **1750.4 Btu/hr**. This is a difference of **558.4 Btu/hr**. The overhang reduced the daily total cooling load by **2249.13 Btu**. This is a **9.6%** reduction.

There are 22 rooms located on the south façade. By installing an overhang, the cooling load would be reduced **49,480.86 Btu** on July 21<sup>st</sup> and **692,732.04 Btu's** of energy would be saved over two weeks. Natural gas costs approximately \$1.218/therm (100,000 Btu)<sup>20</sup>. Just looking at the 2 week period studied in this analysis, operation cost savings would be **\$8.44**.

## 11.11 Construction Cost and Schedule Considerations

### Cost

The material and labor costs are directly related to the size and type of overhang desired. The south façade faces a commonly driven road through Williamsburg so it would be of interest to the college to have the design be aesthetically pleasing. Due to the variety of overhang options, the cost is difficult to estimate. According to the Santa Monica Green Building Program, a single overhang could run approximately \$100<sup>9</sup>.

### Schedule

The installation of overhangs on the south façade of Rogers Hall would not have any impact on the overall construction schedule. There are only 22 windows and overhang construction would be occurring on the building exterior at the same time as the interior renovation. New window installation is the only activity to be coordinated with.

## 11.12 Conclusion and Recommendations

The original objective for this analysis was to calculate the annual cooling loads for the two window designs, with and without an overhang, and then determine the energy cost savings per year. Due to limited information, I was only able to determine the hourly cooling loads for July 21<sup>st</sup>. A footnote below the SCL table says that the “data will suffice for about 2 weeks from the 21<sup>st</sup> day of the given month.”<sup>15</sup> So the figures calculated in this analysis are the daily cooling loads for July 21<sup>st</sup> through August 4<sup>th</sup>. The months of July and August are usually brutally hot and humid, so the cooling loads calculated will peak at this time. Using this information, I can still draw some conclusions and make recommendations about whether installing overhangs above the south facing windows would be economically feasible.

The overhangs would, without a doubt, reduce the daily cooling loads and result in energy consumption and operational cost savings. July 21<sup>st</sup> alone results in an energy reduction of **2249.13 Btu** when a shading device is in place. Because this data is adequate through August 4, this results in a saving of **31,487.82 Btus** over a 2 weeks period. Multiplied by 12 for the total number of offices on the south façade, **377,853.84 Btu**'s of energy is saved. The overhang also results in lowering the peak cooling load. On July 21<sup>st</sup>, the largest cooling load required is **2308.8 Btu/hr** for an office containing a window without a shading device. For the same room but with a window overhang, the peak cooling load is only **1750.4 Btu/hr**, a difference of **558.4 Btu/hr**.

Based on the July 21<sup>st</sup> data, the shading device produces **9.5%** reduction in energy during the summer. This percentage may be a little high for the annual energy savings but it would be close. July 21<sup>st</sup> falls in the middle of the warmest months. Because

Williamsburg will experience warmer and cooler days than typically on July 21<sup>st</sup>, the energy reduction will balance out around this 9.5%.

Even though the overhangs would reduce the required cooling loads and decrease the cost for energy, I would not recommend them to be placed on the Rogers Hall façade. Savings are insignificant when the entire building is considered and would not be realized for many years. Just looking at the 2 week period studied in this analysis, operation cost savings for the 22 rooms on the south façade would be **\$8.44**. It would take years to pay off the initial costs of material and installation. From an architecture standpoint, the new overhangs would not fit in with the typical W&M style of the adjacent buildings. College of William and Mary campus is protecting its colonial architectural consistency. Window overhangs would not be aesthetically pleasing nor do they blend in with the other buildings on campus.




# APPENDIX A

## Site Plans

- C0.0 Existing Conditions
- C0.1 Excavation Site Plan
- C0.2 Superstructure Site Plan
- C0.3 Close-out Site Plan

# VI. SITE PLAN OF EXISTING CONDITIONS




**MEGHAN GRABER**  
 THE PENNSYLVANIA STATE UNIVERSITY  
 TECHNICAL ASSIGNMENT 1  
 SEPTEMBER 29, 2008

**THE COLLEGE OF WILLIAM AND MARY**  
**INTEGRATED SCIENCE CENTER**  
 WILLIAMSBURG, VIRGINIA

EXISTING CONDITIONS  
 SITE PLAN  
**C.00**

# SITE LAYOUT PLANNING – SUPERSTRUCTURE PHASE




**MEGHAN GRABER**  
 THE PENNSYLVANIA STATE UNIVERSITY  
 TECHNICAL ASSIGNMENT 2  
 OCTOBER 24, 2008

**THE COLLEGE OF WILLIAM AND MARY**  
**INTEGRATED SCIENCE CENTER**  
 WILLIAMSBURG, VIRGINIA

**SUPERSTRUCTURE**  
**SITE PLAN**  
**C.02**

# SITE LAYOUT PLANNING – EXCAVATION PHASE




**MEGHAN GRABER**  
 THE PENNSYLVANIA STATE UNIVERSITY  
 TECHNICAL ASSIGNMENT 2  
 OCTOBER 24, 2008

**THE COLLEGE OF WILLIAM AND MARY**  
**INTEGRATED SCIENCE CENTER**  
 WILLIAMSBURG, VIRGINIA

EXCAVATION  
 SITE PLAN  
**C.01**

**SITE LAYOUT PLANNING – CLOSEOUT PHASE**



**MEGHAN GRABER**  
 THE PENNSYLVANIA STATE UNIVERSITY  
 TECHNICAL ASSIGNMENT 2  
 OCTOBER 24, 2008

**THE COLLEGE OF WILLIAM AND MARY  
 INTEGRATED SCIENCE CENTER  
 WILLIAMSBURG, VIRGINIA**

CLOSEOUT PHASE I &  
 START-UP PHASE II  
 SITE PLAN  
**C.03**

# APPENDIX B

## Schedules

Summary Schedule  
Detailed Schedule

Activity ID	Activity Name	Original Duration	Start	Finish	
<b>Integrated Science Cent...</b>		1254	12-May-04	31-Mar-09	31-Mar-09, Integrated Scienc
01	Design Documents	284	12-May-04	23-Jun-05	Design Documents
02	Bid	58	27-Jun-05	16-Sep-05	Bid
03	Award	1	14-Oct-05	14-Oct-05	Award
04	Procurement	33	17-Oct-05	02-Dec-05	Procurement
05	Notice to Proceed	1	12-May-06	12-May-06	Notice to Proceed
06	Mobilize/Secure Site	15	15-May-06	05-Jun-06	Mobilize/Secure Site
07	Sitework	66	05-Jun-06	06-Sep-06	Sitework
08	Foundations - Phase I	168	19-Jul-06	16-Mar-07	Foundations - Phase I
09	Super Structure - Phase I	108	25-Sep-06	27-Feb-07	Super Structure - Phase I
10	Underground Utilities	60	16-Oct-06	11-Jan-07	Underground Utilities
11	Structural Steel Top Out - Phas...	1	27-Feb-07	27-Feb-07	Structural Steel Top Out - Phase I
12	Building Envelope - Phase I	65	25-Jan-07	25-Apr-07	Building Envelope - Phase I
13	Enclosure - Phase I	1	25-Apr-07	25-Apr-07	Enclosure - Phase I
14	Interior Partitions - Phase I	186	18-Dec-06	05-Sep-07	Interior Partitions - Phase I
15	Interior Finishes - Phase I	248	05-Jan-07	18-Dec-07	Interior Finishes - Phase I
16	MEP - Phase I	321	26-Dec-06	19-Mar-08	MEP - Phase I
17	Substantial Completion - Phase I	1	25-Mar-08	25-Mar-08	Substantial Completion - Phase I
18	Commissioning - Phase I	108	26-Mar-08	22-Aug-08	Commissioning - Phase I
19	Demolition - Phase II	30	02-Jun-08	11-Jul-08	Demolition - Phase II
20	Abatement - Phase II	10	16-Jun-08	27-Jun-08	Abatement - Phase II
21	MEP - Phase II	98	16-Jul-08	28-Nov-08	MEP - Phase II
22	Interior Partitions - Phase II	64	08-Aug-08	05-Nov-08	Interior Partitions - Phase II
23	Building Envelope - Phase II	10	25-Aug-08	05-Sep-08	Building Envelope - Phase II
24	Enclosure - Phas II	1	05-Sep-08	05-Sep-08	Enclosure - Phas II
25	Interior Finishes - Phase II	68	29-Sep-08	31-Dec-08	Interior Finishes - Phase II
26	Substantial Completion - Phase II	1	01-Jan-09	01-Jan-09	Substantial Completion - Phase II
27	Demobilization	22	01-Jan-09	30-Jan-09	Demobilization
28	Commissioning - Phase II	49	05-Jan-09	12-Mar-09	Commissioning - Phase II
29	Final Punchlist	12	16-Mar-09	31-Mar-09	Final Punchlist
30	Final Completion/Occupancy	1	31-Mar-09	31-Mar-09	Final Completion/Occupancy

Actual Work    
  Critical Remaining ...  
 Remaining Work    
 ◆ Milestone     ◆ Milestone

ID	Task Name	Duration	Start	2005		2006		2007		2008		2009			
				Jan		Jan		Jan		Jan		Jan			
1	<b>Integrated Science Center Phases I &amp; II</b>	<b>1 day</b>	<b>Mon 6/27/05</b>												
2	<b>Preconstruction Phase</b>	<b>229 days</b>	<b>Mon 6/27/05</b>												
3	Bid Packages Phases I & II	60 days	Mon 6/27/05												
4	Award	0 days	Fri 10/14/05												
5	Notice to Proceed	0 days	Fri 5/12/06												
6	<b>PHASE I - INTEGRATED SCIENCE CENTER</b>	<b>487 days</b>	<b>Mon 5/15/06</b>												
7	<b>Sitework, Shoring, Excavation</b>	<b>184 days</b>	<b>Mon 5/15/06</b>												
8	Site Preparation and Site Utilities	16 days	Mon 5/15/06												
9	Excav. Bldg. Area B	11 days	Mon 6/5/06												
10	Perform Soil Nailing Area B	26 days	Mon 6/12/06												
11	Excav. Bldg. Area A	17 days	Tue 6/20/06												
12	Perform Soil Nailing Area A	8 days	Mon 8/21/06												
13	<b>Foundations</b>	<b>116 days</b>	<b>Thu 8/17/06</b>												
14	Foundation Wall Footings Area B	10 days	Thu 8/17/06												
15	Place Rebar & Imbeds for Perim Walls A	20 days	Thu 8/17/06												
16	Place Rebar & Imbeds for Perim Walls B	18 days	Wed 8/23/06												
17	Foundation Walls Area B	18 days	Fri 8/25/06												
18	Foundation Walls Area A	17 days	Mon 9/18/06												
19	Interior Column Footings Area B	7 days	Wed 9/20/06												
20	Interior Column Footings Area A	6 days	Fri 9/29/06												
21	Foundation Wall Footings Area A	16 days	Tue 10/3/06												
22	Place Elevator Pit Slabs Area B	5 days	Tue 10/10/06												
23	Place Elevator Pit Slabs Area A	6 days	Wed 10/11/06												
24	Install Understab Utilities Area B	52 days	Mon 10/30/06												
25	Install Underslab Utilities Area A	25 days	Fri 12/22/06												
26	<b>Structural Steel/Metal Deck</b>	<b>110 days</b>	<b>Mon 9/25/06</b>												
27	Erect Structural Steel Area B	19 days	Mon 9/25/06												
28	Lay Metal Deck Area B-1	8 days	Wed 10/11/06												
29	Erect Structural Steel Area A	27 days	Thu 10/12/06												
30	Lay Metal Deck Area B-2	3 days	Thu 10/19/06												
31	Lay Metal Deck Area B-3	3 days	Mon 10/23/06												
32	Lay Metal Deck Area B-4	3 days	Wed 11/15/06												
33	Lay Metal Deck Area A-1	3 days	Wed 11/15/06												
34	Structural Steel Top Out	0 days	Fri 11/17/06												
35	Lay Metal Deck Area A-2	2 days	Fri 11/17/06												
36	Lay Metal Deck Area A-3	4 days	Mon 11/27/06												
37	Lay Metal Deck Area A-4	4 days	Thu 11/30/06												
38	Install Stairs Area B	15 days	Fri 1/19/07												
39	Install Stairs Area A	15 days	Mon 2/5/07												
40	<b>Spray Fireproofing</b>	<b>56 days</b>	<b>Mon 11/27/06</b>												
41	Spray Fireproofing Area B-1	5 days	Mon 11/27/06												
42	Spray Fireproofing Area B-2	27 days	Mon 12/4/06												
43	Spray Fireproofing Area B-3	4 days	Wed 1/10/07												
44	Spray Fireproofing Area A-1	4 days	Tue 1/16/07												

Project: Tech II Schedule.mpp Date: Sat 10/25/08	Task		Rolled Up Task		External Tasks	
	Progress		Rolled Up Milestone		Project Summary	
	Milestone		Rolled Up Progress		Group By Summary	
	Summary		Split		Deadline	



ID	Task Name	Duration	Start	2005	2006	2007	2008	2009
				Jan	Jan	Jan	Jan	Jan
45	Spray Fireproofing Area A-2	4 days	Mon 1/22/07					
46	Spray Fireproofing Area A-3	4 days	Fri 1/26/07					
47	Spray Fireproofing Area B-Ground	4 days	Thu 2/1/07					
48	Spray Fireproofing Area A-Ground	4 days	Wed 2/7/07					
49	<b>Concrete Work</b>	<b>78 days</b>	<b>Thu 11/9/06</b>					
50	Place Wire Mesh/Block-outs Area B-1	4 days	Thu 11/9/06					
51	Place Slab-on-Deck Area B-1	1 day	Tue 11/14/06					
52	Place Wire Mesh/Block-outs Area B-2	3 days	Thu 11/16/06					
53	Place Wire Mesh/Block-outs Area B-3	3 days	Mon 11/20/06					
54	Place Slab-on-Deck Area B-2	1 day	Mon 11/20/06					
55	Place Wire Mesh/Block-outs Area B-4	2 days	Fri 11/24/06					
56	Place Slab-on-Deck Area B-3	1 day	Mon 11/27/06					
57	Place Slab-on-Deck Area B-4	1 day	Mon 11/27/06					
58	Place Wire Mesh/Block-outs Area A-1	2 days	Thu 12/7/06					
59	Place Slab-on-Deck Area A-1	1 day	Thu 12/7/06					
60	Place Wire Mesh/Block-outs Area A-2	3 days	Fri 12/8/06					
61	Place Wire Mesh/Block-outs Area A-3	2 days	Wed 12/13/06					
62	Place Slab-on-Deck Area A-2	1 day	Wed 12/13/06					
63	Place Slab-on-Deck Area A-3	1 day	Mon 12/18/06					
64	Place Wire Mesh/Block-outs Area A-4	4 days	Tue 12/19/06					
65	Place Slab-on-Deck Area A-4	1 day	Fri 12/22/06					
66	Backfill Foundation Walls Area B	22 days	Thu 1/4/07					
67	Backfill Foundation Walls Area A	29 days	Fri 1/5/07					
68	Place Slab-On-Grade Area B-Ground	7 days	Thu 2/1/07					
69	Place Slab-On-Grade Area A-Ground	7 days	Fri 2/16/07					
70	<b>Roofing</b>	<b>83 days</b>	<b>Mon 12/4/06</b>					
71	Install Metal Deck Area B-Roof	31 days	Mon 12/4/06					
72	Install Metal Deck Area A-Roof	42 days	Mon 12/4/06					
73	Install Rigid Insulation and Cover Board B	21 days	Tue 1/16/07					
74	Install Rigid Insulation and Cover Board A	21 days	Wed 1/31/07					
75	Install Simulated Slate Roofing Area B	20 days	Wed 2/14/07					
76	Install Simulated Slate Roofing Area A	20 days	Thu 3/1/07					
77	<b>Masonry Work</b>	<b>52 days</b>	<b>Tue 2/13/07</b>					
78	Erect Block Walls Area B-Ground	15 days	Tue 2/13/07					
79	Lay Exterior Brick Area B	30 days	Thu 2/15/07					
80	Erect Block Walls Area A-Ground	15 days	Tue 2/20/07					
81	Lay Exterior Brick Area A	30 days	Thu 3/15/07					
82	Enclosure	0 days	Wed 4/25/07					
83	<b>Glass &amp; Glazing</b>	<b>48 days</b>	<b>Wed 3/28/07</b>					
84	Install Exterior Windows Area B	20 days	Wed 3/28/07					
85	Install Curtainwall Storefront Area B	18 days	Thu 3/29/07					
86	Install Exterior Windows Area A	21 days	Tue 5/1/07					
87	Install Curtainwall Storefront Area A	11 days	Fri 5/18/07					
88	<b>Drywall and Acoustical Ceilings</b>	<b>188 days</b>	<b>Mon 12/18/06</b>					

Project: Tech II Schedule.mpp Date: Sat 10/25/08	Task		Rolled Up Task		External Tasks	
	Progress		Rolled Up Milestone		Project Summary	
	Milestone		Rolled Up Progress		Group By Summary	
	Summary		Split		Deadline	


ID	Task Name	Duration	Start	2005	2006	2007	2008	2009
				Jan	Jan	Jan	Jan	Jan
89	Place Exterior Studs Area B	17 days	Mon 12/18/06					
90	Place Exterior Studs Area A	24 days	Thu 12/28/06					
91	Install Sheathing and Rigid Insulation B	29 days	Tue 1/2/07					
92	Install Sheathing and Rigid Insulation A	28 days	Wed 1/31/07					
93	Frame Partitions Floor 1	21 days	Wed 2/14/07					
94	Frame Partitions Floor 2	21 days	Thu 3/1/07					
95	Frame Partitions Floor 3	21 days	Thu 3/29/07					
96	Frame Partitions Ground Floor	11 days	Mon 4/30/07					
97	Drywall Close-in Walls Incl.Finish Floor 3	22 days	Thu 5/10/07					
98	Drywall Close-in Walls Incl. Finish Ground	22 days	Tue 6/12/07					
99	Drywall Close-in Walls Incl. Finish Floor 1	21 days	Wed 7/11/07					
100	Drywall Close-in Walls Incl. Finish Floor 2	21 days	Wed 8/8/07					
101	Install Ceiling Grid Ground Floor	11 days	Mon 8/13/07					
102	Install Ceiling Grid Floor 1	11 days	Tue 9/4/07					
103	Install Ceiling Grid Floor 2	11 days	Thu 9/20/07					
104	Drop Ceiling Tiles Ground Floor	11 days	Mon 9/24/07					
105	Drop Ceiling Tiles Floor 2	6 days	Wed 10/3/07					
106	Install Ceiling Grid Floor 3	11 days	Mon 10/8/07					
107	Drop Ceiling Tiles Floor 1	6 days	Tue 10/16/07					
108	Drop Ceiling Tiles Floor 3	6 days	Mon 10/22/07					
109	<b>Plumbing and HVAC</b>	<b>265 days</b>	<b>Tue 12/26/06</b>					
110	Overhead Rough-In Piping Floor 1	55 days	Tue 12/26/06					
111	Overhead Rough-In Duct Floor 1	31 days	Wed 1/24/07					
112	Overhead Rough-In Duct Ground Floor	33 days	Wed 2/14/07					
113	Overhead Rough-In Duct Floor 2	41 days	Wed 2/28/07					
114	Overhead Rough-In Piping Ground Floor	19 days	Fri 3/30/07					
115	Overhead Rough-In Piping Floor 2	26 days	Fri 4/13/07					
116	In Wall Rough-In Piping Floor 1	17 days	Mon 4/23/07					
117	In Wall Rough-In Piping Floor 2	43 days	Tue 5/15/07					
118	Overhead Rough-In Piping Floor 3	34 days	Thu 5/24/07					
119	Overhead Rough-In Piping Floor 3	17 days	Mon 6/18/07					
120	In Wall Rough-In Floor 3	33 days	Tue 7/10/07					
121	Diffusers, Registers, and Grilles Floor 1	16 days	Tue 10/23/07					
122	Install Plumbing Fixtures Ground Floor	19 days	Tue 11/6/07					
123	Diffusers, Registers, and Grilles Floor 2	17 days	Tue 11/13/07					
124	Install Plumbing Fixtures Floor 1	18 days	Fri 11/23/07					
125	Diffusers, Registers, and Grilles Floor 3	17 days	Wed 12/5/07					
126	Install Plumbing Fixtures Floor 2	17 days	Fri 12/7/07					
127	Install Plumbing Fixtures Floor 3	12 days	Fri 12/14/07					
128	<b>Electrical</b>	<b>300 days</b>	<b>Thu 1/25/07</b>					
129	Overhead Rough-In Electrical Floor 1	26 days	Thu 1/25/07					
130	Overhead Rough-In Electrical Floor 2	41 days	Thu 3/1/07					
131	In Wall Rough-In Floor 1	26 days	Wed 3/14/07					
132	Overhead Rough-In Electrical Floor 3	42 days	Fri 4/13/07					

Project: Tech II Schedule.mpp Date: Sat 10/25/08	Task		Rolled Up Task		External Tasks	
	Progress		Rolled Up Milestone		Project Summary	
	Milestone		Rolled Up Progress		Group By Summary	
	Summary		Split		Deadline	

ID	Task Name	Duration	Start	2005	2006	2007	2008	2009
				Jan	Jan	Jan	Jan	Jan
133	In Wall Rough-In Floor 2	26 days	Wed 4/18/07					
134	In Wall Rough-In Floor 3	27 days	Wed 5/23/07					
135	Overhead Rough-In Elec. Ground Floor	41 days	Tue 7/17/07					
136	Fire Alarm Rough-In Ground Floor	31 days	Tue 8/28/07					
137	In Wall Rough-In Ground Floor	26 days	Tue 9/11/07					
138	Fire Alarm Rough-In Floor 1	23 days	Tue 9/25/07					
139	Fire Alarm Rough-In Floor 2	23 days	Wed 10/17/07					
140	Install Light Fixtures Floor 1	24 days	Fri 10/26/07					
141	Fire Alarm Rough-In Floor 3	24 days	Wed 11/7/07					
142	Install Light Fixtures Floor 2	24 days	Wed 11/28/07					
143	Install Light Fixtures Floor 3	24 days	Mon 12/31/07					
144	Install Light Fixtures Ground Floor	23 days	Mon 2/18/08					
145	<b>Fire Protection</b>	<b>137 days</b>	<b>Fri 3/30/07</b>					
146	Install Sprinkler Mains Ground Floor	16 days	Fri 3/30/07					
147	Install Sprinkler Mains Floor 1	16 days	Fri 4/13/07					
148	Sprinkler Branch Lines Ground Floor	21 days	Fri 4/13/07					
149	Install Sprinkler Mains Floor 2	16 days	Fri 4/20/07					
150	Sprinkler Branch Lines Floor 1	32 days	Fri 4/27/07					
151	Sprinkler Branch Lines Floor 2	32 days	Fri 5/4/07					
152	Install Sprinkler Mains Floor 3	16 days	Fri 5/4/07					
153	Sprinkler Branch Lines Floor 3	32 days	Fri 5/11/07					
154	Drop Sprinkler Heads Ground Floor	21 days	Mon 8/27/07					
155	Drop Sprinkler Heads Floor 1	21 days	Tue 9/18/07					
156	Drop Sprinkler Heads Floor 2	21 days	Wed 10/10/07					
157	Drop Sprinkler Heads Floor 3	21 days	Thu 11/1/07					
158	<b>Painting</b>	<b>51 days</b>	<b>Mon 7/30/07</b>					
159	Paint Ground Floor	15 days	Mon 7/30/07					
160	Paint Floor 1	13 days	Fri 8/17/07					
161	Paint Floor 2	13 days	Tue 9/4/07					
162	Paint Floor 3	13 days	Thu 9/20/07					
163	<b>Doors</b>	<b>46 days</b>	<b>Fri 8/17/07</b>					
164	Hang Doors Ground Floor	11 days	Fri 8/17/07					
165	Hang Doors Floor 1	11 days	Tue 8/28/07					
166	Hang Doors Floor 2	11 days	Thu 10/4/07					
167	Hang Doors Floor 3	10 days	Mon 10/8/07					
168	<b>Hardware</b>	<b>88 days</b>	<b>Fri 8/17/07</b>					
169	Install Lab Casework Ground Floor	4 days	Fri 8/17/07					
170	Install Fumehoods Ground Floor	6 days	Fri 8/17/07					
171	Install Lab Casework Floor 1	22 days	Thu 9/20/07					
172	Install Fumehoods Floor 1	11 days	Thu 9/20/07					
173	Install Lab Casework Floor 2	21 days	Tue 10/16/07					
174	Install Fumehoods Floor 2	11 days	Tue 10/16/07					
175	Install Lab Casework Floor 3	22 days	Tue 11/6/07					
176	Install Fumehoods Floor 3	11 days	Tue 11/6/07					

Project: Tech II Schedule.mpp Date: Sat 10/25/08	Task		Rolled Up Task		External Tasks	
	Progress		Rolled Up Milestone		Project Summary	
	Milestone		Rolled Up Progress		Group By Summary	
	Summary		Split		Deadline	

ID	Task Name	Duration	Start	2005	2006	2007	2008	2009
				Jan	Jan	Jan	Jan	Jan
177	<b>Flooring</b>	<b>67 days</b>	<b>Fri 9/14/07</b>					
178	Install Carpet & VCT Ground Floor	11 days	Fri 9/14/07					
179	Install Carpet & VCT Floor 2	11 days	Thu 9/20/07					
180	Install Carpet & VCT Floor 3	11 days	Mon 10/8/07					
181	Install Carpet & VCT Floor 1	17 days	Fri 11/23/07					
182	Final Punchlist	31 days	Tue 2/5/08					
183	Substantial Completion	0 days	Tue 3/25/08					
184	Commissioning	108 days	Wed 3/26/08					
185	<b>PHASE II - ROGERS HALL RENOVATION</b>	<b>217 days</b>	<b>Mon 6/2/08</b>					
186	Demolition	30 days	Mon 6/2/08					
187	Asbestos Abatement	10 days	Mon 6/16/08					
188	MEP Floor 2	42 days	Wed 7/16/08					
189	MEP Floor 1	50 days	Mon 7/21/08					
190	Interior Partitions Floor 2	49 days	Fri 8/8/08					
191	Interior Partitions Floor 1	54 days	Fri 8/22/08					
192	Building Envelope	10 days	Mon 8/25/08					
193	Enclosure	0 days	Fri 9/5/08					
194	Interior Finishes Floor 2	58 days	Mon 9/29/08					
195	Interior Finishes Floor 1	58 days	Mon 10/13/08					
196	Substantial Completion	0 days	Thu 1/1/09					
197	Demobilization	22 days	Thu 1/1/09					
198	Commissioning	49 days	Mon 1/5/09					
199	Final Punchlist	12 days	Mon 3/16/09					
200	Final Completion/Occupancy	0 days	Tue 3/31/09					




Project: Tech II Schedule.mpp Date: Sat 10/25/08	Task		Rolled Up Task		External Tasks	
	Progress		Rolled Up Milestone		Project Summary	
	Milestone		Rolled Up Progress		Group By Summary	
	Summary		Split		Deadline	

# APPENDIX C

## Estimates

RS Means SF Estimate  
RS Means Unit Cost Estimate  
D4 Cost Estimate



**Costs per square foot of floor area**

Finisher Work	S.F. Area	12000	20000	25000	30000	40000	50000	60000	80000	100000
		L.F. Perimeter	470	600	690	790	900	1000	1120	1200
Face Brick with Concrete Brick Back-up	Steel Frame	249.75	205.20	184.80	171.85	165.35	158.95	153.75	149.70	147.25
	Bearing Walls	245.20	200.65	180.20	167.30	160.75	154.40	149.15	145.15	142.65
Decorative Concrete Block	Steel Frame	242.95	200.05	180.45	168.10	161.85	155.70	150.85	147.05	144.70
	Bearing Walls	238.60	195.65	176.10	163.80	157.55	151.40	146.50	142.70	140.40
Stucco on Concrete Block	Steel Frame	241.45	198.90	179.50	167.35	161.10	155.05	150.25	146.55	144.20
	Bearing Walls	237.10	194.55	175.15	162.95	156.75	150.70	145.90	142.15	139.85
Perimeter Adj., Add or Deduct	Per 100 L.F.	9.60	5.75	4.10	3.10	2.55	2.10	1.70	1.40	1.25
Story Hgt. Adj., Add or Deduct	Per 1 Ft.	1.75	1.40	1.15	0.95	0.90	0.90	0.75	0.70	0.65
<i>For Basement, add \$28.60 per square foot of basement area</i>										

The above costs were calculated using the basic specifications shown on the facing page. These costs should be adjusted where necessary for design alternatives and owner's requirements. Reported completed project costs, for this type of structure, range from \$138.90 to \$259.45 per S.F.

**Common additives**

Description	Unit	\$ Cost	Description	Unit	\$ Cost
Cabinets, Base, door units, metal	L.F.	243	Safety Equipment, Eye wash, hand held	Each	445
Drawer units	L.F.	480	Deluge shower	Each	805
Tall storage cabinets, open	L.F.	455	Sink, One piece plastic		
With doors	L.F.	690	Flask wash, freestanding	Each	2250
Wall, metal 12-1/2" deep, open	L.F.	180	Tables, acid resist. top, drawers	L.F.	188
With doors	L.F.	325	Titration Unit, Four 2000 ml reservoirs	Each	6050
Carrels Hardwood	Each	655 - 1200			
Countertops, not incl. base cabinets, acid proof	S.F.	43.50 - 56			
Stainless steel	S.F.	112			
Fume Hood, Not incl. ductwork	L.F.	745 - 2550			
Ductwork	Hood	4925 - 8100			
Glassware Washer, Distilled water rinse	Each	6475 - 13,100			
Seating					
Auditorium chair, all veneer	Each	218			
Veneer back, padded seat	Each	264			
Upholstered, spring seat	Each	264			
Classroom, movable chair & desk	Set	65 - 120			
Lecture hall, pedestal type	Each	208 - 620			

# Statement of Probable Cost

W&M ISC - Jun 2006 - VA - Other

Prepared By: **Meghan Graber**

Prepared For: **Technical Assignment I**

Building Sq. Size: **116426**  
 Bid Date:  
 No. of floors: **3**  
 No. of buildings: **1**  
 Project Height: **57**  
 1st Floor Height: **11**  
 1st Floor Size: **24300**

Site Sq. Size: **80205**  
 Building use: **Educational**  
 Foundation: **CON**  
 Exterior Walls: **CUR**  
 Interior Walls: **DRY**  
 Roof Type: **OTH**  
 Floor Type: **VCT**  
 Project Type: **NEW**

Division		Percent	Sq. Cost	Amount
01	<b>General Requirements</b>	<b>4.96</b>	<b>10.69</b>	<b>1,244,036</b>
	General Requirements	4.96	10.69	1,244,036
02	<b>Site Work</b>	<b>5.35</b>	<b>11.53</b>	<b>1,342,292</b>
	Site Work	5.35	11.53	1,342,292
03	<b>Concrete</b>	<b>11.60</b>	<b>25.00</b>	<b>2,911,151</b>
	Concrete	11.60	25.00	2,911,151
04	<b>Masonry</b>	<b>5.19</b>	<b>11.19</b>	<b>1,303,322</b>
	Masonry	5.19	11.19	1,303,322
05	<b>Metals</b>	<b>4.07</b>	<b>8.76</b>	<b>1,020,071</b>
	Metals	4.07	8.76	1,020,071
06	<b>Wood &amp; Plastics</b>	<b>1.24</b>	<b>2.66</b>	<b>309,965</b>
	Wood & Plastics	1.24	2.66	309,965
07	<b>Thermal &amp; Moisture Protection</b>	<b>2.87</b>	<b>6.18</b>	<b>719,981</b>
	Thermal & Moisture Protection	2.87	6.18	719,981
08	<b>Doors &amp; Windows</b>	<b>5.97</b>	<b>12.87</b>	<b>1,498,826</b>
	Doors & Windows	5.97	12.87	1,498,826
09	<b>Finishes</b>	<b>6.81</b>	<b>14.67</b>	<b>1,707,606</b>
	Finishes	6.81	14.67	1,707,606
10	<b>Specialties</b>	<b>0.76</b>	<b>1.63</b>	<b>190,142</b>
	Specialties	0.76	1.63	190,142
11	<b>Equipment</b>	<b>7.97</b>	<b>17.17</b>	<b>1,999,377</b>
	Equipment	7.97	17.17	1,999,377
12	<b>Furnishings</b>	<b>1.58</b>	<b>3.40</b>	<b>396,065</b>
	Furnishings	1.58	3.40	396,065
13	<b>Special Construction</b>	<b>0.80</b>	<b>1.72</b>	<b>199,935</b>
	Special Construction	0.80	1.72	199,935
14	<b>Conveying Systems</b>	<b>0.93</b>	<b>2.01</b>	<b>234,250</b>
	Conveying Systems	0.93	2.01	234,250
15	<b>Mechanical</b>	<b>25.58</b>	<b>55.13</b>	<b>6,418,592</b>
	Mechanical	25.58	55.13	6,418,592
16	<b>Electrical</b>	<b>8.83</b>	<b>19.03</b>	<b>2,215,585</b>
	Electrical	8.83	19.03	2,215,585
21	<b>Fire Suppression</b>	<b>0.13</b>	<b>0.29</b>	<b>33,464</b>
	Fire Suppression	0.13	0.29	33,464
22	<b>Plumbing</b>	<b>0.54</b>	<b>1.16</b>	<b>134,487</b>
	Plumbing	0.54	1.16	134,487

23	HVAC	2.53	5.46	635,903
	HVAC	2.53	5.46	635,903
26	Electrical	1.24	2.67	310,422
	Electrical	1.24	2.67	310,422
27	Communications	0.10	0.21	23,916
	Communications	0.10	0.21	23,916
28	Electronic Safety and Security	0.06	0.13	15,456
	Electronic Safety and Security	0.06	0.13	15,456
31	Earthwork	0.43	0.94	109,035
	Earthwork	0.43	0.94	109,035
32	Exterior Improvements	0.18	0.39	44,845
	Exterior Improvements	0.18	0.39	44,845
33	Utilities	0.28	0.60	69,689
	Utilities	0.28	0.60	69,689
<b>Total Building Costs</b>		<b>100.00</b>	<b>215.49</b>	<b>25,088,412</b>
<b>Total Non-Building Costs</b>		<b>100.00</b>	<b>0.00</b>	<b>0</b>
<b>Total Project Costs</b>		<b>--</b>	<b>--</b>	<b>25,088,412</b>



# Statement of Probable Cost

W&M Rogers Hall - Jun 2006 - VA - Other

Prepared By: **Meghan Graber**

Prepared For: **Technical Assignment I**

Building Sq. Size: **42340**  
 Bid Date:  
 No. of floors: **2**  
 No. of buildings: **1**  
 Project Height: **30**  
 1st Floor Height: **11**  
 1st Floor Size: **22000**

Site Sq. Size: **25402**  
 Building use: **Educational**  
 Foundation: **CON**  
 Exterior Walls: **CUR**  
 Interior Walls: **DRY**  
 Roof Type: **OTH**  
 Floor Type: **VCT**  
 Project Type: **REN**

Division		Percent	Sq. Cost	Amount
01	<b>General Requirements</b>	<b>4.94</b>	<b>12.36</b>	<b>523,277</b>
	General Requirements	4.94	12.36	523,277
02	<b>Site Work</b>	<b>3.97</b>	<b>9.94</b>	<b>420,656</b>
	Site Work	3.97	9.94	420,656
03	<b>Concrete</b>	<b>10.55</b>	<b>26.39</b>	<b>1,117,251</b>
	Concrete	10.55	26.39	1,117,251
04	<b>Masonry</b>	<b>11.54</b>	<b>28.87</b>	<b>1,222,255</b>
	Masonry	11.54	28.87	1,222,255
05	<b>Metals</b>	<b>2.74</b>	<b>6.85</b>	<b>290,237</b>
	Metals	2.74	6.85	290,237
06	<b>Wood &amp; Plastics</b>	<b>2.29</b>	<b>5.73</b>	<b>242,810</b>
	Wood & Plastics	2.29	5.73	242,810
07	<b>Thermal &amp; Moisture Protection</b>	<b>7.62</b>	<b>19.06</b>	<b>807,050</b>
	Thermal & Moisture Protection	7.62	19.06	807,050
08	<b>Doors &amp; Windows</b>	<b>2.54</b>	<b>6.35</b>	<b>268,858</b>
	Doors & Windows	2.54	6.35	268,858
09	<b>Finishes</b>	<b>7.94</b>	<b>19.85</b>	<b>840,533</b>
	Finishes	7.94	19.85	840,533
10	<b>Specialties</b>	<b>0.33</b>	<b>0.83</b>	<b>35,253</b>
	Specialties	0.33	0.83	35,253
11	<b>Equipment</b>	<b>2.41</b>	<b>6.03</b>	<b>255,517</b>
	Equipment	2.41	6.03	255,517
12	<b>Furnishings</b>	<b>2.18</b>	<b>5.45</b>	<b>230,865</b>
	Furnishings	2.18	5.45	230,865
13	<b>Special Construction</b>	<b>1.06</b>	<b>2.65</b>	<b>112,181</b>
	Special Construction	1.06	2.65	112,181
14	<b>Conveying Systems</b>	<b>1.17</b>	<b>2.92</b>	<b>123,443</b>
	Conveying Systems	1.17	2.92	123,443
15	<b>Mechanical</b>	<b>28.20</b>	<b>70.53</b>	<b>2,986,106</b>
	Mechanical	28.20	70.53	2,986,106
16	<b>Electrical</b>	<b>10.51</b>	<b>26.28</b>	<b>1,112,886</b>
	Electrical	10.51	26.28	1,112,886
<b>Total Building Costs</b>		<b>100.00</b>	<b>250.10</b>	<b>10,589,177</b>
<b>Total Non-Building Costs</b>		<b>100.00</b>	<b>0.00</b>	<b>0</b>

Total Project Costs

---

---

-	-	10,589,177
---	---	------------

A 1

A 2

A 3

A 4



# APPENDIX D

## General Conditions Estimate

General Conditions Estimate										
Div.	Description	Unit	Quantity	Mat'l Unit Cost	Mat'l Cost	Labor Unit Cost	Labor Cost	Equipment Unit Cost	Equipment Cost	Total Cost
<b>01 11 31.20 Construction Management Fees</b>										
0300	50,000,000 job, minimum	Project	2.50%							\$1,062,166
<b>01 31 13.20 Field Personnel</b>										
0100	Field Engineer	Week	200			\$1,125	\$225,000			\$225,000
0200	Project Manager, average	Week	200			\$1,850	\$370,000			\$370,000
0250	Superintendent 1, average	Week	200			\$1,700	\$340,000			\$340,000
0250	Superintendent 2, average	Week	200			\$1,700	\$340,000			\$340,000
<b>01 31 13.30 Insurance</b>										
0020	Builders risk, standard, minimum	Job	0.24%							\$101,968
<b>01 31 13.90 Performance Bond</b>										
0020	Performance bond for buildings, minimum	Job	0.60%							\$254,920
<b>01 32 13.50 Scheduling</b>										
0650	Rule of thumb, CPM scheduling, large job (\$50,000)	Job	0.03%							\$12,746
<b>01 41 26.50 Permits</b>										
0020	Rule of thumb, most cities, minimum	Job	0.50%							\$212,433
<b>01 45 23.50 Testing and Inspecting Services</b>										
0010	Testing and Inspecting Services for building costing \$10,000,000, minimum	Project								\$48,182
<b>01 51 13.80 Temporary Utilities</b>										
0100	Heat, incl. fuel and operation, per week, 12 hrs. per day	CSF Flr.	1,587.66	\$10.35	\$16,432	\$3.15	\$5,001			\$21,433
0350	Lighting, incl. service lamps, wiring & outlets, minimum	CSF Flr.	1,587.66	\$2.63	\$4,176	\$10.70	\$16,988			\$21,164
0400	Power for temp lighting only, per month, min/month 6.6 KWH	CSF Flr.	1,587.66							\$1,191
0600	Power for job duration incl. elevator, ect. minimum	CSF Flr.	1,587.66							\$74,620
1000	Toliet 1, portable	Month	46.5	\$150	\$6,975					\$6,975
1000	Toliet 2, portable	Month	46.5	\$150	\$6,975					\$6,975
1000	Toliet 3, portable	Month	46.5	\$150	\$6,975					\$6,975
1000	Toliet 4, portable	Month	46.5	\$150	\$6,975					\$6,975
<b>01 52 13.20 Office and Storage Space</b>										
0300	Trailer, furnished, no hookups, 32'x8' rent per month	Month	46.5	\$241	\$11,207					\$11,207
0500	Trailer, furnished, no hookups, 50'x12' rent per month	Month	46.5	\$375	\$17,438					\$17,438
<b>01 52 13.40 Field Office Expense</b>										
0100	Office equipment rental, average	Month	46.5	\$150	\$6,975					\$6,975
0120	Office supplies, average	Month	46.5	\$95	\$4,418					\$4,418
0140	Telephone bill; avg	Month	46.5	\$210	\$9,765					\$9,765
0160	Lights & HVAC (trailer 1)	Month	46.5	\$110	\$5,115					\$5,115
0160	Lights & HVAC (trailer 2)	Month	46.5	\$110	\$5,115					\$5,115
<b>01 54 16.50 Weekly Forklift Crew</b>										
0100	All terrain forklift, 45' lift, 35' reach, 9000 lb capacity	Month	46.5			\$1,500	\$69,750	\$2,175	\$101,138	\$170,888

<b>01 55 23.50 Roadways and Sidewalks</b>										
0050	Roads, gravel fill, no surfacing, 4" gravel depth	S.Y	1,656	\$4.73	\$7,833	\$2.14	\$3,544	\$0.40	\$662	\$12,039
<b>01 56 13.60 Tarpaulins and Barricades</b>										
0600	Polyvinyl coated nylon, 14 oz. to 18 oz., minimum	S.F	45,000	\$0.48	\$21,600					\$21,600
1000	Guardrail, wooden, 3' high, 1"x6", on 2"x6" posts	L.F	2,388	\$1.09	\$2,603	\$3.05	\$7,283			\$9,886
<b>01 56 26.50 Temporary Fencing and Protective Walkways</b>										
0100	Rented chainlink, 6' high, over 1000' (1st 12 months)	L.F	1,500	\$1.79	\$2,685	\$1.61	\$2,415			\$5,100
0100	Rented chainlink, 6' high, over 1000' (2nd 12 months)	L.F	1,500	\$1.79	\$2,685	\$1.61	\$2,415			\$5,100
0100	Rented chainlink, 6' high, over 1000' (3rd 12 months)	L.F	1,500	\$1.79	\$2,685	\$1.61	\$2,415			\$5,100
2300	Sidewalks, exterior plywood, 2 uses, 1/2" thick	S.F	1,000	\$0.26	\$260	\$0.41	\$410			\$670
<b>01 58 13.50 Signs</b>										
0020	High intensity reflectorized, no posts, buy	S.F	80	\$17.90	\$1,432					\$1,432
<b>01 74 13.20 Cleaning Up</b>										
0020	After job completion, allow, minimum	Job	0.30%							\$127,460
<b>01 91 13.50 Commissioning</b>										
0100	Performance verification, O&M, training, maximum	Project	0.75%							\$318,650
							<b>TOTAL PROJECT GENERAL CONDITIONS</b>			<b>\$3,851,679</b>
							x Location Factor of 0.87			<b>\$3,350,961</b>

# APPENDIX E

## Product Data Sheets

T8 Lamps  
T12 Lamps  
Magnetic Ballasts  
Instant-Start Electrical Ballast

# QUICKSAVINGS

QUICKTRONIC® high frequency electronic ballasts are more efficient than other ballast types. High performance QUICKTRONIC ballasts save money – year after year.

## Energy Savings Guide

### 4-Foot Lamps (2 lamps per system)

**OLD SYSTEM**  
Standard Magnetic  
with F40T12 lamps  
Annual Energy Costs:  
\$38.40 per year

**SAVINGS EXAMPLE**

\$38.40  
- \$16.80  
\$21.60  
Total Energy  
Cost Savings  
Per Year  
(per each  
2 lamp  
system)

**NEW SYSTEM**

QHE2x32T8/UNV ISL-SC  
with F028T8SS lamps  
Annual Energy Costs:  
\$16.80 per year

Ballast Type	Lamps	Lamp Lumens	Ballast Factor	Initial System Lumens	Mean System Lumens	Mean Relative Light Output	Input* (System) Watts	% System Power	System LPW	Annual Energy Cost
STD MAGNETIC	F40T12CW	3050	0.95	5,795	4,984	100%	96	100%	60	\$38.40
	F34T12CW	2650	0.88	4,664	4,011	80%	82	85%	57	\$32.80
ES MAGNETIC	F40T12CW	3050	0.95	5,795	4,984	100%	86	90%	67	\$34.40
	F34T12CW	2650	0.88	4,664	4,011	80%	72	75%	65	\$28.80
ES MAGNETIC	F40T12D41	3200	0.95	6,080	5,472	110%	86	90%	71	\$34.40
	F34T12D41	2800	0.88	4,928	4,435	89%	72	75%	68	\$28.80
ES MAGNETIC	F032T8/700	2800	0.95	5,320	4,788	96%	74	77%	72	\$29.60
QTP2x32T8/UNV ISN-SC	F032T8/800XP	3000	0.88	5,280	5,016	101%	59	61%	89	\$23.60
	F030T8SS/XP	2850	0.88	5,016	4,765	96%	55	57%	91	\$22.00
	F028T8SS/XP	2725	0.88	4,796	4,556	91%	52	54%	92	\$20.80
QTP2x32T8/UNV PSX-TC	F032T8/XPS	3100	0.71	4,400	4,150	83%	47	49%	94	\$18.80
	F030T8SS/XP	2850	0.71	4,047	3,845	77%	44	46%	92	\$17.60
	F028T8SS/XP	2725	0.71	3,870	3,676	74%	41	43%	94	\$16.40
QTP2x32T8/UNV PSN-TC	F032T8/800XP	3000	0.88	5,280	5,016	101%	60	63%	88	\$24.00
	F030T8SS/XP	2850	0.88	5,016	4,765	96%	56	58%	90	\$22.40
	F028T8SS/XP	2725	0.88	4,796	4,556	91%	53	55%	90	\$21.20
QHE 2X32T8/UNV ISN-SC	F032T8/800XP	3000	0.88	5,280	5,016	101%	55	57%	96	\$22.00
	F030T8SS/XP	2850	0.88	5,016	4,765	96%	52	54%	96	\$20.80
	F028T8SS/XP	2725	0.88	4,796	4,556	91%	48	50%	100	\$19.20
QHE 2X32T8/UNV ISL-SC	F032T8/800XP	3000	0.78	4,680	4,446	89%	48	50%	98	\$19.20
	F030T8SS/XP	2850	0.78	4,446	4,224	85%	45	47%	99	\$18.00
	F028T8SS/XP	2725	0.78	4,251	4,038	81%	42	44%	101	\$16.80

SAVINGS EXAMPLE

SAVINGS EXAMPLE

SAVINGS EXAMPLE

### 4-Foot Lamps (4 lamps per system)

**NOTE: Annual energy costs based on assumption of 4000 operating hours per year with energy cost of \$.10/kWh.**

STD MAGNETIC(2)	F40T12CW	3050	0.95	11,590	9,967	100%	192	100%	60	\$76.80
	F34T12CW	2650	0.88	9,328	8,022	80%	164	85%	57	\$65.60
ES MAGNETIC(2)	F40T12CW	3050	0.95	11,590	9,967	100%	172	90%	67	\$68.80
	F34T12CW	2650	0.88	9,328	8,022	80%	144	75%	65	\$57.60
ES MAGNETIC(2)	F40T12D41	3200	0.95	12,160	10,944	110%	172	90%	71	\$68.80
	F34T12D41	2800	0.88	9,856	8,870	89%	144	75%	68	\$57.60
ES MAGNETIC (2)	F032T8/700	2800	0.95	10,640	9,576	96%	148	77%	72	\$59.20
QT4x32T8 ISN-SC	F032T8/800XP	3000	0.89	10,680	10,146	102%	114	59%	94	\$45.60
	F030T8SS/XP	2850	0.89	10,146	9,639	97%	107	56%	95	\$42.80
	F028T8SS/XP	2725	0.89	9,701	9,216	92%	100	52%	97	\$40.00
QTP4x32T8/UNV ISN-SC	F032T8/800XP	3000	0.88	10,560	10,032	101%	112	58%	94	\$44.80
	F030T8SS/XP	2850	0.88	10,032	9,530	96%	105	55%	96	\$42.00
	F028T8SS/XP	2725	0.88	9,592	9,112	91%	98	51%	98	\$39.20
QTP4x32T8/UNV PSX-SC	F032T8/841XPS	3100	0.71	8,804	8,364	84%	93	48%	95	\$37.20
	F030T8SS/XP	2850	0.71	8,094	7,689	77%	88	46%	92	\$35.20
	F028T8SS/XP	2725	0.71	7,739	7,352	74%	82	43%	94	\$32.80
QTP4x32T8/UNV PSN-SC	F032T8/800XP	3000	0.88	10,560	10,032	101%	118	61%	89	\$47.20
	F030T8SS/XP	2850	0.88	10,032	9,530	96%	111	58%	90	\$44.40
	F028T8SS/XP	2725	0.88	9,592	9,112	91%	104	54%	92	\$41.60
QHE4X32T8/UNV ISH	F032T8/800XP	3000	1.15	13,800	13,110	132%	144	75%	96	\$57.60
	F030T8SS/XP	2850	1.15	13,110	12,455	125%	135	70%	97	\$54.00
	F028T8SS/XP	2725	1.15	12,535	11,908	119%	127	66%	99	\$50.80
QHE 4X32T8/UNV ISN-SC	F032T8/800XP	3000	0.88	10,560	10,032	101%	108	56%	98	\$43.20
	F030T8SS/XP	2850	0.88	10,032	9,530	96%	102	53%	98	\$40.80
	F028T8SS/XP	2725	0.88	9,592	9,112	91%	95	49%	101	\$38.00
QHE 4X32T8/UNV ISL-SC	F032T8/800XP	3000	0.78	9,360	8,892	89%	95	49%	99	\$38.00
	F030T8SS/XP	2850	0.78	8,892	8,447	85%	89	46%	100	\$35.60
	F028T8SS/XP	2725	0.78	8,502	8,077	81%	84	44%	101	\$33.60

\* For UNV Models, Input Watts/System Watts shown at 120V.

<sup>1</sup> @ 8000 hours

SEE THE WORLD IN A NEW LIGHT

**SYLVANIA**



## OCTRON® AND OCTRON® CURVALUME® FLUORESCENT LAMPS

### OCTRON® 800 XP® 4 Foot SUPERSAVER® Lamps

Nominal Wattage	Bulb	Nominal Length (in)	MOL (in)	Base	Product Number	Ordering Abbreviation	Pkg Qty	Avg Rated Life		CCT (K)	CRI	Approx Lumens @25°C/77°F		Symbols & Footnotes
								@3hrs/start	@12hrs/start			Initial	Mean	
30	T8	48	47.78	Med Bipin	22063	F030/830/XP/SS/ECO	30	36000	(42000)	3000	85	2850	2710	31,33,76,94,95,16,20,23
					22060	F030/835/XP/SS/ECO	30	36000	(42000)	3500	85	2850	2710	31,33,76,94,95,16,20,23
					22062	F030/841/XP/SS/ECO	30	36000	(42000)	4100	85	2850	2710	31,33,76,87,95,16,20,23
					22202	F030/850/XP/SS/ECO	30	36000	(42000)	5000	85	2800	2660	31,33,76,94,95,16,20,23

### OCTRON® 800 XP® Lamps

Nominal Wattage	Bulb	Nominal Length (in)	MOL (in)	Base	Product Number	Ordering Abbreviation	Pkg Qty	Avg Rated Life		CCT (K)	CRI	Approx Lumens @25°C/77°F		Symbols & Footnotes
								@3hrs/start	@12hrs/start			Initial	Mean	
32	T8	48	47.78	Med Bipin	22039	F032/827/XP/ECO	30	36000	(42000)	2700	85	3000	2850	20,31,33,48,52,76,94
					21759	F032/830/XP/ECO	30	36000	(42000)	3000	85	3000	2850	20,31,33,48,52,76,94
					21763	F032/835/XP/ECO	30	36000	(42000)	3500	85	3000	2850	20,31,33,48,52,76,94
					21767	F032/841/XP/ECO	30	36000	(42000)	4100	85	3000	2850	20,31,33,48,52,76,94
					22026	F032/850/XP/ECO	30	36000	(42000)	5000	85	3000	2850	20,31,33,48,52,76,94
					21720	F032/865/XP/ECO	30	36000	(42000)	6500	85	2850	2708	20,31,33,48,52,76,94
					22594	F032/SKYWHITE/XP/ECO	30	36000	(42000)	8000	88	2650	2518	20,31,33,48,52,76,94

Nominal Wattage	Bulb	Nominal Length (in)	MOL (in)	Base	Product Number	Ordering Abbreviation	Pkg Qty	Avg Rated Life @3hrs/start	CCT (K)	CRI	Approx Lumens @25°C/77°F		Symbols & Footnotes
											Initial	Mean	
17	T8	24	23.78	Med Bipin	21587	F017/827/XP/ECO	30	24000	2700	85	1375	1305	31,33,44,48,52,76,87
					21785	F017/830/XP/ECO	30	24000	3000	85	1375	1305	31,33,44,48,52,76,87
					21778	F017/835/XP/ECO	30	24000	3500	85	1375	1305	31,33,44,48,52,76,87
					21907	F017/841/XP/ECO	30	24000	4100	85	1375	1305	31,33,44,48,52,76,87
					22193	F017/850/XP/ECO	30	24000	5000	85	1375	1305	31,33,44,48,52,76,87
					21718	F017/865/XP/ECO	30	24000	6500	85	1250	1188	31,33,44,48,52,76,87
25	T8	36	35.78	Med Bipin	21586	F025/827/XP/ECO	30	24000	2700	85	2175	2065	31,33,44,48,52,76,87
					21910	F025/830/XP/ECO	30	24000	3000	85	2175	2065	31,33,44,48,52,76,87
					21776	F025/835/XP/ECO	30	24000	3500	85	2175	2065	31,33,44,48,52,76,87
					21774	F025/841/XP/ECO	30	24000	4100	85	2175	2065	31,33,44,48,52,76,87

For more complete product information visit [www.sylvania.com](http://www.sylvania.com)

Symbols/Footnotes on page 160-165





Circline 4-Pin T5



T12 Med Bipin

**PENTRON® T5 FLUORESCENT LAMPS****PENTRON® Circline T5 Lamps**

Nominal Wattage	Bulb	Outside Diameter (in)	Base	Product Number	Ordering Abbreviation	Pkg Qty	Avg Rated Life @3hrs/start (@12hrs/start)	CCT (K)	CRI	Approx Lumens @25°C/77°F		Symbols & Footnotes
										Initial	Mean	
22	T5	8.66 - 9.06	2GX13	20702	<b>FPC22/830</b>	12	12000	3000	82	1800	1585	31,33,38,48,74
				20712	<b>FPC22/835</b>	12	12000	3500	82	1800	1585	31,33,38,48,74
				20715	<b>FPC22/841</b>	12	12000	4100	82	1800	1585	31,33,38,48,74
40	T5	11.54 - 12.01	2GX13	20731	<b>FPC40/830</b>	12	12000	3000	82	3200	2815	31,33,38,48,74
				20732	<b>FPC40/835</b>	12	12000	3500	82	3200	2815	31,33,38,48,74
				20733	<b>FPC40/841</b>	12	12000	4100	82	3200	2815	31,33,38,48,74
55	T5	11.54 - 12.01	2GX13	20741	<b>FPC55/830/HO</b>	12	12000	3000	82	4000	3520	31,33,38,48,74
				20750	<b>FPC55/835/HO</b>	12	12000	3500	82	4000	3520	31,33,38,48,74
				20751	<b>FPC55/841/HO</b>	12	12000	4100	82	4000	3520	31,33,38,48,74

**RAPID START LAMPS**

Rapid Start lamps, 3-foot and 4-foot in length, are typically designated by their wattage: e.g. F40 = Fluorescent 40W. Therefore lamps previously designated as F30T12/RS/SS, F40/SS and FB40/SS energy saving types will now be designated as F25T12/RS/SS, F34/SS and FB34/SS, respectively to comply with standard lamp designation nomenclature for these families of lamps.

**3' SUPERSAVER® Rapid Start Lamps**

Nominal Wattage	Bulb	Nominal Length (in)	MOL (in)	Base	Product Number	Ordering Abbreviation	Pkg Qty	Avg Rated Life @3hrs/start	CCT (K)	CRI	Approx Lumens @25°C/77°F		Symbols & Footnotes
											Initial	Mean	
25	T12	36	35.78	Med Bipin	23473	<b>F25T12/WW/RS/SS</b> <i>formerly F30T12/WW/RS/SS</i>	30	18000	3000	52	1975	1679	22,31,33
					23485	<b>F25T12/D35/RS/SS</b> <i>formerly F30T12/D35/RS/SS</i>	30	18000	3500	70	2050	1804	22,31,33
					23472	<b>F25T12/CW/RS/SS</b> <i>formerly F30T12/CW/RS/SS</i>	30	18000	4200	60	1925	1636	22,31,33

**3' Standard Rapid Start Lamps**

Nominal Wattage	Bulb	Nominal Length (in)	MOL (in)	Base	Product Number	Ordering Abbreviation	Pkg Qty	Avg Rated Life @3hrs/start	CCT (K)	CRI	Approx Lumens @25°C/77°F		Symbols & Footnotes
											Initial	Mean	
30	T12	36	35.78	Med Bipin	23490	<b>F30T12/SW/RP</b>	6	18000	3000	52	2275	1934	30,31,33,48
					23482	<b>F30T12/WW/RS</b>	30	18000	3000	52	2275	1934	30,31,33,48
					23474	<b>F30T12/D830/RS</b>	30	18000	3000	80	2290	2061	30,31,33,48
					23484	<b>F30T12/D35/RS</b>	30	18000	3500	70	2250	1980	30,31,33,48
					23139	<b>F30T12/D835/RS</b>	30	18000	3500	80	2290	2061	30,31,33,48
					23493	<b>F30T12/CW/RP</b>	6	18000	4200	60	2200	1870	30,31,33,48
					23476	<b>F30T12/CW/RS</b>	30	18000	4200	60	2200	1870	30,31,33,48
					23487	<b>F30T12/CW/RS/UPC</b>	30	18000	4200	60	2200	1870	30,31,33,48
					23478	<b>F30T12/D/RS</b>	30	18000	6500	76	1900	1615	30,31,33,48

**4' SUPERSAVER® Rapid Start Lamps**

Nominal Wattage	Bulb	Nominal Length (in)	MOL (in)	Base	Product Number	Ordering Abbreviation	Pkg Qty	Avg Rated Life @3hrs/start	CCT (K)	CRI	Approx Lumens @25°C/77°F		Symbols & Footnotes
											Initial	Mean	
34	T12	48	47.78	Med Bipin	24538	<b>F34WW/SS/ECO</b> <i>formerly F40WW/SS/ECO</i>	30	20000	3000	52	2750	2365	224,30,31,33,56,76
					24535	<b>F34D30/SS/ECO</b> <i>formerly F40D30/SS/ECO</i>	30	20000	3000	70	2800	2520	224,30,31,33,56,76

For more complete product information visit [www.sylvania.com](http://www.sylvania.com)

Symbols/Footnotes on page 160-165

**SPECIFICATION DATA**


Catalog #	Date	Type
Project	Prepared by	
Comments		

**High Efficiency Universal Voltage (120-277V)**




Item Number	OSRAM SYLVANIA Description	Input Current (AMPS)	Lamp Type	Rated Lumens (lm)	No. of Lamps	Ballast Factor (BF)	System Lumens	Mean Lumens	Input Power (W)	System Efficacy (lm/W)	BEF <sup>1</sup>
49968	QHE 1X32T8/UNV ISN-SC <i>Banded Pack</i>	0.25/0.11	F032/700	2800	1	0.88	2465	2220	28	88	3.14
		0.25/0.11	F032/XP	3000	1	0.88	2640	2480	28	94	3.14
		0.22/0.09	F030/SS	2850	1	0.88	2510	2360	26	97	3.38
		0.21/0.09	F028/SS	2725	1	0.88	2400	2255	25	96	3.52
49852	<i>Pallet Pack</i>	0.19/0.09	F025/SS	2475	1	0.88	2175	2045	22	99	4.00
49969	QHE 2X32T8/UNV ISN-SC <i>Banded Pack</i>	0.47/0.20	F032/700	2800	2	0.88	4930	4435	55	90	1.60
		0.47/0.20	F032/XP	3000	2	0.88	5280	4965	55	96	1.60
		0.44/0.19	F030/SS	2850	2	0.88	5015	4715	52	96	1.69
		0.40/0.18	F028/SS	2725	2	0.88	4800	4510	48	100	1.83
49853	<i>10-Pack</i>	0.36/0.16	F025/SS	2475	2	0.88	4355	4095	43	101	2.05
49854	<i>Pallet Pack</i>										
49970	QHE 3X32T8/UNV ISN-SC <i>Banded Pack</i>	0.69/0.30	F032/700	2800	3	0.88	7390	6650	83/82	89/90	1.07
		0.69/0.30	F032/XP	3000	3	0.88	7920	7445	83/82	95/97	1.07
		0.66/0.28	F030/SS	2850	3	0.88	7525	7075	78/77	96/98	1.14
		0.61/0.26	F028/SS	2725	3	0.88	7195	6760	72	100	1.22
49855	<i>10-Pack</i>	0.55/0.23	F025/SS	2475	3	0.88	6530	6140	65/64	101/102	1.38
49856	<i>Pallet Pack</i>										
49971	QHE 4X32T8/UNV ISN-SC <i>Banded Pack</i>	0.91/0.39	F032/700	2800	4	0.88	9855	8870	108/107	91/92	0.82
		0.91/0.39	F032/XP	3000	4	0.88	10560	9925	108/107	98/99	0.82
		0.86/0.37	F030/SS	2850	4	0.88	10030	9430	102/101	98/99	0.87
		0.80/0.35	F028/SS	2725	4	0.88	9590	9015	95	101	0.93
49857	<i>10-Pack</i>	0.71/0.30	F025/SS	2475	4	0.88	8710	8190	85	102	1.04
49858	<i>Pallet Pack</i>										

Banded Pack, (add "-B" to Description). Banded Pack and 10-Pack contain 10 pieces each. Pallet Pack contains 840 pieces, (add "-PAL" to Description).  
 1: Ballast Efficiency Factor (BEF) shown = (Ballast Factor x 100) divided by Input Power (Note: calculation based on lowest wattage value).




**QUICKTRONIC 1x32**




Note: For one lamp application, cap any blue lead. Insulate to 600 volts.

**QUICKTRONIC 2x32**



Note: For two lamp application, cap any blue lead. For one lamp application, cap any two blue leads. Insulate to 600 volts.

**QUICKTRONIC 3x32**




Note: For three lamp application, cap any unused blue lead. For two lamp application, cap two blue leads individually. For one lamp application, cap two blue leads, one red and one yellow lead individually. Insulate to 600 volts.

**QUICKTRONIC 4x32**

**Dimensions:**  
 Overall: 9.5" L x 1.68" W x 1.18" H  
 Mounting: 8.90"

**Product Weight:**  
 1.6 lbs each (approx)

**Wiring:**  
 Leads only  
 (no connectors provided)



Item Number	49970 QHE 3 x 32T8 / UNV ISN-SC	Case Size
QUICKTRONIC High Efficiency		Starting/Ballast Factor
Number of Lamps		Line Voltage (120-277V)
		Primary Lamp Wattage

Specifications subject to change without notice.

**Normal Ballast Factor**

**T8 Instant Start**

**High Efficiency**

**Performance Guide**

Data based upon SYLVANIA OCTRON® lamps shown. QUICKTRONIC® QHE Instant Start ballasts are also compatible with other lamp manufacturers equivalent lamp types that meet ANSI specifications.  
 QHE Instant Start ballasts will operate F17, F25 and F32 (and the SUPER-SAVER® & U-Bend equivalent) T8 lamps. Complete performance data is available in the QUICKSYSTEMS section of the SYLVANIA Electronic Ballast Catalog.

**Specifications**  
Data based on F32T8

- Starting Method: Instant Start
- Ballast Factor: 0.88
- Circuit Type: Parallel
- Lamp Frequency: >40kHz
- Lamp CCF: Less than 1.7
- Starting Temp:<sup>2</sup>
  - 20°F (-29°C) for OCTRON T8 lamps;
  - 60°F (16°C) for SUPERSAVER® T8 lamps
  - 0°F (-18°C) for F040T8
- Input Frequency: 50/60 Hz
- Low THD: <10%
- Power Factor: >98%
- Voltage Range: ±10% of 120-277V rated line (108-305V)
- UL Listed Class P, Type 1 Outdoor
- CSA Certified
- 70°C Max Case Temperature
- FCC 47CFR Part 18 Non-Consumer Class A Sound Rating
- NEMA Ballast Program compliant
- ANSI C62.41 Cat. A Transient Protection
- GFCI compatible
- Emergency ballast compatible
- Remote Mounting (Max. wire length from ballast case to lampholder):
  - 20 ft: full wattage T8s
  - 10 ft: energy saving T8s
  - 4 ft: 25W energy saving T8s
- <sup>2</sup> Operation below 50°F (10°C) may affect light output or lamp operation – see "Low Temp. Starting" definition.

**System Life / Warranty**


QUICKTRONIC products are covered by our QUICK 60+® warranty, a comprehensive lamp and ballast system warranty. For additional details, refer to our QUICK 60+ warranty bulletin.

**OSRAM SYLVANIA National Customer Service and Sales Center**  
 1-800-LIGHTBULB  
 (1-800-544-4828)  
 www.sylvania.com

the system solution®


QHE T8 ISN

# Magnetic T12 Rapid Start Fluorescent Ballasts




**T12 Rapid Start High Power Factor**


Item #	OSRAM SYLVANIA Description	Input Voltage (V <sub>AC</sub> )	No. of Lamps	Input Power (Watts)	Input Current (Amps)	BEF <sup>1</sup>	Ballast Factor (BF)	THD %	Power Factor	Min. Start Temp. (°F)	Certifications				Dim.	Wiring Dia.
											UL	SP	E	CSA		
<b>F34T12 SUPERSAVER® (34W) Rapid Start</b>																
48011**	MB1x40/120RS-SR NK	120	1	44	0.38	2.07	0.91	12	0.97	60	X	X	X	A	1	
48120**	MB1x40/277RS-SR NK	277	1	44	0.16	2.07	0.91	12	0.98	60	X	X	X	A	1	
48001	MB2x40/120RS-SR NK	120	2	73	0.65	1.21	0.88	16	0.94	60	X	X	X	A	2	
48121	MB2x40/277RS-SR NK	277	2	77	0.29	1.16	0.89	13	0.96	60	X	X	X	A	2	
<b>F40T12 (40W) Rapid Start</b>																
48011	MB1x40/120RS-SR NK	120	1	50	0.43	1.90	0.95	8	0.98	50	X	X	X	A	1	
48210	MB1x40/120RES-SR NK <sup>2,3</sup>	120	1	31	0.53	1.94	0.60	10	0.49	50	X	X		B	3	
48120	MB1x40/277RS-SR NK	277	1	50	0.19	1.88	0.95	8	0.98	50	X	X	X	A	1	
48001	MB2x40/120RS-SR NK	120	2	87	0.74	1.07	0.93	12	0.98	50	X	X	X	A	2	
48121	MB2x40/277RS-SR NK	277	2	89	0.34	1.06	0.94	12	0.94	50	X	X	X	A	2	



Wiring Diagram 1



Wiring Diagram 2



Wiring Diagram 3

## Specifications

**Sound Rating:** Class A  
**Starting Method:** Rapid Start  
**Circuit Type:** Series  
**Input Frequency:** 60 Hz  
**Wiring:** Leads Only

UL Listed Class P, Type 1 Outdoor  
 CSA Certified

1: BEF denotes Ballast Efficacy Factor  
 2: Normal Power Factor  
 3: For Residential Use Only

\*\* Operating only 1 energy saver lamp on this ballast may effect the operation and life of the lamp. Consult individual lamp manufacturer for lamp specifications.

Ballast is compatible with other manufacturer's equivalent lamp types that meet ANSI standards.


For lead lengths refer to page 30.

For additional ballast case dimensions refer to page 31.

Additional product information is available at [www.sylvania.com](http://www.sylvania.com).

## Warranty

SYLVANIA Magnetic Ballasts are covered for 3 years by our Magnetic Ballast Limited Warranty. For details go to [www.sylvania.com](http://www.sylvania.com).



Dim.	Dimensions (inches)				Packaging	
	L	W	H	M	Quantity	Weight (approx.)
A	9.5	2.38	1.5	8.91	10	3.5 lbs. ea.
B	6.5	1.94	1.38	6.0	16	2.3 lbs. ea.

## Ordering Guide

Item Number 48001 MB 2 x 40 120 RS SRNK ————— Ballasts are Individually Shrink Wrapped  
 Magnetic Ballast ————— Starting Method  
 Number of Lamps ————— Line Voltage  
 Primary Lamp Wattage —————

Specifications subject to change without notice.

OSRAM SYLVANIA National Customer Service and Sales Center  
 1-800-LIGHTBULB (1-800-544-4828)  
[www.sylvania.com](http://www.sylvania.com)




# APPENDIX F


## Product Data Sheet

Light Level Sensor

## East Facing Windows




September 22, 2009 – 7 AM




September 22, 2009 – 8 AM

### East Facing Windows




September 22, 2009 – 9 AM




September 22, 2009 – 10 AM

## East Facing Windows




September 22, 2009 – 11 AM




September 22, 2009 – 12 PM (noon)

## East Facing Windows




September 22, 2009 – 1 PM




September 22, 2009 – 2 PM



## East Facing Windows




September 22, 2009 – 3 PM




September 22, 2009 – 4 PM

## East Facing Windows



September 22, 2009 – 5 PM



September 22, 2009 – 6 PM


# APPENDIX G

## AGi32 Analysis

Hourly Daylight Illuminance Levels



# LightSaver® LS-101 Daylighting Controller



PROJECT
LOCATION/TYPE

## Product Overview

### Description

The LS-101 Daylighting Controller is a single zone, ON/OFF device which can be installed in an open or closed loop application to turn lights off automatically when sufficient natural daylight is present. It consists of an advanced digital multi-band photosensor that measures light similar to the way the human eye perceives it, an on-board microcontroller, and an LCD display. This photosensor is positioned behind a 100° cone that cuts off unwanted light, preventing false triggering.

### Operation

The LS-101 is a self-contained 24 VDC device with an extended range of 1-1400 fc that only requires a low voltage power pack to operate. By adjusting the setpoints, it will turn lighting systems off when the ambient light levels exceed the OFF setpoint, and will turn lighting systems back on when natural light levels have fallen far enough to warrant it. Because of its factory presets, many set-up applications require little or no adjustment of the settings. The LS-101 is expandable with a low voltage wall switch to enable manual override or with an occupancy sensor to enable its 'Hold On While Occupied' feature.

## Features

- Easy-to-read LCD Display prompts installer through set-up and accurately reflects the current control mode and light level.
- Four user-adjustable parameters: ON Setpoint, OFF Setpoint, OFF Setpoint Time Delay, and 'Hold On While Occupied' Mode (if wired with an occupancy sensor)
- Test Mode overrides the programmed Time Delay to allow installer to check if settings are correct.
- Control load status verification allows testing and confirmation that the wiring is correct by pressing the select button
- Manual Override for one hour (if wired with a low voltage, push-button wall switch)

## On, Off & Deadband Settings

The LS-101 features adjustable settings for ON setpoint, OFF setpoint and time delay, should adjustment be required. Adjusting the ON setpoint will automatically calculate your OFF setpoint to a predetermined deadband setting. The deadband can be adjusted to a value of 25%, 50%, 75% or 100% above the ON setpoint. When the sensed light level drops below the ON setpoint for 20 seconds, the output signal will switch on. And when the sensed light level exceeds the OFF setpoint for the length of the time delay, the output signal will switch OFF. The time delay can be adjusted to 3, 10, 20 or 30 minutes.

## Applications

The LS-101 Daylighting Controller can be used to control any type of lighting: incandescent, fluorescent, compact fluorescent (CFL) and HID. The sensors work in peripheral offices, skylit areas, cafeterias, warehouses and any other indoor areas with natural light access.

- Meets Section 119's requirement for daylighting in California's Title 24 Lighting Code.
- LED status indicator identifies if the LS-101 is in Override or Test Mode, or if the device has switched the lights on or off.
- Two mounting options for either top-lit or side-lit applications
- Low voltage leads are color coded to match wire colors on the power pack.
- Shape and design developed to prevent mis-alignments.
- Can be programmed in most daylight conditions




### Specifications

- Digital Multi-Band Photosensor Range: 1-1400 foot candles
- ON Setpoint Range: 1-850 foot candles
- Status Indicator: Multi-function green LED
- Power Requirements: 12/24 VDC; 7 mA typical
- Output Signal: 24VDC; maximum 120 mA
- Location: Suitable for dry interior locations
- Environment: 32 to 120°F, less than 90% rh
- Dimensions: 2.4" diameter x 0.7" deep (61mm x 17mm)
- Five-year warranty
- UL listed


### Wiring & Installation Location

#### Wiring Diagram




For other wiring diagrams, please visit the CAD Resource Center at [www.wattstopper.com](http://www.wattstopper.com)


#### Mounting Installation




#### Side Lighting Application



#### Top Lighting Application



### Deadband Level Chart



If the LS-101's photosensor lighting level drops below the ON setpoint, the lights will remain on. If the sensor's lighting level rises above the OFF setpoint, the LS-101 will automatically turn the lights off. If the sensor's lighting level remains in the predetermined deadband range (25%, 50%, 75% or 100%) the lighting will be passive until the sensor's level reaches the high or low setpoints.

### Ordering Information

Catalog No.	Voltage	Current	Photosensor Range	Deadband Adjustment Range
<input type="checkbox"/> LS-101	12-24 VDC	7 mA Typical	1-1400 foot candles	25%, 50%, 75% & 100% above the ON setpoint

# APPENDIX H

## CLTD/SCL/CLF Method

Calculation Tables

Table 8.7 Cooling Load Temperature Difference for Conduction through Glass and Doors

Solar Time, h		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
CLTD, °F		1	0	-1	-2	-2	-2	-2	0	2	4	7	9	12	13	14	14	13	12	10	8	6	4	3	2

Corrections: The values in the table were calculated for an inside temperature of 78°F and an outdoor maximum temperature of 95°F with an outdoor daily range of 21°F. The table remains approximately correct for other outdoor maximums (93 to 102°F) and other outdoor daily ranges (16 to 34°F), provided the outdoor daily

average temperature remains approximately 85°F. If the room air temperature is different from 78°F, and/or the outdoor daily average temperature is different from 85°F, see note 2, Table 8.3.

Table 8.8A Zone Types for Use with SCL and CLF Tables, Single-Story Building

No. Walls	Zone Parameters*			Glass Solar	Zone Type			Error Band	
	Floor Covering	Partition Type	Inside Shade		People and Equipment	Lights	Plus	Minus	
1 or 2	Carpet	Gypsum	**	A	B	B	9	2	
1 or 2	Carpet	Concrete block	**	B	C	C	9	0	
1 or 2	Vinyl	Gypsum	Full	B	C	C	9	0	
1 or 2	Vinyl	Gypsum	Half to None	C	C	C	16	0	
1 or 2	Vinyl	Concrete block	Full	C	D	D	8	0	
1 or 2	Vinyl	Concrete block	Half to None	D	D	D	10	6	
3	Carpet	Gypsum	**	A	B	B	9	2	
3	Carpet	Concrete block	Full	A	B	B	9	2	
3	Carpet	Concrete block	Half to None	B	B	B	9	0	
3	Vinyl	Gypsum	Full	B	C	C	9	0	
3	Vinyl	Gypsum	Half to None	C	C	C	16	0	
3	Vinyl	Concrete block	Full	B	C	C	9	0	
3	Vinyl	Concrete block	Half to None	C	C	C	16	0	
4	Carpet	Gypsum	**	A	B	B	6	3	
4	Vinyl	Gypsum	Full	B	C	C	11	6	
4	Vinyl	Gypsum	Half to None	C	C	C	19	-1	

\*A total of 14 zone parameters is fully defined in Chapter 2. Those not shown in this table were selected to achieve the minimum error band shown in the right-hand column for Solar Cooling Load (SCL). The error band for Lights and People

and Equipment is approximately 10%.

\*\*The effect of inside shade is negligible in this case.

Table 8.8C Zone Types for Use with SCL and CLF Tables, First Floor of Multistory Building

No. Walls	Mid-Floor Type	Zone Parameters*				Inside Shade	Zone Type			Error Band	
		Ceiling Type	Floor Covering	Partition Type	Glass Solar		People and Equipment	Lights	Plus	Minus	
1 or 2	2.5 in. Concrete	With	Carpet	Gypsum		Full	A	C	B	7	1
	2.5 in. Concrete	With	Carpet	Gypsum		Half to None	B	C	B	9	2
	2.5 in. Concrete	With	Carpet	Concrete block		Full	B	D	C	9	2
	2.5 in. Concrete	With	Carpet	Concrete block		Half to None	C	D	C	0	0
	2.5 in. Concrete	With	Vinyl	Gypsum		Full	C	D	D	19	0
	2.5 in. Concrete	With	Vinyl	Gypsum		Half to None	C	D	D	26	0
	2.5 in. Concrete	With	Vinyl	Concrete block		Full	D	D	D	6	3
	2.5 in. Concrete	With	Vinyl	Concrete block		Half to None	D	D	D	16	3
	2.5 in. Concrete	Without	Carpet	Gypsum		**	B	C	B	9	2
	2.5 in. Concrete	Without	Carpet	Concrete block		Full	C	D	C	19	0
	2.5 in. Concrete	Without	Carpet	Concrete block		Half to None	C	D	C	16	0
	2.5 in. Concrete	Without	Vinyl	Gypsum		Full	C	D	D	19	6
	2.5 in. Concrete	Without	Vinyl	Gypsum		Half to None	D	D	D	6	6
	2.5 in. Concrete	Without	Vinyl	Concrete block		Full	C	D	D	16	0
	2.5 in. Concrete	Without	Vinyl	Concrete block		Half to None	D	D	D	6	3
	1 in. Wood	**	Carpet	Gypsum		Full	A	A	B	2	-2
	1 in. Wood	**	Carpet	Gypsum		Half to None	B	A	B	6	6
	1 in. Wood	**	Carpet	Concrete block		Full	B	B	C	6	6
	1 in. Wood	**	Carpet	Concrete block		Half to None	C	B	C	7	3
	1 in. Wood	**	Vinyl	Gypsum		Full	B	B	B	18	6
1 in. Wood	**	Vinyl	Gypsum		Half to None	C	B	B	14	3	
1 in. Wood	**	Vinyl	Concrete block		Full	C	C	D	14	3	
1 in. Wood	**	Vinyl	Concrete block		Half to None	D	C	D	2	4	
3	2.5 in. Concrete	With	Carpet	Gypsum		Full	A	C	B	7	1
	2.5 in. Concrete	With	Carpet	Gypsum		Half to None	B	C	B	9	2
	2.5 in. Concrete	With	Carpet	Concrete block		**	B	C	B	9	2
	2.5 in. Concrete	With	Vinyl	Gypsum		Full	C	D	C	19	0
	2.5 in. Concrete	With	Vinyl	**		Half to None	C	D	C	26	0
	2.5 in. Concrete	With	Vinyl	Concrete block		Full	C	D	C	19	0
	2.5 in. Concrete	Without	Carpet	Gypsum		**	B	C	B	9	2
	2.5 in. Concrete	Without	Carpet	Concrete block		Full	B	C	B	9	2
	2.5 in. Concrete	Without	Carpet	Concrete block		Half to None	C	C	B	0	0
	2.5 in. Concrete	Without	Vinyl	Gypsum		Full	C	D	C	19	6
	2.5 in. Concrete	Without	Vinyl	**		Half to None	C	D	C	26	0
	2.5 in. Concrete	Without	Vinyl	Concrete block		Full	C	D	C	19	0
	1 in. Wood	**	Carpet	Gypsum		Full	A	A	B	2	-2
	1 in. Wood	**	Carpet	Gypsum		Half to None	B	A	B	6	6
	1 in. Wood	**	Carpet	Concrete block		**	B	B	B	6	6
	1 in. Wood	**	Vinyl	Gypsum		Full	B	B	C	18	6
	1 in. Wood	**	Vinyl	Gypsum		Half to None	C	B	C	14	3
	1 in. Wood	**	Vinyl	Concrete block		Full	C	B	C	7	3
	1 in. Wood	**	Vinyl	Concrete block		Half to None	C	B	C	14	3
	4	2.5 in. Concrete	With	Carpet	Gypsum		Full	A	B	B	4
2.5 in. Concrete		With	Carpet	Gypsum		Half to None	B	B	B	18	6
2.5 in. Concrete		With	Vinyl	Gypsum		**	C	C	C	19	3
2.5 in. Concrete		Without	Carpet	Gypsum		**	B	C	C	7	6
2.5 in. Concrete		Without	Vinyl	Gypsum		**	B	C	C	31	6
1 in. Wood		**	Carpet	Gypsum		Full	A	B	A	0	0
1 in. Wood		**	Carpet	Gypsum		Half to None	A	B	A	12	0
1 in. Wood		**	Vinyl	Gypsum		Full	B	B	B	16	8
1 in. Wood		**	Vinyl	Gypsum		Half to None	C	B	B	20	6

\*A total of 14 zone parameters is fully defined in Chapter 2. Those not shown in this table were selected to achieve the minimum error band shown in the right-hand column for Solar Cooling Load (SCL). The error band for Lights and People

and Equipment is approximately 10%.

\*\*The effect of this parameter is negligible in this case.



Table 8.9B Solar Cooling Load for Sunlit Glass—36° North Latitude, July

Glass Facing	Zone type A												Solar Time, h											
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
N	0	0	0	0	0	25	29	28	32	36	39	40	41	39	36	32	33	36	12	6	3	1	1	0
NE	0	0	0	0	0	79	129	139	120	84	58	50	45	41	37	32	26	17	7	3	2	1	0	0
E	0	0	0	0	0	86	153	184	182	155	107	67	54	45	39	33	26	17	7	3	2	1	0	0
SE	0	0	0	0	0	42	90	125	142	140	119	86	58	48	40	34	27	17	7	3	2	1	0	0
S	0	0	0	0	0	8	17	24	36	53	70	80	79	68	52	38	29	18	7	3	2	1	0	0
SW	0	0	0	0	0	8	17	24	30	35	38	57	90	122	141	144	127	85	32	15	8	4	2	1
W	1	0	0	0	0	8	17	24	30	35	38	40	66	115	159	188	191	149	53	25	12	6	3	2
NW	1	0	0	0	0	8	17	24	30	35	38	40	40	56	93	129	148	127	43	21	10	5	2	1
hor	0	0	0	0	0	20	66	120	171	215	246	263	265	251	221	178	124	66	28	13	7	3	2	1

Glass Facing	Zone type B												Solar Time, h											
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
N	2	2	1	1	1	21	25	25	29	33	36	38	38	38	35	32	33	35	15	10	7	5	4	3
NE	2	1	1	1	1	68	109	120	108	81	61	54	50	46	42	37	30	22	12	9	6	5	3	3
E	2	2	1	1	1	73	130	158	161	143	106	75	63	55	48	41	34	25	14	10	7	5	4	3
SE	2	2	1	1	1	36	77	107	124	125	111	85	64	55	48	41	33	24	14	10	7	5	4	3
S	2	2	1	1	1	7	14	21	31	47	61	71	72	65	52	41	33	24	13	9	7	5	4	3
SW	6	4	3	3	2	8	15	21	27	31	35	51	80	108	126	131	119	86	43	29	20	14	11	8
W	8	6	5	4	3	9	16	22	27	32	35	37	60	101	140	166	172	141	63	42	29	20	15	11
NW	6	5	4	3	2	8	15	21	27	31	35	37	38	52	84	115	132	117	49	32	22	16	11	8
hor	8	6	5	4	3	19	57	103	148	188	218	237	244	237	215	182	137	88	53	37	26	19	14	11

Glass Facing	Zone type C												Solar Time, h											
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
N	5	5	4	4	3	24	25	24	27	31	33	35	35	34	32	29	31	34	14	10	8	7	6	6
NE	7	6	6	5	5	71	106	111	95	68	51	48	46	44	41	37	32	24	16	13	11	10	9	8
E	9	8	8	7	6	77	128	148	145	124	89	62	56	52	47	43	37	29	20	17	15	13	12	11
SE	8	8	7	6	5	40	77	102	114	112	97	73	55	49	45	40	35	27	18	15	13	12	11	9
S	6	6	5	4	4	10	17	22	31	45	58	65	65	57	45	35	30	22	14	11	10	9	8	7
SW	13	12	10	9	8	14	20	25	29	32	35	50	77	102	116	118	105	74	34	26	21	18	16	14
W	16	15	13	12	11	16	22	27	31	34	36	37	59	98	132	154	155	122	48	34	28	24	21	18
NW	12	11	10	9	8	14	20	25	29	32	35	36	36	50	80	108	122	104	37	26	21	18	15	14
hor	24	22	19	17	16	31	66	107	145	178	203	217	220	212	192	161	122	81	53	44	38	34	30	27

Glass Facing	Zone type D												Solar Time, h											
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
N	8	7	6	6	5	21	22	21	25	27	30	31	32	32	31	29	30	32	17	14	12	11	10	9
NE	11	10	9	8	7	59	87	93	82	63	51	49	47	46	43	40	35	29	22	19	17	15	14	12
E	15	13	12	11	10	65	105	123	124	110	84	65	60	57	53	48	43	36	28	25	22	20	18	16
SE	13	12	11	10	9	36	65	85	96	97	87	70	56	52	49	45	40	33	25	22	20	18	16	15
S	9	9	8	7	6	11	16	20	27	39	49	56	57	52	43	36	31	26	19	16	15	13	12	11
SW	20	18	16	14	13	17	21	25	28	31	33	45	67	87	100	103	95	72	41	35	30	27	24	22
W	25	22	20	18	16	20	24	27	30	33	34	36	53	84	112	131	134	111	55	45	39	34	31	28
NW	18	17	15	14	12	16	20	24	27	30	32	34	34	45	69	92	104	92	42	34	29	26	23	21
hor	37	33	30	27	24	35	62	94	125	153	174	189	195	191	179	157	128	95	72	63	56	51	46	41

- Notes: 1. Direct application of data
- Standard double-strength glass with no inside shade
  - Clear sky, 21st day of month
2. Adjustments to table data
- Latitudes other than 24, 36, and 48° north
    - Linear interpolation is acceptable or a table for a specific latitude may be generated. See text.
  - Months other than July
    - For design purposes, the data will suffice for about 2 weeks from the 21st day of given month.
    - Tables may be generated for a specific month. See text.
  - Other types of glass and internal shade
    - Use shading coefficients as multiplier. See text.
  - Externally shaded glass
    - Use north orientation. See text.