



Senior Thesis Final Presentation



Rami Moussa
Mechanical Option
Advisor: Professor Treado

Peirce Hall, Kenyon College
Gambier, Ohio
4/11/11



Introduction

Project Information



Introduction

- Project and Facility Background Information
- Intention of Study
- Key Preliminary Research Findings

Studies:

- Depth: Combined Heat and Power (CHP) Study
 - CHP Concepts
 - Model Results & Analysis
- Breadth No.1: Acoustic Study

Conclusion

- Effectiveness Assessment of Systems

Acknowledgements

Questions




Kenyon College
The Village of Gambier
Peirce Hall history

Intention of Studies
LEED certification

Benefits
Reduced energy use
Qualify for incentives
Grants



The Village of Gambier



Kenyon College Campus



- I. Introduction
- II. Background Information
 - ▶ 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Kenyon College

Size: 66,640 SF

Occupancy types: A-2 (restaurant) and A-3 (assembly)

Dates of Construction: Spring 2006 - Spring 2008

Total Cost: \$18 Million

Project Team:

Owner - Kenyon College
 Architect - Gund Partnership
 Structural Engineer - LeMessurier Consultants, Inc.
 Construction Management - The Albert M. Higley Co.
 MEP and FP Engineers - Syska Hennessy Group, Inc.

Project Delivery: Design-Bid-Build



Rear View from North East



Rear View from South East



Servedy Link Construction



New Servedy Link



- I. Introduction
- II. Background Information
 - 1) Project Information
 - ▶ 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Heating

- Kenyon College natural gas fueled campus steam distribution
- Steam system (26 PSI)
- Hot water system (190°F)

Power

- Purchased from American Electric Power Company

LEED Credit Assessment	
Section	Points Acquired
Sustainable Sites	9/29
Water Efficiency	4/10
Energy and Atmosphere	5/35
Materials and Resources	2/14
Indoor Environmental Quality	6/15
Innovation Design	1/6
Regional Priority	0/4
Total	27/80



System Information

CHP Concepts

Selected Prime Mover



- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - ▶ 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Basic CHP Concept


-Burn fuel to generate electricity. Recover and distribute a fraction of the exhausted heat from heat engine.

Benefits

- Highly efficient process → lower utility cost
- Distributed generation
- Multiple uses for recovered heat
- Decreased exhaust emissions

Disadvantages

- Complex operation and maintenance
- Careful application design considerations





System Information

CHP Concepts

Selected Prime Mover



- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - ▶ 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Basic CHP Concept

-Burn fuel to generate electricity. Recover and distribute a fraction of the exhausted heat from heat engine.

Benefits

- Highly efficient process → lower utility cost
- Distributed generation
- Multiple uses for recovered heat
- Decreased exhaust emissions

Disadvantages


- Complex operation and maintenance
- Careful application design considerations

Spark Gap Calculation		
Cost per Million Btu		Spark Gap
Power	Fuel	
\$36	\$10	\$26


Components

- Heat engine (prime mover)
- Generator
- Heat exchanger
- System interconnections

Average Monthly Demand Loads



Average Monthly Demand Loads



Siemens' W501FD Test Facility in Berlin, Germany



Capstone C30 Microturbine



- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - ▶ 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Microturbine



Capstone C800 High-Pressure Natural Gas 800 kW Power Package

Benefits:

- Efficiency
- Emissions
- Capacity

Prime Mover Statistics:

- 800 kW power output
- 5,400 Btu/h heat output per kW generated





Selected Prime Mover Control Scenarios Results & Analysis



- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - ▶ 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

CHP Model

- Calculate demand load
- Apply desired control scenario
- Calculate prime mover output
- Analyze amount of demand met and amount of additional energy needed or wasted


Legend for the Following Tables:

Q_M,CS: Heating Demand Load Met By Campus Steam System
 Q_L,CHP: Unused Heat Generated by CHP Prime Mover
 Q_M,CHP: Heating Demand Load Met By CHP System

W_L,CHP: Unused Electricity Generated by CHP Prime Mover
 W_M,GRID: Electrical Demand met by Grid
 W_M,CHP: Electrical Demand Load Met By CHP System


Electric Load Following

- 100% of power demand met by CHP system
- Large amount of heat wasted during summer months



Thermal Load Following

- 100% heating demand met by CHP system
- System becomes inactive in summer months
- Large amount of power required from grid





- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - ▶ 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Summary of Results

- Electric load following design is most effective:
 - Independence from grid provider
 - Efficiency equal to grid provider
 - Wasted energy can potentially be utilized


Legend for the Following Tables:

Q_M,CS: Heating Demand Load Met By Campus Steam System
 Q_L,CHP: Unused Heat Generated by CHP Prime Mover
 Q_M,CHP: Heating Demand Load Met By CHP System

W_L,CHP: Unused Electricity Generated by CHP Prime Mover
 W_M,GRID: Electrical Demand met by Grid
 W_M,CHP: Electrical Demand Load Met By CHP System

Room for Improvement

- Absorption cooling
- Expanded system



System	Fuel	Δ from SHP	Power	Δ from SHP	Total	Δ from SHP
SHP	\$99,000		\$416,000		\$515,000	
CHP (Electric)	\$468,000	373%	\$0	-100%	\$468,000	-9%
CHP (Thermal)	\$190,000	92%	\$378,000	-9%	\$568,000	10%

EPA Annual Emissions Analysis (SHP Comparison)	CHP System	Displaced Electricity Production	Displaced Thermal Production	Emissions/Fuel Reduction	Percent Reduction
NOx (tons/year)	0.77	9.34	1.29	9.86	93%
SO2 (tons/year)	0.01	28.15	0.01	28.14	100%
CO2 (tons/year)	2,530	3,942	1,500	2,913	54%
Carbon (metric tons/year)	625	975	371	720	54%
Fuel Consumption (MBtu/year)	43,352	38,426	25,714	20,788	32%
Number of Cars Removed				481	



Results & Analysis

Acoustic Considerations

Acoustic Treatment




- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - ▶ 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Location Considerations


- Size
- Proximity to steam and power building entrances
- Sightlines to inner campus and surrounding areas

Acoustic Characteristics

- Single unit sound pressure level (SPL) is 65 dBA at 10 m
- Known part load high pitch noise
- Reduced SPL at Pierce Hall exterior wall below 50 dBA



Peirce Hall Site with Possible Prime Mover Location



Google Map of Peirce Hall Site



Acoustic Considerations Acoustic Treatment

Existing Lighting Conditions




- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - ▶ 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Acoustic Characteristics

- Construct a “sealed” housing structure for the prime movers
- Three CMU wall constructions explored:
 - 1) Standard 8” x 8” x 16” CMU [STC – 45]
 - 2) (1) with center grout and steel reinforcement [STC – 48]
 - 3) (2) with 2 coats oil based paint on each side [STC – 55]

Sound Pressure Level at Peirce Hall from 20 ft		
Type	STC	SPL (dBA)
1	45	33
2	48	30
3	55	23



Peirce Hall Site with Prime Mover Location



Google Map of Peirce Hall Site



Lighting Modification
Conclusion
 Acknowledgements



- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Meeting Intentions of Studies

- Recognizably efficient building systems
- Fuel savings provide improvement needed
- LEED prerequisites

LEED Credit Assessment	
Section	Points Acquired
Sustainable Sites	9/29
Water Efficiency	4/10
Energy and Atmosphere	5(+13)/35
Materials and Resources	2/14
Indoor Environmental Quality	6/15
Innovation Design	1/6
Regional Priority	0/4
Total	40/80



- I. Introduction
- II. Background Information
 - 1) Project Information
 - 2) System Information
- III. Combined Heat and Power
 - 1) CHP Concepts
 - 2) Selected Prime Mover
 - 3) Control Scenarios
 - 4) Summary of Results
- IV. Acoustic Study
 - 1) Acoustic Considerations
 - 2) Acoustic Treatment
- V. Conclusion
- VI. Acknowledgements

Sponsors:

Kenyon College
Syska Hennessy Group, Inc.

Kenyon College Contacts:

Mr. Mark Kohlman
Mr. Everett Neal

Syska Hennessy Group, Inc. Contacts:

Mr. William Caretsky
Mr. John Leeds

Pennsylvania State University Architectural Engineering department:

Professor Stephen Treado
Professor James Freihaut
Professor William Bahnfleth
Professor Bob Holland
Professor Kevin Parfitt



Peirce Hall, Kenyon College
Gambier, Ohio
Rami Moussa | Mechanical Option

Acknowledgements Questions

Peirce Hall, Kenyon College
Gambier, Ohio
Rami Moussa | Mechanical Option



Questions?