

Technical Report 1: *(Code Compliance with ASHRAE 62.1 & 90.1)*
Due Date: October 4, 2010

The Mirinda Center for Sports, Spirituality, and Character Development



Table of Contents


| | |
|-------------------------------------------------------------------------------|----|
| Executive Summary..... | 4 |
| General Building Overview | 4 |
| Mechanical System Overview | 5 |
| ASHRAE 62.1 Section 5 Compliance Report..... | 6 |
| 5.1 Natural Ventilation..... | 6 |
| 5.2 Ventilation Air Distribution | 6 |
| 5.3 Exhaust Duct Location..... | 6 |
| 5.4 Ventilation System Controls..... | 6 |
| 5.5 Airstream Surfaces | 6 |
| 5.6 Outdoor Air Intakes..... | 6 |
| Discussion 1 –(<i>Filtration</i>)..... | 7 |
| 5.7 Local Capture of Contaminants..... | 7 |
| 5.8 Combustion Air | 7 |
| 5.9 Particulate Matter Removal..... | 7 |
| 5.10 Dehumidification Systems | 7 |
| 5.11 Drain Pans | 7 |
| 5.12 Finned-Tube Coils and Heat Exchangers | 8 |
| 5.13 Humidifiers and Water-Spray Systems | 8 |
| 5.14 Access for Inspection, Cleaning, and Maintenance | 8 |
| 5.15 Building Envelope and Interior Surfaces..... | 8 |
| 5.16 Buildings with Attached Parking Garages | 8 |
| 5.17 Air Classification and Recirculation..... | 8 |
| 5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas | 8 |
| ASHRAE 62.1 Section 6 Compliance Report..... | 9 |
| 6 Minimum Outdoor Air Requirement..... | 9 |
| Discussion 2 –(<i>Ventilation Rate Calculation Procedure</i>)..... | 10 |
| ASHRAE 90.1 COMPLIANCE..... | 11 |
| 5. Building Envelope..... | 11 |
| 5.4 Air Leakage..... | 12 |
| 5.5 Prescriptive Building Envelope Option..... | 12 |
| 6. Heating, Ventilation, and Air Conditioning | 13 |

| | |
|--------------------------------------------------|----|
| 7 Service Water | 13 |
| 8 Power | 14 |
| 9 Lighting..... | 14 |
| Discussion 3 – <i>(Overall Compliance)</i> | 15 |
| Appendix A..... | 16 |
| RTU_1 –Minimum Airflow Calculation..... | 16 |
| RTU_2 –Minimum Airflow Calculation..... | 17 |
| RTU_3 –Minimum Airflow Calculation..... | 18 |
| RTU_4–Minimum Airflow Calculation..... | 18 |
| RTU_5 –Minimum Airflow Calculation..... | 18 |
| RTU_6 –Minimum Airflow Calculation..... | 19 |

Executive Summary


General Building Overview

The Miranda Center for Sports, Spirituality, and Character Development (CSSCD) is a two story building. The ground floor entrance is at the second level in the front of the building, while the lower level is underground at the front of the building while the sloping topography brings the lower level to exit at ground level in the rear of the building. See East Elevation below for orientation.



East Elevation

The core of the building is the main gymnasium that seats up to 1450 spectators at the lower level. Wrapped around the main gym at the second level is an indoor running track. The outer most perimeter is as follows: Offices on the east side, Auxiliary gym on the north side, multipurpose and fitness center on the west side, and open glazed atrium on the south side. See Layout below for orientation.



Layout

Mechanical System Overview

The Mirenda Center is primarily heated and cooled by 6 roof top air handling units, their location is above the auxiliary gym. RTU-5&6 serve the main gymnasium and the indoor running track in unison. RTU-3 & 4 are Aaon type and serve only the auxiliary gym. RTU-1 and 2 serve the remaining perimeter spaces: the multipurpose and fitness center, the offices, and atrium. There is a secondary split system to cool specified office areas and other specialty spaces. The condensing unit for the split system is located on the roof of the auxiliary gym with the RTU's. Liquid refrigerant is pipe to the locations of each individual load point. The concept is a smaller secondary system will be used more frequently for the daily office cooling. This is because there will not be a large scale sports event every day. Thus it would be inefficient to run the large roof top units daily. There is natural gas burners for heating of the RTU's and reheats for each zone in the constant air volume boxes. There is also electric resistant strip heat around the perimeter of the building. This electric strip heat is primarily to keep condensation from forming on the glazing.

ASHRAE 62.1 Section 5 Compliance Report

ASHRAE Standard 62.1 is used to specify measures that will improve the indoor air quality in a building that is both acceptable for the human occupants and will minimize health effects. Section 5 details these measures for systems and equipment.

5.1 Natural Ventilation

There is no opportunity for occupant controlled natural ventilation in the form of operable windows.

5.2 Ventilation Air Distribution

Variable Air Volume boxes are used to control the ventilation airflow to each space as required by Section 6 of this standard. An analysis of the compliance with this section is included in this report.

5.3 Exhaust Duct Location

All air exhaust ducts are sealed following the requirements of SMACNA Seal Class A, therefore this section does not apply. Also all exhaust ducts are on the east and west side of the building which are in a safe location.

5.4 Ventilation System Controls

Run conditions of the air handling units are based upon an operator adjustable schedule in one of the following modes: occupied, unoccupied, & disabled. The roof top units are equipped with manual and automatic controls to enable the fan system to operate whenever the space being served is occupied.

5.5 Airstream Surfaces

The duct systems installed are specifically called out to comply with ASTM C 1071 which prevents any erosion due to direct contact of airstream surfaces. This is achieved by applying a coating to the ducts with glass fibers. The ducts also comply with NFPA 90A&B which insures correct installation to protect against possibility of mold growth due to warm air.

5.6 Outdoor Air Intakes

The location of exhaust fans relative to outdoor air intakes was analyzed using Table 5.1. Results are as follows:

EF-3 Auxiliary Gym Restrooms Contaminated within 30ft of RTU 2 and RTU 4
Exhaust fan number 3 is at the rear of the building within 30 feet of the intake of RTU 2 and RTU 4. This could lead to bringing contaminated lavatory air into Auxiliary Gym and Perimeter Zones but is highly unlikely.

Discussion 1 –(Filtration)

The Mirenda Center has two stages of filtration. Stage one is located at the point of entry for outdoor air. All air that is brought in from outdoors is filtered with a Merv 13 filter. Merv filtration is described more in depth in ASHRAE Standard 52.5. Merv filters range from 1 to 20; 1 being the least effective only able to filter as much as a carpet fiber, and 20 being the most effective able to filter particulate matter as small as 10^{-12} meters. The Merv 13 filter is 89-90% efficient in filtering particulate matter as small as the range of $(0.3-1.0) \times 10^{-12}$ meters. The second stage of filtration is at the site of the contaminant source. There are multiple constant volume boxes that have Merv 13 filters on the return air (induced air) side that also receive air from a variable air supply damper which was already filtered at stage one. The filtration process for any and every room reaches the maximum cleanliness in approximately 30 mins or 3 complete air changes. Having two stages of filtration ensures a high standard indoor air quality, assuming consistent maintenance of filter replacement once full.

5.7 Local Capture of Contaminants

All potentially harmful exhaust is ducted to the roof and exhausted from here, meeting the requirements of the section.

5.8 Combustion Air

All heating is in Natural Gas Burners in the Roof Top Units that are certified by the manufacturer, and is exterior to the building thus the requirement for combustion air is met. Auxiliary heat is provided by electric resistance strip heat along perimeter of building.

5.9 Particulate Matter Removal

All air handling units are equipped with two sets of replaceable type MERV 8 prefilters and two sets of cartridge type MERV 13 final filters. During construction only one set of filters is to be installed until after the final clean up of the area after which the second set will be installed. Both filters exceed the minimum requirement of this section of MERV 6.

5.10 Dehumidification Systems

Other than the dehumidification that is within the roof top units, no other system is installed. The installed roof top units dehumidify to 53/53 °F with is above 65%, however upon mixing with the room air, the RH decrease to meet the requirement for 65% RH. Thus this section complies.

5.11 Drain Pans

Specifications call for a double-sloped, insulated, stainless steel drain pan is to be provided with the cooling coil and will extend beyond the leaving side of the coil and under the cooling coil connections. These specifications meet the sections requirements. All drain connections must be used and individually trapped to ensure a minimum amount of condensate accumulation in the drain pans. ABS type cement should be used to join the drain pipe connections.

5.12 Finned-Tube Coils and Heat Exchangers

Aluminum-plate fin and seamless copper tube will be provided with stainless steel drain pan underneath. Heat Exchanger: Stainless-steel construction for natural-gas-fired burners. The coils and heat exchangers are spaced at a minimum of 18 inches for access to maintain. The access to the coils has been met by manufacturer, and bears ARI Certification.

5.13 Humidifiers and Water-Spray Systems

There is no steam or direct evaporation humidifiers, air washers or other water spray systems used in this project so this section does not apply.

5.14 Access for Inspection, Cleaning, and Maintenance

All ventilation equipment is installed with adequate space to facilitate routine maintenance and inspection. All air handling units and fan powered boxes are equipped with access doors or panels for easy access, meeting the requirements of the standard.

5.15 Building Envelope and Interior Surfaces

A vapor barrier coupled with airspace behind the brick finish provides an adequate means of preventing condensation from forming on cold surfaces of the building envelope. Extensive details for vapor barrier are described thoroughly in the specifications. The requirement for the building envelope has been met.

5.16 Buildings with Attached Parking Garages

The Mirenda Center does not have an attached parking garage so this section does not apply.

5.17 Air Classification and Recirculation

A majority of the building air can be classified as Class 1 and recirculated. Exhaust fall into Classes 3 & 4 and is directly exhausted with no recirculation. Any Class 2 air can be re-designated as Class 1 air by circulating through the energy recovery ventilator. These classifications meet the requirements of the section.

5.18 Requirements for Buildings Containing ETS Areas and ETS-Free Areas

The Mirenda Center is a smoke-free facility therefore this section does not apply.

ASHRAE 62.1 Section 6 Compliance Report

ASHRAE Standard 62.1 Section 6 is a prescriptive procedure to calculate the minimum outdoor air intakes required based on contaminant sources and source strengths typical for the particular space type. This calculation requires an analysis of the spaces served, occupancy level and square footage.

6 Minimum Outdoor Air Requirement

The minimum ventilation requirement is in place to ensure that occupants will have acceptable air. The code derives a system for supplying ventilation air (Outdoor Air) to space as a function of number of people and square floor area. The equation is as follows: $V_{bz}=(R_p \cdot P_z)+(R_a \cdot A_z)$ where;

V_{bz} is the breathing zone outdoor airflow

R_p is the outdoor airflow rate required per person

P_z is the number of people of in the zone that is being considered

R_a is the outdoor airflow rate required per square foot of floor area

A_z is the square foot area of the zone being considered.

E_z is the zone air distribution effectiveness, for the building is unity

V_{oz} is the zone outdoor airflow

V_{ot} is the outdoor air intake airflow

V_{pz} is the minimum expected primary airflow for design purposes

Z_p is the zone primary outdoor air fraction

V_{ou} is the uncorrected outdoor air intake

D is the occupant diversity

P_s is the system population

$$V_{bz} = R_p \cdot P_z + R_a \cdot A_z \quad V_{ot} = \sum_{all\ zones} V_{oz}$$

Discussion 2 –(Ventilation Rate Calculation Procedure)

According to the prescribed Ventilation Rate Calculation Procedure the building complies. Each air handling unit exceeds the minimum value required for their cooling zones. See appendix A for spreadsheet calculation data.

| | Calculated | Design Minimum | Percent | Design Supply | ASHRAE 62.1 |
|-------|-------------|----------------|----------|---------------|-------------|
| | Outdoor Air | Outdoor Air | Exceeded | Air Flow | Compliance |
| RTU_1 | 8800 | 3812 | 43% | 22000 | yes |
| RTU_2 | 8500 | 5054 | 59% | 17000 | yes |
| RTU_3 | 3600 | 1123 | 31% | 8000 | yes |
| RTU_4 | 3600 | 1249 | 35% | 8000 | yes |
| RTU_5 | 12100 | 4750 | 39% | 20100 | yes |
| RTU_6 | 12100 | 4193 | 35% | 20100 | yes |

Figure 1

ASHRAE 90.1 COMPLIANCE

ASHRAE Standard 90.1 is the energy standard for buildings with the exception of low-rise residential buildings. The Mirenda Center is an educational building therefore it qualifies for analysis using this standard. The prescriptive requirements for this standard include the building envelope, mechanical equipment efficiencies, service hot water, power and lighting density. Included below is an analysis of these prescriptive requirements applied to The Mirenda Center.

5. Building Envelope

Section 5 of this standard is dedicated to describing the performance requirements for a structure's building envelope. These requirements are dependent on both the location of the building and the space conditioning category.

To assess the compliance to this standard, the climate category first needs to be determined. Using Table A-1 in the Normative Appendix A of this standard it was determined that Aston Pennsylvania, which is situated in Delaware County, is classified as Climate **Zone 4A**.

The method to be used to analyze the building envelope is detailed in Section 5.5: Prescriptive Building Envelope Option. In order to use this method two prerequisites must be met. Firstly the total vertical fenestration area cannot exceed 40% of the gross wall area. The table below shows that the building, with a total of 39.7% glazing meets this requirement. The second prerequisite is that skylight fenestration cannot exceed 5% of the gross roof area. The Mirenda Center does not have any skylights, therefore this requirement is met. Because both of these prerequisites are met, the building envelope can be analyzed using the Prescriptive Building Envelope Option.

| | |
|---------------------|-----------------------|
| Fenestrations West | 1305 ft ² |
| Walls West | 4525 ft ² |
| Fenestrations South | 3672 ft ² |
| Walls South | 438 ft ² |
| Fenestrations East | 1338 ft ² |
| Walls East | 5204 ft ² |
| Fenestrations North | 626 ft ² |
| Walls North | 7283 ft ² |
| | |
| Wall Total | 17450 ft ² |

| | |
|---------------------|----------------------|
| Fenestrations Total | 6941 ft ² |
| Ratio | 0.397765 |

Figure 2

5.4 Air Leakage

The building envelope is sealed, caulked, gasketed, and weather-stripped with prescribed methods according to ASTM C1193. This standard allows for LEED Accreditation for Sustainable Design. There were laboratory Pre-Construction Test and Field Pre-Construction Testing done. No certification found by the National Fenestration Rating Council was found in the specifications.

5.5 Prescriptive Building Envelope Option

The building envelope consists of face brick, air space, and masonry cmu block with fenestration opening on the east and west walls. The south wall is completely covered in store front glazing with a U-factor of 0.33. The roof assembly is built up type consisting of metal deck with 6 inch rigid insulation that resists a majority of the thermal heat transfer consisting of an R-value of 29. The slab size varies from 4 to 6 inches in depth with 2" rigid insulation underneath. The 2 inch insulation accounts for a majority of the thermal resistance to heat flow of R-value of 12.

The variation in wind speed with decrease the Resistance values for all assemblies exposed to the outdoor environment. This decrease is significant and was considered in the design. See figure 3 below for ASHRAE 90.1 for compliance.

| | Actual | 90.1 Req. | Comply |
|----------------------|-----------|-----------|--------|
| Fenestration U-Value | 0.33 | 0.5 | yes |
| SHGC | 0.33-0.55 | 0.55 | yes |
| Wall Type #1 R_Value | 15 | 13 | yes |
| Wall Type #2 R_Value | 16 | 13 | yes |
| Roof R_Value | 29 | 20 | yes |
| Slab R_Value | 12 | NR | yes |

Figure 3

6. Heating, Ventilation, and Air Conditioning

The purpose of section 6 of this code is to ensure that The Mirenda Center HVAC mechanical equipment complies with the mandated efficiencies: specifically the Horsepower and Energy Efficiency Ratio for the Roof Top Units, Ducts, and refrigerant piping. Duct insulation is minimum of 1 inch thick with a R-Value of 3.85 (h ft² F)/(BTU). This meets the minimum 90.1 requirement of 3.5 (h ft² F)/(BTU) for Duct insulation. All roof top units have a minimum of 1.5 thick insulation with a R-Value of 5.8 (h ft² F)/(BTU). All ducts are exposed to interior heated spaces thus all ducts do not have a minimum insulation requirement. See figure 4 below for Air handling equipment power and efficiency compliance. Also see Appendix A table B for 90.1 requirements for duct insulation.

| Equipment | hp | | CFMs*0.0011 | Comply | Design | EER | Comply |
|-----------|-------|---|-------------|--------|--------|------|--------|
| RTU_1 | 15.6 | ≥ | 24.2 | yes | 9.8 | 9.0 | yes |
| RTU_2 | 10.8 | ≥ | 18.7 | yes | 9.4 | 9.0 | yes |
| RTU_3 | 6.2 | ≥ | 8.8 | yes | 11.8 | 9.3 | yes |
| RTU_4 | 6.2 | ≥ | 8.8 | yes | 11.8 | 9.3 | yes |
| RTU_5 | 14.7 | ≥ | 22.1 | yes | 9.4 | 9.0 | yes |
| RTU_6 | 14.7 | ≥ | 22.1 | yes | 9.4 | 9.0 | yes |
| AC_1 | 0.412 | ≥ | 0.4 | yes | 10.8 | 10.0 | yes |
| AC_2 | 0.412 | ≥ | 0.6 | yes | 10.8 | 10.0 | yes |
| AC_3 | 0.558 | ≥ | 0.6 | yes | 10.8 | 10.0 | yes |
| AC_4 | 0.558 | ≥ | 0.6 | yes | 10.8 | 10.0 | yes |
| AC_5 | 0.558 | ≥ | 0.6 | yes | 10.8 | 10.0 | yes |
| AC_6 | 0.866 | ≥ | 0.9 | yes | 10.8 | 10.0 | yes |
| AC_7 | 0.076 | ≥ | 0.8 | yes | 10.8 | 10.0 | yes |

Figure 4

7 Service Water

There are 2 Lochinvar domestic hot water heaters with an 85% thermal fuel to water efficiency. This meets 90.1 section 7 requirements for 80% or better efficiency.

8 Power

This section prescribes the allowable voltage drop for a building's power system. The building designer designed based on this standard and sized all feeders and branch circuits to comply with the required 3% and 3% respective with the total 5% voltage drops at the design load. The two main distribution feeders comply with 3%. Branch circuiting could vary, because it is out of control of the designer. Feeder 1 comes from the main transformer and feed the main distribution panel which is approximately 85 feet in length. This complies with the max length of 161 feet allowable for 3% voltage drop. See figure below for feeder 2 which also complies.

| Type | Length actual ft | Length max ft | Current | Vd % | Constant | Conductivity | Area cm |
|----------|------------------|---------------|---------|------|----------|--------------|---------|
| Feeder 1 | 85 | 161 | 2000 | 3 | 1.73 | 12.9 | 2400000 |
| Feeder 2 | 120 | 161 | 1000 | 3 | 1.73 | 12.9 | 1200000 |

9 Lighting

The majority of light loads meet the power density requirements. See table 5 below for results.

| Space Classification | Lights, W/sf | 90.1 Compliance | |
|----------------------|--------------|-----------------|-----|
| Main Gym | 2.26 | 2.4 | yes |
| Aux Gym | 1.27 | 2.4 | yes |
| Stairs | 0.3 | 0.6 | yes |
| PE Lockers | 0.9 | 0.6 | no |
| Varsity Lockers | 0.9 | 0.6 | no |
| Mech/Elec | 0.44 | 1.5 | yes |
| Student Lounge | 0.85 | 1.2 | yes |
| Corridor | 1 | 0.5 | no |
| Lobby | 1.4 | 1.3 | no |
| Coach Lockers | 0.78 | 0.6 | no |
| Office | 1 | 1.1 | yes |
| Training Room | 0.84 | 1.2 | yes |
| Equipment Storage | 0.5 | 0.3 | no |
| Gym Storage | 0.5 | 0.3 | no |
| Restroom | 0 | 0.9 | yes |
| Hospitality Suite | 1.6 | 1.1 | no |
| CSSCD Offices | 0.9 | 1.1 | yes |
| Classroom | 0.8 | 1.4 | yes |
| Athletics Office | 0.7 | 1.1 | yes |

| | | | |
|----------------|------|-----|-----|
| Track | 1.5 | 2.7 | yes |
| Fitness Center | 0.3 | 0.9 | yes |
| Studio | 0.26 | 1 | yes |
| Multipurpose | 0.3 | 1.3 | yes |
| Dining | 0.9 | 1 | yes |
| Alumni Hall | 1.1 | 1.2 | yes |
| IT/Media Rooms | 2.3 | 1.2 | yes |

Table 5

Discussion 3 – (Overall Compliance)

The building as a whole complies with the ASHRAE standards 62.1 and 90.1-2007. Expect for the lighting power per square foot of area. These values may have been changes since the 2004 version of the 90.1 code. However the areas where the values exceed the maximum allowable are justified by other areas that are significantly lower than the maximum.

A potential risk taken on by the mechanical designer pertains to the split-system. According to there is no opportunity to drain condensation from the evaporative coils placed in there specified rooms. If the latent load in any specific room were to get exceedingly large, moisture could form on the coil and condense directly into the space. Example would be for open office space to have an annual family holiday party for employees.

Appendix A

RTU_1 -Minimum Airflow Calculation

| Description | System | Total Flr Area | No. People | Rp cfm/per | Ra cfm/ft ² | Vbz = Total |
|---------------------------|--------|----------------|------------|---------------|---------------------------|----------------|
| 116 Equipment Storage | RTU-1 | 1,250 | 0 | 0 | 0.12 | 150 |
| 115 Gym Storage | RTU-1 | 1,200 | 0 | 0 | 0.12 | 144 |
| 114 Laundry room | RTU-1 | 250 | 2 | 5 | 0.12 | 40 |
| 108 Training Room | RTU-1 | 1,000 | 10 | 20 | 0.06 | 260 |
| 113 Office | RTU-1 | 110 | 1 | 5 | 0.06 | 11.6 |
| 112 Exam | RTU-1 | 100 | 1 | 10 | 0.18 | 28 |
| 111 Office | RTU-1 | 50 | 1 | 5 | 0.06 | 8 |
| 110 Training Storage | RTU-1 | 140 | 0 | 0 | 0.12 | 16.8 |
| 105 Womens referee Toilet | RTU-1 | 335 | 4 | 0 | 0.5 | 167.5 |
| 106 Mens referee Toilet | RTU-1 | 335 | 4 | 0 | 0.5 | 167.5 |
| 102 Elevator Lobby | RTU-1 | 320 | 0 | 5 | 0.06 | 19.2 |
| 101 Stair | RTU-1 | 320 | 0 | 0 | 0.06 | 19.2 |
| 142 Corridor West | RTU-1 | 980 | | 0 | 0.06 | 58.8 |
| 142 Lower lounge | RTU-1 | 860 | 5 | 5 | 0.06 | 76.6 |
| 232 Fitness Ctr | RTU-1 | 3,275 | 33 | 20 | 0.06 | 856.5 |
| 233 Performance Studio | RTU-1 | 600 | 24 | 20 | 0.06 | 516 |
| 235 Multi Purpose | RTU-1 | 1,210 | 42 | 5 | 0.06 | 282.6 |
| 238 Corridor West | RTU-1 | 480 | 0 | 0 | 0.06 | 28.8 |
| 237 Elevator Lobby | RTU-1 | 200 | 0 | 5 | 0.06 | 12 |
| 203 Lobby/Lounge | RTU-1 | 3,000 | 90 | 5 | 0.06 | 630 |
| 204 Café | RTU-1 | 410 | 13 | 7 | 0.06 | 115.6 |
| 141 Corridor | RTU-1 | 540 | 0 | 0 | 0.06 | 32.4 |
| 121 122 Exteroir storage | RTU-1 | 560 | 0 | 0 | 0.12 | 67.2 |
| 148 Gym Storage | RTU-1 | 300 | 0 | 0 | 0.12 | 36 |
| 145 Gym Storage | RTU-1 | 563 | 0 | 0 | 0.12 | 67.56 |
| | Total | | | | | 3811.86 |

RTU_2 - Minimum Airflow Calculation

| Description | System | Total Flr Area | No. People | Rp cfm/per | Ra cfm/ft ² | Vbz = Total |
|-----------------------------|--------|----------------|------------|------------|------------------------|-------------|
| 138 Corridor East | RTU-2 | 980 | 0 | 0 | 0.06 | 58.8 |
| 132 Womens Varsity Toilet | RTU-2 | 1050 | 12 | 0 | 0.5 | 525 |
| 133 Mens Varsity Toilet | RTU-2 | 1050 | 10 | 0 | 0.5 | 525 |
| 134 Womens PE Toilet | RTU-2 | 1050 | 12 | 0 | 0.5 | 525 |
| 135 Mens PE Toilet | RTU-2 | 1050 | 10 | 0 | 0.5 | 525 |
| 136 Storage | RTU-2 | 125 | 0 | 0 | 0.12 | 15 |
| 140 Lower Lounge | RTU-2 | 860 | 5 | 5 | 0.06 | 76.6 |
| 217 Athletic Offices | RTU-2 | 1160 | 7 | 5 | 0.06 | 104.6 |
| 218 Office | RTU-2 | 150 | 1 | 5 | 0.06 | 14 |
| 219 Office | RTU-2 | 110 | 1 | 5 | 0.06 | 11.6 |
| 220 Office | RTU-2 | 220 | 1 | 5 | 0.06 | 18.2 |
| 221 Office | RTU-2 | 120 | 1 | 5 | 0.06 | 12.2 |
| 222 Office | RTU-2 | 110 | 1 | 5 | 0.06 | 11.6 |
| 223 Copy | RTU-2 | 150 | 1 | 10 | 0.5 | 85 |
| 216 Classroom | RTU-2 | 1100 | 73 | 10 | 0.12 | 862 |
| 224 Corridor East | RTU-2 | 1000 | 0 | 0 | 0.06 | 60 |
| 215 Conference room | RTU-2 | 280 | 17 | 5 | 0.06 | 101.8 |
| 210 CSSCD Offices | RTU-2 | 135 | 3 | 5 | 0.06 | 23.1 |
| 212 CSSCD Offices | RTU-2 | 120 | 1 | 5 | 0.06 | 12.2 |
| 211 CSSCD Offices | RTU-2 | 120 | 1 | 5 | 0.06 | 12.2 |
| 214 CSSCD Offices | RTU-2 | 265 | 1 | 5 | 0.06 | 20.9 |
| 207 Mens Room | RTU-2 | 290 | 4 | 0 | 0.5 | 145 |
| 208 Womens Room | RTU-2 | 290 | 4 | 0 | 0.5 | 145 |
| 205 Reflection Center | RTU-2 | 1250 | 52 | 5 | 0.06 | 335 |
| 203 Lobby Lounge | RTU-2 | 3000 | 87 | 5 | 0.06 | 615 |
| 123 Mens Restroom | RTU-2 | 140 | 2 | 0 | 0.5 | 70 |
| 124 Womens Restroom | RTU-2 | 140 | 2 | 0 | 0.5 | 70 |
| 126 Caterer (as Break Room) | RTU-2 | 250 | 6 | 5 | 0.06 | 45 |
| 146 Gym Storage | RTU-2 | 240 | 0 | 0 | 0.12 | 28.8 |
| | Total | | | | | 5053.6 |

RTU_3 -Minimum Airflow Calculation

| Description | System | Total Flr Area | No. People | Rp cfm/per | Ra cfm/ft ² | Vbz = Total |
|------------------------|--------------|----------------|------------|------------|------------------------|-------------|
| 119 Vestibule | RTU-3 | 204 | 0 | 0 | 0.06 | 12.24 |
| 120A Aux Gym | RTU-3 | 3348 | 100 | 7.5 | 0.06 | 950.88 |
| 121 Ext Storage | RTU-3 | 300 | 0 | 0 | 0.12 | 36 |
| 122 Storage | RTU-3 | 247 | 0 | 0 | 0.12 | 29.64 |
| 230 Storage | RTU-3 | 785 | 31 | 0 | 0.12 | 94.2 |
| | Total | | | | | 1122.96 |

RTU_4-Minimum Airflow Calculation

| Description | System | Total Flr Area | No. People | Rp cfm/per | Ra cfm/ft ² | Vbz = Total |
|----------------------|--------|----------------|------------|------------|------------------------|-------------|
| 120B Aux Gym | RTU-4 | 3348 | 100 | 7.5 | 0.06 | 950.88 |
| 123 Men's Room | RTU-4 | 210 | 3 | 0 | 0.5 | 105 |
| 124 Women's Room | RTU-4 | 210 | 5 | 0 | 0.5 | 105 |
| 126 Catering Kitchen | RTU-4 | 168 | 0 | 7.5 | 0.18 | 30.24 |
| 127 Vestibule | RTU-4 | 187 | 0 | 0 | 0.06 | 11.22 |
| 225 Cardio Fitness | RTU-4 | 785 | 0 | 20 | 0.06 | 47.1 |
| | Total | | | | | 1249.44 |

RTU_5 -Minimum Airflow Calculation

| Description | System | Total Flr Area | No. People | Rp cfm/per | Ra cfm/ft ² | Vbz = Total |
|-------------------|--------|----------------|------------|------------|------------------------|-------------|
| 117 IT Room | RTU-5 | 72 | 0 | 10 | 0.12 | 8.64 |
| 118 Elec Room | RTU-5 | 88 | 0 | 0 | 0.06 | 5.28 |
| 144A Main Gym | RTU-5 | 7362 | 221 | 7.5 | 0.06 | 2099.22 |
| 146 Stage | RTU-5 | 1300 | 39 | 10 | 0.06 | 468 |
| 224A Jog Track | RTU-5 | 3200 | 96 | 20 | 0.06 | 2112 |
| 228 Electric Room | RTU-5 | 135 | 0 | 10 | 0.12 | 16.2 |
| 229 IT Room | RTU-5 | 169 | 0 | 10 | 0.12 | 20.28 |
| 229A Storage | RTU-5 | 169 | 0 | 0 | 0.12 | 20.28 |
| | Total | | | | | 4749.9 |

RTU_6 -Minimum Airflow Calculation

| Description | System | Total Flr Area | No. People | Rp cfm/per | Ra cfm/ft ² | Vbz = Total |
|----------------------|--------|----------------|------------|------------|------------------------|-------------|
| 144B Main Gym | RTU-6 | 7038 | 211 | 7.5 | 0.06 | 2004.78 |
| 147 Storage | RTU-6 | 303 | 0 | 0 | 0.12 | 36.36 |
| 224B Jog Track | RTU-6 | 3200 | 96 | 20 | 0.06 | 2112 |
| 226 Media Production | RTU-6 | 175 | 1 | 10 | 0.12 | 31 |
| 227 Electric Room | RTU-6 | 155 | 0 | 0 | 0.06 | 9.3 |
| | Total | | | | | 4193.44 |

| Opaque Elements | Nonresidential | | Residential | | Semihated | |
|-----------------------------------------------------|------------------------|---------------------------|------------------------|---------------------------|------------------------|---------------------------|
| | Assembly Maximum | Insulation Min. R-Value | Assembly Maximum | Insulation Min. R-Value | Assembly Maximum | Insulation Min. R-Value |
| <i>Roofs</i> | | | | | | |
| Insulation Entirely above Deck | U-0.048 | R-20.0 c.i. | U-0.048 | R-20.0 c.i. | U-0.173 | R-5.0 c.i. |
| Metal Building | U-0.065 | R-19.0 | U-0.065 | R-19.0 | U-0.097 | R-10.0 |
| Attic and Other | U-0.027 | R-38.0 | U-0.027 | R-38.0 | U-0.053 | R-15.0 |
| <i>Walls, Above-Grade</i> | | | | | | |
| Mass | U-0.104 | R-9.5 c.i. | U-0.090 | R-11.4 c.i. | U-0.580 | NR |
| Metal Building | U-0.113 | R-13.0 | U-0.113 | R-13.0 | U-0.134 | R-10.0 |
| Steel-Framed | U-0.064 | R-13.0 + R-7.5 c.i. | U-0.064 | R-13.0 + R-7.5 c.i. | U-0.124 | R-13.0 |
| Wood-Framed and Other | U-0.089 | R-13.0 | U-0.064 | R-13.0 + R-3.8 c.i. | U-0.089 | R-13.0 |
| <i>Walls, Below-Grade</i> | | | | | | |
| Below-Grade Wall | C-1.140 | NR | C-0.115 | R-7.5 c.i. | C-1.140 | NR |
| <i>Floors</i> | | | | | | |
| Mass | U-0.087 | R-8.3 c.i. | U-0.074 | R-10.4 c.i. | U-0.137 | R-4.2 c.i. |
| Steel-Joist | U-0.038 | R-30.0 | U-0.038 | R-30.0 | U-0.069 | R-13.0 |
| Wood-Framed and Other | U-0.033 | R-30.0 | U-0.033 | R-30.0 | U-0.066 | R-13.0 |
| <i>Slab-On-Grade Floors</i> | | | | | | |
| Unheated | F-0.730 | NR | F-0.540 | R-10 for 24 in. | F-0.730 | NR |
| Heated | F-0.860 | R-15 for 24 in. | F-0.860 | R-15 for 24 in. | F-1.020 | R-7.5 for 12 in. |
| <i>Opaque Doors</i> | | | | | | |
| Swinging | U-0.700 | | U-0.700 | | U-0.700 | |
| Nonswinging | U-1.500 | | U-0.500 | | U-1.450 | |
| Fenestration | | | | | | |
| | Assembly Max. U | Assembly Max. SHGC | Assembly Max. U | Assembly Max. SHGC | Assembly Max. U | Assembly Max. SHGC |
| <i>Vertical Glazing, 0%–40% of Wall</i> | | | | | | |
| Nonmetal framing (all) ^b | U-0.40 | | U-0.40 | | U-1.20 | |
| Metal framing (curtainwall/storefront) ^c | U-0.50 | SHGC-0.40 all | U-0.50 | SHGC-0.40 all | U-1.20 | SHGC-NR all |
| Metal framing (entrance door) ^c | U-0.85 | | U-0.85 | | U-1.20 | |
| Metal framing (all other) ^c | U-0.55 | | U-0.55 | | U-1.20 | |
| <i>Skylight with Curb, Glass, % of Roof</i> | | | | | | |
| 0%–2.0% | U _{all} -1.17 | SHGC _{all} -0.49 | U _{all} -0.98 | SHGC _{all} -0.36 | U _{all} -1.98 | SHGC _{all} -NR |
| 2.1%–5.0% | U _{all} -1.17 | SHGC _{all} -0.39 | U _{all} -0.98 | SHGC _{all} -0.19 | U _{all} -1.98 | SHGC _{all} -NR |
| <i>Skylight with Curb, Plastic, % of Roof</i> | | | | | | |
| 0%–2.0% | U _{all} -1.30 | SHGC _{all} -0.65 | U _{all} -1.30 | SHGC _{all} -0.62 | U _{all} -1.90 | SHGC _{all} -NR |
| 2.1%–5.0% | U _{all} -1.30 | SHGC _{all} -0.34 | U _{all} -1.30 | SHGC _{all} -0.27 | U _{all} -1.90 | SHGC _{all} -NR |
| <i>Skylight without Curb, All, % of Roof</i> | | | | | | |
| 0%–2.0% | U _{all} -0.69 | SHGC _{all} -0.49 | U _{all} -0.58 | SHGC _{all} -0.36 | U _{all} -1.36 | SHGC _{all} -NR |
| 2.1%–5.0% | U _{all} -0.69 | SHGC _{all} -0.39 | U _{all} -0.58 | SHGC _{all} -0.19 | U _{all} -1.36 | SHGC _{all} -NR |

*The following definitions apply: c.i. = continuous insulation (see Section 3.2), NR = no (insulation) requirement.

^bNonmetal framing includes framing materials other than metal with or without metal reinforcing or cladding.

^cMetal framing includes metal framing with or without thermal break. The "all other" subcategory includes operable windows, fixed windows, and non-entrance doors.

Table A

| Climate Zone | Duct Location | | | | | | |
|---------------------------|---------------|------------------|----------------------------------------|--------------------------------------------------|----------------------------------|-------------------------------------------|--------|
| | Exterior | Ventilated Attic | Unvented Attic Above Insulated Ceiling | Unvented Attic with Roof Insulation ^a | Unconditioned Space ^b | Indirectly Conditioned Space ^c | Buried |
| Heating-Only Ducts | | | | | | | |
| 1, 2 | none | none | none | none | none | none | none |
| 3 | R-3.5 | none | none | none | none | none | none |
| 4 | R-3.5 | none | none | none | none | none | none |
| 5 | R-6 | R-3.5 | none | none | none | none | R-3.5 |
| 6 | R-6 | R-6 | R-3.5 | none | none | none | R-3.5 |
| 7 | R-8 | R-6 | R-6 | none | R-3.5 | none | R-3.5 |
| 8 | R-8 | R-8 | R-6 | none | R-6 | none | R-6 |
| Cooling-Only Ducts | | | | | | | |
| 1 | R-6 | R-6 | R-8 | R-3.5 | R-3.5 | none | R-3.5 |
| 2 | R-6 | R-6 | R-6 | R-3.5 | R-3.5 | none | R-3.5 |
| 3 | R-6 | R-6 | R-6 | R-3.5 | R-1.9 | none | none |
| 4 | R-3.5 | R-3.5 | R-6 | R-1.9 | R-1.9 | none | none |
| 5, 6 | R-3.5 | R-1.9 | R-3.5 | R-1.9 | R-1.9 | none | none |
| 7, 8 | R-1.9 | R-1.9 | R-1.9 | R-1.9 | R-1.9 | none | none |
| Return Ducts | | | | | | | |
| 1 to 8 | R-3.5 | R-3.5 | R-3.5 | none | none | none | none |

^a Insulation R-values, measured in (ft·ft²·°F)/Btu, are for the insulation as installed and do not include film resistance. The required minimum thicknesses do not consider water vapor transmission and possible surface condensation. Where exterior walls are used as plenum walls, wall insulation shall be as required by the most restrictive condition of Section 6.4.4.2 or Section 5. Insulation resistance measured on a horizontal plane in accordance with ASTM C518 at a mean temperature of 75°F at the installed thickness.

^b Includes crawlspaces, both ventilated and nonventilated.

^c Includes return air plenums with or without exposed roofs above.

Table B