

Technical Report 1

ASHRAE Standard 62.1
& Standard 90.1 Evaluation



The Salvation Army Ray & Joan Kroc Corps Community Center of Salem Oregon

Mathias Kehoe
Mechanical Option
Advisor: Stephen Treado
September 23, 2011

Table of Contents

| | |
|--|----|
| <i>Executive Summary</i> | 3 |
| <i>Building System Overview</i> | 4 |
| <i>Mechanical System Overview</i> | 4 |
| | |
| <i>Standard 62.1</i> | |
| Section 5 – Systems and Equipment | 5 |
| Section 6 – Procedures | 8 |
| Standard 62.1 Summary | 10 |
| | |
| <i>Standard 90.1</i> | |
| Section 5 – Building Envelope | 11 |
| Section 6 – Heating, Ventilating, and Air-Conditioning | 13 |
| Section 7 – Service Water Heating | 14 |
| Section 8 – Power | 15 |
| Section 9 – Lighting | 15 |
| Standard 90.1 Summary | 16 |
| | |
| <i>References</i> | 17 |
| <i>Appendix A</i> | 18 |
| <i>Appendix B</i> | 33 |

Executive Summary

In the following report, a detailed analysis will be performed on the Ray & Joan Kroc Corps Community Center of Salem Oregon to determine whether or not the building complies with ASHRAE (American Society of Heating, Refrigerating, and Air-Conditioning Engineers) Standard 62.1 and Standard 90.1. Standard 62.1 analyzes the ventilation equipment and addresses ventilation requirements for each room based on occupancy and square footage. Standard 90.1 evaluates the energy usage of buildings. This standard addresses the tightness of the building envelope, the intelligence of the HVAC control system, the efficiency of the water heaters, the distribution of power, and the density of lighting. This report will break down each part of these standards to reveal how closely the Kroc Center adheres to ASHRAE's standards.

The Kroc Center followed ASHRAE's requirements remarkably well in section five of Standard 62.1. The building met or exceeded the requirements in all but one category. The area where the building failed to comply dealt with air filters in the air handling units; about half of the air handlers did not specify filters with high enough quality. The design team probably consulted ASHRAE Standard 62.1 when designing the building for it to perform this well.

The building met minimum design standards addressed in section six of Standard 62.1 for all but one of the air handlers. As addressed later in the report, the compliance failure was most likely a result of different assumptions which caused a few of the spaces to be grossly over ventilated. The two pools had very high ventilation rates, but that may have been an air quality issue that caused such high rates. The design team must have been much more conservative when laying out the ventilation system which would explain the high outdoor air rates. Whether the high ventilation rates are justifiable or not, they do present an area of potential energy savings.

The Kroc Center performed well in Standard 90.1, and it should have since the building was designed to achieve LEED Gold. The building envelope failed to meet the requirements for floor, roof, and window insulation values. These systems were close to passing but came up a little short. The building has a very advanced control system which allowed it meet the requirements for HVAC control and water heating. Also, a well thought out lighting and electrical scheme helped earn more energy savings. The Kroc Center performed very well with Standard 90.1, complying in nearly every section.

Building Summary

The Salvation Army Ray & Joan Kroc Corps Community Center of Salem Oregon was a new construction project located in Salem, Oregon. The Kroc Center is a one story, ninety-two thousand square foot facility located on a ten and a half acre campus. The building has a number of large, energy-intensive spaces including a full-size gymnasium, a competition pool, a leisure pool, a large chapel, a commercial size kitchen, and rooms to host community events. The Kroc Center also contains several offices, classrooms, small recreation rooms, and support spaces for the larger areas. The Kroc Center is surrounded by large athletic fields which are owned by the Salvation Army. The different building features enable the Kroc Center to be used by children, teens, families and adults from the community.

The Kroc Center was funded entirely by the Salvation Army. The Salvation Army allotted \$35.5 million to build the Kroc Center, but the total cost of construction was slightly less than that at approximately \$33.3 million. The Salvation Army also donated a matching \$35.5 million endowment to operate the building.

Mechanical System Summary

The Kroc Center uses a variety of mechanical equipment to condition its many different spaces. All of the heating, cooling and ventilation loads are supplied by air handlers scattered across the roof of the building. The two pools are conditioned by very large, individual air handling units. The kitchen, community spaces, and most of the classrooms are conditioned by an individual packaged rooftop unit. Two rooftop units are used to condition the gymnasium space. Other packaged rooftop units are spread out across the roof and service smaller spaces around community center. Two fan coil units are used to condition the platform of the chapel and the backstage spaces. Also the Kroc Center has two make-up air units; one above the kitchen, and one above the restrooms and storage areas on the south side of the competition pool. All of the ventilation for the entire building is supplied through the above equipment. Also, there is a mechanical room by the leisure pool that supplies domestic hot water for the entire building and hot water for the two pools.

ASHRAE 62.1 Analysis

Section 5 - Systems and Equipment

Section 5.1 - Natural Ventilation

Natural Ventilation is not a viable option given the colder, northern climate of Oregon. As a result, the windows in the Kroc Center are not operable.

Section 5.2 – Ventilation Air Distribution

The individual air handlers were able to meet the ventilation requirements stated in section 6 of ASHRAE Standard 62.1 except one. Rooftop Unit 7 is about 200 CFM below the required level. The results will be discussed in more detail later in the report.

Section 5.3 – Exhaust Duct Location

The Kroc Center is a one-story building. All of the exhaust ductwork is exhausted directly through the roof or exterior walls; there is no potential for leakage between spaces. Also, the exhaust fans are located away from outdoor air inlets on the rooftop mechanical equipment, so there is no possibility of cross contamination there. The areas of most concern are the pool areas, but the air is returned to the air handling unit and exhausted away from the outdoor air inlet.

Section 5.4 – Ventilation System Controls

The Kroc Center uses a VAV system to distribute the conditioned air. Each VAV box has a minimum setting that meets the minimum outdoor airflow requirements as required by section 6 of ASHRAE Standard 62.1. Actuators are located on dampers upstream of the diffuser. The actuators are thermostatically reset to maintain airflows within ten percent of required load even at part load.

Section 5.5 – Airstream Surfaces

The Kroc Center uses both sheet metal and fabric ducts. Section 15880 of the project specifications states that all ductwork must conform to the requirements of UL181. The Kroc Center complies with ASHRAE's standards on this subject.

Section 5.6 – Outdoor Air Intakes

The outdoor air intakes on the rooftop units and air handling units exceed the minimum distance from exhaust vents as described in table 5-1 of Standard 62.1. Also, all exterior ductwork is designed to prevent the intrusion of moisture into the airflow, see Note 8/M702.

Section 5.7 – Local Capture of Contaminants

The major area for contamination is the two pool areas. A quick check with a ductulator reveals that the exhaust ductwork is large enough to handle airflows much higher than the supply air. By exhausting more air than is being supplied, the pools are negatively pressurized which will keep the chlorine and other chemicals from spreading into the building. The building complies with this section.

Section 5.8 – Combustion Air

There are five natural gas boilers housed in the mechanical room on the south side of the leisure pool. A large relief vent is located above the mechanical room to provide an adequate amount of combustion air to the space.

Section 5.9 – Particulate Matter Removal

Filters are specified to have a rating of MERV 6 for rooftop units from 20 to 75 tons. For the smaller units, filters are called for but are not specified strictly enough to meet the requirements of the ASHRAE standard. These filters are inadequate to fulfill the requirements, so the Kroc Center does not comply with this section.

Section 5.10 – Dehumidification Systems

The maximum humidity specified for the Kroc Center is 60% and occurs in summer mode; this is less than the 65% required by ASHRAE. The entire building has a net positive pressure which will help limit infiltration. The building complies with this section.

Section 5.11 – Drain Pans

Air Handling Units are to have stainless steel, insulated drain pans with two connections, one to each side of the unit. The packaged rooftop units are also specified to have drain pans under the entire unit. The Kroc Center complies with this section.

Section 5.12 – Finned-Tube Coils and Heat Exchangers

The air handling units are specified to have drain pans under the heat exchangers in the unit. The drain pans meet the requirements of Section 5.11, and comply with this section.

Section 5.13 – Humidifiers and Water-Spray Systems

The Kroc Center does not employ humidifiers or water-spray systems.

Section 5.14 – Access for Inspection, Cleaning, and Maintenance

An access panels to above the ceiling is provided for the series fan powered boxes inside the building. The remainder of the air handling equipment is located on the roof, so the maintenance staff has easy access to them.

Section 5.15 – Building Envelope and Interior Surfaces

Vapor barriers are provided throughout the entire building envelope to prevent liquid penetration through the walls and roof. All HVAC ductwork, condensate piping, cold water piping, and refrigerant piping is specified to have insulation to prevent condensation. The Kroc Center complies with this section.

Section 5.16 – Buildings with Attached Parking Garages

The Kroc Center does not have an attached parking garage.

Section 5.17 – Air Classification and Recirculation

Most of the building contains Class 1 air that can be recirculated throughout the building. The restrooms and locker rooms are considered Class 2 air and are exhausted through the roof. The gymnasium is also Class 2 air but some of the air is recirculated back into the gym only. The two pools have Class 3 air and recirculate a portion of the air but only in their respective spaces. The kitchen has Class 4 air, but that air is exhausted outdoors and not recirculated to other parts of the building.

Section 5.18 – Requirements for Buildings Containing ETS Areas and ETS-Free Areas

The Kroc Center is a community center trying to reach LEED status, so the entire building is ETS-free. This section does not apply to this building.

Section 6 – Procedures

The Kroc Center was tested against ASHAE Standard 62.1-2007 to discover whether or not it complies with ASHRAE's minimum ventilation design requirements. With such a large variation of spaces within the Kroc Center, it was determined that all of the mechanical units that supply outside air should be checked for compliance. A spreadsheet was provided to run the tests, and the spreadsheet results for each of the units are listed in Appendix A. The following equations were used to determine compliance.

Breathing Zone Outdoor Airflow

$$V_{bz} = (R_p * P_z) + (R_a * A_z)$$

Where: V_{bz} = breathing zone outdoor airflow (cfm)
 R_p = required airflow rate per person (cfm/person)
 P_z = zone population (people)
 R_a = require airflow rate per unit area (cfm/sq.ft.)
 A_z = zone floor area (sq. ft.)

Zone Outdoor Airflow

$$V_{oz} = V_{bz} / E_z$$

Where: V_{oz} = Zone Outdoor Flow
 E_z = Zone Air Distribution Effectiveness = 1.0

Outdoor Air Intake Flow

$$V_{ot} = V_{oz}$$

Primary Outdoor Air Fraction

$$Z_p = V_{oz} / V_{pz}$$

Where: V_{pz} = Zone Primary Airflow

For VAV systems V_{pz} is the minimum expected airflow

After analyzing the entire ventilation system for the Kroc Center, it was determined that the current ventilation system meets or exceeds minimum design requirements established by ASHRAE Standard 62.1 for all units except one. Rooftop unit 7 is a little below the required level. The main space that RTU 7 services is an aerobics exercise room. ASHRAE’s suggested population density and required airflow per person seemed high, 40 (people / 1000 sq ft) and 20 (cfm / person) respectively. The design team most likely used less conservative assumptions for that space which could explain the small outdoor air deficit. Table 1 shows how the current system compares to ASHRAE’s minimum standards.

| Unit | Description | Scheduled OA | ASHRAE Required OA | Compliance | % Difference |
|--------|-------------------|--------------|--------------------|------------|--------------|
| AHU 1 | Competition Pool | 10488 | 5818 | Y | 80% |
| AHU 2 | Leisure Pool | 8988 | 4735 | Y | 90% |
| FCU 1 | Stage - North | 880 | 648 | Y | 36% |
| FCU 2 | Stage - South | 880 | 647 | Y | 36% |
| RTU 1 | North Office Wing | 9610 | 8188 | Y | 17% |
| RTU 2 | Office Wing | 1640 | 1094 | Y | 50% |
| RTU 3 | Chapel | 4800 | 1795 | Y | 167% |
| RTU 4 | Climbing Wall | 2300 | 342 | Y | 573% |
| RTU 5 | Gym - North | 2800 | 2203 | Y | 27% |
| RTU 6 | Gym - South | 2800 | 2203 | Y | 27% |
| RTU 7 | Aerobics | 1230 | 1430 | N | -14% |
| RTU 8 | Fitness | 1200 | 1005 | Y | 19% |
| RTU 9 | Wet Multi-Purpose | 1360 | 370 | Y | 268% |
| RTU 10 | Locker Rooms | 2750 | 1142 | Y | 141% |

Table 1 – Ventilation Compliance

A number of units have outside air measurements much higher than the required amount. The pool areas probably have much higher amounts to maintain a healthier indoor air quality level by flushing out the chlorine and other chemicals. The other areas that are significantly over the required values are the chapel, climbing wall, and the locker rooms. The locker rooms are probably high to maintain a better indoor environment, much like the pools. The chapel probably accounted for a higher density of people or a higher activity level for the people in the chapel. The climbing wall is a very unique space and doesn’t fit well into any of ASHRAE’s predetermined spaces. The closest option was selected, but the designers probably took a more conservative approach. Overall, the ventilation rates are a little larger than the minimum required amount to ensure that the ventilation requirements will be met, even when the VAV boxes are at partial load.

Standard 62.1 Summary

The Kroc Center complied very closely to ASHRAE Standard 62.1. A few small issues arose, but they do not pose serious problems. The failure of the filters to meet ASHRAE's requirements could be easily remedied, and the one ventilation deficit could be fixed by dispersing the air slightly differently. Overall, it was impressive how well the Kroc Center performed.

ASHRAE Standard 90.1 Analysis

Section 5 – Building Envelope

5.1.4 Climate

The Kroc Center was built in Salem, Oregon which is located in climate zone 4.




Figure 1 - United States Climate Map

5.4 Mandatory Provisions

All fenestrations and doors are to be sealed as mentioned in the drawings and the specifications. Additionally all fenestrations and doors in the pool areas are to use bituminous dampproofing to prevent moisture penetration in areas subject to high humidity, dampness, and direct water content.

The Kroc Center has two primary entrances. Both have sets of double doors more than seven feet apart when closed. Another back entrance has a set of double with close to seven feet in between the doors, which is acceptable because those doors are not used as a primary entrance.

5.5 Prescriptive Building Envelope Option

Verify that the building elements meet minimum Building Envelope Requirements for Climate Zone 4. The walls, roof, floor, and glazing were all evaluated. The results are listed below in Table 2 and Table 3.

| Element | Description | Prescribed by 90.1 | | As Designed | | Std. 90.1 Compliance |
|-------------------|--------------------------------|--------------------|------------------------|----------------|------------------------|----------------------|
| | | Assembly U Max | Insulation Min R-Value | Assembly U Max | Insulation Min R-Value | |
| Roof | Insulation Entirely Above Deck | 0.048 | 20 | 0.053 | 19 | No |
| Walls Above Grade | Mass | 0.104 | 9.5 | 0.077 | 13 | Yes |
| Walls Below Grade | Below-Grade Walls | 1.140 | NR | NA | NA | Yes |
| SOG Floors | Unheated | 0.073 | NR | 0.100 | NA | No |

Table 2 – Building Envelope Compliance

After a quick glance at the building elevations, one can see that the glazing is well under forty percent of the total surface area of the exterior of the building, which is a requirement for the building to comply with the ASHRAE standard.

| Element | Description | Prescribed by 90.1 | | As Designed | | Std. 90.1 Compliance |
|---------------------|------------------------------|--------------------|----------|----------------|----------|----------------------|
| | | Assembly U Max | Max SHGC | Assembly U Max | Max SHGC | |
| Glazing (Base) | Metal Framing (Curtain Wall) | 0.50 | 0.40 | 0.35 | 0.50 | No |
| Glazing (Alternate) | Metal Framing (Curtain Wall) | 0.50 | 0.40 | 0.28 | 0.31 | Yes |

Table 3 – Building Glazing Compliance

There are several areas where the building envelope fails to comply with ASHRAE Standard 90.1. The roof u-value is just slightly under the ASHRAE standard, so it does not represent a major concern. The floors also failed to comply with ASHRAE Standard 90.1, but the U-value is still very low so the floors will not pose a problem either. Lastly the glazing. It could not be determined which glazing the contractor selected. If the contractor chose the base product it would fail to comply because the shading coefficient was too high. But if the contractor selected the alternate glazing, then it would comply with the standard. There were a lot of little areas where the building failed to comply, but none will present major problems moving forward.

Section 6 – Heating, Ventilating, and Air Conditioning

6.2 Compliance Paths

There are two methods for determining compliance with this standard: the simplified approach or the mandatory provisions. The simplified approach can only be used for buildings with less than 25,000 square feet, so this report used the mandatory provisions method.

6.4 Mandatory Provisions

The Building Control System is a Direct Digital Control (DDC) system which can perform all of the automatic temperature control and energy management functions as required in the plans and specifications. The system will independently control the building's HVAC equipment to maintain a controlled environment in an energy efficient manner. The building operator can communicate with the system and control the sequence of operation to maintain the desired temperature.

The control system allows for all of the mechanical equipment to be turned down or off according to the owner's desire to allow for energy savings. The owner is given a lot of control over the system and the owner can determine the operating times for all of the equipment. Some of the mechanical equipment will shut off until the building drops below 60F. When the temperature of the building drops that low the equipment will turn back on to prevent the building from cooling too much and causing possible freezing damage. This allows the building to save the most energy without worrying about damaging the building. The Kroc Center meets all the control requirements and complies with this section.

All of the HVAC piping and ductwork is to be insulated. All exterior ductwork will have rigid insulation, and all interior ductwork will be covered in fiberglass insulation. Also, all hot and cold water piping will be wrapped in fiberglass insulation, elastomeric foam, or cellular glass.

6.5 Prescriptive Path

All of the rooftop units are equipped with economizers that are capable of producing up to one hundred percent outdoor air to allow for free cooling. The DDC control system controls the adjusting of the dampers on the unit, but the owner can adjust the ventilation rates. The two large air handling units do not employ economizers because they are over 65,000 Btu/h and do not need economizers as required in Table 6.5.1 in ASHRAE Standard 90.1

All fan motors that are over 1 hp must meet the restrictions listed in Table 6.5.3.1.1A of ASHRAE Standard 90.1. Table 4 shows the compliance of all fans that exceed 1 hp; the smaller fans were left off to conserve space. The two large air handlers have VFD controls instead of VAV boxes, so they were still treated the same as the other variable systems.

| Unit | HP | CFM | CFM x 0.0015 | Compliance |
|--------------|--------|-------|--------------|------------|
| AHU 1 Supply | 25 (2) | 41960 | 31.5 (2) | Y |
| AHU 1 Return | 15 (2) | 26170 | 20 (2) | Y |
| AHU 2 Supply | 20 (2) | 35950 | 27 (2) | Y |
| AHU 2 Return | 10 (2) | 21570 | 16 (2) | Y |
| REF R2 | 5 | 5400 | 8.1 | Y |
| REF R5 | 5 | 7000 | 10.5 | Y |
| REF R6 | 5 | 7000 | 10.5 | Y |
| REF R8 | 5 | 8300 | 12.45 | Y |
| MAU R2 | 5 | 5200 | 7.8 | Y |

Table 4 – Fan HP Compliance

There is a fume hood in the kitchen. However, the total cfm is under 5000, so no makeup air is necessary, although some is provided. The Kroc Center complies with this section.

6.7 Submittals

The specifications call for copies of all drawings and operating and maintenance manuals to be handed over to the owner upon completion of the building. Also, a testing and balancing report is to be performed after the entire system is installed. The Kroc Center is still going through the LEED certification process at this time, so the final commissioning report is not available.

Section 7 – Service Water Heating

There are four water heaters that supply the domestic hot water to the building. Two gas boilers are located in the mechanical room. Another gas boiler is located in the janitor closet near the kitchen, and an electric hot water heater is located in the janitor closet by the competition pool. The two satellite water heaters are primarily used to provide a quick source of hot water to areas of the building far from the mechanical room. All of the hot water heaters in the Kroc Center besides the two satellite heaters are tankless.

Three additional gas boilers are located in the mechanical room and supply hot water to the two pools and two air handling units. These boilers are connected and work together to meet the hot water demands; so when the pools are at partial load one or two of the boilers can shut off. The three pool boilers can also be manually shut off as is required in ASHRAE Standard 90.1. Overall the water heating service complies with ASHRAE Standard 90.1

Section 8 – Power

The specifications state that the maximum allowable voltage drop for feeders is two percent, and the maximum voltage drop for branch circuits is three percent. It is the responsibility of the contractor to increase cable sizes to ensure that proper voltage drop levels are achieved. This is exactly what is called for in section 8 of ASHRAE Standard 90.1, so the Kroc Center complies with this section.

Section 9 – Lighting

9.2 Compliance Path

There are two methods for determining the compliance of the Kroc Center: the Building Area Method and the Space-by-Space Method. This report will use the Building Area Method to check for compliance.

9.4 Mandatory Provisions

Photoelectric switches are to be used on exterior and interior lighting. The exterior switches will turn off the exterior lighting during the day. The interior switches will adjust interior lighting levels based on daylight levels within the building. Occupancy sensors are also to be installed in the rooms to prevent wasted electricity.

9.5 Building Area Method Compliance Path

The first step is to determine the building type which will give you a specific maximum lighting density. The Kroc Center is composed of a lot of different types of spaces, so I chose the Convention Center. It is an accurate depiction because it is a little higher than the gymnasiums to show the increased lighting density in the smaller areas. The results are summarized in Table 5, but the full worksheet can be seen in Appendix B.

| Total Watts | Total SF | Design W/SF | Required W/SF | Compliance |
|-------------|----------|-------------|---------------|------------|
| 104998 | 92000 | 1.14 | 1.20 | Yes |

Table 5 – Lighting Compliance

Standard 90.1 Summary

Overall the Kroc Center complied very well with the requirements established in ASHARE Standard 90.1. There were a few small issues with the building envelope, but these issues are minor and not cost-effective to change. Even as they stand, the envelope systems that fail to comply are very close to the ASHRAE requirements. The section on HVAC complied nearly perfectly with the standard 90.1. The Kroc Center has a very sophisticated control sequence enabling it to meet the requirements for optimal energy savings. Also, the fan power selections in the air handlers were well done; the design team kept them well below ASHRAE standards. The water heaters also benefited from the advanced control system, and fit within the standard 90.1 guidelines. The electrical power system also fulfills ASHRAE’s requirements by maintaining low voltage drops throughout the whole system. Lastly, the lighting system came in just under the requirements, which was surprising considering the accent lighting and high-bay lighting throughout the building. Overall the Kroc Center fulfills the requirements of ASHRAE Standard 90.1 with only a few minor faults.

References

ASHRAE. 2007, ANSI/ASHRAE, Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality. American Society of Heating Refrigeration and Air-Conditioning Engineers, Inc., Atlanta GA.

ASHRAE. 2007, ANSI/ASHRAE, Standard 90.1-2007, Energy Standard for Building Except Low-Rise Residential Buildings. American Society of Heating Refrigeration and Air-Conditioning Engineers, Inc., Atlanta GA.

Construction Documents and Project Specifications for The Salvation Army Ray & Joan Kroc Corps Community Center of Salem Oregon. Courtesy of BRS Architecture.

Appendix A

| Building: | | Kroc Center | |
|--|--|----------------------|--|
| System Tag/Name: | | AHU 1 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | ft ³ /min | |
| Inputs for System | | | |
| Floor area served by system | As | ft ² | System |
| Population of area served by system (including diversity) | Ps | P | 12,120 |
| Design primary supply fan airflow rate | Vpsd | cfm | 10 |
| OA req'd per unit area for system (Weighted average) | Ras | cfm/ft ² | 42,000 |
| OA req'd per person for system area (Weighted average) | Rps | cfm/psf | 0.48 |
| OA req'd per person for system area (Weighted average) | Rps | cfm/psf | 0.0 |
| Potentially Critical Zone | | | |
| Zone Name | Zone rate turns purple (ask for critical zone's) | | |
| Zone Tag | | | |
| Space type | Selected from pull-down list | | |
| Floor Area of zone | Az | ft ² | Selected from pull-down list |
| Design population of zone | Pz | P | (default value listed, may be overridden) |
| Design total supply to zone (primary plus local recirculated) | Vztd | cfm | Selected from pull-down list or leave blank if N/A |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Er | | |
| Local recirc. air % representative of ave system return air | | | |
| Inputs for Operating Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | |
| Air distribution type at conditioned analyzed | Ez | | Selected from pull-down list |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | |
| Primary air fraction of supply air at conditioned analyzed | | | |
| Results | | | |
| Ventilation System Efficiency | E _v | cfm | 1.00 |
| Outdoor air intake required for system | Vot | cfm | 5818 |
| Outdoor air per unit floor area | Vot/As | cfm/ft ² | 0.48 |
| Outdoor air per person served by system (including diversity) | Vot/Ps | cfm/psf | 581.8 |
| Outdoor air as a % of design primary supply air | ypd | cfm | 14% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 42000 |
| Unrecirculated OA requirement for system | Vou | cfm | 5518 |
| Unrecirculated OA req'd as a fraction of primary SA | Xs | | 0.14 |
| Initial Calculations for Individual Zones | | | |
| OA rate per unit area for zone | Raz | cfm/ft ² | 0.48 |
| OA rate per person | Rpz | cfm/psf | 0.00 |
| Total supply air to zone (at condition being analyzed) | Vztd | cfm | 42000 |
| Unused OA req'd to breathing zone | Vbz | cfm | 5817.6 |
| Unused OA requirement for zone | Vbz/Ez | | 0.0 |
| Fraction of zone supply not directly recirc. from zone | Fz | | 5818 |
| Fraction of zone supply from fully mixed primary air | Fp | | 1.00 |
| Fraction of zone OA not directly recirc. from zone | Fc | | 1.00 |
| Unused OA fraction required in supply air to zone | Zd | | 0.14 |
| Unused OA fraction required in primary air to zone | Zp | | 0.00 |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | E _{vz} | | (Fa + FDxz - Fcz) / Fa |
| System Ventilation Efficiency (App A Method) | E _v | | min (E _{vz}) |
| Ventilation System Efficiency (Table 6.3 Method) | E _v | | Value from Table 6.3 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vot | cfm | 5818 |
| OA intake req'd as a fraction of primary SA | Y | | 0.14 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | cfm | 5752 |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.14 |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.01 |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.01 |
| OA Temp at which Min OA provides all cooling | | | |
| OA T below which OA intake flow is @ minimum | Deq F | | -51 |

| | | | |
|--|--|-------------|--|
| Building: | | Knox Center | |
| System Tag/Name: | | AHU 2 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | P | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | As | SF | 5965 |
| Design primary supply fan airflow rate | Ps | P | 10 |
| CA req'd per unit area for system (Weighted average) | Vpsd | cfm | 36,000 |
| CA req'd per unit area for system area (Weighted average) | Ras | cfm/sf | 0.48 |
| CA req'd per person for system area (Weighted average) | Rps | cfm | 0.0 |
| Potentially Critical Zones | | | |
| Zone Name | Zone the turns purple (note for critical zones: 9) | | |
| Space type | Selected from pull-down list | | |
| Floor Area of zone | Az | SF | Selected from pull-down list |
| Design population of zone | Pz | P | (default value listed; may be overridden) |
| Design total supply to zone (primary plus local recirculated) | Voztd | cfm | Selected from pull-down list or leave blank if N/A |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Er | | |
| Local recirc. air % representative of one system return air | | | |
| Inputs for Operating Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | | Selected from pull-down list |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | 100% |
| Primary air fraction of supply air at conditioned analyzed | | | 100% |
| Results | | | |
| Ventilation System Efficiency | Ev | | 1.00 |
| Outdoor air intake required for system | Vot | cfm | 4735 |
| Outdoor air per unit floor area | Vot/As | cfm/sf | 0.48 |
| Outdoor air per person served by system (including diversity) | Vot/Ps | cfm | 473.5 |
| Outdoor air as a % of design primary supply air | Ypd | cfm | 13% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 36000 |
| Uncorrected CA requirement for system | Vou | cfm | 4735 |
| Uncorrected CA req'd as a fraction of primary SA | Xs | | 0.13 |
| Initial Calculations for Individual Zones | | | |
| CA rate per unit area for zone | Raz | cfm/sf | 0.48 |
| CA rate per person | Rpz | cfm/sf | 0.00 |
| Total supply air to zone (at condition being analyzed) | Voz | cfm | 36000 |
| Unused CA req'd to breathing zone | Voz/Ez | | 4735.2 |
| Unused CA requirement for zone | Voz/Ez | | 4735 |
| Fraction of zone supply not directly recirc. from zone | Fa | | 1.00 |
| Fraction of zone supply from fully mixed primary air | Fb | | 1.00 |
| Fraction of zone CA not directly recirc. from zone | Fc | | 1.00 |
| Unused CA fraction required in supply air to zone | Zd | | 0.13 |
| Unused CA fraction required in primary air to zone | Zp | | 0.13 |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Ez | | (Fa + Fb)Xs - FcZd / Fa |
| System Ventilation Efficiency (App A Method) | Ev | | min (Ez) |
| Ventilation System Efficiency (Table 6.3 Method) | Ev | | Value from Table 6.3 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vot | cfm | 4735 |
| CA intake req'd as a fraction of primary SA | Y | | 0.13 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | cfm | 4649 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.13 |
| CA Intake at which Min OA provides all cooling | Deg F | | -57 |
| CA Int below which CA intake flows @ minimum | | | |

| Building: | | Kiroo Center | |
|--|---|--------------|--------|
| System Tag/Name: | | FCU 1 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | ppm | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | As | SF | 1150 |
| Design primary supply fan airflow rate | Ps | cfm | 53 |
| CA req'd per unit area for system (Weighted average) | Vpzd | cfm | 1,600 |
| CA req'd per unit area for system area (Weighted average) | Ras | cfm/sf | 0.08 |
| CA req'd per person for system area (Weighted average) | Rps | cfm/ps | 9.9 |
| Inputs for Potentially Critical Zones | | | |
| Zone Name | Zone the lungs purple italic for critical zone(s) | | |
| Zone Tag | Potentially Critical Zones | | |
| Space type | Storage rooms | | |
| Floor Area of zone | Az | SF | 315 |
| Design population of zone | Pz | P | 0 |
| Design total supply to zone (primary plus local recirculated) | Vozd | cfm | 150 |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Er | | NTU |
| Local recirc. air % representative of zone system return air | | | 75% |
| Inputs for Operating Condition Analyzed | | | |
| Percent of local design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | | CS |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | 1.00 |
| Primary air fraction of supply air at conditioned analyzed | | | 100% |
| Results | | | |
| Ventilation System Efficiency | Ev | cfm | 0.95 |
| Outdoor air intake required for system | Voz | cfm/sf | 648 |
| Outdoor air per unit floor area | Voz/As | cfm/ps | 0.54 |
| Outdoor air per person served by system (including diversity) | Voz/Ps | cfm/ps | 12.3 |
| Outdoor air as a % of design primary supply air | Ypd | cfm | 41% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 1600 |
| Uncorrected OA requirement for system | Vou | cfm | 615 |
| Uncorrected CA req'd as a fraction of primary SA | Xs | | 0.38 |
| Initial Calculations for Individual Zones | | | |
| CA rate per unit area for zone | Raz | cfm/sf | |
| CA rate per person | Rpz | cfm/ps | |
| Total supply air to zone (at condition being analyzed) | Voz | cfm | |
| Unused OA req'd to breathing zone | Voz | cfm | |
| Unused CA requirement for zone | Voz/Ez | | |
| Fraction of zone supply not directly recirc. from zone | Fa | | |
| Fraction of zone supply from fully mixed primary air | Fp | | |
| Fraction of zone OA not directly recirc. from zone | Fz | | |
| Unused CA fraction required in supply air to zone | Zp | | |
| Unused CA fraction required in primary air to zone | | | |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Evz | | |
| System Ventilation Efficiency (App A Method) | Ev | | 0.95 |
| Ventilation System Efficiency (Table 6.3 Method) | Ev | | 0.71 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Voz | cfm | 648 |
| CA intake req'd as a fraction of primary SA | Y | | 0.41 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Voz | cfm | 361 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.54 |
| OA Temp. at which Min. OA provides all cooling | Deg F | | 30 |
| CA1 below which OA intake flow is @ minimum | | | |

| Building: | | Kroc Center | | | | |
|--|--------|------------------------------|---|----------------------------|---|-------|
| System Tag/Name: | | FCU 2 | | | | |
| Operating Condition Description: | | Ventilation | | | | |
| Units (select from pull-down list) | | psf | | | | |
| Inputs for System | | | | | | |
| Floor area served by system | As | sf | | | | |
| Population of area served by system (including diversity) | Ps | p | | | | |
| Design primary supply fan airflow rate | Vpsd | cfm | | | | |
| CA req'd per unit area for system (Weighted average) | Ras | cfm/psf | | | | |
| CA req'd per person for system area (Weighted average) | Rps | cfm/psf | | | | |
| Potentially Critical Zones | | | | | | |
| Zone Name | | | | | | |
| Zone Tag | | | | | | |
| Space type | | | | | | |
| Floor Area of zone | Az | sf | | | | |
| Design population of zone | Pz | p | | | | |
| Design total supply to zone (primary plus local recirculated) | Vzsd | cfm | | | | |
| Inoutlet Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | | | | | | |
| Local recirc. air % representative of ave system return air | Er | % | | | | |
| Inputs for Operating Condition Analyzed | | | | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | | | | |
| Air distribution type at conditioned analyzed | Ez | Selected from pull-down list | | | | |
| Zone air distribution effectiveness at conditioned analyzed | Ez | | | | | |
| Primary air fraction of supply air at conditioned analyzed | Ep | | | | | |
| Results | | | | | | |
| Ventilation System Efficiency | Ev | 0.95 | | | | |
| Outdoor air intake required for system | Voi | cfm | | | | |
| Outdoor air per unit floor area | Voi/As | cfm/sf | | | | |
| Outdoor air per person served by system (including diversity) | Voi/Ps | cfm/psf | | | | |
| Outdoor air as a % of design primary supply air | Ypd | cfm | | | | |
| Detailed Calculations | | | | | | |
| Initial Calculations for the System as a whole | | | | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | - | VpsDs | - | 1600 |
| Uncorrected OA requirement for system | Vou | cfm | - | Rps Ps + Ras As | - | 613 |
| Uncorrected OA req'd as a fraction of primary SA | Xs | | - | Vou / Vps | - | 0.38 |
| Initial Calculations for Individual Zones | | | | | | |
| CA rate per unit area for zone | Raz | cfm/sf | - | | - | 0.12 |
| CA rate per person | Rpz | cfm/psf | - | | - | 0.00 |
| Total supply air to zone (at condition being analyzed) | Voz | cfm | - | Rpz Pz + Raz Az | - | 10.00 |
| Unused OA req'd to breathing zone | Voz | cfm | - | Voz/Ez | - | 300 |
| Unused OA requirement for zone | Voz | cfm | - | Voz/Ez | - | 45.8 |
| Fraction of zone supply not directly recirc. from zone | Fz | | - | Ep + (1-Ep)/Er | - | 47 |
| Fraction of zone supply from fully mixed primary air | Fp | | - | Ep | - | 566 |
| Fraction of zone OA not directly recirc. from zone | Fz | | - | 1-(1-Ez)(1-Ep)/(1-Er) | - | 1.00 |
| Unused OA fraction required in supply air to zone | Zd | | - | Voz / Vps | - | 1.00 |
| Unused OA fraction required in primary air to zone | Zp | | - | Voz / Vpz | - | 0.44 |
| System Ventilation Efficiency | | | | | | |
| Zone Ventilation Efficiency (App A Method) | Evz | | - | (Fa + FDXs - Fdz) / Fa | - | 1.23 |
| System Ventilation Efficiency (App A Method) | Ev | | - | min (Evz) | - | 0.95 |
| Ventilation System Efficiency (Table 6.3 Method) | Ev | | - | Value from Table 6.3 | - | 0.71 |
| Minimum outdoor air intake airflow | | | | | | |
| Outdoor Air Intake Flow required to System | Voi | cfm | - | Vou / Ev | - | 647 |
| OA Intake req'd as a fraction of primary SA | Y | | - | Voi / Vps | - | 0.40 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Voi | cfm | - | Vou / Ev | - | 856 |
| OA Intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | - | Voi / Vps | - | 0.54 |
| OA Temp. at which Min. OA provides all cooling | | | | | | |
| CAI below which OA Intake flow is @ minimum | Deg F | | - | ((Tb-dT)h(1-Y)/Y)(Tt-hdTt) | - | 30 |

| Building: | | Room Center | |
|--|------------|-------------|----------------------------|
| System TrailName: | | RTU 1 | |
| Operating Condition Description: | | Ventilation | |
| Units (selected from pull-down list) | | IP | |
| Inputs for System: | | | |
| Floor area served by system | Area | Units | System |
| Population of area served by system (including diversity) | Ps | P | 16092 |
| Design primary supply fan airflow rate | Ypsd | cfm | 596 |
| CA req'd per unit area for system (Weighted average) | Ras | cfm/sq ft | 23.630 |
| CA req'd per person for system area (Weighted average) | Ras | cfm/sq ft | 0.16 |
| CA req'd per person for system area (Weighted average) | Rps | cfm/sq ft | 8.3 |
| Inputs for Potentially Critical zones: | | | |
| Zone Name | Zone Tag | Zone Name | Zone Tag |
| Zone Name | Zone Tag | Zone Name | Zone Tag |
| Space type | Space type | Space type | Space type |
| Floor Area of zone | Fa | dm | dm |
| Design population of zone | Pz | dm | dm |
| Design total supply to zone (primary plus local recirculation) | Ypdz | cfm | cfm |
| Infiltration (room unit, Dual Fan Dual Duct or Transfer Part) | Ypdz | cfm | cfm |
| Local recirculation (fraction of zone supply return air) | Ypdz | cfm | cfm |
| Inputs for Specific Condition analyzed: | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | dm | Select from pull-down list |
| Zone air distribution effectiveness at conditioned analyzed | Ez | dm | Select from pull-down list |
| Primary air fraction of supply air at conditioned analyzed | Ep | dm | Select from pull-down list |
| Results: | | | |
| Ventilation System Efficiency | Ev | dm | 0.81 |
| Outdoor air intake required for system | Vor | cfm | 8188 |
| Outdoor air per unit floor area | VorPs | cfm/sq ft | 0.45 |
| Outdoor air per person served by system (including diversity) | VorPs | cfm | 44.1 |
| Outdoor air as a % of design primary supply air | Ypd | dm | 35% |
| Output Calculations for the System as a whole: | | | |
| Primary supply air flow to system at conditioned analyzed | Yps | cfm | 23600 |
| Unrecirculated CA req'd as a fraction of primary SA | Ys | dm | 6883 |
| Unrecirculated CA req'd as a fraction of primary SA | Ys | dm | 0.28 |
| Output Calculations for Individual zones: | | | |
| CA rate per unit area for zone | Raz | dm/sq ft | 0.06 |
| CA rate per person | Rps | dm/sq ft | 0.06 |
| Total supply air to zone (if condition being analyzed) | Ypdz | cfm | 7.50 |
| Unrecirculated CA req'd for zone | VorZ | cfm | 6.80 |
| Unrecirculated CA req'd for zone | VorZ | cfm | 333.0 |
| Fraction of zone supply not directly recirc. from zone | Fz | dm | 0.98 |
| Fraction of zone supply not directly recirc. from zone | Fz | dm | 0.98 |
| Fraction of zone CA not directly recirc. from zone | Fz | dm | 0.98 |
| Unrecirculated CA fraction recirculated to zone | Zp | dm | 0.02 |
| Unrecirculated CA fraction recirculated to zone | Zp | dm | 0.02 |
| System Ventilation Efficiency: | | | |
| Zone Ventilation Efficiency (Asp A Method) | Evz | dm | 0.81 |
| System Ventilation Efficiency (Asp A Method) | Ev | dm | 0.81 |
| System Ventilation Efficiency (Table 6.3 Method) | Ev | dm | 0.98 |
| Minimum outdoor air intake airflow: | | | |
| Outdoor Air Intake Flow required to System | Vor | cfm | 8188 |
| CA intake req'd as a fraction of primary SA | Vor | dm | 0.35 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vor | cfm | 8778 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Vor | dm | 0.41 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Vor | cfm | 23 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Vor | dm | 0.41 |

| Building: | | Knox Center | |
|---|------------|----------------------------|--|
| System Tag/Name: | | RTU 5 | |
| Operating Condition Description: | | Condition | |
| Units (selected from pull-down list) | | 100% | |
| Results for System | | | |
| Floor area served by system | Area | 164750 | System |
| Population of area served by system (including diversity) | Pop | 16475 | 16475 |
| Design primary supply fan airflow rate | Fp | 23.678 | 23.678 |
| CA req'd per unit area for system (Weighted average) | Ca | 6.10 | 6.10 |
| CA req'd per person for system area (Weighted average) | Rp | 8.3 | 8.3 |
| Results for Individual Critical Areas | | | |
| Zone Name | Zone Tag | Zone Name | Zone Tag |
| Space type | Space type | Space type | Space type |
| Floor Area of zone | Area | Select from pull-down list | Select from pull-down list |
| Design population of zone | Pop | P | (default value listed, may be overridden) |
| Design total supply to zone (primary plus local recirculated) | Voltd | cfm | |
| Inlet/outlet Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Er | cfm | Select from pull-down list or leave blank if N/A |
| Local recirc. air % (representative of air system return air) | Ca | % | |
| Results for Operating Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Ca | % | 100% |
| Air distribution type at conditioned analyzed | Er | Select from pull-down list | |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | |
| Primary air fraction of supply air at conditioned analyzed | Ca | % | 100% |
| Results | | | |
| Variation System Efficiency | Ev | cfm | 0.81 |
| Outdoor air intake required for system | Vol | cfm | 8188 |
| Outdoor air per unit floor area | Vol/A | cfm/sqft | 0.46 |
| Outdoor air per person served by system (including diversity) | Vol/P | cfm | 44.1 |
| Outdoor air as a % of design primary supply air | Ypd | cfm | 35% |
| Overall Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 23600 |
| Unrecirculated CA requirement for system | Vou | cfm | 6663 |
| Unrecirculated CA req'd as a fraction of primary SA | Xa | | 0.28 |
| Initial Calculations for Individual Zones | | | |
| CA rate per unit area for zone | Rz | cfm/sqft | |
| CA rate per person | Rp | cfm | |
| Total supply air to zone (if condition being analyzed) | Volz | cfm | |
| Unused CA req'd to breathing zone | Volz | cfm | |
| Unused CA requirement for zone | Volz | cfm | |
| Fraction of zone supply not directly recirc. from zone | Fa | | |
| Fraction of zone supply from fully mixed primary air | Fp | | |
| Unused CA req'd to breathing zone | Fp | | |
| Unused CA fraction required to primary air to zone | Zp | | |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Evz | | |
| System Ventilation Efficiency (App A Method) | Ev | | |
| Variation System Efficiency (Table 6.3 Method) | Ev | | |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vol | cfm | 8188 |
| CA Intake req'd as a fraction of primary SA | Y | | 0.35 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vol | cfm | 9778 |
| CA Intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.41 |
| CA Temp at which Min. OA fraction is all cooling | Dwg F | | 23 |
| CA Temp below which CA intake flow is minimum | | | |

| Building: | | Keoc Center |
|------------------------------------|--|-------------|
| System Tag/Name: | | RTU 2 |
| Operating Condition Description: | | Ventilation |
| Units (select from pull-down list) | | IP |

| Inputs for System | Name | Units | System |
|---|------|--------|--------|
| Floor area served by system | As | sf | 6700 |
| Population of area served by system (including diversity) | Ps | P | 84 |
| Design primary supply flow airflow rate | Vpsd | cfm | 6,792 |
| CA need per unit area for system (Weighted average) | Rps | cfm/sf | 0.20 |
| CA need per person for system area (Weighted average) | Rps | cfm/ps | 6.3 |

| Inputs for Potentially Critical zones | Zone Name | Zone Tag | Space Type | Area | Population | CA need per unit area | CA need per person | Design primary supply flow | Design primary supply flow | CA need per unit area | CA need per person |
|---------------------------------------|-----------|--------------------------|-----------------------|------|------------|-----------------------|--------------------|----------------------------|----------------------------|-----------------------|--------------------|
| Potentially Critical Zones | | | | | | | | | | | |
| | VAW S1.1 | 111, 112, 114 | central | 882 | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 | 8.3 |
| | VAW S1.2 | C119, 120, 121 | Office space | 1060 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 | 5.3 |
| | VAW S1.3 | C115, 118, 118 | Classrooms (ages 5-8) | 656 | 16.37 | 16.37 | 16.37 | 16.37 | 16.37 | 16.37 | 16.37 |
| | VAW S1.4 | C113 | Computer Lab | 218 | 2.37 | 2.37 | 2.37 | 2.37 | 2.37 | 2.37 | 2.37 |
| | VAW S1.5 | C122, 123 | Conference/Meeting | 420 | 20 | 20 | 20 | 20 | 20 | 20 | 20 |
| | VAW S1.6 | C125, 126, 127, 128, 131 | Office space | 725 | 6.40 | 6.40 | 6.40 | 6.40 | 6.40 | 6.40 | 6.40 |
| | VAW S1.7 | C132 | Office space | 307 | 1.22 | 1.22 | 1.22 | 1.22 | 1.22 | 1.22 | 1.22 |
| | VAW S1.8 | C133, 137, 138 | Office space | 527 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 | 2.6 |
| | VAW S1.9 | C118, 141 | Break rooms | 792 | 18.87 | 18.87 | 18.87 | 18.87 | 18.87 | 18.87 | 18.87 |

| Inputs for Operating Condition Analyzed | Percent of total design airflow rate at conditioned analyzed | Ds | % |
|---|---|----|------------------------------|
| Air distribution type at conditioned analyzed <td>Zone air distribution effectiveness at conditioned analyzed <td>Ep</td> <td>Selected from pull-down list</td> </td> | Zone air distribution effectiveness at conditioned analyzed <td>Ep</td> <td>Selected from pull-down list</td> | Ep | Selected from pull-down list |
| Primary air fraction of supply air at conditioned analyzed <td> <td>Ep</td> <td>100%</td> </td> | <td>Ep</td> <td>100%</td> | Ep | 100% |

| Results | Ev | Vot | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps | Vo/ps |
|---|------|-----|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Ventilation System Efficiency | 0.88 | | | | | | | | | | | | | | | | | |
| Outdoor air intake required for system | 1084 | | | | | | | | | | | | | | | | | |
| Outdoor air per unit floor area | 0.20 | | | | | | | | | | | | | | | | | |
| Outdoor air per person served by system (including diversity) | 13.1 | | | | | | | | | | | | | | | | | |
| Outdoor air as a % of design primary supply air | 16% | | | | | | | | | | | | | | | | | |

| Standard Calculations | Initial Calculations for the System as a whole | Vps | dm | Vps | dm | Vps | dm | Vps | dm | Vps | dm | Vps | dm | Vps | dm | Vps | dm | Vps | dm |
|---|--|-------|----|-----|----|-----|----|-----|----|-----|----|-----|----|-----|----|-----|----|-----|----|
| Primary supply air flow to system at conditioned analyzed | | 6700 | | | | | | | | | | | | | | | | | |
| Unconditioned CA requirement for system | | 651 | | | | | | | | | | | | | | | | | |
| Unconditioned CA need as a fraction of primary SA | | 0.14 | | | | | | | | | | | | | | | | | |
| CA rate per unit area for zone | Raz | dm/sf | | | | | | | | | | | | | | | | | |
| CA rate per person for zone | Rps | dm/ps | | | | | | | | | | | | | | | | | |
| Totals supply air to zone (at condition being analyzed) | Vzsd | cfm | | | | | | | | | | | | | | | | | |
| Unmixed CA need to breathing zone | Vzsd | cfm | | | | | | | | | | | | | | | | | |
| Unmixed CA requirement for zone | Vzsd | cfm | | | | | | | | | | | | | | | | | |
| Fraction of zone supply not directly recirc. from zone | Fz | | | | | | | | | | | | | | | | | | |
| Fraction of zone supply from this mixed primary air | Fz | | | | | | | | | | | | | | | | | | |
| Fraction of zone CA not directly recirc. from zone | Fz | | | | | | | | | | | | | | | | | | |
| Fraction of zone CA not directly recirc. from zone | Fz | | | | | | | | | | | | | | | | | | |
| Unmixed CA fraction required to supply air to zone | Zp | | | | | | | | | | | | | | | | | | |
| Unmixed CA fraction required to primary air to zone | Zp | | | | | | | | | | | | | | | | | | |
| System Ventilation Efficiency | Ev | | | | | | | | | | | | | | | | | | |
| Zone Ventilation Efficiency (App A Method) | Evz | | | | | | | | | | | | | | | | | | |
| System Ventilation Efficiency (App A Method) | Ev | | | | | | | | | | | | | | | | | | |
| System Ventilation Efficiency (Table 6.3 Method) | Ev | | | | | | | | | | | | | | | | | | |
| Minimum outdoor air intake | Vot | cfm | | | | | | | | | | | | | | | | | |
| Outdoor air intake flow required to System | Vot | cfm | | | | | | | | | | | | | | | | | |
| Outdoor air intake need as a fraction of primary SA | Vot | | | | | | | | | | | | | | | | | | |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | cfm | | | | | | | | | | | | | | | | | |
| CA intake need as a fraction of primary SA (Table 6.3 Method) | Vot | | | | | | | | | | | | | | | | | | |
| CA intake need as a fraction of primary SA (Table 6.3 Method) | Vot | | | | | | | | | | | | | | | | | | |
| CA intake need as a fraction of primary SA (Table 6.3 Method) | Vot | | | | | | | | | | | | | | | | | | |
| CA intake need as a fraction of primary SA (Table 6.3 Method) | Vot | | | | | | | | | | | | | | | | | | |
| CA intake need as a fraction of primary SA (Table 6.3 Method) | Vot | | | | | | | | | | | | | | | | | | |

| Building: Kroc Center | | | | | | | | | | | | | | | | | | | |
|---|---|-------------------------------|-------|--------|--|------|------|---|--------|------|---|--------|-------|--|----------|------|-----|----------|-----|
| System Tag/Name: RTU 3 | | | | | | | | | | | | | | | | | | | |
| Operating Condition Description: Ventilation | | | | | | | | | | | | | | | | | | | |
| Units (select from pull-down list) | | | | | | | | | | | | | | | | | | | |
| Inputs for System | <table border="1"> <thead> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>As</td> <td>cfm</td> <td>2990</td> </tr> <tr> <td>Ps</td> <td>P</td> <td>318</td> </tr> <tr> <td>Vpsd</td> <td>cfm</td> <td>7.680</td> </tr> <tr> <td>Ras</td> <td>cfm/cfpm</td> <td>0.07</td> </tr> <tr> <td>Rps</td> <td>cfm/cfpm</td> <td>5.0</td> </tr> </tbody> </table> | Name | Units | System | As | cfm | 2990 | Ps | P | 318 | Vpsd | cfm | 7.680 | Ras | cfm/cfpm | 0.07 | Rps | cfm/cfpm | 5.0 |
| Name | Units | System | | | | | | | | | | | | | | | | | |
| As | cfm | 2990 | | | | | | | | | | | | | | | | | |
| Ps | P | 318 | | | | | | | | | | | | | | | | | |
| Vpsd | cfm | 7.680 | | | | | | | | | | | | | | | | | |
| Ras | cfm/cfpm | 0.07 | | | | | | | | | | | | | | | | | |
| Rps | cfm/cfpm | 5.0 | | | | | | | | | | | | | | | | | |
| <p>Floor area served by system</p> <p>Population of area served by system (including diversity)</p> <p>Design primary supply fan airflow rate</p> <p>OA req'd per unit area for system (Weighted average)</p> <p>OA req'd per person for system area (Weighted average)</p> <p>Inputs for Potentially Critical Zone</p> <p>Zone Name</p> <p>Zone Tag</p> <p>Space type</p> <p>Floor Area of zone</p> <p>Design population of zone</p> <p>Design total supply to zone (primary plus local recirculated)</p> <p>Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?</p> <p>Local recirc. air % representative of ave system return air</p> | | | | | | | | | | | | | | | | | | | |
| Inputs for Operating Condition Analyzed | <table border="1"> <thead> <tr> <th></th> <th>%</th> <th></th> </tr> </thead> <tbody> <tr> <td>Percent of total design airflow rate at conditioned analyzed</td> <td>100%</td> <td></td> </tr> <tr> <td>Air distribution type at conditioned analyzed</td> <td>CS</td> <td>CS</td> </tr> <tr> <td>Zone air distribution effectiveness at conditioned analyzed</td> <td>1.00</td> <td>1.00</td> </tr> <tr> <td>Primary air fraction of supply air at conditioned analyzed</td> <td>100%</td> <td>100%</td> </tr> </tbody> </table> | | % | | Percent of total design airflow rate at conditioned analyzed | 100% | | Air distribution type at conditioned analyzed | CS | CS | Zone air distribution effectiveness at conditioned analyzed | 1.00 | 1.00 | Primary air fraction of supply air at conditioned analyzed | 100% | 100% | | | |
| | % | | | | | | | | | | | | | | | | | | |
| Percent of total design airflow rate at conditioned analyzed | 100% | | | | | | | | | | | | | | | | | | |
| Air distribution type at conditioned analyzed | CS | CS | | | | | | | | | | | | | | | | | |
| Zone air distribution effectiveness at conditioned analyzed | 1.00 | 1.00 | | | | | | | | | | | | | | | | | |
| Primary air fraction of supply air at conditioned analyzed | 100% | 100% | | | | | | | | | | | | | | | | | |
| Results | <table border="1"> <tbody> <tr> <td>Ventilation System Efficiency</td> <td>Ev</td> <td>1.00</td> </tr> <tr> <td>Outdoor air intake required for system</td> <td>Vor</td> <td>1795</td> </tr> <tr> <td>Outdoor air per unit floor area</td> <td>Vor/As</td> <td>0.60</td> </tr> <tr> <td>Outdoor air per person served by system (including diversity)</td> <td>Vor/Ps</td> <td>5.6</td> </tr> <tr> <td>Outdoor air as a % of design primary supply air</td> <td>ypd</td> <td>23%</td> </tr> </tbody> </table> | Ventilation System Efficiency | Ev | 1.00 | Outdoor air intake required for system | Vor | 1795 | Outdoor air per unit floor area | Vor/As | 0.60 | Outdoor air per person served by system (including diversity) | Vor/Ps | 5.6 | Outdoor air as a % of design primary supply air | ypd | 23% | | | |
| Ventilation System Efficiency | Ev | 1.00 | | | | | | | | | | | | | | | | | |
| Outdoor air intake required for system | Vor | 1795 | | | | | | | | | | | | | | | | | |
| Outdoor air per unit floor area | Vor/As | 0.60 | | | | | | | | | | | | | | | | | |
| Outdoor air per person served by system (including diversity) | Vor/Ps | 5.6 | | | | | | | | | | | | | | | | | |
| Outdoor air as a % of design primary supply air | ypd | 23% | | | | | | | | | | | | | | | | | |
| Detailed Calculations | | | | | | | | | | | | | | | | | | | |
| Initial Calculations for the System as a whole | | | | | | | | | | | | | | | | | | | |
| Primary supply air flow to system at conditioned analyzed | | | | | | | | | | | | | | | | | | | |
| Uncorrected/OA requirement for system | | | | | | | | | | | | | | | | | | | |
| Uncorrected OA req'd as a fraction of primary SA | | | | | | | | | | | | | | | | | | | |
| Initial Calculations for Individual Zones | | | | | | | | | | | | | | | | | | | |
| OA rate per unit area for zone | | | | | | | | | | | | | | | | | | | |
| OA rate per person | | | | | | | | | | | | | | | | | | | |
| Total supply air to zone (at condition being analyzed) | | | | | | | | | | | | | | | | | | | |
| Unused OA req'd to breathing zone | | | | | | | | | | | | | | | | | | | |
| Unused OA requirement for zone | | | | | | | | | | | | | | | | | | | |
| Fraction of zone supply not directly recirc. from zone | | | | | | | | | | | | | | | | | | | |
| Fraction of zone supply from fully mixed primary air | | | | | | | | | | | | | | | | | | | |
| Fraction of zone OA not directly recirc. from zone | | | | | | | | | | | | | | | | | | | |
| Unused OA fraction required in supply air to zone | | | | | | | | | | | | | | | | | | | |
| Unused OA fraction required in primary air to zone | | | | | | | | | | | | | | | | | | | |
| System Ventilation Efficiency | | | | | | | | | | | | | | | | | | | |
| Zone Ventilation Efficiency (App A Method) | | | | | | | | | | | | | | | | | | | |
| System Ventilation Efficiency (App A Method) | | | | | | | | | | | | | | | | | | | |
| Ventilation System Efficiency (Table 6.3 Method) | | | | | | | | | | | | | | | | | | | |
| Minimum outdoor air Intake airflow | | | | | | | | | | | | | | | | | | | |
| Outdoor Air Intake Flow required to System | | | | | | | | | | | | | | | | | | | |
| OA intake req'd as a fraction of primary SA | | | | | | | | | | | | | | | | | | | |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | | | | | | | | | | | | | | | | | | | |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | | | | | | | | | | | | | | | | | | | |
| OA Temp at which Min. OA provides all cooling | | | | | | | | | | | | | | | | | | | |
| OAT below which OA Intake flows is minimum | | | | | | | | | | | | | | | | | | | |

| | | | |
|--|--|----------------------|---|
| Building: | | Kios Center | |
| System Tag/Name: | | RTU 4 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | ft ³ /min | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | A6 | sf | 2700 |
| Design primary supply fan airflow rate | P6 | p | 32 |
| OA req'd per unit area for system (Weighted average) | Vpsd | cfm | 6.000 |
| OA req'd per person for system area (Weighted average) | Rps | cfm | 0.06 |
| OA req'd per person for system area (Weighted average) | Rps | cfm | 5.0 |
| Inputs for Potentially Critical Zone | | | |
| Zone Name | Zone the lunge purple (air for critical zone(s)) | | |
| Zone Tag | Selected from pull-down list | | |
| Space type | Selected from pull-down list | | |
| Floor Area of zone | Az | sf | |
| Design population of zone | Pz | p | (default value listed; may be overridden) |
| Design total supply to zone (primary plus local recirculated) | Vzsd | cfm | |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Selected from pull-down list or leave blank if N/A | | |
| Local recirc. air % representative of zone system return air | Er | % | |
| Inputs for Operating Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | | Selected from pull-down list |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | |
| Primary air fraction of supply air at conditioned analyzed | | | |
| Results | | | |
| Ventilation System Efficiency | Ev | | 0.96 |
| Outdoor air intake required for system | Vot | cfm | 342 |
| Outdoor air per unit floor area | Vot/As | cfm/sf | 0.13 |
| Outdoor air per person served by system (including diversity) | Vot/Ps | cfm | 10.8 |
| Outdoor air as a % of design primary supply air | Vpd | cfm | 6% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 6000 |
| Unrecirculated OA requirement for system | Vou | cfm | 328 |
| Unrecirculated OA req'd as a fraction of primary SA | Xs | | 0.05 |
| Initial Calculations for Individual Zones | | | |
| OA rate per unit area for zone | Raz | cfm/sf | |
| OA rate per person | Roz | cfm | |
| Total supply air to zone (at condition being analyzed) | Vzsd | cfm | |
| Unused OA req'd to breathing zone | Vbz | cfm | |
| Unused OA requirement for zone | Voz | cfm | |
| Fraction of zone supply not directly recirc. from zone | Fa | | |
| Fraction of zone supply from fully mixed primary air | Fp | | |
| Fraction of zone OA not directly recirc. from zone | Fz | | |
| Unused OA fraction required in supply air to zone | Zp | | |
| Unused OA fraction required in primary air to zone | Zp | | |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Ez | | |
| System Ventilation Efficiency (App A Method) | Ev | | 0.96 |
| System Ventilation Efficiency (Table 6.3 Method) | Ev | | 1.05 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vot | cfm | 342 |
| OA intake req'd as a fraction of primary SA | Y | | 0.06 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | cfm | 311 |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.05 |
| OA intake req'd at which Min OA provides all cooling | Deg F | | -226 |
| OA/T below which OA intake flow is @ minimum | | | |

| | | | |
|--|---|-------------|---------|
| Building: | | Knox Center | |
| System Tag/Name: | | RTU 5 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | p | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | As | sf | 4590 |
| Design primary supply fan airflow rate | Ps | p | 0 |
| OA req'd per unit area for system (Weighted average) | Wpsd | cfm | 7.200 |
| OA req'd per person for system area (Weighted average) | Ras | cfm/sf | 0.48 |
| OA req'd per person for system area (Weighted average) | Rps | cfm/p | 0.0 |
| Potentially Critical Zones | | | |
| Zone Name | Zone the lung purple (air for critical zone(s)) | | |
| Zone Tag | Selected from pull-down list | | |
| Space type | Selected from pull-down list | | |
| Floor Area of zone | Az | sf | 4590 |
| Design population of zone | Pz | p | 0 |
| Design total supply to zone (primary plus local recirculated) | Wztd | cfm | 7.200 |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Et | | 75% |
| Local recirc. air % representative of a/c system return air | Potentially Critical Zones | | |
| Inputs for Operating Condition Analyzed | | | |
| Percent of local design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | | CS |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | 1.00 |
| Primary air fraction of supply air at conditioned analyzed | 100% | | |
| Results | | | |
| Ventilation System Efficiency | EV | | 1.00 |
| Outdoor air intake required for system | Vol | cfm | 2203 |
| Outdoor air per unit floor area | Vol/As | cfm/sf | 0.48 |
| Outdoor air per person served by system (including diversity) | Vol/Ps | cfm/p | #DIV/0! |
| Outdoor air as a % of design primary supply air | Vpd | cfm | 31% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 7200 |
| Uncorrected OA requirement for system | Vou | cfm | 2203 |
| Uncorrected OA req'd as a fraction of primary SA | Xs | | 0.31 |
| Initial Calculations for Individual Zones | | | |
| OA rate per unit area for zone | Raz | cfm/sf | 0.48 |
| OA rate per person | Rpz | cfm/p | 0.00 |
| Total supply air to zone, (at condition being analyzed) | Wztd | cfm | 7200 |
| Unused OA req'd to breathing zone | Wbz | cfm | 0.0 |
| Unused OA requirement for zone | Wbz/Ez | | 2203.2 |
| Fraction of zone supply not directly recirc. from zone | Fa | | 1.00 |
| Fraction of zone supply from fully mixed primary air | Fp | | 1.00 |
| Fraction of zone OA not directly recirc. from zone | Fc | | 1.00 |
| Unused OA fraction required in supply air to zone | Zd | | 0.31 |
| Unused OA fraction required in primary air to zone | Zp | | 0.31 |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Ez/EV | | 1.00 |
| System Ventilation Efficiency (App A Method) | Ez | | 1.00 |
| Ventilation System Efficiency (Table 6.3 Method) | EV | | 0.94 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vol | cfm | 2203 |
| OA intake req'd as a fraction of primary SA | Y | | 0.31 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vol | cfm | 2610 |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.36 |
| OA Temp at which Min OA provides all cooling | | | |
| OAT below which OA intake flow is @ minimum | Deg F | | 16 |

| Building: | Kroc Center | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|---------------------|-------|--------|--|------------------------------|---------------------|---|------------------------------|------|---|---|-------|--|--|---------|--|--------|-----|--|----|--|--|----|--|--|----|--|---|----|--|--|----|--|
| System Tag/Name: | RTU 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Operating Condition Description: | Ventilation | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Units (select from pull-down list) | IP | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Inputs for System <table border="1"> <thead> <tr> <th>Name</th> <th>Units</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>Az</td> <td>sf</td> <td>4590</td> </tr> <tr> <td>Pz</td> <td>P</td> <td>0</td> </tr> <tr> <td>Vpzd</td> <td>dm</td> <td>7.200</td> </tr> <tr> <td>Raz</td> <td>dm/st</td> <td>0.48</td> </tr> <tr> <td>Rps</td> <td>dmip</td> <td>0.0</td> </tr> </tbody> </table> | | Name | Units | System | Az | sf | 4590 | Pz | P | 0 | Vpzd | dm | 7.200 | Raz | dm/st | 0.48 | Rps | dmip | 0.0 | | | | | | | | | | | | | | | |
| Name | Units | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Az | sf | 4590 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Pz | P | 0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Vpzd | dm | 7.200 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Raz | dm/st | 0.48 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Rps | dmip | 0.0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Inputs for Operating Condition Analyzed <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>Floor area of zone</td> <td>Selected from pull-down list</td> <td>4,590 (pool & deck)</td> </tr> <tr> <td>Design population of zone</td> <td>Selected from pull-down list</td> <td>0</td> </tr> <tr> <td>Design total supply to zone (primary plus local recirculated)</td> <td>(default value listed; may be overridden)</td> <td>7,200</td> </tr> <tr> <td>Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan?</td> <td>Selected from pull-down list or leave blank if N/A</td> <td>ITU</td> </tr> <tr> <td>Local recirc. air % representative of zone system return air</td> <td></td> <td>75%</td> </tr> </tbody> </table> | | Parameter | Value | System | Floor area of zone | Selected from pull-down list | 4,590 (pool & deck) | Design population of zone | Selected from pull-down list | 0 | Design total supply to zone (primary plus local recirculated) | (default value listed; may be overridden) | 7,200 | Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Selected from pull-down list or leave blank if N/A | ITU | Local recirc. air % representative of zone system return air | | 75% | | | | | | | | | | | | | | | |
| Parameter | Value | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Floor area of zone | Selected from pull-down list | 4,590 (pool & deck) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Design population of zone | Selected from pull-down list | 0 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Design total supply to zone (primary plus local recirculated) | (default value listed; may be overridden) | 7,200 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Selected from pull-down list or leave blank if N/A | ITU | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Local recirc. air % representative of zone system return air | | 75% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Results <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>Percent of local design airflow rate at conditioned analyzed</td> <td>Ds %</td> <td>100%</td> </tr> <tr> <td>Air distribution type at conditioned analyzed</td> <td>Ez</td> <td>CS</td> </tr> <tr> <td>Zone air distribution effectiveness at conditioned analyzed</td> <td>Ez</td> <td>1.00</td> </tr> <tr> <td>Primary air fraction of supply air at conditioned analyzed</td> <td>Ep</td> <td>100%</td> </tr> </tbody> </table> | | Parameter | Value | System | Percent of local design airflow rate at conditioned analyzed | Ds % | 100% | Air distribution type at conditioned analyzed | Ez | CS | Zone air distribution effectiveness at conditioned analyzed | Ez | 1.00 | Primary air fraction of supply air at conditioned analyzed | Ep | 100% | | | | | | | | | | | | | | | | | | |
| Parameter | Value | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Percent of local design airflow rate at conditioned analyzed | Ds % | 100% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Air distribution type at conditioned analyzed | Ez | CS | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Zone air distribution effectiveness at conditioned analyzed | Ez | 1.00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Primary air fraction of supply air at conditioned analyzed | Ep | 100% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Detailed Calculations <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>Ventilation System Efficiency</td> <td>Ev</td> <td>1.00</td> </tr> <tr> <td>Outdoor air intake required for system</td> <td>Vot</td> <td>2203</td> </tr> <tr> <td>Outdoor air per unit floor area</td> <td>Vot/As</td> <td>0.48</td> </tr> <tr> <td>Outdoor air per person served by system (including diversity)</td> <td>Vot/Ps</td> <td>#DN/901</td> </tr> <tr> <td>Outdoor air as a % of design primary supply air</td> <td>Ypd</td> <td>31%</td> </tr> </tbody> </table> | | Parameter | Value | System | Ventilation System Efficiency | Ev | 1.00 | Outdoor air intake required for system | Vot | 2203 | Outdoor air per unit floor area | Vot/As | 0.48 | Outdoor air per person served by system (including diversity) | Vot/Ps | #DN/901 | Outdoor air as a % of design primary supply air | Ypd | 31% | | | | | | | | | | | | | | | |
| Parameter | Value | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Ventilation System Efficiency | Ev | 1.00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Outdoor air intake required for system | Vot | 2203 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Outdoor air per unit floor area | Vot/As | 0.48 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Outdoor air per person served by system (including diversity) | Vot/Ps | #DN/901 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Outdoor air as a % of design primary supply air | Ypd | 31% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Initial Calculations for the System as a whole <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>Primary supply air flow to system at conditioned analyzed</td> <td>Vps</td> <td>7200</td> </tr> <tr> <td>Uncorrected OA requirement for system</td> <td>Vou</td> <td>2203</td> </tr> <tr> <td>Uncorrected OA req'd as a fraction of primary SA</td> <td>Xs</td> <td>0.31</td> </tr> </tbody> </table> | | Parameter | Value | System | Primary supply air flow to system at conditioned analyzed | Vps | 7200 | Uncorrected OA requirement for system | Vou | 2203 | Uncorrected OA req'd as a fraction of primary SA | Xs | 0.31 | | | | | | | | | | | | | | | | | | | | | |
| Parameter | Value | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | 7200 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Uncorrected OA requirement for system | Vou | 2203 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Uncorrected OA req'd as a fraction of primary SA | Xs | 0.31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Initial Calculations for Individual Zones <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>OA rate per unit area for zone</td> <td>Raz</td> <td>dm/st</td> </tr> <tr> <td>OA rate per person</td> <td>Rpz</td> <td>dmip</td> </tr> <tr> <td>Total supply air to zone (at condition being analyzed)</td> <td>Voz</td> <td>dm</td> </tr> <tr> <td>Unused OA req'd to breathing zone</td> <td>Voz</td> <td>dm</td> </tr> <tr> <td>Unused OA requirement for zone</td> <td>Voz/Ez</td> <td></td> </tr> <tr> <td>Fraction of zone supply not directly recirc. from zone</td> <td>Fa</td> <td></td> </tr> <tr> <td>Fraction of zone supply from fully mixed primary air</td> <td>Fb</td> <td></td> </tr> <tr> <td>Fraction of zone OA not directly recirc. from zone</td> <td>Fc</td> <td></td> </tr> <tr> <td>Unused OA fraction required in supply air to zone</td> <td>Zd</td> <td></td> </tr> <tr> <td>Unused OA fraction required in primary air to zone</td> <td>Zp</td> <td></td> </tr> </tbody> </table> | | Parameter | Value | System | OA rate per unit area for zone | Raz | dm/st | OA rate per person | Rpz | dmip | Total supply air to zone (at condition being analyzed) | Voz | dm | Unused OA req'd to breathing zone | Voz | dm | Unused OA requirement for zone | Voz/Ez | | Fraction of zone supply not directly recirc. from zone | Fa | | Fraction of zone supply from fully mixed primary air | Fb | | Fraction of zone OA not directly recirc. from zone | Fc | | Unused OA fraction required in supply air to zone | Zd | | Unused OA fraction required in primary air to zone | Zp | |
| Parameter | Value | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OA rate per unit area for zone | Raz | dm/st | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OA rate per person | Rpz | dmip | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Total supply air to zone (at condition being analyzed) | Voz | dm | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Unused OA req'd to breathing zone | Voz | dm | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Unused OA requirement for zone | Voz/Ez | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fraction of zone supply not directly recirc. from zone | Fa | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fraction of zone supply from fully mixed primary air | Fb | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fraction of zone OA not directly recirc. from zone | Fc | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Unused OA fraction required in supply air to zone | Zd | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Unused OA fraction required in primary air to zone | Zp | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| System Ventilation Efficiency <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>Zone Ventilation Efficiency (App A Method)</td> <td>E/z</td> <td></td> </tr> <tr> <td>System Ventilation Efficiency (App A Method)</td> <td>Ev</td> <td>1.00</td> </tr> <tr> <td>Ventilation System Efficiency (Table 6.3 Method)</td> <td>Ev</td> <td>0.84</td> </tr> </tbody> </table> | | Parameter | Value | System | Zone Ventilation Efficiency (App A Method) | E/z | | System Ventilation Efficiency (App A Method) | Ev | 1.00 | Ventilation System Efficiency (Table 6.3 Method) | Ev | 0.84 | | | | | | | | | | | | | | | | | | | | | |
| Parameter | Value | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Zone Ventilation Efficiency (App A Method) | E/z | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| System Ventilation Efficiency (App A Method) | Ev | 1.00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Ventilation System Efficiency (Table 6.3 Method) | Ev | 0.84 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Minimum outdoor air intake airflow <table border="1"> <thead> <tr> <th>Parameter</th> <th>Value</th> <th>System</th> </tr> </thead> <tbody> <tr> <td>Outdoor Air Intake Flow required to System</td> <td>Vot</td> <td>dm</td> </tr> <tr> <td>OA intake req'd as a fraction of primary SA</td> <td>Y</td> <td></td> </tr> <tr> <td>Outdoor Air Intake Flow required to System (Table 6.3 Method)</td> <td>Vot</td> <td>dm</td> </tr> <tr> <td>OA intake req'd as a fraction of primary SA (Table 6.3 Method)</td> <td>Y</td> <td></td> </tr> </tbody> </table> | | Parameter | Value | System | Outdoor Air Intake Flow required to System | Vot | dm | OA intake req'd as a fraction of primary SA | Y | | Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | dm | OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | | | | | | | | | | | | | | | | | | |
| Parameter | Value | System | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Outdoor Air Intake Flow required to System | Vot | dm | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OA intake req'd as a fraction of primary SA | Y | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | dm | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| OA Temp. at which Min. OA provides all cooling CAT below which OA intake flow is at minimum Deg F = ((T _p -T _o) ^{0.15} / (1-Y)) ^{1.1} / (T _p +T _o) = 16 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

| | | | |
|--|--|-------------|--|
| Building: | | Kino Center | |
| System Tag/Name: | | RTU 7 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | ppm | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | As | sf | 2260 |
| Design primary supply fan airflow rate | Ps | cfm | 511 |
| OA req'd per unit area for system (Weighted average) | Vpzd | cfm | 2,000 |
| OA req'd per person for system area (Weighted average) | Ras | cfm/sf | 0.09 |
| | Rps | cfm/ps | 20.0 |
| Inputs for Potentially Critical Zones | | | |
| Zone Name | Zone the turns purple (click for critical zone(s)) | | |
| Zone Tag | | | |
| Space type | Selected from pull-down list | | |
| Floor Area of zone | Az | sf | Selected from pull-down list |
| Design population of zone | Pz | ps | (default value listed; may be overridden) |
| Design total supply to zone (primary plus local recirculated) | Vztd | cfm | Selected from pull-down list or leave blank if N/A |
| Inclusion Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Et | | |
| Local recirc. air % representative of zone system return air | | | |
| Inputs for Operation Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | | Selected from pull-down list |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | |
| Primary air fraction of supply air at conditioned analyzed | | | |
| Results | | | |
| Ventilation System Efficiency | Ev | | 0.85 |
| Outdoor air intake required for system | Vot | cfm | 1430 |
| Outdoor air per unit floor area | Vot/As | cfm/sf | 0.63 |
| Outdoor air per person served by system (including diversity) | Vot/Ps | cfm/ps | 28.1 |
| Outdoor air as a % of design primary supply air | Vpd | cfm | 71% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 2000 |
| Uncorrected OA requirement for system | Vou | cfm | 1211 |
| Uncorrected OA req'd as a fraction of primary SA | Xs | | 0.61 |
| Initial Calculations for Individual Zones | | | |
| OA rate per unit area for zone | Raz | cfm/sf | 0.12 |
| OA rate per person | Rpz | cfm/ps | 0.00 |
| Total supply air to zone (at condition being analyzed) | Vz | cfm | 460 |
| Unused OA req'd to breathing zone | Vbz | cfm | 97.2 |
| Unused OA requirement for zone | Vbz/Ez | | 1092.2 |
| Fraction of zone supply not directly recirc. from zone | Fa | | 1.00 |
| Fraction of zone supply from fully mixed primary air | Ep | | 1.00 |
| Fraction of zone OA not directly recirc. from zone | Fz | | 1.00 |
| Unused OA fraction required in supply air to zone | Zd | | 0.21 |
| Unused OA fraction required in primary air to zone | Zp | | 0.21 |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Ez | | (Fa + FDXs - FzD) / Fa |
| System Ventilation Efficiency (App A Method) | Ev | | min (Ez) |
| Ventilation System Efficiency (Table 6.3 Method) | EV | | Value from Table 6.3 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vot | cfm | 1430 |
| OA intake req'd as a fraction of primary SA | Y | | 0.71 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | cfm | n/a |
| OA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | n/a |
| OA Temp at which Min OA provides all cooling | | | |
| OA Temp at which Min OA provides all cooling | Deg F | | 48 |
| OAT below which OA intake flow is @ minimum | | | |

| | | | |
|--|--|--------------|--------|
| Building: | | Kiroc Center | |
| System Tag/Name: | | RTU 8 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | ppm | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | As | sf | 5780 |
| Design primary supply fan airflow rate | Ps | p | 32 |
| CA req'd per unit area for system (Weighted average) | Vpsd | cfm | 9.500 |
| CA req'd per person for system area (Weighted average) | Ras | cfm/sf | 0.06 |
| Potentially Critical Zones | Rps | cfm/p | 23.0 |
| Zone Name | Zone the turns purple (ask for critical zone(s)) | | |
| Zone Tag | Potentially Critical Zones | | |
| Space type | Fitness | | |
| Floor Area of zone | C107 | | |
| Design population of zone | Health | | |
| Design total supply to zone (primary plus local recirculated) | club/weight rooms | | |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Az | sf | 3,220 |
| Local recirc. air % representative of ave system return air | Pz | p | 32.2 |
| | Vozd | cfm | 8,200 |
| | Er | | TTU |
| | | | 75% |
| Inputs for Operating Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Os | % | 100% |
| Air distribution type at conditioned analyzed | Served from pull-down list | | |
| Zone air distribution effectiveness at conditioned analyzed | Ez | | C9 |
| Primary air fraction of supply air at conditioned analyzed | Ep | | 1.00 |
| | | | 100% |
| Results | | | |
| Ventilation System Efficiency | Ey | cfm | 0.39 |
| Outdoor air intake required for system | Voz | cfm/sf | 1005 |
| Outdoor air per unit floor area | Voz/As | cfm/sf | 0.17 |
| Outdoor air per person served by system (including diversity) | Voz/ps | cfm/p | 31.2 |
| Outdoor air as a % of design primary supply air | Ypd | cfm | 11% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a Whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 9500 |
| Uncorrected CA requirement for system | Vou | cfm | 991 |
| Uncorrected CA req'd as a fraction of primary SA | Xs | | 0.10 |
| Initial Calculations for Individual Zones | | | |
| CA rate per unit area for zone | Raz | cfm/sf | 0.06 |
| CA rate per person | Rpz | cfm/p | 20.00 |
| Total supply air to zone (at condition being analyzed) | Voz | cfm | 8200 |
| Unused CA req'd to breathing zone | Vbz | cfm | 837.2 |
| Unused CA requirement for zone | Voz | cfm | 837 |
| Fraction of zone supply not directly recirc. from zone | Fa | | 1.00 |
| Fraction of zone supply from fully mixed primary air | Fp | | 1.00 |
| Fraction of zone CA not directly recirc. from zone | Fz | | 1.00 |
| Unused CA fraction required in supply air to zone | Zd | | 0.10 |
| Unused CA fraction required in primary air to zone | Zp | | 0.10 |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Eyz | | 1.00 |
| System Ventilation Efficiency (App A Method) | Ey | | 0.39 |
| Ventilation System Efficiency (Table 6.3 Method) | Ey | | 1.03 |
| Minimum outdoor air intake airflow | | | |
| Outdoor air intake flow required to System | Voz | cfm | 1005 |
| CA intake req'd as a fraction of primary SA | Y | | 0.11 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Voz | cfm | 960 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.10 |
| CA Intake at which Min CA provides all cooling | Deg F | | -89 |
| CA/T below which CA intake flow is @ minimum | | | |

| Building: | | Kron Center | |
|--|---|-------------|--|
| System Tag/Name: | | RTU 3 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | P | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | As | sf | 1170 |
| Design primary supply fan airflow rate | Pc | P | 45 |
| CA req'd per unit area for system (Weighted average) | Vpsd | cfm | 2,600 |
| CA req'd per person for system area (Weighted average) | Ras | cfm/sf | 0.06 |
| CA req'd per person for system area (Weighted average) | Rps | cfm/p | 5.0 |
| Inputs for Potentially Critical Zones | | | |
| Zone Name | Zone the lungs purple italic for critical zone(s) | | |
| Zone Tag | Zone the lungs purple italic for critical zone(s) | | |
| Space type | Selected from pull-down list | | |
| Floor Area of zone | Az | sf | Selected from pull-down list |
| Design population of zone | Pz | P | (default value listed; may be overridden) |
| Design total supply to zone (primary plus local recirculated) | Vozd1 | cfm | Selected from pull-down list or leave blank if N/A |
| Induction Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Er | | |
| Local recirc. air % representative of zone system return air | Ds | % | |
| Inputs for Operating Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | | Selected from pull-down list |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | |
| Primary air fraction of supply air at conditioned analyzed | Ev | | 0.80 |
| Results | | | |
| Ventilation System Efficiency | Voz | cfm | 370 |
| Outdoor air intake required for system | Voz/As | cfm/sf | 0.32 |
| Outdoor air per unit floor area | Voz/Ps | cfm/p | 8.1 |
| Outdoor air per person served by system (including diversity) | Vpd | cfm | 14% |
| Outdoor air as a % of design primary supply air | | | |
| Detailed Calculations for the System as a Whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 2600 |
| Uncorrected OA requirement for system | Vou | cfm | 297 |
| Uncorrected OA req'd as a fraction of primary SA | Xs | | 0.11 |
| Initial Calculations for Individual Zones | | | |
| OA rate per unit area for zone | Raz | cfm/sf | |
| OA rate per person | Rpz | cfm/p | |
| Total supply air to zone (at condition being analyzed) | Voz | cfm | |
| Unused OA req'd to breathing zone | Voz | cfm | |
| Unused OA requirement for zone | Voz/Ez | | |
| Fraction of zone supply not directly recirc. from zone | Fa | | |
| Fraction of zone supply from fully mixed primary air | Fb | | |
| Fraction of zone OA not directly recirc. from zone | Fc | | |
| Unused OA fraction required in supply air to zone | Zd | | |
| Unused OA fraction required in primary air to zone | Zp | | |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Ez | | |
| System Ventilation Efficiency (App A Method) | Ev | | 0.80 |
| Ventilation System Efficiency (Table 6.3 Method) | Ev | | 0.84 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vot | cfm | 370 |
| CA intake req'd as a fraction of primary SA | Y | | 0.14 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | cfm | 354 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.14 |
| CA Temp at which Min OA provides all cooling | Deg F | | -48 |
| OAT below which OA intake flow is @ minimum | | | |

| Potentially Critical Zones | | | |
|----------------------------|--------|--------|--------|
| Zone | Supply | Supply | Supply |
| | cfm | cfm | cfm |
| Meal Mgmt. A & B | 100% | 100% | 100% |
| Multi-Purpose | 100% | 100% | 100% |
| Team Lockers | 100% | 100% | 100% |
| Office space | 100% | 100% | 100% |
| Conference room | 100% | 100% | 100% |
| ITU | 100% | 100% | 100% |

| Building: | | Kroc Center | |
|--|---|-------------|--|
| System Tag/Name: | | RTU 10 | |
| Operating Condition Description: | | Ventilation | |
| Units (select from pull-down list) | | p | |
| Inputs for System | | | |
| Floor area served by system | Name | Units | System |
| Population of area served by system (including diversity) | As | sf | 4500 |
| Design primary supply fan airflow rate | Ps | p | 101 |
| CA req'd per unit area for system (Weighted average) | Vpsd | cfm | 4.530 |
| CA req'd per unit area for system area (Weighted average) | Ras | cfm/sf | 0.09 |
| CA req'd per person for system area (Weighted average) | Rps | cfm | 6.2 |
| Inputs for Potentially Critical Zones | | | |
| Zone Name | Zone the turns purple hair for critical zones | | |
| Zone Tag | Potentially Critical Zones | | |
| Space type | VAV S1 10 VAV S1 11 VAV S1 12 VAV S1 13 VAV S1 14 | | |
| Floor Area of zone | Az | sf | Selected from pull-down list |
| Design population of zone | Pz | p | (default value listed; may be overridden) |
| Design total supply to zone (primary plus local recirculated) | Vozd | cfm | Selected from pull-down list or leave blank if N/A |
| Innusion Terminal Unit, Dual Fan Dual Duct or Transfer Fan? | Er | | |
| Local recirc. air % representative of zone system return air | | | |
| Inputs for Operating Condition Analyzed | | | |
| Percent of total design airflow rate at conditioned analyzed | Ds | % | 100% |
| Air distribution type at conditioned analyzed | Ez | | Selected from pull-down list |
| Zone air distribution effectiveness at conditioned analyzed | Ep | | |
| Primary air fraction of supply air at conditioned analyzed | | | |
| Results | | | |
| Ventilation System Efficiency | Ev | cfm | 0.89 |
| Outdoor air intake required for system | Vod | cfm/sf | 11.42 |
| Outdoor air per unit floor area | Vod/as | cfm/sf | 0.25 |
| Outdoor air per person served by system (including diversity) | Vod/ps | cfm/p | 11.3 |
| Outdoor air as a % of design primary supply air | Ypd | cfm | 25% |
| Detailed Calculations | | | |
| Initial Calculations for the System as a whole | | | |
| Primary supply air flow to system at conditioned analyzed | Vps | cfm | 4530 |
| Uncorrected OA requirement for system | Vou | cfm | 1013 |
| Uncorrected CA req'd as a fraction of primary SA | Xs | | 0.22 |
| Initial Calculations for Individual Zones | | | |
| OA rate per unit area for zone | Raz | cfm/sf | |
| OA rate per person | Rps | cfm/p | |
| Total supply air to zone (at condition being analyzed) | Voz | cfm | |
| Unused OA req'd to breathing zone | Voz/Ez | cfm | |
| Unused OA requirement for zone | Fa | cfm | |
| Fraction of zone supply not directly recirc. from zone | Ep | | |
| Fraction of zone supply from fully mixed primary air | Fp | | |
| Fraction of zone OA not directly recirc. from zone | Fg | | |
| Unused OA fraction required in supply air to zone | Zd | | |
| Unused OA fraction required in primary air to zone | Zp | | |
| System Ventilation Efficiency | | | |
| Zone Ventilation Efficiency (App A Method) | Ez | | |
| System Ventilation Efficiency (App A Method) | Ev | | 0.89 |
| Ventilation System Efficiency (Table 6.3 Method) | Ev | | 0.81 |
| Minimum outdoor air intake airflow | | | |
| Outdoor Air Intake Flow required to System | Vot | cfm | 1142 |
| CA intake req'd as a fraction of primary SA | Y | | 0.25 |
| Outdoor Air Intake Flow required to System (Table 6.3 Method) | Vot | cfm | 1245 |
| CA intake req'd as a fraction of primary SA (Table 6.3 Method) | Y | | 0.27 |
| OA Temp at which Min OA provides all cooling | Deg F | | 5 |
| OAT below which OA intake flow is @ minimum | | | |

Appendix B

| Lighting Compliance | | | | | | | | |
|---------------------|----|----|----|----|----|-------|--------------|-------------|
| Fixture | A | B | C | D | E | Total | Watt/Fixture | Total Watts |
| A1 | 11 | 5 | 2 | | | 18 | 45 | 810 |
| A1G | 7 | | | 2 | | 9 | 45 | 405 |
| A2 | 13 | | 2 | 6 | | 21 | 66 | 1386 |
| A3 | 4 | | | | | 4 | 53 | 212 |
| B1 | | 22 | | | | 22 | 250 | 5500 |
| B2 | | 26 | | | | 26 | 250 | 6500 |
| B4 | | 12 | | | | 12 | 120 | 1440 |
| B5 | | 10 | | | | 10 | 120 | 1200 |
| BF | | 1 | | | | 1 | 120 | 120 |
| BF2 | | 1 | | | | 1 | 120 | 120 |
| C1 | 8 | | | 10 | 8 | 26 | 28 | 728 |
| C2 | 60 | 6 | | | | 66 | 28 | 1848 |
| C3 | | 6 | | | | 6 | 90 | 540 |
| D1 | 2 | | 2 | 1 | 1 | 6 | 27 | 162 |
| D10 | | 3 | | | | 3 | 180 | 540 |
| D11 | | 2 | | | | 2 | 240 | 480 |
| D14 | | 4 | | | | 4 | 35 | 140 |
| D2 | 10 | 3 | | | | 13 | 70 | 910 |
| D2L | | 3 | | | | 3 | 105 | 315 |
| D2S | | 6 | | | | 6 | 35 | 210 |
| D3 | | 9 | | | | 9 | 60 | 540 |
| D4 | 7 | | | | | 7 | 27 | 189 |
| D5 | | | | 36 | | 36 | 45 | 1620 |
| D6 | | | | 15 | | 15 | 17 | 255 |
| D8 | | 1 | | | | 1 | 180 | 180 |
| D9 | 4 | | | | | 4 | 90 | 360 |
| F1 | 87 | 23 | 17 | 4 | 9 | 140 | 35 | 4900 |
| F1D | 18 | | 8 | | | 26 | 35 | 910 |
| F2 | | | | 15 | 7 | 22 | 35 | 770 |
| F3D | | | 7 | | | 7 | 35 | 245 |
| F4 | 8 | 9 | | 10 | 4 | 31 | 35 | 1085 |
| H1 | | | 20 | | | 20 | 324 | 6480 |
| H2 | | | 21 | | | 21 | 240 | 5040 |
| K1 | 2 | | 1 | | 3 | 6 | 45 | 270 |
| K1E | 8 | 6 | 6 | 5 | 3 | 28 | 45 | 1260 |
| L1 | 3 | | | | | 3 | 90 | 270 |
| L2 | | | 2 | | | 2 | 90 | 180 |
| L3 | | | 1 | | | 1 | 45 | 45 |
| M1 | 19 | 8 | 33 | 1 | 12 | 73 | 60 | 4380 |
| M1D | | 6 | | | | 6 | 60 | 360 |
| M1G | 4 | 2 | | | | 6 | 60 | 360 |
| M2 | 27 | | 19 | | | 46 | 34 | 1564 |
| M2G | 7 | | | | | 7 | 34 | 238 |
| M3 | | | 18 | 12 | | 30 | 45 | 1350 |
| N | 28 | | | | | 28 | 70 | 1960 |

| | | | | | | | | |
|-----|----|----|----|----|----|----|-----|-------|
| N2 | | | 4 | | | 4 | 79 | 316 |
| Q1 | | | | 14 | 18 | 32 | 820 | 26240 |
| Q2 | | | | 2 | | 2 | 820 | 1640 |
| Q4 | | | 2 | 19 | 23 | 44 | 60 | 2640 |
| R | | 1 | | | | 1 | 66 | 66 |
| S1 | 8 | 3 | 9 | 3 | 1 | 24 | 28 | 672 |
| S1A | | | 3 | | 2 | 5 | 45 | 225 |
| S2 | 4 | 10 | 6 | 11 | | 31 | 88 | 2728 |
| S2A | | | | | 9 | 9 | 88 | 792 |
| S3 | | | | | 2 | 2 | 27 | 54 |
| T1 | | 76 | | | | 76 | 75 | 5700 |
| T2 | | 4 | | | | 4 | 300 | 1200 |
| T3 | 13 | | | | | 13 | 150 | 1950 |
| T4 | | 4 | 15 | | | 19 | 34 | 646 |
| U1 | | | | 2 | | 2 | 28 | 56 |
| U2 | | 3 | | | | 3 | 22 | 66 |
| V6 | | 1 | | | | 1 | 85 | 85 |
| W1 | | | | 6 | 16 | 22 | 45 | 990 |
| X1 | | 1 | 6 | 6 | 6 | 19 | 5 | 95 |
| X2 | 20 | 11 | 8 | | | 39 | 5 | 195 |
| X3 | 1 | | | | | 1 | 10 | 10 |
| XW | | | 3 | | | 3 | 5 | 15 |
| Y | | 4 | | 4 | 4 | 12 | 10 | 120 |
| YW | | | 12 | | | 12 | 10 | 120 |

| | |
|--------------------------------|--------|
| Total Lighting Wattage: | 104998 |
| Building SF: | 92000 |

| | |
|-----------------------|------|
| Total W/SF: | 1.14 |
| Required W/SF: | 1.2 |
| Compliance: | Yes |