

TECHNICAL REPORT 2

*CENTRAL HIGH  
SCHOOL  
MID-ATLANTIC  
REGION*

ADAM BROWN

MECHANICAL OPTION

ADVISOR LAURA MILLER

Submitted 10/4/13

---

# Contents

- Executive Summary..... 2
- Building Overview ..... 3
  - Building Description ..... 3
  - Mechanical System Overview ..... 3
  - Occupant and Project Team..... 4
- Load Calculation Procedure ..... 5
  - Design Conditions ..... 5
  - Model Design ..... 5
  - Load Assumptions..... 5
  - Calculated vs. Design Load Analysis..... 6
- Energy Calculation and Operating Cost ..... 8
  - Energy Consumption..... 8
  - Energy Inputs ..... 9
  - Annual Operation Costs ..... 9
  - Emissions..... 10
- Summary ..... 11
- References ..... 11
- Appendix A..... 12
- Appendix B..... 14

## Executive Summary

This report will discuss the load and energy simulation analysis of Central High School. Heating, cooling, energy consumption and operating costs will be reported.

Trane TRACE 700, software recognized in industry as a leading energy modeling program, was used to calculate both loads and energy consumption of the building. Roughly 300 spaces were modeled that were then put into their respective zones serviced by 20 energy recovery units. Block calculations done by TRACE 700 yielded a total cooling load of 678 [tons] and 13147 [MBH] for heating loads which was found to vary greatly from the design engineers calculations.

Energy consumption for Central High School came out to be 878,111 [kWh] per year. An energy model was run by a previous MEP team but could not be obtained for comparison.

The emissions report from TRACE 700 shows that Central High School puts out CO<sub>2</sub> at 1,174,596 lbm/year, SO<sub>2</sub> at 10,577 gm/year, and NO<sub>x</sub> at 2,204 gm/year.

## Building Overview

### Building Description



Central High School is a newly renovated high school located in the Mid-Atlantic region. At roughly 320,000 square feet it is an impressive state of the art school with two levels the top one being the addition. The building has food and science labs, classrooms, offices, gyms and an auditorium to serve the learning needs of the occupants. It is expected to be completed by February 2015.

### Mechanical System Overview

Twenty energy recovery units are located throughout the building that delivers outdoor air to fan coil units with recirculated air serving the zones. Along with that, two air cooled chillers and boiler serve the energy recovery units and fan coil units.

## Occupant and Project Team

Owner: Confidential

Construction Manager: Jacobs    <http://jacobs.com/>

Architect: SHW Group, LLP    <http://www.shwgroup.com/>

Structural Engineer: Adtek Engineers, INC.    <http://www.adtekengineers.com/>

Mechanical and Electrical Engineers: SHW Group, LLP    <http://www.shwgroup.com/>

Civil Engineers: Bowman Consulting    <http://www.bowmanconsulting.com/>

Kitchen Consultant: Nyikos Associates    <http://nyikosassociates.com/>

Acoustical and Technology: Polysonics Corporation    <http://www.polysonics-corp.com/>

# Load Calculation Procedure

To model the load and energy costs of the building, Trane TRACE 700 was the HVAC program used for this report. In order to create an accurate model, information was taken from specifications, mechanical floor plans and schedules. Assumptions were made to complete the model and will be stated later in this report.

## Design Conditions

Central High School is a high school located in the Mid-Atlantic region. Baltimore, Maryland is the closest area to the building site found in the Weather Library in TRACE 700. Default settings for the thermostats were typical of the Baltimore, Maryland region.

## Model Design

There are twenty zones throughout the building and within each one there are different occupancies, equipment and envelope loads to take into account. Central High School has eleven varieties of rooms and therefore eleven templates were created for these general spaces. The eleven templates are: Auditorium, Bathroom, Cafeteria, Classroom, Conference Room, Gymnasium, Hallway, Laboratory, Library, Office, and Reception. Outdoor air ventilation rates from the design specifications were used in place of ASHRAE Standard 62.1 rates. To further develop the model individual occupancies were used that were found in the design specifications. Exact areas of the rooms, ceiling heights and how much glass were included for each space. Directions of the walls were also included along with the entire direction of the building which is roughly 30 degrees from North.

## Load Assumptions

Certain rooms did not fit under the templates made such as kitchens which were put under the cafeteria template. Lighting load information was not provided therefore basic ASHRAE Standard 90.1 design lighting densities were used. Standard school equipment was picked as the miscellaneous electrical loads on the building. Figure 1 shows the Construction Template used for each room template. An infiltration rate of 0.3 cfm/square foot (sf) of wall was inputted for a more accurate construction design. Schedules were selected from the TRACE 700 library and inputted into internal loads, airflows and thermostats.

Construction...		U-factor Btu/h·ft <sup>2</sup> ·°F
Slab	6" LW Concrete	0.156986
Roof	Steel Sheet, 6" Ins	0.0468386
Wall	Face Brick, 6" LW Conc blk, 3" Ins	0.0601104
Partition	0.75" Gyp Frame	0.387955

Glass type...		U-factor Btu/h·ft <sup>2</sup> ·°F	Shading coeff
Window	Double Clear 1/4"	0.6	0.82
Skylight	Single Clear 1/4"	0.95	0.95
Door	Standard Door	0.2	0

Height...		Pct wall area to underfloor plenum	Room type
Wall	10 ft		Conditioned
Fir to fir	10 ft		
Plenum	3 ft		

Buttons: Internal Load, Airflow, Thermostat, **Construction**, Room

Figure 1 – Construction Template

## Calculated vs. Design Load Analysis

An energy model was performed by a previous MEP team assigned to this project but could not be obtained, so the values shown in Table 1, under Design, were used. These values were acquired from the schedules listed in Appendix A, Figure 7. Table 1 gives the design calculations versus the model outputs. Note that there are varying degrees of differences between the design and the model. Discrepancies can be accounted for by how the systems and plants were modeled along with data inputted for construction types and infiltration rates. Heating loads were not as close as the cooling loads since there is a variance of 900 MBH compared to 173 ton difference among the two models. These of course would affect how the cooling square foot per ton and heating Btuh per square foot were calculated. The supply airflows from the model yielded almost twice the amount of cfm/sf versus the calculated design. More cooling and heating affected the amount of supply air to deal with the load in the space. Ventilation rates had little difference between the design and model. Differences in areas for spaces could be accounted for in the difference between the two rates.

	Design	Model
Cooling [tons]	505	678
Heating [MBH]	11289	13147
Cooling [sf/ton]	634	472
Heating [Btuh/sf]	35	41
Supply [cfm/sf]	0.51	1.22
Ventilation [cfm/sf]	0.48	0.41

Figure 2 – Design Calculations vs. Model Outputs



# Energy Calculation and Operating Cost

## Energy Consumption

The TRACE 700 report of energy consumption for Central High School is below in Figure 3. Electricity is the primary source of energy to the building with Natural Gas as the secondary source. Natural gas is used by the primary boiler in the mechanical room for the entire building as electricity powers the air cooled chillers. Consumption of electricity peaks in May which makes sense since much of the mechanical equipment including chillers are running. Even though in May there isn't the largest on peak demand the chillers still consume the most amount of energy at this time. Natural gas usage peaks in January and is not used in the summer months for the use of heating the zones.




Figure 3 – Monthly Energy Consumption

## Energy Inputs

No energy model could be provided by the original MEP team on the project. TRACE 700 template schedules were used as models for when equipment would be turned on/off were selected. Also occupancy times for schools were chosen using the occupancy templates. Fuel costs were taken to be baseline costs from TRACE 700 library of energy costs. All air and water flow rates along with equipment performances were taken from the equipment schedules.

## Annual Operation Costs

Figure 4 and Figure 5 are monthly breakdowns for the end uses of heating, cooling, lighting, and miscellaneous loads. July has the highest month of end use by equipment at about \$11,257. Utility cost per square area is \$0.27 per square foot.

<b>MONTHLY UTILITY COSTS</b>													
By ACADEMIC													
Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
<b>Alternative 1</b>													
<b>Electric</b>													
On-Pk Demand (\$)	4,211	4,143	4,960	5,575	7,900	10,103	10,995	10,028	8,694	6,142	5,563	4,339	82,652
Off-Pk Demand (\$)	314	314	314	272	272	272	272	272	272	272	272	314	3,435
<b>Total (\$):</b>	<b>4,525</b>	<b>4,457</b>	<b>5,274</b>	<b>5,847</b>	<b>8,172</b>	<b>10,375</b>	<b>11,267</b>	<b>10,300</b>	<b>8,966</b>	<b>6,414</b>	<b>5,835</b>	<b>4,653</b>	<b>86,086</b>
<b>Gas</b>													
On-Pk Cons. (\$)	244	230	66	0	0	0	0	0	0	3	7	111	660
Off-Pk Cons. (\$)	285	250	21	0	0	0	0	0	0	0	15	149	720
<b>Total (\$):</b>	<b>529</b>	<b>479</b>	<b>87</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>3</b>	<b>22</b>	<b>260</b>	<b>1,380</b>
<b>Monthly Total (\$):</b>	<b>5,054</b>	<b>4,936</b>	<b>5,361</b>	<b>5,847</b>	<b>8,172</b>	<b>10,375</b>	<b>11,267</b>	<b>10,300</b>	<b>8,966</b>	<b>6,417</b>	<b>5,858</b>	<b>4,913</b>	<b>87,467</b>
Building Area =	320,000 ft <sup>2</sup>												
Utility Cost Per Area =	0.27 \$/ft <sup>2</sup>												

Figure 4 – Monthly Utility Costs




Figure 5 – Monthly End Use Cost

## Emissions

Figure 6 gives the yearly environmental impact the building has on the environment. These output values were taken from the energy model done in TRACE 700. The condensing boiler is the primary pollutant of the building and attributes to most of these gases.




Figure 6 – Yearly Environmental Impact

## Summary

A load and energy simulation was performed for Central High School with the goal of finding loads, energy consumption and emissions. Inputs and assumptions for some of those inputs were included in this report. Discrepancies exist between calculations from the mechanical engineer and this TRACE 700 model.

All values were compared to calculations in the specifications and drawings done by the mechanical engineer. Therefore the assumptions made for the TRACE 700 model affected the outputs. Yet these outputs weren't too far off from the calculated values showing that the model was within a close range of accuracy.

The emissions report shows that there is room for improvement on the entire building system when it comes to polluting the environment. This will have a huge impact on how the re-designed system must perform with a goal to lower these emissions. To do so reducing energy consumption from natural gas and electricity will reduce emissions from the mechanical equipment.

## References

SHW Group LLP "Final Bid Set". Reston, Virginia.

Central High School "Master Specifications".

ASHRAE. Standard 62.1-2010, Ventilation for Acceptable Indoor Air Quality. Atlanta, GA. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

ASHRAE. Standard 90.1-2010, Energy Standards for Buildings Except Low-Rise Residential Buildings. Atlanta, GA. American Society of Heating Refrigeration and Air Conditioning Engineers, Inc.

# Appendix A

Energy recovery unit schedule.

ENERGY RECOVERY UNIT SCHEDULE																											
SYMBOL	DESIGN OUTSIDE ENT. AIR TEMP.		DESIGN EXHAUST ENT. AIR TEMP.		WHEEL LAT AT DESIGN		SUPPLY FAN		EXHAUST FAN		ER WHEEL		COOLING COIL			HEADPIPE REHEAT			PREHEAT HEATING COIL			REHEAT HEATING COIL					
	SUMMER D.B./W.B.	WINTER D.B./W.B.	SUMMER D.B./W.B.	WINTER D.B./W.B.	DESIGN CFM	E.S.P.	H P	DESIGN CFM	E.S.P.	H P	H P	H P	TOTAL MBH	SENSIBLE MBH	LAT DB/WB	EWT	LMT	ROWS	LAT DB/WB	TOTAL MBH	LAT DB	EWT	LMT	TOTAL MBH	DB	EWT	LMT
ERU-1	91F/76F	11F	76F/67F	70F	12,100	1.700	1.3	2	1,850	0.8	1.5	1/20	484.3	396.6	55F/54F	44F	54F	-	-	-	-	-	-	609.9	95F	180F	157F
ERU-2A/B			80F/67F	49F	1,700	1,700	1.3	2	1,650	0.8	1.5		65.1	45.5	55F/54F		54F	-	-	-	-	-	-	66.7	95F		155F
ERU-3			79F/66F	57F	6,990	6,990	1.3	5	6,790	0.8	5		166.6	151.0	55F/54F		54F	3	68F/59F	-	-	-	-	313.5	96F		158F
ERU-4			79F/66F	57F	1,655	1,655	1.3	2	1,580	0.8	1		40.5	36.2	55F/54F		54F	3	68F/59F	-	-	-	-	86.5	96F		158F
ERU-5			79F/67F	54F	6,000	3,500	1.3	7.5	3,400	0.8	7.5		222.9	158.2	55F/54F		54F	-	-	-	-	-	-	329.3	104F		152F
ERU-6			78F/65F	56F	1,535	1,535	1.3	2	1,515	0.8	1		40.5	36.2	55F/54F		54F	3	68F/59F	-	-	-	-	86.5	96F		158F
ERU-7			80F/67F	55F	20,393	20,130	1.3	40	20,130	0.8	25	1/2	840.7	574.4	55F/54F		54F	4	68F/59F	1,535	70F	180F	160F	339.1	70F		150F
ERU-8			80F/67F	55F	28,655	28,360	1.3	60	28,360	0.8	40	1/2	1,160.0	798.6	55F/54F		54F	4	68F/59F	2,263	70F	180F	150F	480.7	70F		150F
ERU-9			78F/65F	54F	5,570	5,570	1.3	7.5	5,345	0.8	5		196.5	145.0	55F/54F		54F	4	65F/56F	573.5	95F	160F	150F	63.4	65F		150F
ERU-10			78F/65F	54F	4,700	4,700	1.3	7.5	3,400	0.8	5		171.0	125.1	55F/54F		54F	-	-	-	-	-	-	336.5	95F		155F
ERU-11			79F/66F	54F	8,480	4,500	1.3	10	4,500	0.8	7.5		333.3	233.2	55F/54F		54F	-	-	-	-	-	-	590.6	107F		155F
ERU-12			79F/66F	53F	10,700	10,700	1.3	15	10,700	0.8	10		385.0	273.5	55F/54F		54F	-	-	-	-	-	-	590.6	107F		155F
ERU-13			79F/66F	53F	2,295	2,295	1.3	2	2,175	0.8	1		50.7	43.6	55F/54F		54F	3	68F/59F	-	-	-	-	97.3	96F		160F
ERU-14			80F/67F	53F	10,660	10,660	1.3	15	10,660	0.8	10		395.0	273.5	55F/54F		54F	-	-	-	-	-	-	590.6	107F		155F
ERU-15			79F/66F	55F	4,420	2,170	1.3	5	2,170	0.8	5		154.4	112.6	55F/54F		54F	-	-	-	-	-	-	244.1	105F		155F
ERU-16			79F/67F	54F	4,050	4,050	1.3	5	3,830	0.8	3		110.4	95.6	55F/54F		54F	3	64F/58F	-	-	-	-	178.1	96F		160F
ERU-17			79F/67F	52F	9,480	9,480	1.3	15	9,000	0.8	7.5		385.4	263.1	55F/54F		54F	-	-	-	-	-	-	576.1	106F		155F
ERU-18			79F/67F	52F	9,480	9,480	1.3	15	9,000	0.8	7.5		385.4	263.1	55F/54F		54F	-	-	-	-	-	-	576.1	106F		155F
ERU-19			79F/67F	52F	2,925	2,925	1.3	3	2,475	0.8	1.5		71.1	56.3	55F/54F		54F	3	68F/59F	-	-	-	-	131.6	95F		160F
ERU-20			79F/67F	54F	2,925	2,925	1.3	3	2,475	0.8	1.5		71.1	56.3	55F/54F		54F	3	68F/59F	-	-	-	-	131.6	95F		160F

BASIS OF DESIGN:  
SEE SCHEDULE

COOLING		WATER FLOW		REHEAT		BRANCH PIPING SIZE		UNIT ELECTRICAL DATA		MANUF.	MODEL	NOMINAL SIZE L x W x H	MAX. OPERATING WEIGHT (LBS)	GENERAL LOCATION	SYMBOL
GPM	WPD (PSI)	GPM	WPD (PSI)	PREHEAT	REHEAT	CLG	PREHEAT	MCA	MOP	VOLT/PHASE					
87.7	11.9"	-	-	54.1	13.1"	3"	-	2-1/2"	26.0	35	460V-3ø	288" x 98" x 98"	12,000	CAFETERIA - ROOFTOP UNIT	ERU-1
11.2	3.6"	-	-	7.2	1.0"	1-1/2"	-	1-1/4"	8.0	15	460V-3ø	98" x 56" x 50"	1,800	STAGE - INDOOR UNIT	ERU-2A/B
32.4	1.1"	-	-	29.5	2.2"	2"	-	2"	18.5	25	460V-3ø	199" x 97" x 91"	9,800	EAST CLERK ADDITION - INDOOR UNIT	ERU-3
8.2	0.5"	-	-	8.0	1.0"	1-1/4"	-	1-1/4"	7.2	15	460V-3ø	158" x 69" x 64"	4,500	CHILD DEV./CONF. - INDOOR UNIT	ERU-4
42.0	3.4"	-	-	24.0	3.2"	2-1/2"	-	2"	26.1	35	460V-3ø	117" x 76" x 70"	4,500	MEDIA CENTER - INDOOR UNIT	ERU-5
8.2	0.5"	-	-	8.0	1.0"	1-1/4"	-	1-1/4"	7.2	15	460V-3ø	158" x 69" x 64"	4,500	MAIN LOBBY - ROOFTOP UNIT	ERU-6
152.2	9.5"	156.4	3.1"	22.4	1.0"	4"	4"	2"	105.2	175	460V-3ø	CUSTOM UNIT	-	1ST FLOOR EXISTING CLASSROOM CORE	ERU-7
214.4	12.6"	147.1	9.5"	31.5	1.0"	4"	4"	2"	150.0	225	460V-3ø	CUSTOM UNIT	-	2ND FLOOR EXISTING CLASSROOM CORE	ERU-8
37.7	14.2"	39.2	6.0"	11.5	1.0"	2-1/2"	2-1/2"	1-1/2"	27.8	35	460V-3ø	CUSTOM UNIT	-	ADMIN./PART. OR. ADD. - INDOOR UNIT	ERU-9
31.8	10.5"	39.2	6.0"	10.5	1.0"	2"	2-1/2"	1-1/4"	27.8	35	460V-3ø	CUSTOM UNIT	-	PART. CLERK ADDITION - INDOOR UNIT	ERU-10
58.2	4.5"	-	-	37.7	3.3"	2-1/2"	-	2-1/2"	29.9	40	460V-3ø	ERCH-90H-30	6,000	AUXILIARY GYM - INDOOR UNIT	ERU-11
71.9	6.5"	-	-	46.6	9.3"	3"	-	2-1/2"	41.6	60	460V-3ø	ERCH-90H-30	6,000	NEW GYM - INDOOR UNIT	ERU-12
71.9	6.5"	-	-	46.6	9.3"	3"	-	2-1/2"	41.6	60	460V-3ø	ERCH-90H-30	6,000	NEW GYM - INDOOR UNIT	ERU-13
10.2	0.5"	-	-	9.7	1.3"	1-1/4"	-	1-1/4"	7.2	15	460V-3ø	ERCH-45H-30	4,500	GYM LOBBY/OFFICES - INDOOR UNIT	ERU-14
71.9	6.5"	-	-	46.6	9.3"	3"	-	2-1/2"	41.6	60	460V-3ø	ERCH-90H-30	6,000	TEAM/LOCKER AREA - INDOOR UNIT	ERU-15
30.1	2.2"	-	-	19.6	2.4"	2"	-	2"	17.9	25	460V-3ø	ERCH-45H-30	3,500	FITNESS AREA - INDOOR UNIT	ERU-16
20.7	1.1"	-	-	18.4	2.2"	2"	-	2"	15.1	20	460V-3ø	ERT-57H-30	4,500	EXTERIOR MUSIC AREA - INDOOR UNIT	ERU-17
68.4	6.1"	-	-	45.2	8.8"	3"	-	2-1/2"	38.6	50	460V-3ø	ERCH-90H-30	6,000	AUDITORIUM - INDOOR UNIT	ERU-18
68.4	6.1"	-	-	45.2	8.8"	3"	-	2-1/2"	38.6	50	460V-3ø	ERCH-90H-30	6,000	AUDITORIUM - INDOOR UNIT	ERU-19
14.4	0.5"	-	-	13.6	1.0"	1-1/2"	-	1-1/2"	9.8	15	460V-3ø	ERT-52S-15	4,500	INTERIOR MUSIC AREA - INDOOR UNIT	ERU-20

# Appendix B

## ERU-1 Checksum

### System Checksums By ACADEMIC

ERU - 1

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES					
Peaked at Time: Outside Air: OADB/WB/HR: 89 / 76 / 113				Mo/HR: Sum of OADB: Peaks				Mo/HR: Heating Design OADB: 13				SADB					
Space Sens. - Lat.	Plenum Sens. - Lat	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Space Peak	Percent Of Total	Space Peak	Percent Of Total	Cooling	Heating	Return	Ret/OA	Fn MTRD	Fn BHTD	Fn Frict	
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	58.8	70.0	74.3	74.5	77.0	77.0	69.0	
Envelope Loads	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sky/Lite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sky/Lite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Roof Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Glass Solar	63,314	21,395	3	158,765	52	16,900	2.07	0	0	0	0	0	0	0	0	0	0
Glass/Door Cond	8,539	0	0	-9,185	-3	-40,807	5.03	0	0	0	0	0	0	0	0	0	0
Wall Cond	48	513	0	-57	0	-173	0.24	0	0	0	0	0	0	0	0	0	0
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Infiltration	25,864	0	0	0	0	-32,771	4.04	0	0	0	0	0	0	0	0	0	0
Sub Total ==>	97,765	21,908	19	148,523	49	-73,751	11.39	-32,771	-92,236	0	0	0	0	0	0	0	0
Internal Loads				Internal Loads				Internal Loads				Internal Loads					
Lights	21,843	0	4	21,843	7	0	0.00	0	0	0	0	0	0	0	0	0	0
People	301,195	0	48	136,095	44	0	0.00	0	0	0	0	0	0	0	0	0	0
Misc	2,307	0	0	2,307	1	0	0.00	0	0	0	0	0	0	0	0	0	0
Sub Total ==>	325,345	0	52	159,245	52	0	0.00	0	0	0	0	0	0	0	0	0	0
Ceiling Load	-1,344	1,344	0	-3,294	-1	-1,937	0.00	-1,937	0	0	0	0	0	0	0	0	0
Ventilation Load	0	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Dehumid. Ov Sizing	0	0	0	0	0	-84,958	10.37	-84,958	0	0	0	0	0	0	0	0	0
Ov/Under Sizing	0	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Exhaust Heat	5,978	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Sup. Fan Heat	20,661	0	3	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Ret. Fan Heat	2,787	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Duct Heat Pkup	-33,623	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Underfir Sup Ht Pkup	0	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Supply Air Leakage	0	0	0	0	0	0	0.00	0	0	0	0	0	0	0	0	0	0
Grand Total ==>	421,765	-1,606	621,275	100.00	305,473	100.00	100.00	-810,547	-810,547	0	0	0	0	0	0	0	0

COOLING COIL SELECTION				HEATING COIL SELECTION			
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Leave DB/WB/HR	Gross Total	Glass	Total
ton	MBh	cfm	°F	°F	ft²	ft²	(%)
Main Clg	51.8	621.3	326.2	15,158	77.4	65.3	74.6
Aux Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total	51.8	621.3	326.2	15,158	77.4	65.3	74.6

ENGINEERING CKS			
% OA	cfm/ft²	ft²/ton	No. People
0.0	67.4	0.0	604
2.37	292.79	123.62	-126.65
0.0	97.07	0.0	0

HEATING COIL SELECTION			
Capacity	Coil Airflow	Enter	Exit
MBh	cfm	°F	°F
Main Htg	15,158	31.3	79.5
Aux Htg	0.0	0.0	0.0
Preheat	0.0	0.0	0.0
Humidif	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0
Total	-810.6	0.0	0.0





### System Checksums By ACADEMIC

COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Peaked at Time: Outside Air: OADB/WB/HR: 91/77/118		Mo/Hr: Sum of OADB: Peaks		Mo/Hr: Heating Design OADB: 13		Mo/Hr: Heating Design OADB: 13	
Space Sens.+ Lat. Sens.+ Plenum	Net Total	Space Sensible	Percent Of Total	Space Sens	Percent Of Total	Space Sens	Percent Of Total
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)
Envelope Loads	0	0	0	0	0	0	0
Skylite Solar	0	0	0	0	0	0	0
Skylite Cond	0	0	0	0	0	0	0
Roof Cond	0	29,214	6	0	0	-20,541	2.46
Glass Solar	16,331	16,331	3	48,697	22	0	0.00
Glass/Door Cond	2,994	0	1	-1,947	-1	-11,575	1.38
Wall Cond	314	208	0	249	0	-2,103	0.25
Partition/Door	0	0	0	0	0	0	0.00
Floor	0	0	0	0	0	0	0.00
Adjacent Floor	0	0	0	0	0	0	0.00
Infiltration	9,356	9,356	2	2,467	1	-17,979	2.15
<b>Sub Total ==&gt;</b>	<b>28,995</b>	<b>29,423</b>	<b>12</b>	<b>49,367</b>	<b>22</b>	<b>-30,700</b>	<b>6.24</b>
<b>Internal Loads</b>							
Lights	59,299	14,826	15	61,909	28	0	0.00
People	124,342	0	28	74,415	33	0	0.00
Misc	15,562	0	3	16,432	7	0	0.00
<b>Sub Total ==&gt;</b>	<b>199,203</b>	<b>14,826</b>	<b>44</b>	<b>152,756</b>	<b>68</b>	<b>0</b>	<b>0.00</b>
Ceiling Load	24,263	-24,263	0	20,321	9	-7,875	0.00
Ventilation Load	0	0	0	0	0	0	0.00
Adj Air Trans Heat	0	0	0	0	0	0	0.00
Dehumid. Ov Sizing	1,471	0	0	1,471	1	-306,498	36.67
Ov/Undr Sizing	0	0	0	0	0	340	-0.04
Exhaust Heat	-18,349	-18,349	-4	0	0	-350,065	41.88
Sup. Fan Heat	1,448	1,448	0	0	0	-127,409	15.24
Ret. Fan Heat	-24,648	-24,648	0	0	0	0	0.00
Duct Heat PkUp	0	0	0	0	0	0	0.00
Underfr. Sup Rt PkUp	0	0	0	0	0	0	0.00
Supply Air Leakage	0	0	0	0	0	0	0.00
<b>Grand Total ==&gt;</b>	<b>253,932</b>	<b>-21,565</b>	<b>100.00</b>	<b>223,914</b>	<b>100.00</b>	<b>-345,073</b>	<b>-835,829</b>
<b>COOLING COIL SELECTION</b>		<b>COOLING COIL SELECTION</b>		<b>COOLING COIL SELECTION</b>		<b>HEATING COIL SELECTION</b>	
Total Capacity	ton	Sens Cap. MBh	Coil Airflow cfm	Enter °F	Enter °F	Capacity MBh	Coil Airflow cfm
Main Cig	40.3	483.1	11,112	83.4	30.2	-835.8	11,112
Aux Cig	0.0	0.0	0	0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0	0	0.0	0.0	0.0
<b>Total</b>	<b>40.3</b>	<b>483.1</b>	<b>11,112</b>	<b>83.4</b>	<b>30.2</b>	<b>0.0</b>	<b>0.0</b>
<b>AREAS</b>		<b>AREAS</b>		<b>AREAS</b>		<b>AREAS</b>	
Gross Total	ft²	Glass	ft²	Gross Total	ft²	Glass	ft²
Floor	23,060	Floor	0	Floor	23,060	Floor	0
Part	0	Part	0	Part	0	Part	0
Int Door	0	Int Door	0	Int Door	0	Int Door	0
ExFr	0	ExFr	0	ExFr	0	ExFr	0
Roof	7,842	Roof	7,842	Roof	7,842	Roof	0
Wall	948	Wall	948	Wall	948	Wall	329
Ext Door	0	Ext Door	0	Ext Door	0	Ext Door	0
<b>ENGINEERING CKS</b>		<b>ENGINEERING CKS</b>		<b>ENGINEERING CKS</b>		<b>ENGINEERING CKS</b>	
% OA	0.48	% OA	0.48	% OA	0.48	% OA	0.48
cfm/ft²	276.04	cfm/ft²	276.04	cfm/ft²	276.04	cfm/ft²	276.04
ft³/ton	572.83	ft³/ton	572.83	ft³/ton	572.83	ft³/ton	572.83
Btu/hr-ft²	20.95	Btu/hr-ft²	20.95	Btu/hr-ft²	20.95	Btu/hr-ft²	20.95
No. People	307	No. People	307	No. People	307	No. People	307

**System Checksums**  
By ACADEMIC

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Outside Air:				Mo/Hr: 7 / 15				Mo/Hr: Heating Design						
OADB/WB/HR: 91 / 77 / 118				OADB: Peaks				OADB: 13						
Envelope Loads	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Space Sensible	Percent OF Total	Space Sens	Percent OF Total	Space Sens	Percent OF Total	Coil Peak Tot Sens	Percent OF Total	SADB	Cooling	Heating
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0.00	56.8	56.8	99.0
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0.00	74.5	74.5	69.5
Roof Cond	0	4,033	4,033	0	3	0	3	0	0	0	0.00	74.7	74.7	69.5
Glass Solar	29,077	0	29,077	66	3	0	3	0	0	0	0.00	76.3	76.3	69.5
Glass/Door Cond	3,289	0	3,289	-2	3	0	3	0	0	0	0.00	0.1	0.1	0.0
Wall Cond	0	135	135	-1,817	-2	0	-2	0	0	0	0.00	0.3	0.3	0.0
Partition/Door	0	0	0	0	0	0	0	0	0	0	0.00	0.8	0.8	0.0
Floor	0	0	0	0	0	0	0	0	0	0	0.00	0.3	0.3	0.0
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0.00	0.8	0.8	0.0
Infiltration	9,915	0	9,915	-100	8	0	8	0	0	0	0.00	0.3	0.3	0.0
Sub Total ==>	42,281	4,168	46,449	63	37	54,302	63	-22,501	-25,751	10,71	10,71	1,615	1,615	0
Internal Loads														
Lights	10,263	2,566	12,828	10	10	10,406	12	0	0	0	0.00	36	36	155
People	32,673	0	32,673	26	26	16,287	21	0	0	0	0.00	0	0	0
Misc	2,711	0	2,711	2	2	2,745	3	0	0	0	0.00	0	0	0
Sub Total ==>	45,647	2,566	48,212	38	38	31,437	37	0	0	0	0.00	0	0	0
Ceiling Load	-628	628	0	-1,096	-1	0	-1	0	0	0	0.00	0	0	0
Ventilation Load	0	0	23,288	18	0	0	0	0	0	0	0.00	0	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0
Denumid. Ov. Sizing	1,058	613	1,058	1	1	1,058	1	-113,583	-113,583	-113,583	-47,25	0	0	0
Ov/Undr Sizing	613	613	0	0	0	0	0	0	0	0	0.00	0	0	0
Exhaust Heat	5,796	5,796	0	0	0	0	0	0	0	0	0.00	0	0	0
Sup. Fan Heat	784	784	0	0	0	0	0	0	0	0	0.00	0	0	0
Ret. Fan Heat	-9,433	-9,433	0	0	0	0	0	0	0	0	0.00	0	0	0
Duct Heat PkUp	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0
Underfir Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0.00	0	0	0
<b>Grand Total ==&gt;</b>	<b>88,358</b>	<b>-875</b>	<b>126,200</b>	<b>100.00</b>	<b>100.00</b>	<b>85,701</b>	<b>100.00</b>	<b>-136,779</b>	<b>-240,377</b>	<b>100.00</b>	<b>100.00</b>			

COOLING COIL SELECTION			HEATING COIL SELECTION		
Total Capacity	Sens MBh	Coil Airflow	Capacity	Coil Airflow	Ent Lvg
ton	MBh	cfm	MBh	cfm	Ent
10.5	126.2	87.0	-240.4	4,253	48.0
Aux Clg	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0.0	0.0
<b>Total</b>	<b>10.5</b>	<b>126.2</b>	<b>-240.4</b>	<b>4,253</b>	<b>48.0</b>

AREAS		
Gross Total	Glass	ft²
4,192	0	0
Floor	0	0
Part	0	0
Int. Door	0	0
Ext. Door	0	0
Roof	1,030	0
Wall	516	361
Ext Door	0	0
<b>Total</b>	<b>516</b>	<b>361</b>

ENGINEERING CKS		
% OA	cfm/ft²	ft²/ton
38.0	1.01	1.01
Cooling	38.0	1.01
Heating	0.0	0.0
404.38	388.61	-57.34
cfm/ton	388.61	-57.34
Btu/hr-ft²	30.10	-78
No. People	78	0

## System Checksums By ACADEMIC

ERU - 5		Fan Coil																																																																																																																																																																																																
<b>COOLING COIL PEAK</b> Peaked at Time: Outside Air: Mo/Hr: 6/9 OADB/WB/HR: 73/66/84		<b>HEATING COIL PEAK</b> Mo/Hr: Heating Design OADB: 13																																																																																																																																																																																																
<b>CLG SPACE PEAK</b> Mo/Hr: Sum of OADB: Peaks																																																																																																																																																																																																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Envelope Loads</th> <th>Space Sens. + Lat.</th> <th>Plenum</th> <th>Net Total</th> <th>Percent Of Total</th> <th>Space Sensible</th> <th>Percent Of Total</th> </tr> <tr> <td>Skylite Solar</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>SkyLite Cond</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Roof Cond</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Glass Solar</td> <td>95,343</td> <td>0</td> <td>95,343</td> <td>34</td> <td>95,343</td> <td>56</td> </tr> <tr> <td>Glass/Door Cond</td> <td>-2,140</td> <td>0</td> <td>-2,140</td> <td>-1</td> <td>-2,140</td> <td>-1</td> </tr> <tr> <td>Wall Cond</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Partition/Door</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Floor</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Adjacent Floor</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Infiltration</td> <td>4,277</td> <td>0</td> <td>4,277</td> <td>2</td> <td>-998</td> <td>-1</td> </tr> <tr> <td><b>Sub Total ==&gt;</b></td> <td><b>97,481</b></td> <td><b>72</b></td> <td><b>97,652</b></td> <td><b>35</b></td> <td><b>92,205</b></td> <td><b>54</b></td> </tr> </table>	Envelope Loads	Space Sens. + Lat.	Plenum	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Skylite Solar	0	0	0	0	0	0	SkyLite Cond	0	0	0	0	0	0	Roof Cond	0	0	0	0	0	0	Glass Solar	95,343	0	95,343	34	95,343	56	Glass/Door Cond	-2,140	0	-2,140	-1	-2,140	-1	Wall Cond	0	0	0	0	0	0	Partition/Door	0	0	0	0	0	0	Floor	0	0	0	0	0	0	Adjacent Floor	0	0	0	0	0	0	Infiltration	4,277	0	4,277	2	-998	-1	<b>Sub Total ==&gt;</b>	<b>97,481</b>	<b>72</b>	<b>97,652</b>	<b>35</b>	<b>92,205</b>	<b>54</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Envelope Loads</th> <th>Space Peak</th> <th>Percent</th> <th>Coil Peak</th> <th>Percent</th> </tr> <tr> <td>Skylite Solar</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>SkyLite Cond</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Roof Cond</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Glass Solar</td> <td>-38,019</td> <td>0</td> <td>-38,019</td> <td>6.30</td> </tr> <tr> <td>Glass/Door Cond</td> <td>0</td> <td>0</td> <td>0</td> <td>0.00</td> </tr> <tr> <td>Wall Cond</td> <td>0</td> <td>0</td> <td>-411</td> <td>0.07</td> </tr> <tr> <td>Partition/Door</td> <td>0</td> <td>0</td> <td>0</td> <td>0.00</td> </tr> <tr> <td>Floor</td> <td>0</td> <td>0</td> <td>0</td> <td>0.00</td> </tr> <tr> <td>Adjacent Floor</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Infiltration</td> <td>-22,758</td> <td>0</td> <td>-22,758</td> <td>3.77</td> </tr> <tr> <td><b>Sub Total ==&gt;</b></td> <td><b>-60,777</b></td> <td></td> <td><b>-61,188</b></td> <td><b>10.15</b></td> </tr> </table>		Envelope Loads	Space Peak	Percent	Coil Peak	Percent	Skylite Solar	0	0	0	0	SkyLite Cond	0	0	0	0	Roof Cond	0	0	0	0	Glass Solar	-38,019	0	-38,019	6.30	Glass/Door Cond	0	0	0	0.00	Wall Cond	0	0	-411	0.07	Partition/Door	0	0	0	0.00	Floor	0	0	0	0.00	Adjacent Floor	0	0	0	0	Infiltration	-22,758	0	-22,758	3.77	<b>Sub Total ==&gt;</b>	<b>-60,777</b>		<b>-61,188</b>	<b>10.15</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">TEMPERATURES</th> </tr> <tr> <td>SADB</td> <td>Cooling 56.8 Heating 104.0</td> </tr> <tr> <td>Ra Plenum</td> <td>74.1 70.0</td> </tr> <tr> <td>Return</td> <td>74.3 70.0</td> </tr> <tr> <td>Rn/OA</td> <td>73.3 70.0</td> </tr> <tr> <td>Fn MfTD</td> <td>0.1 0.0</td> </tr> <tr> <td>Fn BkTD</td> <td>0.3 0.0</td> </tr> <tr> <td>Fn Frict</td> <td>0.8 0.0</td> </tr> </table>	TEMPERATURES		SADB	Cooling 56.8 Heating 104.0	Ra Plenum	74.1 70.0	Return	74.3 70.0	Rn/OA	73.3 70.0	Fn MfTD	0.1 0.0	Fn BkTD	0.3 0.0	Fn Frict	0.8 0.0	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">AIRFLOWS</th> </tr> <tr> <td>Diffuser</td> <td>Cooling 8,448 Heating 8,448</td> </tr> <tr> <td>Terminal</td> <td>8,448 8,448</td> </tr> <tr> <td>Main Fan</td> <td>8,448 8,448</td> </tr> <tr> <td>Sec. Fan</td> <td>0 0</td> </tr> <tr> <td>Nom Vent</td> <td>4,500 0</td> </tr> <tr> <td>AHU Vent</td> <td>4,500 0</td> </tr> <tr> <td>Infil</td> <td>360 360</td> </tr> <tr> <td>Min Stop/Rh</td> <td>0 0</td> </tr> <tr> <td>Return</td> <td>8,808 8,808</td> </tr> <tr> <td>Exhaust</td> <td>4,860 360</td> </tr> <tr> <td>Rm Exh</td> <td>0 0</td> </tr> <tr> <td>Auxiliary</td> <td>0 0</td> </tr> <tr> <td>Leakage Dwn</td> <td>0 0</td> </tr> <tr> <td>Leakage Ups</td> <td>0 0</td> </tr> </table>	AIRFLOWS		Diffuser	Cooling 8,448 Heating 8,448	Terminal	8,448 8,448	Main Fan	8,448 8,448	Sec. Fan	0 0	Nom Vent	4,500 0	AHU Vent	4,500 0	Infil	360 360	Min Stop/Rh	0 0	Return	8,808 8,808	Exhaust	4,860 360	Rm Exh	0 0	Auxiliary	0 0	Leakage Dwn	0 0	Leakage Ups	0 0
Envelope Loads	Space Sens. + Lat.	Plenum	Net Total	Percent Of Total	Space Sensible	Percent Of Total																																																																																																																																																																																												
Skylite Solar	0	0	0	0	0	0																																																																																																																																																																																												
SkyLite Cond	0	0	0	0	0	0																																																																																																																																																																																												
Roof Cond	0	0	0	0	0	0																																																																																																																																																																																												
Glass Solar	95,343	0	95,343	34	95,343	56																																																																																																																																																																																												
Glass/Door Cond	-2,140	0	-2,140	-1	-2,140	-1																																																																																																																																																																																												
Wall Cond	0	0	0	0	0	0																																																																																																																																																																																												
Partition/Door	0	0	0	0	0	0																																																																																																																																																																																												
Floor	0	0	0	0	0	0																																																																																																																																																																																												
Adjacent Floor	0	0	0	0	0	0																																																																																																																																																																																												
Infiltration	4,277	0	4,277	2	-998	-1																																																																																																																																																																																												
<b>Sub Total ==&gt;</b>	<b>97,481</b>	<b>72</b>	<b>97,652</b>	<b>35</b>	<b>92,205</b>	<b>54</b>																																																																																																																																																																																												
Envelope Loads	Space Peak	Percent	Coil Peak	Percent																																																																																																																																																																																														
Skylite Solar	0	0	0	0																																																																																																																																																																																														
SkyLite Cond	0	0	0	0																																																																																																																																																																																														
Roof Cond	0	0	0	0																																																																																																																																																																																														
Glass Solar	-38,019	0	-38,019	6.30																																																																																																																																																																																														
Glass/Door Cond	0	0	0	0.00																																																																																																																																																																																														
Wall Cond	0	0	-411	0.07																																																																																																																																																																																														
Partition/Door	0	0	0	0.00																																																																																																																																																																																														
Floor	0	0	0	0.00																																																																																																																																																																																														
Adjacent Floor	0	0	0	0																																																																																																																																																																																														
Infiltration	-22,758	0	-22,758	3.77																																																																																																																																																																																														
<b>Sub Total ==&gt;</b>	<b>-60,777</b>		<b>-61,188</b>	<b>10.15</b>																																																																																																																																																																																														
TEMPERATURES																																																																																																																																																																																																		
SADB	Cooling 56.8 Heating 104.0																																																																																																																																																																																																	
Ra Plenum	74.1 70.0																																																																																																																																																																																																	
Return	74.3 70.0																																																																																																																																																																																																	
Rn/OA	73.3 70.0																																																																																																																																																																																																	
Fn MfTD	0.1 0.0																																																																																																																																																																																																	
Fn BkTD	0.3 0.0																																																																																																																																																																																																	
Fn Frict	0.8 0.0																																																																																																																																																																																																	
AIRFLOWS																																																																																																																																																																																																		
Diffuser	Cooling 8,448 Heating 8,448																																																																																																																																																																																																	
Terminal	8,448 8,448																																																																																																																																																																																																	
Main Fan	8,448 8,448																																																																																																																																																																																																	
Sec. Fan	0 0																																																																																																																																																																																																	
Nom Vent	4,500 0																																																																																																																																																																																																	
AHU Vent	4,500 0																																																																																																																																																																																																	
Infil	360 360																																																																																																																																																																																																	
Min Stop/Rh	0 0																																																																																																																																																																																																	
Return	8,808 8,808																																																																																																																																																																																																	
Exhaust	4,860 360																																																																																																																																																																																																	
Rm Exh	0 0																																																																																																																																																																																																	
Auxiliary	0 0																																																																																																																																																																																																	
Leakage Dwn	0 0																																																																																																																																																																																																	
Leakage Ups	0 0																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">INTERNAL LOADS</th> </tr> <tr> <td>Lights</td> <td>17</td> </tr> <tr> <td>People</td> <td>25</td> </tr> <tr> <td>Misc</td> <td>5</td> </tr> <tr> <td><b>Sub Total ==&gt;</b></td> <td><b>47</b></td> </tr> </table>		INTERNAL LOADS		Lights	17	People	25	Misc	5	<b>Sub Total ==&gt;</b>	<b>47</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">INTERNAL LOADS</th> </tr> <tr> <td>Lights</td> <td>0</td> </tr> <tr> <td>People</td> <td>0</td> </tr> <tr> <td>Misc</td> <td>0</td> </tr> <tr> <td><b>Sub Total ==&gt;</b></td> <td><b>0</b></td> </tr> </table>		INTERNAL LOADS		Lights	0	People	0	Misc	0	<b>Sub Total ==&gt;</b>	<b>0</b>																																																																																																																																																																											
INTERNAL LOADS																																																																																																																																																																																																		
Lights	17																																																																																																																																																																																																	
People	25																																																																																																																																																																																																	
Misc	5																																																																																																																																																																																																	
<b>Sub Total ==&gt;</b>	<b>47</b>																																																																																																																																																																																																	
INTERNAL LOADS																																																																																																																																																																																																		
Lights	0																																																																																																																																																																																																	
People	0																																																																																																																																																																																																	
Misc	0																																																																																																																																																																																																	
<b>Sub Total ==&gt;</b>	<b>0</b>																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">CEILING LOADS</th> </tr> <tr> <td>Ceiling Load</td> <td>-2</td> </tr> <tr> <td>Ventilation Load</td> <td>0</td> </tr> <tr> <td>Adj Air Trans Heat</td> <td>0</td> </tr> <tr> <td>Dehumid. Ov. Sizing</td> <td>0</td> </tr> <tr> <td>Exhaust Heat</td> <td>1</td> </tr> <tr> <td>Sup. Fan Heat</td> <td>0</td> </tr> <tr> <td>Duct Heat PkUp</td> <td>0</td> </tr> <tr> <td>Underfir Sup Ht PkUp</td> <td>0</td> </tr> <tr> <td>Supply Air Leakage</td> <td>0</td> </tr> <tr> <td><b>Grand Total ==&gt;</b></td> <td><b>206,035</b></td> </tr> </table>		CEILING LOADS		Ceiling Load	-2	Ventilation Load	0	Adj Air Trans Heat	0	Dehumid. Ov. Sizing	0	Exhaust Heat	1	Sup. Fan Heat	0	Duct Heat PkUp	0	Underfir Sup Ht PkUp	0	Supply Air Leakage	0	<b>Grand Total ==&gt;</b>	<b>206,035</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">CEILING LOADS</th> </tr> <tr> <td>Ceiling Load</td> <td>-116</td> </tr> <tr> <td>Ventilation Load</td> <td>0</td> </tr> <tr> <td>Adj Air Trans Heat</td> <td>0</td> </tr> <tr> <td>Dehumid. Ov. Sizing</td> <td>0</td> </tr> <tr> <td>Exhaust Heat</td> <td>1</td> </tr> <tr> <td>Sup. Fan Heat</td> <td>0</td> </tr> <tr> <td>Duct Heat PkUp</td> <td>0</td> </tr> <tr> <td>Underfir Sup Ht PkUp</td> <td>0</td> </tr> <tr> <td>Supply Air Leakage</td> <td>0</td> </tr> <tr> <td><b>Grand Total ==&gt;</b></td> <td><b>-318,545</b></td> </tr> </table>		CEILING LOADS		Ceiling Load	-116	Ventilation Load	0	Adj Air Trans Heat	0	Dehumid. Ov. Sizing	0	Exhaust Heat	1	Sup. Fan Heat	0	Duct Heat PkUp	0	Underfir Sup Ht PkUp	0	Supply Air Leakage	0	<b>Grand Total ==&gt;</b>	<b>-318,545</b>																																																																																																																																																			
CEILING LOADS																																																																																																																																																																																																		
Ceiling Load	-2																																																																																																																																																																																																	
Ventilation Load	0																																																																																																																																																																																																	
Adj Air Trans Heat	0																																																																																																																																																																																																	
Dehumid. Ov. Sizing	0																																																																																																																																																																																																	
Exhaust Heat	1																																																																																																																																																																																																	
Sup. Fan Heat	0																																																																																																																																																																																																	
Duct Heat PkUp	0																																																																																																																																																																																																	
Underfir Sup Ht PkUp	0																																																																																																																																																																																																	
Supply Air Leakage	0																																																																																																																																																																																																	
<b>Grand Total ==&gt;</b>	<b>206,035</b>																																																																																																																																																																																																	
CEILING LOADS																																																																																																																																																																																																		
Ceiling Load	-116																																																																																																																																																																																																	
Ventilation Load	0																																																																																																																																																																																																	
Adj Air Trans Heat	0																																																																																																																																																																																																	
Dehumid. Ov. Sizing	0																																																																																																																																																																																																	
Exhaust Heat	1																																																																																																																																																																																																	
Sup. Fan Heat	0																																																																																																																																																																																																	
Duct Heat PkUp	0																																																																																																																																																																																																	
Underfir Sup Ht PkUp	0																																																																																																																																																																																																	
Supply Air Leakage	0																																																																																																																																																																																																	
<b>Grand Total ==&gt;</b>	<b>-318,545</b>																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">COOLING COIL SELECTION</th> </tr> <tr> <td>Total Capacity ton</td> <td>23.6</td> </tr> <tr> <td>Main Clig</td> <td>282.7</td> </tr> <tr> <td>Aux Clig</td> <td>0.0</td> </tr> <tr> <td>Opt Vent</td> <td>0.0</td> </tr> <tr> <td><b>Total</b></td> <td><b>282.7</b></td> </tr> </table>		COOLING COIL SELECTION		Total Capacity ton	23.6	Main Clig	282.7	Aux Clig	0.0	Opt Vent	0.0	<b>Total</b>	<b>282.7</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">HEATING COIL SELECTION</th> </tr> <tr> <td>Main Htg</td> <td>0.0</td> </tr> <tr> <td>Aux Htg</td> <td>0.0</td> </tr> <tr> <td>Preheat</td> <td>0.0</td> </tr> <tr> <td>Humidif</td> <td>0.0</td> </tr> <tr> <td>Opt Vent</td> <td>0.0</td> </tr> <tr> <td><b>Total</b></td> <td><b>-603.1</b></td> </tr> </table>		HEATING COIL SELECTION		Main Htg	0.0	Aux Htg	0.0	Preheat	0.0	Humidif	0.0	Opt Vent	0.0	<b>Total</b>	<b>-603.1</b>																																																																																																																																																																					
COOLING COIL SELECTION																																																																																																																																																																																																		
Total Capacity ton	23.6																																																																																																																																																																																																	
Main Clig	282.7																																																																																																																																																																																																	
Aux Clig	0.0																																																																																																																																																																																																	
Opt Vent	0.0																																																																																																																																																																																																	
<b>Total</b>	<b>282.7</b>																																																																																																																																																																																																	
HEATING COIL SELECTION																																																																																																																																																																																																		
Main Htg	0.0																																																																																																																																																																																																	
Aux Htg	0.0																																																																																																																																																																																																	
Preheat	0.0																																																																																																																																																																																																	
Humidif	0.0																																																																																																																																																																																																	
Opt Vent	0.0																																																																																																																																																																																																	
<b>Total</b>	<b>-603.1</b>																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">COOLING COIL SELECTION</th> </tr> <tr> <td>Total Capacity ton</td> <td>23.6</td> </tr> <tr> <td>Sens Cap. MBh</td> <td>182.9</td> </tr> <tr> <td>Coil Airflow cfm</td> <td>8,448</td> </tr> <tr> <td>Enter DB/HR</td> <td>73.7</td> </tr> <tr> <td>Enter DB/HR</td> <td>64.2</td> </tr> <tr> <td>Leave DB/HR</td> <td>54.0</td> </tr> <tr> <td>Leave DB/HR</td> <td>53.0</td> </tr> <tr> <td>g/ib</td> <td>58.8</td> </tr> </table>		COOLING COIL SELECTION		Total Capacity ton	23.6	Sens Cap. MBh	182.9	Coil Airflow cfm	8,448	Enter DB/HR	73.7	Enter DB/HR	64.2	Leave DB/HR	54.0	Leave DB/HR	53.0	g/ib	58.8	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">HEATING COIL SELECTION</th> </tr> <tr> <td>Capacity MBh</td> <td>-603.1</td> </tr> <tr> <td>Coil Airflow cfm</td> <td>8,448</td> </tr> <tr> <td>Ent</td> <td>0.0</td> </tr> <tr> <td>Lvg</td> <td>104.0</td> </tr> </table>		HEATING COIL SELECTION		Capacity MBh	-603.1	Coil Airflow cfm	8,448	Ent	0.0	Lvg	104.0																																																																																																																																																																			
COOLING COIL SELECTION																																																																																																																																																																																																		
Total Capacity ton	23.6																																																																																																																																																																																																	
Sens Cap. MBh	182.9																																																																																																																																																																																																	
Coil Airflow cfm	8,448																																																																																																																																																																																																	
Enter DB/HR	73.7																																																																																																																																																																																																	
Enter DB/HR	64.2																																																																																																																																																																																																	
Leave DB/HR	54.0																																																																																																																																																																																																	
Leave DB/HR	53.0																																																																																																																																																																																																	
g/ib	58.8																																																																																																																																																																																																	
HEATING COIL SELECTION																																																																																																																																																																																																		
Capacity MBh	-603.1																																																																																																																																																																																																	
Coil Airflow cfm	8,448																																																																																																																																																																																																	
Ent	0.0																																																																																																																																																																																																	
Lvg	104.0																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">AREAS</th> </tr> <tr> <td>Gross Total</td> <td>12,134</td> </tr> <tr> <td>Floor Part</td> <td>0</td> </tr> <tr> <td>Int Door</td> <td>0</td> </tr> <tr> <td>ExFir</td> <td>0</td> </tr> <tr> <td>Roof</td> <td>1,200</td> </tr> <tr> <td>Wall</td> <td>1,080</td> </tr> <tr> <td>Ext Door</td> <td>0</td> </tr> </table>		AREAS		Gross Total	12,134	Floor Part	0	Int Door	0	ExFir	0	Roof	1,200	Wall	1,080	Ext Door	0	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">AREAS</th> </tr> <tr> <td>Gross Total</td> <td>-603.1</td> </tr> <tr> <td>Main Htg</td> <td>0.0</td> </tr> <tr> <td>Aux Htg</td> <td>0.0</td> </tr> <tr> <td>Preheat</td> <td>0.0</td> </tr> <tr> <td>Humidif</td> <td>0.0</td> </tr> <tr> <td>Opt Vent</td> <td>0.0</td> </tr> <tr> <td><b>Total</b></td> <td><b>-603.1</b></td> </tr> </table>		AREAS		Gross Total	-603.1	Main Htg	0.0	Aux Htg	0.0	Preheat	0.0	Humidif	0.0	Opt Vent	0.0	<b>Total</b>	<b>-603.1</b>																																																																																																																																																															
AREAS																																																																																																																																																																																																		
Gross Total	12,134																																																																																																																																																																																																	
Floor Part	0																																																																																																																																																																																																	
Int Door	0																																																																																																																																																																																																	
ExFir	0																																																																																																																																																																																																	
Roof	1,200																																																																																																																																																																																																	
Wall	1,080																																																																																																																																																																																																	
Ext Door	0																																																																																																																																																																																																	
AREAS																																																																																																																																																																																																		
Gross Total	-603.1																																																																																																																																																																																																	
Main Htg	0.0																																																																																																																																																																																																	
Aux Htg	0.0																																																																																																																																																																																																	
Preheat	0.0																																																																																																																																																																																																	
Humidif	0.0																																																																																																																																																																																																	
Opt Vent	0.0																																																																																																																																																																																																	
<b>Total</b>	<b>-603.1</b>																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">ENGINEERING CKS</th> </tr> <tr> <td>% OA</td> <td>53.3</td> </tr> <tr> <td>cfm/ft</td> <td>0.70</td> </tr> <tr> <td>cfm/ton</td> <td>358.62</td> </tr> <tr> <td>ft<sup>2</sup>/ton</td> <td>515.11</td> </tr> <tr> <td>Btu/hr-ft<sup>2</sup></td> <td>23.30</td> </tr> <tr> <td>No. People</td> <td>202</td> </tr> </table>		ENGINEERING CKS		% OA	53.3	cfm/ft	0.70	cfm/ton	358.62	ft <sup>2</sup> /ton	515.11	Btu/hr-ft <sup>2</sup>	23.30	No. People	202	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">ENGINEERING CKS</th> </tr> <tr> <td>% OA</td> <td>0.0</td> </tr> <tr> <td>cfm/ft</td> <td>0.70</td> </tr> <tr> <td>cfm/ton</td> <td>358.62</td> </tr> <tr> <td>ft<sup>2</sup>/ton</td> <td>515.11</td> </tr> <tr> <td>Btu/hr-ft<sup>2</sup></td> <td>23.30</td> </tr> <tr> <td>No. People</td> <td>202</td> </tr> </table>		ENGINEERING CKS		% OA	0.0	cfm/ft	0.70	cfm/ton	358.62	ft <sup>2</sup> /ton	515.11	Btu/hr-ft <sup>2</sup>	23.30	No. People	202																																																																																																																																																																			
ENGINEERING CKS																																																																																																																																																																																																		
% OA	53.3																																																																																																																																																																																																	
cfm/ft	0.70																																																																																																																																																																																																	
cfm/ton	358.62																																																																																																																																																																																																	
ft <sup>2</sup> /ton	515.11																																																																																																																																																																																																	
Btu/hr-ft <sup>2</sup>	23.30																																																																																																																																																																																																	
No. People	202																																																																																																																																																																																																	
ENGINEERING CKS																																																																																																																																																																																																		
% OA	0.0																																																																																																																																																																																																	
cfm/ft	0.70																																																																																																																																																																																																	
cfm/ton	358.62																																																																																																																																																																																																	
ft <sup>2</sup> /ton	515.11																																																																																																																																																																																																	
Btu/hr-ft <sup>2</sup>	23.30																																																																																																																																																																																																	
No. People	202																																																																																																																																																																																																	

**System Checksums**  
By ACADEMIC

ERU - 6

COOLING COIL PEAK			CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES					
Space	Plenum	Net Percent	Space	Percent	Space Peak	Coil Peak	Cooling			Heating				
Sens. + Lat.	Sens. + Lat.	Total Of Total	Sensible	Of Total	Space Sens	Tot Sens	Mo/Hr: Heating Design	SADB	Ra Plenum	Return	Fn MrTD	Fn BltdTD	Fn Frict	
Btu/h	Btu/h	Btu/h (%)	Btu/h	Btu/h (%)	Btu/h	Btu/h	QADB: 13	56.8	78.1	78.4	0.1	0.3	0.8	
Mo/Hr: 7/15	Mo/Hr: Sum of	Mo/Hr: Heating Design	Mo/Hr: 7/15	Mo/Hr: Sum of	Mo/Hr: Heating Design	Mo/Hr: Heating Design	Mo/Hr: 7/15	99.0	68.7	68.7	0.0	0.0	0.0	
QADB/WB/HR: 91/77/118	QADB: Peaks	QADB: Peaks	QADB/WB/HR: 91/77/118	QADB: Peaks	QADB: Peaks	QADB: Peaks	QADB/WB/HR: 91/77/118	78.4	79.8	79.8	0.0	0.0	0.0	
Envelope Loads			Envelope Loads			Envelope Loads								
Skylite Solar	0	0	Skylite Solar	0	0	Skylite Solar	0	0	0	0	0	0	0	0
Roof/Cond	0	0	Roof/Cond	0	0	Roof/Cond	0	0	0	0	0	0	0	0
Glass/Solar	7,235	7,235	Glass/Solar	3,487	10	Glass/Solar	-5,030	4.67	0.00	4.67	0.00	0.00	0.00	0.00
Glass/Door/Cond	1,454	1,454	Glass/Door/Cond	0	0	Glass/Door/Cond	-1,647	1.53	0.00	1.53	0.00	0.00	0.00	0.00
Wall/Cond	412	412	Wall/Cond	100	0	Wall/Cond	-370	0.34	0.00	0.34	0.00	0.00	0.00	0.00
Partition/Door	52	82	Partition/Door	49	0	Partition/Door	-214	0.19	0.00	0.19	0.00	0.00	0.00	0.00
Floor	0	0	Floor	0	0	Floor	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Adjacent Floor	0	0	Adjacent Floor	0	0	Adjacent Floor	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Infiltration	2,549	2,549	Infiltration	301	1	Infiltration	-2,959	2.75	0.00	2.75	0.00	0.00	0.00	0.00
Sub Total ==>	4,467	11,733	Sub Total ==>	3,937	11	Sub Total ==>	-4,820	9.30	0.00	9.30	0.00	0.00	0.00	0.00
Internal Loads			Internal Loads			Internal Loads								
Lights	15,817	32	Lights	16,496	47	Lights	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
People	9,756	16	People	5,834	17	People	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Misc	3,733	6	Misc	3,857	11	Misc	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Sub Total ==>	29,306	54	Sub Total ==>	26,188	74	Sub Total ==>	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Ceiling Load	5,869	0	Ceiling Load	5,110	15	Ceiling Load	-2,549	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Ventilation Load	0	0	Ventilation Load	0	0	Ventilation Load	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Adj Air Trans Heat	0	0	Adj Air Trans Heat	0	0	Adj Air Trans Heat	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Dehumid. Ov Sizing	0	0	Dehumid. Ov Sizing	0	0	Dehumid. Ov Sizing	-48,866	45.41	0.00	45.41	0.00	0.00	0.00	0.00
Ov/Undr Sizing	0	0	Ov/Undr Sizing	0	0	Ov/Undr Sizing	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Exhaust Heat	0	0	Exhaust Heat	0	0	Exhaust Heat	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Sup. Fan Heat	-3,131	-5	Sup. Fan Heat	0	0	Sup. Fan Heat	-35,942	33.40	0.00	33.40	0.00	0.00	0.00	0.00
Ret. Fan Heat	2,383	4	Ret. Fan Heat	0	0	Ret. Fan Heat	-12,865	11.95	0.00	11.95	0.00	0.00	0.00	0.00
Duct Heat Pkup	638	1	Duct Heat Pkup	0	0	Duct Heat Pkup	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Underfir Sup Ht Pkup	-3,878	0	Underfir Sup Ht Pkup	0	0	Underfir Sup Ht Pkup	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Supply Air Leakage	0	0	Supply Air Leakage	0	0	Supply Air Leakage	0	0.00	0.00	0.00	0.00	0.00	0.00	0.00
<b>Grand Total ==&gt;</b>	<b>39,642</b>	<b>100.00</b>	<b>Grand Total ==&gt;</b>	<b>35,235</b>	<b>100.00</b>	<b>Grand Total ==&gt;</b>	<b>-56,235</b>	<b>100.00</b>	<b>-107,611</b>	<b>100.00</b>	<b>-107,611</b>	<b>100.00</b>	<b>100.00</b>	<b>100.00</b>

AIRFLOWS	
Cooling	1,748
Heating	1,748
Diffuser	1,748
Terminal	1,748
Main Fan	1,748
Sec Fan	0
Nom Vent	790
AHU Vent	790
Infil	47
Min Stop/Rh	0
Return	1,795
Exhaust	837
Rm Exh	0
Auxiliary	0
Leakage Dwn	0
Leakage Ups	0

ENGINEERING CKS	
% OA	45.2
cfm/ton	0.29
cfm/ft <sup>2</sup>	343.03
ft <sup>2</sup> /ton	1,191.06
Btu/hr-ft <sup>2</sup>	-10.08
No. People	24

COOLING COIL SELECTION			HEATING COIL SELECTION		
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Leave DB/WB/HR	Lvg
ton	MBh	cfm	°F	°F	°F
Main Clg	5.1	81.2	80.2	65.7	99.0
Aux Clg	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0.0	0.0
<b>Total</b>	<b>5.1</b>	<b>81.2</b>	<b>80.2</b>	<b>65.7</b>	<b>99.0</b>

AREAS		
Gross Total	Glass	ft <sup>2</sup> (%)
Floor	6,071	0
Part	0	0
Int Door	0	0
Exfir	0	0
Roof	1,929	0
Wall	156	47
Ext Door	0	0

**System Checksums**  
By ACADEMIC

ERU - 7

COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Peaked at Time: Mo/Hr: 7 / 15		Mo/Hr: Sum of OADB: Peaks		Mo/Hr: Heating Design OADB: 13			
Outside Air: OADB/WB/Hr: 91 / 77 / 118							
Envelope Loads	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent (%)	Space Sens Btu/h	Coil Peak Tot Btu/h	Percent (%)
Skylite Solar	0	0	0	0	0	0	0.00
Skylite Cond	0	0	0	0	0	0	0.00
Roof Cond	0	3,223	3,223	0	0	-2,214	0.16
Glass Solar	95,175	0	95,175	6	207,961	0	0.00
Glass/Door Cond	13,204	0	13,204	1	-4,799	-52,318	3.80
Wall Cond	2,914	1,746	4,660	0	-409	-18,691	1.36
Partition/Door	0	0	0	0	0	0	0.00
Floor	0	0	0	0	0	0	0.00
Adjacent Floor	0	0	0	0	0	0	0.00
Infiltration	123,174	0	123,174	8	7,306	-131,767	9.56
Sub Total ==>	234,468	4,969	239,437	16	210,059	-198,658	14.87
<b>Internal Loads</b>							
Lights	135,876	33,969	169,845	11	134,811	0	0.00
People	384,715	0	384,715	26	200,381	0	0.00
Misc	36,092	0	36,092	2	35,792	0	0.00
Sub Total ==>	556,683	33,969	590,652	40	370,984	0	0.00
Ceiling Load	6,911	-6,911	0	0	-3,032	0	0.00
Ventilation Load	0	0	603,150	40	0	0	0.00
Adj Air Trans Heat	0	0	0	0	0	0	0.00
Dehumid. Ov. Sizing	0	0	0	0	0	0	0.00
Ov/Undr Sizing	20,956	-6,617	20,956	1	20,956	112	-0.01
Exhaust Heat	0	-6,617	-6,617	0	0	-846,816	61.44
Sup. Fan Heat	0	41,138	41,138	3	0	-326,646	23.70
Ret. Fan Heat	0	3,785	3,785	0	0	0	0.00
Duct Heat PkUp	0	-66,948	-66,948	0	0	0	0.00
Underfir Sup Ht PkUp	0	0	0	0	0	0	0.00
Supply Air Leakage	0	0	0	0	0	0	0.00
Grand Total ==>	819,018	-37,753	1,492,502	100.00	608,237	-1,378,340	100.00

COOLING COIL SELECTION		HEATING COIL SELECTION	
Total Capacity ton	Sens Cap. MBh	Capacity MBh	Ent Lvg
124.4	1,492.5	-1,378.4	34.8
Main Clg	0.0	30,183	75.9
Aux Clg	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0
Total	124.4	30,183	75.9

AREAS	
Gross Total	Glass ft² (%)
51,760	0
Floor	0
Part	0
Int Door	0
ExFir	0
Roof	832
Wall	6,948
Ext Door	0
Total	1,486

ENGINEERING CKS	
Cooling	Heating
% OA	0.0
cfm/ft²	0.58
cfm/ton	242.67
ft²/ton	416.16
Btu/hr-ft²	28.84
No. People	854

TEMPERATURES	
SADB	Heating
56.8	70.0
Ra Plenum	75.4
Return	69.8
Ret/OA	75.6
Fn MfrTD	81.2
Fn BldTD	0.1
Fn FricT	0.3
Fn FricR	0.8
Fn FricD	0.0

AIRFLOWS	
Cooling	Heating
30,183	30,183
Terminal	30,183
Main Fan	30,183
Sec Fan	0
Nom Vent	0
AHU Vent	18,623
Infil	731
Min Stop/Rh	2,084
Return	0
Exhaust	21,780
Rm Exh	10,201
Auxiliary	9,153
Leakage Dwn	547
Leakage Ups	1,537

**System Checksums**  
By ACADEMIC

ERU - 8		COOLING COIL PEAK			CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES		
Peaked at Time: OutsideAir:		Mo/Hr: 7 / 15			Mo/Hr: Sum of			Mo/Hr: Heating Design			Cooling		
OADB/WBHR: 91.77 / 118		OADB: 13			OADB: Peaks			OADB: 13			Heating		
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Space Sensible	Space Percent	Envelope Loads	Space Peak	Coil Peak	SADB	Ra Plenum	Return	Fn MktD	Fn BldTD	Fn Frict
Btu/h	Btu/h	Btu/h	Btu/h	(%)	Btu/h	Btu/h	Btu/h	Btu/h	78.1	80.5	0.1	0.3	0.8
%	%	%	%	%	%	%	%	%	67.5	67.5	0.0	0.0	0.0
121,764	30,441	152,206	11	129,782	Lights	0	0	0	56.8	70.0	0	0	0
497,340	0	497,340	37	292,084	People	0	0	0	77.9	67.5	0	0	0
31,528	0	31,528	2	34,399	Misc	0	0	0	0	0	0	0	0
650,633	30,441	681,074	50	456,265	Sub Total ==>	681,074	71	456,265	78.1	80.5	0.1	0.3	0.8
47,703	-47,703	0	0	26,921	Ceiling Load	0	4	-41,481	80.5	67.5	0.0	0.0	0.0
0	0	330,102	24	0	Ventilation Load	0	0	0	0.1	0.0	0.0	0.0	0.0
0	0	0	0	0	Adj Air Trans Heat	0	0	0	0.3	0.0	0.0	0.0	0.0
10,494	-87,361	10,494	1	10,494	Dehumid. Ov Sizing	0	2	4,834	0.8	0.0	0.0	0.0	0.0
0	0	-87,361	-6	0	Exhaust Heat	0	0	-1,034,759	0.0	0.62	0.0	0.0	0.0
0	5,982	43,534	3	0	OA Preheat Diff.	0	0	-339,425	283.49	0.62	0.0	0.0	0.0
0	-70,847	5,982	0	0	RA Preheat Diff.	0	0	20.36	455.90	0.62	0.0	0.0	0.0
0	0	0	0	0	Additional Reheat	0	0	0	26.32	0.0	0.0	0.0	0.0
0	0	0	0	0	Underfir Sup Ht Pkup	0	0	0	1,241	-32.45	0.0	0.0	0.0
0	0	0	0	0	Supply Air Leakage	0	0	0	0	0	0.0	0.0	0.0
883,874	23,649	1,352,005	100.00	643,430	Grand Total ==>	1,352,005	100.00	-202,527	1,666.995	100.00	0.0	0.0	0.0

ERU - 8		COOLING COIL SELECTION			HEATING COIL SELECTION		
Total Capacity	Sens Cap.	Coil Airflow	Enter	DB/WB/HR	Leave	DB/WB/HR	
ton	MBh	cfm	°F	gr/lb	°F	gr/lb	
112.7	1,352.0	880.4	31,940	80.9	66.8	76.7	
0.0	0.0	0.0	0.0	0.0	0.0	0.0	
0.0	0.0	0.0	0.0	0.0	0.0	0.0	
112.7	1,352.0	880.4	31,940	80.9	66.8	76.7	

AREAS			
Gross Total	Class	ft²	(%)
51,365	Floor	51,365	0
0	Part	0	0
0	Int Door	0	0
0	ExFir	0	0
51,365	Roof	51,365	0
5,700	Wall	1,236	22
0	Ext Door	0	0

HEATING COIL SELECTION			
Capacity	Coil Airflow	Ent	Lvg
MBh	cfm	°F	°F
-1,667.0	31,940	28.7	75.7
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
0.0	0	0.0	0.0
-1,667.0	31,940	28.7	75.7

**System Checksums**  
By ACADEMIC

ERU - 9

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 7 / 15		Mo/Hr: Sum of		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Mo/Hr: Heating Design	
Outside Air:		OADB/WBHR: 91.77 / 118		OADB: Peaks		OADB: 13		OADB: 13		OADB: 13		OADB: 13		OADB: 13	
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent OF Total	Space Sensible	Percent OF Total	Space Peak	Percent OF Total	Space Peak	Percent OF Total	Space Peak	Percent OF Total	Space Peak	Percent OF Total	Space Peak	Percent OF Total
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)
Envelope Loads	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Skyllite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Skyllite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Roof Cond	0	30,725	3	0	0	0	0	0	0	0	0	0	0	0	0
Glass Solar	540,249	0	50	1,151,949	95	0	0	0	0	0	0	0	0	0	0
Glass/Door/Cond	71,036	0	7	-22,313	-2	-275,173	24.76	-275,173	24.76	-275,173	24.76	-275,173	24.76	-275,173	24.76
Wall/Cond	550	0	0	-310	0	-2,113	0.74	-2,113	0.74	-2,113	0.74	-2,113	0.74	-2,113	0.74
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Infiltration	109,105	0	10	4,314	0	-193,896	17.44	-193,896	17.44	-193,896	17.44	-193,896	17.44	-193,896	17.44
Sub Total ==>	720,939	32,458	70	1,133,640	93	-471,182	44.80	-471,182	44.80	-471,182	44.80	-471,182	44.80	-471,182	44.80
<b>Internal Loads</b>				<b>Internal Loads</b>				<b>Internal Loads</b>				<b>Internal Loads</b>			
Lights	38,337	9,440	4	34,007	3	0	0	0	0	0	0	0	0	0	0
People	87,240	0	8	43,211	4	0	0	0	0	0	0	0	0	0	0
Misc	10,034	0	1	8,834	1	0	0	0	0	0	0	0	0	0	0
Sub Total ==>	135,611	9,440	13	86,051	7	0	0	0	0	0	0	0	0	0	0
Ceiling Load	-6,499	6,499	0	-7,828	-1	-1,771	0.00	-1,771	0.00	-1,771	0.00	-1,771	0.00	-1,771	0.00
Ventilation Load	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Dehumid. Ov Sizing	1,017	0	0	1,017	0	-333,761	30.03	-333,761	30.03	-333,761	30.03	-333,761	30.03	-333,761	30.03
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Exhaust Heat	8,241	0	1	8,241	1	1,211	-0.11	1,211	-0.11	1,211	-0.11	1,211	-0.11	1,211	-0.11
Sup. Fan Heat	0	0	0	0	0	-203,414	18.30	-203,414	18.30	-203,414	18.30	-203,414	18.30	-203,414	18.30
Ret. Fan Heat	11,016	0	1	11,016	1	-77,614	6.98	-77,614	6.98	-77,614	6.98	-77,614	6.98	-77,614	6.98
Duct Heat Pkup	-133,500	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Underfir. Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total ==>	851,069	-65,846	100.00	1,212,880	100.00	-806,704	100.00	-806,704	100.00	-806,704	100.00	-806,704	100.00	-806,704	100.00

COOLING COIL SELECTION				HEATING COIL SELECTION			
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WBHR	Capacity	Coil Airflow	Ent	Lvg
ton	MBh	cfm	°F	MBh	cfm	°F	°F
Main Cig	90.1	1,080.9	898.9	60,187	60,187	65.4	82.1
Aux Cig	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total	90.1	1,080.9	898.9	-1,111.5	60,187	65.4	82.1

AREAS			
Gross Total	Glass	ft²	(%)
Floor	15,693	0	0
Part	0	0	0
Int Door	0	0	0
ExFir	0	0	0
Roof	7,786	0	0
Wall	10,224	7,817	76
Ext Door	0	0	0
Total	33,703	7,817	23

ENGINEERING CKS			
% OA	ctm/ft²	ft²/ton	Btu/hr-ft²
7.8	3.84	668.17	174.22
0.0	0.0	0.0	0.0
3.84	3.84	174.22	-70.83
221	221	221	221





# System Checksums

By ACADEMIC

ERU - 11

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Outside Air: OADB/WB/HR: 91 / 77 / 118				Mo/HR: Sum of OADB: Peaks				Mo/HR: Heating Design OADB: 13				SADB			
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Space Btu/h	Percent Of Total	Space Peak Btu/h	Percent Of Total	Coil Peak Tot Sens	Percent Of Total	Return	Ra Plenum	Cooling	Heating
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)		(%)		(%)	Btu/h	(%)				
Envelope Loads															
SkyLite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	56.8	95.0
SkyLite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	76.2	67.9
Roof Cond	0	23,619	10	0	0	0	0	0	0	-16,241	3.93	76.3	67.9	76.3	67.9
Glass Solar	19,402	19,402	8	26,364	26	26,364	26	0	0	0	0	79.2	67.9	79.2	67.9
Glass/Door Cond	2,537	2,537	1	2,513	1	2,513	1	-10,138	-2.45	-10,138	-2.45	0.1	0.0	0.1	0.0
Wall Cond	1,816	2,640	1	2,002	2	2,002	2	-6,784	-1.55	-9,989	-2.41	0.3	0.0	0.3	0.0
Partition/Door	0	0	0	0	0	0	0	0	0	0	0	0.8	0.0	0.8	0.0
Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Infiltration	50,355	50,355	22	15,297	14	15,297	14	-61,446	-14.85	-61,446	-14.85	0	0	0	0
Sub Total ==>	74,110	24,443	43	48,176	45	48,176	45	-78,368	-23.65	-97,813	-23.65	0	0	0	0
<b>Internal Loads</b>				<b>Internal Loads</b>				<b>Internal Loads</b>				<b>AIRFLOWS</b>			
Lights	21,577	0	9	21,577	20	21,577	20	0	0	0	0	0	0	5,360	5,360
People	49,500	0	22	38,750	31	38,750	31	0	0	0	0	0	0	5,360	5,360
Misc	4,035	0	2	2,421	2	2,421	2	0	0	0	0	0	0	5,360	5,360
Sub Total ==>	75,112	0	33	57,748	53	57,748	53	0	0	0	0	0	0	0	0
Ceiling Load	2,308	-2,308	0	0	0	0	0	-4,316	0	0	0	0	0	0	0
Ventilation Load	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Dehumid, Ov Sizing	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Ov/Undr Sizing	0	0	0	0	0	0	0	-65,935	-15.94	-65,935	-15.94	0	0	0	0
Exhaust Heat	0	-7,449	-3	0	0	0	0	-2,322	-0.56	-2,322	-0.56	0	0	0	0
Sup. Fan Heat	0	7,306	3	0	0	0	0	-188,550	-45.58	-188,550	-45.58	0	0	0	0
Ret. Fan Heat	0	1,126	0	0	0	0	0	-63,673	-15.39	-63,673	-15.39	0	0	0	0
Duct Heat PkUp	0	-11,890	0	0	0	0	0	0	0	0	0	0	0	0	0
Underfir Sup Ht PkUp	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>Grand Total ==&gt;</b>	151,530	3,922	230,086	108,019	100.00	108,019	100.00	-148,619	-100.00	-413,650	-100.00	0	0	0	0

COOLING COIL SELECTION				HEATING COIL SELECTION			
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Capacity	Coil Airflow	Ent	Lvg
ton	MBh	cfm	°F	MBh	cfm	°F	°F
Main Clg	19.2	230.1	148.8	-413.7	5,360	25.4	95.0
Aux Clg	0.0	0.0	0.0	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0.0	0	0.0	0.0
<b>Total</b>	19.2	230.1					

AREAS			
Gross Total	Glass	ft²	(%)
Floor	6,322	0	0
Part	0	0	0
Int Door	0	0	0
ExFlr	0	0	0
Roof	6,322	0	0
Wall	3,240	288	9
Ext Door	0	0	0

## System Checksums

By ACADEMIC

ERU - 12/13

		COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Peaked at Time: Outside Air:		Mo/Hr: 7 / 5 OADB/WB/HR: 73.7 / 70.1 / 104		Mo/Hr: Sum of OADB: Pkgs		Mo/Hr: Heating Design OADB: 13			
	Space Sens. + Lat. Sens. Btu/h	Plenum Sens. + Lat. Sens. Btu/h	Net Total Of Total Btu/h	Space Sensible Btu/h	Space Percent Sensible (%)	Space Peak Sens Btu/h	Coil Peak Sens Btu/h	SADB	Cooling
								Ra Plenum	Heating
<b>Envelope Loads</b>								Return	107.0
Skylite Solar	0	0	0	0	0	0	0	Ret/OA	73.2
Skylite Cond	0	0	0	0	0	0	0	Fn MfrTD	73.4
Roof Cond	0	-2,962	-2,962	0	0	0	-31,124	Fn BldTD	72.8
Glass Solar	0	0	0	0	0	0	0	Fn Frict	0.1
Glass Door/Cond	0	0	0	0	0	0	0		0.3
Wall Cond	0	0	0	0	0	0	0		0.8
Partition/Door	0	0	0	0	0	0	0		0.0
Floor	0	0	0	0	0	0	0		0.0
Adjacent Floor	0	0	0	0	0	0	0		0.0
Infiltration	0	0	0	0	0	0	0		0.0
Sub Total ==>	0	-2,962	-2,962	0	0	0	-31,124		0.0
<b>Internal Loads</b>									
Lights	40,700	0	40,700	4	11	0	0	Diffuser	18,578
People	330,000	0	330,000	34	60	0	0	Terminal	18,578
Misc	0	0	0	0	2	0	0	Main Fan	18,578
Sub Total ==>	370,700	0	370,700	38	73	0	0	Sec. Fan	0
Ceiling Load	-6,845	6,845	0	0	0	0	0	Nom Vent	0
Ventilation Load	0	0	440,643	45	0	0	0	AHU Vent	18,578
Adj Air Trans Heat	0	0	0	0	0	0	0	Infil	0
Dehumid. Ov Sizing	100,340	0	0	0	0	0	0	Min Stop/Rh	0
Ov/Undr Sizing	100,340	0	0	0	0	0	0	Return	18,578
Exhaust Heat	34,021	34,021	0	0	0	0	0	Exhaust	18,578
Sup. Fan Heat	25,321	25,321	0	0	0	0	0	Rm Exh	0
Ret. Fan Heat	3,303	3,303	0	0	0	0	0	Auxiliary	0
Duct Heat Pkup	-41,207	0	0	0	0	0	0	Leakage Dwn	0
Underfir Sup Ht Pkup	0	0	0	0	0	0	0	Leakage Ups	0
Supply Air Leakage	0	0	0	0	0	0	0		0
<b>Grand Total ==&gt;</b>	<b>464,195</b>	<b>0</b>	<b>971,365</b>	<b>100.00</b>	<b>100.00</b>	<b>100.00</b>	<b>-762,325</b>	<b>1,000</b>	<b>1,000</b>

		COOLING COIL SELECTION			HEATING COIL SELECTION		
Total Capacity ton	Sens Cap. MBh	Coil Airflow cfm	Enter DB/HR °F	Gross Total	Glass ft² (%)	Capacity/Coil Airflow cm	Ent Lvg °F
Main Clg	81.0	971.4	380.4	11,925	0	-1,936.7	18,578
Aux Clg	0.0	0.0	0.0	0	0	0.0	13.0
Opt Vent	0.0	0.0	0.0	0	0	0.0	0.0
<b>Total</b>	<b>81.0</b>	<b>971.4</b>	<b>380.4</b>	<b>11,925</b>	<b>0</b>	<b>-1,936.7</b>	<b>13.0</b>

# System Checksums

By ACADEMIC

ERU - 14

COOLING COIL PEAK			CLG SPACE PEAK			HEATING COIL PEAK			TEMPERATURES					
Peaked at Time: Outside Air: Mo/Hr: 7/15 OADB/WB/HR: 91/77/118			Mo/Hr: Sum of OADB: Peaks			Mo/Hr: Heating Design OADB: 13			Cooling Heating					
Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Space Sensible Btu/h	Percent Of Total (%)	Space Peak Btu/h	Coil Peak Btu/h	Percent Of Total (%)	SADB	Ra Plenum	Return	Ret/OA	Fn MtrTD	Fn BlidTD	Fn Frict
Envelope Loads	0	0	0	0	Envelope Loads	0	0	Diffuser	2,918	2,918	2,918	0	0	0
Skylite Solar	0	0	0	0	Skylite Solar	0	0	Terminal	2,918	2,918	2,918	0	0	0
Skylite Cond	0	0	0	0	Skylite Cond	0	0	Main Fan	885	885	885	0	0	0
Roof Cond	0	0	0	0	Roof Cond	0	0	Norm Vent	885	885	885	0	0	0
Glass Solar	5,848	5,848	14,830	25	Glass Solar	-3,717	-3,717	AHU Vent	79	79	79	0	0	0
Glass/Door Cond	962	962	628	1	Glass/Door Cond	-543	-543	Min Stop/Rh	0	0	0	0	0	0
Wall Cond	72	140	52	0	Wall Cond	0	0	Return	2,997	2,997	2,997	0	0	0
Partition/Door	0	0	0	0	Partition/Door	0	0	Exhaust	964	964	964	0	0	0
Floor	0	0	0	0	Floor	0	0	Rm Exh	0	0	0	0	0	0
Adjacent Floor	0	0	0	0	Adjacent Floor	0	0	Auxiliary	0	0	0	0	0	0
Infiltration	4,854	4,854	773	1	Infiltration	-5,007	-5,007	Leakage Dwn	0	0	0	0	0	0
Sub Total ==>	11,735	11,804	16,283	28	Infiltration	-8,995	-8,995	Leakage Ups	0	0	0	0	0	0
Internal Loads			Internal Loads			Internal Loads			ENGINEERING CKS					
Lights	29,905	7,476	28,645	49	Lights	0	0	% OA	36.7	0.0	0.0	0.26	387.74	1,466.04
People	10,870	0	4,950	8	People	0	0	cfm/ft	0.26	0.26	0.26	8.19	8.19	-12.71
Misc	6,701	0	6,376	11	Misc	0	0	ft <sup>2</sup> /ton	1,466.04	8.19	25	25	25	25
Sub Total ==>	47,477	7,476	39,971	68	Sub Total ==>	0	0	No. People	25	25	25	25	25	25
Ceiling Load	2,120	-2,120	1,880	3	Ceiling Load	-139	-139	HEATING COIL SELECTION			Capacity/Coil Airflow			
Ventilation Load	0	0	0	0	Ventilation Load	0	0	Main Htg	-140.2	2,918	52.7	96.0	96.0	96.0
Adj Air Trans Heat	0	0	0	0	Adj Air Trans Heat	0	0	Aux Htg	0.0	0.0	0.0	0.0	0.0	0.0
Dehumid. Ov Sizing	666	0	0	0	Dehumid. Ov Sizing	0	0	Preheat	0.0	0.0	0.0	0.0	0.0	0.0
Humid. Ov Sizing	0	0	0	0	Humid. Ov Sizing	0	0	Humidif	0.0	0.0	0.0	0.0	0.0	0.0
Ov/Undr Sizing	666	666	666	1	Ov/Undr Sizing	-75,006	-75,006	Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0
Exhaust Heat	-953	-953	0	0	Exhaust Heat	0	0	Total	-140.2	2,918	52.7	96.0	96.0	96.0
Sup. Fan Heat	3,977	3,977	0	0	Sup. Fan Heat	0	0	AREAS			Gross Total			
Ret. Fan Heat	533	533	0	0	Ret. Fan Heat	0	0	Floor	11,033	0	0	0	0	0
Duct Heat Pkup	-6,472	-6,472	0	0	Duct Heat Pkup	0	0	Part	0	0	0	0	0	0
Underfir Sup Ht Pkup	0	0	0	0	Underfir Sup Ht Pkup	0	0	Int Door	0	0	0	0	0	0
Supply Air Leakage	0	0	0	0	Supply Air Leakage	0	0	ExFlr	0	0	0	0	0	0
Grand Total ==>	61,988	-1,468	90,308	100.00	Grand Total ==>	-84,140	-84,140	Roof Wall	264	106	40	0	0	0
COOLING COIL SELECTION			COOLING COIL SELECTION			COOLING COIL SELECTION			COOLING COIL SELECTION			COOLING COIL SELECTION		
Total Capacity ton	7.5	90.3	67.9	2,918	77.5	64.6	70.8	Leave DB/WB/HR	54.0	64.0	62.5	62.5	62.5	62.5
Sens Cap. MBh	0.0	0.0	0.0	0.0	Sens Cap. MBh	0.0	0.0	Enter DB/HR	0.0	0.0	0.0	0.0	0.0	0.0
Coil Airflow cfm	0.0	0.0	0.0	0.0	Coil Airflow cfm	0.0	0.0	gr/lb	0.0	0.0	0.0	0.0	0.0	0.0



### System Checksums By ACADEMIC

ERU - 16		COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Peaked at Time:	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17	Mo/Hr: 7 / 17
Outside Air:	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107	OADB/WBHR: 89 / 75 / 107
<b>Envelope Loads</b>	<b>Space Sens. + Lat. Sens.</b>	<b>Plenum Sens. + Lat. Sens.</b>	<b>Net Total</b>	<b>Space Sensible</b>	<b>Space Peak</b>	<b>Space Sens</b>	<b>Coil Peak Tot</b>	<b>Diffuser</b>	<b>Terminal</b>
SkyLite Solar	0	0	0	0	0	0	0	9,562	9,562
SkyLite Cond	0	0	0	0	0	0	0	9,562	9,562
Roof Cond	0	0	0	0	0	0	0	9,562	9,562
Glass Solar	127,821	14,260	142,821	135,984	45,623	45,623	-45,623	0	0
GlassDoorCond	11,309	0	11,309	10,322	-45,623	-45,623	-45,623	0	0
WallCond	463	722	1,185	482	-1,776	-1,776	-4,393	0	0
PartitionDoor	0	0	0	0	0	0	0	0	0
Floor	0	0	0	0	0	0	0	0	0
AdjacentFloor	0	0	0	0	0	0	0	0	0
Infiltration	37,349	0	37,349	10,513	-49,157	-49,157	-49,157	0	0
<b>Sub Total ==&gt;</b>	<b>176,941</b>	<b>14,982</b>	<b>191,923</b>	<b>157,301</b>	<b>-96,566</b>	<b>-96,566</b>	<b>-109,454</b>	<b>2,370</b>	<b>2,370</b>
<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>	<b>Internal Loads</b>
Lights	10,481	363	10,844	12,512	0	0	0	778	778
People	33,000	0	33,000	22,500	0	0	0	10,339	10,339
Misc	1,434	0	1,434	1,434	0	0	0	3,148	3,148
<b>Sub Total ==&gt;</b>	<b>44,916</b>	<b>363</b>	<b>45,278</b>	<b>36,446</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Ceiling Load</b>	<b>Ventilation Load</b>	<b>Adj Air Trans Heat</b>	<b>Dehumid. Ov Sizing</b>	<b>OviUndr Sizing</b>	<b>Exhaust Heat</b>	<b>RA Preheat Diff.</b>	<b>Additional Reheat</b>	<b>% OA</b>	<b>cfm/ft</b>
-742	0	0	0	0	0	0	0	24.8	2.44
0	0	0	0	0	0	0	0	396.93	162.77
0	0	0	0	0	0	0	0	73.72	-134.94
0	0	0	0	0	0	0	0	100	100
<b>Grand Total ==&gt;</b>	<b>221,115</b>	<b>-1,785</b>	<b>289,075</b>	<b>192,689</b>	<b>-371,159</b>	<b>-371,159</b>	<b>-529,094</b>	<b>100.00</b>	<b>100.00</b>
<b>COOLING COIL SELECTION</b>	<b>COOLING COIL SELECTION</b>	<b>COOLING COIL SELECTION</b>	<b>COOLING COIL SELECTION</b>	<b>COOLING COIL SELECTION</b>	<b>COOLING COIL SELECTION</b>	<b>COOLING COIL SELECTION</b>	<b>COOLING COIL SELECTION</b>	<b>HEATING COIL SELECTION</b>	<b>HEATING COIL SELECTION</b>
Total Capacity ton	24.1	289.1	24.1	289.1	24.1	289.1	24.1	Capacity MBh	9.562
Main Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Coil Airflow cfm	56.1
Aux Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Ent Lvg	105.0
Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0	0.0	Main Htg	0.0
<b>Total</b>	<b>24.1</b>	<b>289.1</b>	<b>24.1</b>	<b>289.1</b>	<b>24.1</b>	<b>289.1</b>	<b>24.1</b>	Aux Htg	0.0
								Preheat	0.0
								Humidif	0.0
								Opt Vent	0.0
								<b>Total</b>	<b>-529.1</b>

**System Checksums**  
By ACADEMIC

ERU - 17

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES						
Peaked at Time:		Mo/Hr: 7 / 15		Mo/Hr: Sum of		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Mo/Hr: Heating Design		Mo/Hr: Heating Design				
Outside Air:		OADB/WBHR: 91 / 77 / 118		OADB: Peaks		OADB: 13		OADB: 13		OADB: 13		OADB: 13		OADB: 13				
Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent OF Total	Space Sensible	Percent OF Total	Space Sens	Percent OF Total	Space Sens	Percent OF Total	Space Sens	Percent OF Total	Cooling	Heating	Cooling	Heating			
Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	(%)	Btu/h	Btu/h	Btu/h	Btu/h			
14,324	3,581	17,905	7	9,965	6	0	0	0	0	0	0	56.8	95.0	56.8	95.0			
66,147	0	66,147	25	18,997	12	0	0	0	0	0	0	76.3	68.4	76.3	68.4			
3,208	0	3,208	1	2,149	1	0	0	0	0	0	0	77.7	68.4	77.7	68.4			
83,679	3,581	87,260	33	31,110	20	0	0	0	0	0	0	0.1	0.0	0.1	0.0			
2,157	-2,157	0	0	1,155	1	0	0	0	0	0	0	0.3	0.0	0.3	0.0			
0	0	0	0	0	0	0	0	0	0	0	0	0.8	0.0	0.8	0.0			
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
0	-4,839	-4,839	-2	0	0	0	0	0	0	0	0	0	0	0	0			
0	10,609	10,609	4	0	0	0	0	0	0	0	0	0	0	0	0			
0	1,453	1,453	1	0	0	0	0	0	0	0	0	0	0	0	0			
0	-17,265	-17,265	-6	0	0	0	0	0	0	0	0	0	0	0	0			
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
167,788	4,351	263,990	100.00	155,858	100.00	-215,816	-100.00	-287,732	-100.00	-287,732	-100.00							
Grand Total ==>				Grand Total ==>		Grand Total ==>		Grand Total ==>		Grand Total ==>								
Internal Loads				Internal Loads				Internal Loads				Internal Loads						
Lights	14,324	3,581	17,905	7	9,965	0	0	0	0	0	0	0	0	0	0			
People	66,147	0	66,147	25	18,997	0	0	0	0	0	0	0	0	0	0			
Misc	3,208	0	3,208	1	2,149	0	0	0	0	0	0	0	0	0	0			
Sub Total ==>	83,679	3,581	87,260	33	31,110	0	0	0	0	0	0	0	0	0	0			
Ceiling Load	2,157	-2,157	0	1,155	1	-3,032	-3,032	0	0	0	0	0	0	0	0			
Ventilation Load	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Adj Air Trans Heat	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Dehumid. Ov Sizing	0	0	0	0	0	-155,349	-155,349	0	0	0	0	0	0	0	0			
Ov/Undr Sizing	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Exhaust Heat	0	-4,839	-4,839	0	0	682	-0.24	682	-0.24	682	-0.24	0	0	0	0			
Sup. Fan Heat	0	10,609	10,609	4	0	-43,100	-14.98	-43,100	-14.98	-43,100	-14.98	0	0	0	0			
Ret. Fan Heat	0	1,453	1,453	1	0	-15,156	-5.27	-15,156	-5.27	-15,156	-5.27	0	0	0	0			
Duct Heat PkUp	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Underfir. Sup Ht PkUp	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Grand Total ==>	167,788	4,351	263,990	100.00	155,858	-215,816	-100.00	-287,732	-100.00	-287,732	-100.00							
COOLING COIL SELECTION				HEATING COIL SELECTION				ENGINEERING CKS				HEATING COIL SELECTION						
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WBHR	Leave DB/WBHR	Gross Total	Glass	ft²	ft²	ft²	% OA	cfm/ft²	cfm/ton	Btu/hr-ft²	No. People	Capacity	Coil Airflow	Ent	Lvg
ton	MBh	cfm	°F	°F	gribs	(%)		cfm	°F						MBh	cfm	°F	°F
22.0	264.0	167.5	78.1	64.8	6,047	0	0	6,047	0	0	0	0	0	0	-287.7	7,784	61.7	95.0
Aux Clg	0.0	0.0	0.0	0.0	Floor	0	0	0	0	0	0	0	0	0	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0.0	Part	0	0	0	0	0	0	0	0	0	0.0	0	0.0	0.0
Total	22.0	264.0			Int Door	0	0	0	0	0	0	0	0	0	0.0	0	0.0	0.0
					Roof	0	0	0	0	0	0	0	0	0	0.0	0	0.0	0.0
					Wall	1,680	907	54	54	0	0	0	0	0	0.0	0	0.0	0.0
					Ext Door	0	0	0	0	0	0	0	0	0	-287.7	0	0.0	0.0
					Total													

# System Checksums

By ACADEMIC

ERU - 18/19	COOLING COIL PEAK	CLG SPACE PEAK	HEATING COIL PEAK	FAN COIL
Peaked at Time: OutsideAir: OADB/WBHR: 91.777 / 118	Mo/Hr: 7 / 15 OADB: Peaks	Mo/Hr: Sum of OADB: Peaks	Mo/Hr: Heating Design OADB: 13	
<b>Envelope Loads</b>	<b>Space</b> Sens. + Lat. Btu/h	<b>Net Percent Total</b> Sensible (%)	<b>Space Peak</b> Space Sens Btu/h	<b>TEMPERATURES</b>
SkyLite Solar	Plenum	Total	Coil Peak	Cooling
SkyLite Cond	Sens. + Lat	Of Total	Tot Sens	Heating
Roof Cond	41,628	7	Of Total	SADB
Glass Solar	0	0	(%)	Ra Plenum
Glass/Door Cond	0	0	Envelope Loads	Return
Wall Cond	0	0	SkyLite Solar	Ret/OA
Partition/Door	0	0	SkyLite Cond	Fn MtrTD
Floor	0	0	Roof Cond	Fn BldTD
Adjacent Floor	0	0	Glass Solar	Fn Frict
Infiltration	0	0	Glass/Door Cond	Cooling
Sub Total ==>	0	7	Wall Cond	Heating
	41,628		Partition/Door	14,356
<b>Internal Loads</b>			Floor	14,356
Lights	35,316	6	Adjacent Floor	14,356
People	262,929	44	Infiltration	0
Misc	6,788	1	Sub Total ==>	0
Sub Total ==>	305,032	51	Ceiling Load	0
			Ventilation Load	0
Ceiling Load	1,867	0	Adj Air Trans Heat	0
Ventilation Load	0	0	Dehumid. Ov Sizing	0
Adj Air Trans Heat	0	0	Ov/Undr Sizing	0
Dehumid. Ov Sizing	0	0	Exhaust Heat	0
Ov/Undr Sizing	42,880	7	Sup. Fan Heat	0
Exhaust Heat	-11,270	-2	Ret. Fan Heat	0
Sup. Fan Heat	19,566	3	Duct Heat PkUp	0
Ret. Fan Heat	2,552	0	Underfr Sup Ht PkUp	0
Duct Heat PkUp	-31,842	0	Supply Air Leakage	0
Underfr Sup Ht PkUp	0	0	Grand Total ==>	349,779
Supply Air Leakage	0	0		0
Grand Total ==>	598,452	100.00	Grand Total ==>	598,452
			Internal Loads	0
			Lights	0
			People	0
			Misc	0
			Sub Total ==>	0
			Ceiling Load	-4,940
			Ventilation Load	0
			Adj Air Trans Heat	0
			Dehumid. Sizing	-600,066
			Exhaust Heat	0
			OA Preheat Diff.	0
			RA Preheat Diff.	0
			Additional Reheat	0
			Underfr Sup Ht PkUp	0
			Supply Air Leakage	0
			Grand Total ==>	-1,512,515
			% OA	100.0
			cfm/ff	1.33
			cfm/ton	287.86
			ft <sup>3</sup> /ton	215.80
			Btu/hr-ft <sup>2</sup>	55.61
			No. People	904
			Cooling	14,356
			Heating	14,356
			Return	14,356
			Exhaust	14,356
			Rm Exh	0
			Auxiliary	0
			Leakage Dwn	0
			Leakage Ups	0
			Diffuser	14,356
			Terminal	14,356
			Main Fan	14,356
			Sec Fan	0
			Nom Vent	14,356
			AHU Vent	14,356
			Infil	0
			Min Stop/Rh	0
			Return	14,356
			Exhaust	14,356
			Rm Exh	0
			Auxiliary	0
			Leakage Dwn	0
			Leakage Ups	0
			Engineering CKS	
			Cooling	100.0
			Heating	0.0
			Capacity	14,356
			Coil Airflow	13.0
			Ent	108.0
			Lvg	0.0
			Main Htg	0.0
			Aux Htg	0.0
			Preheat	0.0
			Humidif	0.0
			Opt Vent	0.0
			Total	-1,512.5
			Gross Total	10,762
			Glass	0
			Floor	0
			Part	0
			Int Door	0
			ExFlr	0
			Roof	0
			Wall	0
			Ext Door	0
			Leave DB/WBHR	54.0
			Enter DB/WBHR	62.4
			Total Capacity	49.9
			Sens Cap.	598.5
			Coil Airflow	14,356
			Enter DB/WBHR	80.0
			Enter DB/WBHR	80.7
			Main Clg	0.0
			Aux Clg	0.0
			Opt Vent	0.0
			Total	49.9

**System Checksums**  
By ACADEMIC

ERU - 20				Fan Coil			
COOLING COIL PEAK		CLG SPACE PEAK		HEATING COIL PEAK		TEMPERATURES	
Peaked at Time: Outside Air:	Mo/Hr: 7 / 15 OADB/WB/HR: 91.777 / 118	Mo/Hr: Sum of OADB: Peaks	Mo/Hr: Heating Design OADB: 13				
Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total OF Total Btu/h	Space Sensible Btu/h	Space Peak Space Sens Btu/h	Coil Peak Tot Sens Of Total Btu/h	Percent (%)	Percent (%)
Envelope Loads	0	0	0	0	0	0.00	0.00
Skylite Solar	0	0	0	0	0	0.00	0.00
Skylite Cond	0	0	0	0	0	0.00	0.00
Roof Cond	0	0	0	0	-21,249	8.39	8.39
Glass Solar	31,008	31,008	31,008	31,008	0	0.00	0.00
Glass/Door Cond	0	0	0	0	0	0.00	0.00
Wall Cond	0	0	0	0	0	0.00	0.00
Partition/Door	0	0	0	0	0	0.00	0.00
Floor	0	0	0	0	0	0.00	0.00
Adjacent Floor	0	0	0	0	0	0.00	0.00
Infiltration	0	0	0	0	0	0.00	0.00
Sub Total ==>	31,008	31,008	31,008	31,008	-21,249	8.39	8.39
Internal Loads		Internal Loads		Internal Loads		Internal Loads	
Lights	20,024	5,006	22,017	34	0	0.00	0.00
People	45,577	0	28,250	43	0	0.00	0.00
Misc	5,184	0	5,842	9	0	0.00	0.00
Sub Total ==>	70,785	5,006	56,109	86	0	0.00	0.00
Ceiling Load	13,127	-13,127	0	14	0	0.00	0.00
Ventilation Load	0	0	40,616	0	0	0.00	0.00
Adj Air Trans Heat	0	0	0	0	-9,087	0.00	0.00
Dehumid. Ov Sizing	0	0	0	0	-80,626	31.84	31.84
Ov/Undr Sizing	0	0	0	0	0	0.00	0.00
Exhaust Heat	-14,277	-14,277	-10	0	-115,777	45.71	45.71
Sup. Fan Heat	4,410	4,410	3	0	-35,608	14.06	14.06
Ret. Fan Heat	575	575	0	0	0	0.00	0.00
Duct Heat Pkup	-7,177	-7,177	0	0	0	0.00	0.00
Underfir. Sup Ht Pkup	0	0	0	0	0	0.00	0.00
Supply Air Leakage	0	0	0	0	0	0.00	0.00
Grand Total ==>	83,911	2,009	138,123	100.00	65,201	100.00	100.00
				<b>HEATING COIL SELECTION</b> Capacity: 2,009 MBh Main Htg: 3,236 cfm Aux Htg: 82.6 cfm Preheat: 0 cfm Opt Vent: 0 cfm Total: 138.1 ton			
				<b>COOLING COIL SELECTION</b> Capacity: 138.1 ton Main Clg: 11.5 ton Aux Clg: 0.0 ton Opt Vent: 0.0 ton Total: 11.5 ton			
				<b>AREAS</b> Gross Total: 8,462 sq ft Floor: 8,462 sq ft Part: 0 sq ft Int Door: 0 sq ft Ext Door: 0 sq ft			
				<b>ENGINEERING CKS</b> Cooling: 78.7 cfm/ft² Heating: 0.38 cfm/ft² % OA: 281.11 Btu/hr-ft²: 735.17 No. People: 113			
				<b>AIRFLOWS</b> Cooling: 3,236 cfm Heating: 3,236 cfm Diffuser: 3,236 cfm Terminal: 3,236 cfm Main Fan: 3,236 cfm Sec Fan: 0 cfm Nom Vent: 2,546 cfm AHU Vent: 2,546 cfm Infil: 0 cfm Min Stop/Rh Return: 3,236 cfm Exhaust: 2,546 cfm Rim Exh: 0 cfm Auxiliary: 0 cfm Leakage Dwn: 0 cfm Leakage Ups: 0 cfm			



