

The State Institute of Rehabilitation New Jersey



Elizabeth C. Krauss
Mechanical Option



The State Institute of Rehabilitation

- Building Summary

- Objectives

- Mechanical Investigation

- Electrical Investigation


- Overall Evaluation

- Conclusion



- Building Summary
 - **Location and Occupancy**
 - Facility and Façade
 - Equipment
 - Existing Building
 - Building Addition
 - Electric Consumption
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- Conclusion

Location



Outdoor Conditions



Summer (0.4%):

- 94°F DB
- 74.9°F WB

Winter (99.6%):

- 11°F DB

Occupancy



Indoor Conditions

Summer:

- 75°F DB
- 50% RH

Winter:

- 72°F DB
- 50% RH

- Building Summary
 - Location and Occupancy
 - **Facility and Façade**
 - Equipment
 - Existing Building
 - Building Addition
 - Electric Consumption
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- Conclusion

Facility



Façade



- Building Summary
 - Location and Occupancy
 - Facility and Façade
 - Equipment
 - **Existing Building**
 - Building Addition
 - Electric Consumption
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- Conclusion

Heating



Boiler-1(1973):
 Natural Gas
 Output: 5021 MBH

Boiler-2(1973):
 Natural Gas
 Output: 5021 MBH



Cooling



Chiller-1(1973):
 Electric Centrifugal
 Output: 300 tons

Chiller-2(1973):
 Air Cooled Liquid
 Output: 15.2 tons

Chiller-2(1973):
 Air Cooled Liquid
 Output: 18.4 tons

Decommissioned Chiller (1973):
 Steam Absorption
 Output: 230 tons

- Building Summary
 - Location and Occupancy
 - Facility and Façade
 - Equipment
 - Existing Building
 - **Building Addition**
 - Electric Consumption
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- Conclusion

Rooftop Units



RTU-1
 39 Tons cooling
 470 MBH heating
 11500 CFM

RTU-2
 39 Tons cooling
 470 MBH heating
 11500 CFM

RTU-3
 45 Tons cooling
 470 MBH heating
 12000 CFM

RTU-4
 45 Tons cooling
 470 MBH heating
 12000 CFM

RTU-5
 47 Tons cooling
 570 MBH heating
 14000 CFM

RTU-6
 47 Tons cooling
 570 MBH heating
 14000 CFM

RTU-7
 40 Tons cooling
 510 MBH heating
 12500 CFM


RTU-8
 39 Tons cooling
 510 MBH heating
 12500 CFM

RTU-9
 39 Tons cooling
 476 MBH heating
 12500 CFM



Capacities

- RTU-1
- RTU-2
- RTU-3
- RTU-4
- RTU-5
- RTU-6
- RTU-7
- RTU-8
- RTU-9



Total:
 381 Tons cooling | 4516 MBH | 112,500 CFM

- Building Summary
 - Location and Occupancy
 - Facility and Façade
 - Equipment
 - Existing Building
 - **Building Addition**
- Electric Consumption
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- Conclusion


Heating



Boilers-1
 Input: 2000 MBH
 Output: 1600 MBH

Boilers-2
 Input: 2000 MBH
 Output: 1600 MBH

Boilers-3
 Input: 2000 MBH
 Output: 1600 MBH



Equipment



8 Cabinet Unit Heaters

8 Unit Heaters

137 Variable Air Volume
 Units, hot water reheat

- Building Summary
 - Location and Occupancy
 - Facility and Façade
 - Equipment
 - Existing Building
 - Building Addition
- **Electric Consumption**

- Objectives

- Mechanical Investigation

- Electrical Investigation

- Overall Evaluation

- Conclusion

Building Addition, Electricity

Electricity Use					
Month	Elevator	Receptacles	System	Interior	Total
	MBtu	MBtu	MBtu	MBtu	MBtu
January	3.969	87.691	161.368	90.88	343.907
February	3.751	81.63	145.333	84.682	315.396
March	4.291	92.391	172.872	95.912	365.466
April	3.95	87.033	172.365	90.156	353.503
May	4.13	89.462	391.538	92.892	578.022
June	4.111	88.804	593.269	92.169	778.352
July	3.969	87.691	730.719	90.88	913.259
August	4.291	92.391	704.895	95.912	897.488
September	4.111	88.804	567.473	92.169	752.557
October	3.969	87.691	262.532	90.88	445.071
November	4.111	88.804	168.067	92.169	353.151
December	4.13	90.62	165.628	93.899	354.277
Annual	48.78	1063.01	4236.059	1102.598	6450.446

= 1890 MWh

Existing Building, Electricity

=(2)*1890 MWh

= 3780 MWh

Total: 5,671 MWh

- Building Summary
 - Location and Occupancy
 - Facility and Façade
 - Equipment
 - Existing Building
 - Building Addition
- Electric Consumption

- Objectives

- Mechanical Investigation

- Electrical Investigation

- Overall Evaluation

- Conclusion

Operation Cost, Building Addition

Building Electricity				
Month	Btu	kWh	\$/kWh	Cost
January	343,907,000.00	100789.2	\$0.0688	\$6,934.30
February	315,396,000.00	92433.4	\$0.0688	\$6,359.42
March	365,466,000.00	107107.5	\$0.0688	\$7,369.00
April	353,503,000.00	103601.5	\$0.0688	\$7,127.78
May	578,022,000.00	169401.5	\$0.0688	\$11,654.82
June	778,352,000.00	228112.5	\$0.0737	\$16,811.89
July	913,259,000.00	267649.8	\$0.0737	\$19,725.79
August	897,488,000.00	263027.8	\$0.0737	\$19,385.15
September	752,557,000.00	220552.7	\$0.0737	\$16,254.73
October	445,071,000.00	130437.4	\$0.0688	\$8,974.10
November	353,151,000.00	103498.3	\$0.0688	\$7,120.69
December	354,277,000.00	103828.3	\$0.0688	\$7,143.39
Annual	6,450,449,000.00	1890440.0	-	\$134,861.05

$$(134,861) + (120,226) = \$255,087$$

System Natural Gas				
Month	Btu	Therms	\$/Therm	Cost
January	2,159,000,000.00	21595.2	\$0.5780	\$12,482.00
February	1,776,000,000.00	17764.2	\$0.5740	\$10,196.67
March	1,712,000,000.00	17124.1	\$0.5860	\$10,034.72
April	1,522,000,000.00	15223.6	\$0.6280	\$9,560.44
May	1,599,000,000.00	15993.8	\$0.6470	\$10,348.00
June	1,552,000,000.00	15523.7	\$0.6470	\$10,043.84
July	1,560,000,000.00	15603.7	\$0.5980	\$9,331.03
August	1,616,000,000.00	16163.9	\$0.5590	\$9,035.60
September	1,584,000,000.00	15843.8	\$0.5710	\$9,046.80
October	1,603,000,000.00	16033.8	\$0.5630	\$9,027.04
November	1,696,000,000.00	16964.0	\$0.5570	\$9,448.98
December	1,971,000,000.00	19714.7	\$0.5920	\$11,671.11
Annual	20,350,000,000.00	203548.6	-	\$120,226.22

Operation Cost, Existing Building

Building Electricity				
Month	Btu	kWh	\$/kWh	Cost
January	687,814,000.00	201578.4	\$0.0688	\$13,868.59
February	630,792,000.00	184866.9	\$0.0688	\$12,718.84
March	730,932,000.00	214215.0	\$0.0688	\$14,737.99
April	707,006,000.00	207203.0	\$0.0688	\$14,255.57
May	1,156,044,000.00	338803.1	\$0.0688	\$23,309.65
June	1,556,704,000.00	456224.9	\$0.0737	\$33,623.78
July	1,826,518,000.00	535299.6	\$0.0737	\$39,451.58
August	1,794,976,000.00	526055.5	\$0.0737	\$38,770.29
September	1,505,114,000.00	441105.4	\$0.0737	\$32,509.47
October	890,142,000.00	260874.9	\$0.0688	\$17,948.19
November	706,302,000.00	206996.7	\$0.0688	\$14,241.37
December	708,554,000.00	207656.7	\$0.0688	\$14,286.78
Annual	12,900,898,000.00	3780880.0	-	\$269,722.10

$$(269,772) + (240,452) = \$510,174$$

System Natural Gas				
Month	Btu	Therms	\$/Therm	Cost
January	4,318,000,000.00	43190.3	\$0.5780	\$24,964.00
February	3,552,000,000.00	35528.5	\$0.5740	\$20,393.35
March	3,424,000,000.00	34248.2	\$0.5860	\$20,069.43
April	3,044,000,000.00	30447.3	\$0.6280	\$19,120.88
May	3,198,000,000.00	31987.6	\$0.6470	\$20,696.00
June	3,104,000,000.00	31047.4	\$0.6470	\$20,087.68
July	3,120,000,000.00	31207.4	\$0.5980	\$18,662.05
August	3,232,000,000.00	32327.7	\$0.5590	\$18,071.19
September	3,168,000,000.00	31687.6	\$0.5710	\$18,093.60
October	3,206,000,000.00	32067.7	\$0.5630	\$18,054.09
November	3,392,000,000.00	33928.1	\$0.5570	\$18,897.95
December	3,942,000,000.00	39429.4	\$0.5920	\$23,342.21
Annual	40,700,000,000.00	407097.2	-	\$240,452.44

- Building Summary

- Objectives

- Mechanical Investigation

- Electrical Investigation

- Overall Evaluation

- Conclusion

Objectives

Upgrade



Increase




Decrease



Plan

Combined Heat, Cooling, and Power



Source: United States Environmental Protection Agency (EPA)

- Building Summary

- Objectives

- Mechanical Investigation

- Equipment

- **Boilers**

- Combustion Turbine

- Chiller

- Air Distribution

- Operations and Cost

- Emissions

- Electrical Investigation

- Overall Evaluation

- Conclusion

Heating

Peak Demand Loads


Existing Building
2 * (5021 MBH)
= 10042 MBH

Building Addition
4080 MBH

Total:

10042 MBH
+ 4080 MBH
14,122 MBH Demand

14,122 MBH ÷ (3 boilers) = 4703.3 MBH/boiler



Boilers

(3) 6400 MBH Output

(3) 8000 MBH Input

6,598 lbs./hr. steam ea.



- Building Summary

- Objectives

- Mechanical Investigation

- Equipment

- Boilers

- **Combustion Turbine**

- Chiller

- Air Distribution

- Operations and Cost


- Emissions

- Electrical Investigation


- Overall Evaluation

- Conclusion

Waste Heat



Combustion Turbine



Combustion Turbine Operation

Inputs	
Exhaust Flow (lb./hr)	51890
Exhaust Temperature (°F)	940
c_p (BTU/lb.-°F)	0.26
$T_{ex, boiler}$ (°F)	440
Electric Generation (MW)	1.2
Result	
$Qu = m_{ex} \times c_{p_{ex}} \times (T_{ex, engine} - T_{ex, boiler})$	= 6745700 = 6745.7 MBTU

- Building Summary

- Objectives

- Mechanical Investigation

- Equipment

- Boilers

- Combustion Turbine

- **Chiller**

- Air Distribution

- Operations and Cost

- Emissions

- Electrical Investigation

- Overall Evaluation

- Conclusion

Cooling Loads

Peak Demand Loads

Existing Building

300 tons

+ 18.4 tons

+ 15.2 tons

= 333.6 tons

Building Addition


448 tons

Total:

333.6 tons

+448.0 tons

781.6 ton Demand



Double Effect Absorption Chiller

802 ton capacity
6873 lbs. steam/hr.
consumption



- Building Summary

- Objectives

- Mechanical Investigation

- Equipment

- Boilers

- Combustion Turbine

- Chiller

- **Air Distribution**

- Operations and Cost

- Emissions

- Electrical Investigation

- Overall Evaluation

- Conclusion

Air Distribution, Addition



Cooling:
DX to Chilled Water

Heating:
Gas Burner to Steam

Air Distribution, Existing




Cooling:
Chilled Water

Heating:
Steam

- Building Summary
- Objectives
- Mechanical Investigation
 - Equipment
 - Boilers
 - Combustion Turbine
 - Chiller
 - Air Distribution
- **Operations and Cost**
- Emissions
- Electrical Investigation
- Overall Evaluation
- Conclusion

Operation, Winter



Operation, Summer



- Building Summary

- Objectives

- Mechanical Investigation

- Equipment

- Boilers

- Combustion Turbine

- Chiller

- Air Distribution

- Operations and Cost

- Emissions

- Electrical Investigation

- Overall Evaluation

- Conclusion

Building Addition, Demand

Month	Heating Load	Heating Load (BTU)	Percentage of Maximum Demand
January	1786	1786000000	100.00%
February	1464	1464000000	81.97%
March	1398	1398000000	78.28%
April	1231	1231000000	68.92%
May	1297	1297000000	72.62%
June	1259	1259000000	70.49%
July	1262	1262000000	70.66%
August	1312	1312000000	73.46%
September	1288	1288000000	72.12%
October	1301	1301000000	72.84%
November	1384	1384000000	77.49%
December	1623	1623000000	90.87%
Maximum	1786	1786000000	100.00%

Month	Cooling	Cooling Load (BTU)	Percentage of Maximum Demand
January	57	57000000	2.30%
February	56	56000000	2.26%
March	103	103000000	4.15%
April	136	136000000	5.48%
May	964	964000000	38.84%
June	1931	1931000000	77.80%
July	2482	2482000000	100.00%
August	2408	2408000000	97.02%
September	1817	1817000000	73.21%
October	455	455000000	18.33%
November	141	141000000	5.68%
December	100	100000000	4.03%
Maximum	2482	2482000000	100.00%

Existing Building, Demand

Month	Percentage of Maximum Demand	Heating Load (BTU)
January	100.00%	7471248000.00
February	81.97%	6124248080.63
March	78.28%	5848154929.45
April	68.92%	5149555592.39
May	72.62%	5425648743.56
June	70.49%	5266686020.16
July	70.66%	5279235708.85
August	73.46%	5488397187.01
September	72.12%	5387999677.49
October	72.84%	5442381661.81
November	77.49%	5789589715.57
December	90.87%	6789381581.19
Maximum	100.00%	7471248000.00

Maximum Heating Load: 7,471,248,000 BTU, Jan.

Maximum Cooling Load: 2,978,380,800 BTU, July

Month	Percentage of Maximum Demand	Cooling Load (BTU)
January	2.30%	68399559.07
February	2.26%	67199566.80
March	4.15%	123599203.22
April	5.48%	163198947.95
May	38.84%	1156792542.79
June	77.80%	2317185062.37
July	100.00%	2978380800.00
August	97.02%	2889581372.44
September	73.21%	2180385944.24
October	18.33%	545996480.26
November	5.68%	169198909.27
December	4.03%	119999226.43
Maximum	100.00%	2482000000.00

- Building Summary

- Objectives

- Mechanical Investigation

- Equipment

- Boilers

- Combustion Turbine

- Chiller

- Air Distribution

- Operations and Cost

- Emissions

- Electrical Investigation

- Overall Evaluation

- Conclusion

Annual Operating Cost

Heating Plant								
Month	Heating Load	Modeled (BTU)	Existing (BTU)	Sum (BTU)	Sum, load (Therms)	Input (Therms)	\$/Therm	Cost
January	1786	1786000000	7471248000.00	9257248000.00	92594.58	115743.23	\$0.5780	\$66,899.59
February	1464	1464000000	6124248080.63	7588248080.63	75900.60	94875.75	\$0.5740	\$54,458.68
March	1398	1398000000	5848154929.45	7246154929.45	72478.85	90598.56	\$0.5860	\$53,090.76
April	1231	1231000000	5149555592.39	6380555592.39	63820.79	79775.99	\$0.6280	\$50,099.32
May	1297	1297000000	5425648743.56	6722648743.56	67242.54	84053.17	\$0.6470	\$54,382.40
June	1259	1259000000	5266686020.16	6525686020.16	65272.44	81590.55	\$0.6470	\$52,789.09
July	1262	1262000000	5279235708.85	6541235708.85	65427.98	81784.97	\$0.5980	\$48,907.41
August	1312	1312000000	5488397187.01	6800397187.01	68020.21	85025.26	\$0.5590	\$47,529.12
September	1288	1288000000	5387999677.49	6675999677.49	66775.94	83469.92	\$0.5710	\$47,661.32
October	1301	1301000000	5442381661.81	6743381661.81	67449.92	84312.40	\$0.5630	\$47,467.88
November	1384	1384000000	5789589715.57	7173589715.57	71753.03	89691.28	\$0.5570	\$49,958.04
December	1623	1623000000	6789381581.19	8412381581.19	84143.90	105179.88	\$0.5920	\$62,266.49
Total	1786	16605000000	69462526898	86067526898	860880.77	1076100.963	-	\$635,510.1037

Annual Operating Cost, Cooling

Cooling				
Month	Modeled (BTU)	Sum (BTU)	Sum(Therms)	% Heating System
January	57000000	125399559	1254.30	0.00001%
February	56000000	123199567	1232.29	0.00001%
March	103000000	226599203	2266.53	0.00002%
April	136000000	299198948	2992.70	0.00003%
May	964000000	2120792543	21212.99	0.00023%
June	1931000000	4248185062	42491.99	0.00046%
July	2482000000	5460380800	54616.85	0.00059%
August	2408000000	5297581372	52988.46	0.00057%
September	1817000000	3997385944	39983.40	0.00043%
October	455000000	1000996480	10012.35	0.00011%
November	141000000	310198909	3102.73	0.00003%
December	100000000	219999226	2200.52	0.00002%

- Building Summary
- Objectives
- Mechanical Investigation
 - Equipment
 - Boilers
 - Combustion Turbine
 - Chiller
 - Air Distribution
 - Operations and Cost
 - Emissions
- Electrical Investigation
- Overall Evaluation
- Conclusion

Emissions, Before

Electricity

At Power Plant				
Combustion Byproducts by Fuel Source for Specified Electric Consumption (MWh): 5671				
Fuel Type	Distribution by Fuel Source, MWh	lbs CO ₂	lbs SO ₂	lbs NO ₂
Natural Gas	2325.04	2,638,920.48	232.50	3,952.57
Coal	146.84	330,253.59	1,908.98	881.07
Nuclear	3059.26	-	-	-
Renewables	139.85	-	-	-

On Site				
Combustion Byproducts by Fuel Source for Specified Electric Consumption (MWh): 5671				
Fuel Type	Distribution by Fuel Source, MWh	lbs CO ₂	lbs SO ₂	lbs NO ₂
Natural Gas	2325.04	7,916,761.45	697.51	11,857.70
Coal	146.84	990,760.76	5,726.94	2,643.20
Nuclear	3059.26	-	-	-
Renewables	5671.00	-	-	-
Total		8907522.213	6424.453	14500.90783

Natural Gas

Emissions (lbs/MWh)			
Combustion Byproduct	Emissions (lbs/MWh)	MWh	Emissions, lbs
Carbon Dioxide	1135	17889	20,304,015
Sulfur Dioxide	0.1	17889	1,789
Nitrous Oxides	1.7	17889	30,411

Total

29,211,537 lbs. CO₂ | 8,213 lbs. SO₂ | 44,912 lbs. NO

Emissions, After

Electricity

0

Natural Gas

Emissions (lbs/MWh)			
Combustion Byproduct	Emissions (lbs/MWh)	MWh	Emissions, lbs
Carbon Dioxide	1135	41120	46,671,200
Sulfur Dioxide	0.1	41120	4,112
Nitrous Oxides	1.7	41120	69,904

Total

46,671,200 lbs. CO₂ | 4,112 lbs. SO₂ | 69,904 lbs. NO

37% increase CO₂ | 50% decrease lbs. SO₂ | 35% increase NO

- Building Summary

- Objectives

- Mechanical Investigation

- Electrical Investigation

 - **First Cost & Offset**

 - Cost of Operation & Grid Resale

- Overall Evaluation

- Conclusion

First Cost, System

Electricity

			Capital Cost					
Equipment			\$/sf	\$/KW	\$/kWh	\$/ton	\$/MMBH	Total Cost
Name	Capacity	Unit						
Boiler 1	6400	MBH	-	-	-	-	\$5,100.00	\$32,640.00
Boiler 2	6400	MBH	-	-	-	-	\$5,100.00	\$32,640.00
Boiler 3	6400	MBH	-	-	-	-	\$5,100.00	\$32,640.00
SAM-1	802	Tons	-	-	-	\$430.00	-	\$344,860.00
CT-1	1.2	MW	-	\$1,200.00	-	-	-	\$1,440,000.00
							Total	\$1,882,780.00

Incentives

Incentive		
Incentive Quantities	1 MW	>1 MW
Electricity Produced, MW	1.2 MW	
Electricity Produced, W	1000000	200000
Incentive Price (\$/W)	0.55	0.35
Financial Incentive, \$	\$550,000.00	\$70,000.00
Total Incentive, \$	\$620,000.00	

\$1,882,780.00 - \$620,000.00 = \$1,262,780

32.9% savings

- Building Summary
- Objectives
- Mechanical Investigation
- Electrical Investigation
 - First Cost & Offset
 - **Cost of Operation & Grid Resale**

- Overall Evaluation
- Conclusion

Costs of Operation

Before Retrofit

$(255,087, \text{Addition}) + (510,174, \text{Existing}) = \$765,261$

After Retrofit

$(458,418, \text{boilers}) + (371,945, \text{CT}) = \$830,364$

Grid Resale

Electricity Consumption vs. Production			
	Produced (MWh)	Used (MWh)	Residual (MWh)
Addition	10512	1890	4841.2
Existing		3780.8	

$= \$340,981 \text{ earned}$

$\$830,364 - \$340,981 = \$489,383$

36% decrease in operational costs

- Building Summary

- Objectives

- Mechanical Investigation

- Electrical Investigation

- Overall Evaluation

- Conclusion

Equipment

Installed Equipment

- (1) Gas-fired generator Combustion Turbine (1.2 MW)
- (1) 6400 MBh waste-heat fueled, forced draft steam boiler
- (2) 6400 natural-gas fired, forced draft steam boilers
- (1) 802 ton steam absorption chiller

Altered Equipment

Rooftop Air Handling Units

- DX to Chilled Water
- Gas Burner to Steam

Performance

37% increase CO₂ | 50% decrease lbs. SO₂ | 35% increase NO

32.9% first-cost savings

36% decrease in operational costs

- Building Summary
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- **Conclusion**

Acknowledgements

Thank you to:


Robert Gould P.E.
Dr. Laura Miller

Also to:

Family
Friends
Fellow AE students



Questions



- Building Summary

- Objectives

- Mechanical Investigation

- Electrical Investigation

- Overall Evaluation

- Conclusion

- **Mechanical Space**

- Domestic Water Reheat

- Electricity Production, Plant vs. Site

Mechanical Space, Before

Mechanical Room											
Equipment	Machine		Access Requirements								Area Total
	Width	Length	Front		Back		Side		Side		
			Width	Length	Width	Length	Width	Length	Width	Length	
Water Softener	5	3	-	-	-	-	-	-	-	-	15
Hot Water Boiler, 1	3	9.167	3	3	3	3	3	9.167	3	9.167	100.503
Hot Water Boiler, 2	3	9.167	3	3	3	3	3	9.167	3	9.167	100.503
Hot Water Boiler, 3	3	9.167	3	3	3	3	3	9.167	3	9.167	100.503
Hot Water Pump,1	2	4.5	3	3	3	3	3	4.5	3	4.5	54
Hot Water Pump,2	2	4.5	3	3	3	3	3	4.5	3	4.5	54
Hot Water Pump, 3	2	4.5	3	3	3	3	3	4.5	3	4.5	54
										Total	478.509

Mechanical Space, After

Mechanical Room											
Equipment	Machine		Access Requirements								Area Total
	Width	Length	Front		Back		Side		Side		
			Width	Length	Width	Length	Width	Length	Width	Length	
Combustion Turbine	8	21.91	3	3	3	3	3	3	3	3	202.28
Steam Absorption Chiller	9.51	25.85	3	3	3	3	3	9.167	3	9.167	318.8355
Hot Water Boiler, 1	4.5	14	3	3	3	3	3	9.167	3	9.167	136.002
Hot Water Boiler, 2	4.5	14	3	3	3	3	3	9.167	3	9.167	136.002
Hot Water Boiler, 3	4.5	14	3	3	3	3	3	9.167	3	9.167	136.002
										Total	929.122


- Building Summary
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- Conclusion
 - Mechanical Space
 - Domestic Water Reheat
 - Electricity Production, Plant vs. Site

Domestic Water Reheat

Logarithmic Mean Area

For use in Heat Transfer Equations

$$A_m = \frac{2\pi(L)(r_o - r_i)}{\ln(r_o/r_i)} = \frac{0.0150}{0.0870} = 0.1727$$



Heat Transfer Through Schedule 40 Steel

Through a Pipe of Singular Composition (one material)

$$Q = \frac{(k_{\text{pipe}})(A_m)(T_i - T_o)}{(r_o - r_i)} = \frac{269.457}{0.023} = 11715.53 \text{ BTU/hr}$$

Heat Transfer Through Steel "Insulation"

Through Insulation Only

$$*Q = \frac{(k_{\text{insulation}})(A_m)(T_i - T_o)}{(r_e - r_o)} = \frac{269.457}{0.011} = 24496.1$$

*Assumes that thermal resistance of pipe is negligible compared to thermal resistance of insulation, and that little accuracy will be lost if the pipe wall thickness term is omitted from the denominator

Heat Transfer

Through an Insulated Pipe


$$Q = \frac{(2\pi)(L)(T_i - T_o)}{[\ln(r_o/r_i)/k_{\text{pipe}}] + [\ln(r_e/r_o)/k_{\text{insulation}}]} = \frac{39.226}{0.005} = 8088.385$$

Inputs

Input Data

Equation Variables

L =	0.104	Pipe Length (ft)
r _o =	0.276	Radius, outer (ft)
r _i =	0.253	Radius, inner (ft)
r _e =	0.287	Radius, insulation exterior (ft)
T _o =	40	Temperature, outside (°F)
T _i =	100	Temperature, inside (°F)
k _{pipe} =	26	Thermal conductivity (Btu-ft/(hr-ft ² -°F)), pipe
k _{insulation} =	26	Thermal conductivity (Btu-ft/(hr-ft ² -°F)), insulation



- Building Summary

- Objectives

- Mechanical Investigation

- Electrical Investigation

- Overall Evaluation

- Conclusion

- Mechanical Space

- **Domestic Water Reheat**

- Electricity Production, Plant vs. Site

Results

8.088 MBh heat recovered

358.87 MBh required

2.3% savings

Suggestions

- Change condensate pipe to copper

- Increase length of apparatus

- Duplicate apparatus for existing building sanitary line

- Building Summary
- Objectives
- Mechanical Investigation
- Electrical Investigation
- Overall Evaluation
- Conclusion
 - Mechanical Space
 - Domestic Water Reheat
 - **Electricity Production, Plant vs. Site**

1.2 MW Electricity, Plant

Electricity, Consumed

At Power Plant				
Combustion Byproducts by Fuel Source for Specified Electric Consumption (MWh): 10512				
Fuel Type	Distribution by Fuel Source, MWh	lbs CO ₂	lbs SO ₂	lbs NO ₂
Natural Gas	4309.79	4,891,612.08	430.98	7,326.64
Coal	272.20	612,171.70	3,538.56	1,633.18
Nuclear	5670.78	-	-	-
Renewables	259.24	-	-	-

On Site				
Combustion Byproducts by Fuel Source for Specified Electric Consumption (MWh): 10512				
Fuel Type	Distribution by Fuel Source, MWh	lbs CO ₂	lbs SO ₂	lbs NO ₂
Natural Gas	4309.79	14,674,836.25	1,292.94	21,979.93
Coal	272.20	1,836,515.10	10,615.69	4,899.55
Nuclear	5670.78	-	-	-
Renewables	10512.00	-	-	-
Total		16511351.35	11908.63	26879.48212

Total

16,511,351 lbs. CO₂ | 11,909 lbs. SO₂ | 26,879 lbs. NO

1.2 MW Electricity, Site

Electricity, Produced

Emissions (lbs/MWh)			
Combustion Byproduct	Emissions (lbs/MWh)	MWh	Emissions, lbs
Carbon Dioxide	1135	18419	20,905,565
Sulfur Dioxide	0.1	18419	1,842
Nitrous Oxides	1.7	18419	31,312

Total

20,905,565 lbs. CO₂ | 1,842 lbs. SO₂ | 31,312 lbs. NO

21% increase CO₂ | 84% decrease lbs. SO₂ | 14% decrease NO